

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 7:22 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/29/13 - Roseville & Saint Paul
Power outage - Roseville & Saint Paul

Wendy

From: Gilland, William P
Sent: Tuesday, January 29, 2013 2:45 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In :
Time Out : 02:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3118

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 30, 2013 7:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Tree Report
Attachments: IMG_1087.JPG; IMG_1077.JPG
FYI...Tree report!

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, January 30, 2013 7:29 AM
To: Gilland, William P; dl Electric Outage ME Notification
Subject: RE: Second Outage Notice - Tree Report

Non-Preventable

Small diameter silver maple branch broke from within the canopy due to wind and fell into the conductors.
Tree was pruned to full extent on last cycle
Tree work last complete 12/2010

Christopher Loiselle
Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Gilland, William P
Sent: Tuesday, January 29, 2013 3:39 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/29/2013
Time Out : 02:38

Date In : 1/29/2013
Time In : 03:30

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 3118

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : branch on feeder at approx

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 7:23 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/29/13 - Roseville & Saint Paul - POWER RESTORED

Power outage - Roseville & Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, January 29, 2013 3:39 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In : 1/29/2013
Time Out : 02:38 Time In : 03:30

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 3118

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : branch on feeder at approx

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 31, 2013 11:28 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/31/13 - Lake Elmo, Maplewood & Oakdale
Power outage - Lake Elmo, Maplewood & Oakdale

Wendy

From: Gilland, William P
Sent: Thursday, January 31, 2013 11:25 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/31/2013 Date In :
Time Out : 11:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 31, 2013 1:08 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/31/13 - Lake Elmo, Maplewood & Oakdale -
POWER RESTORED

Power outage - Lake Elmo, Maplewood & Oakdale - power restored.

Wendy

From: Gilland, William P
Sent: Thursday, January 31, 2013 12:18 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/31/2013 Date In : 1/31/2013
Time Out : 11:18 Time In : 12:12

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 2313

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : z19f07 fuse failed to clear/allowed fault unto feeder

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 02, 2013 11:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/2/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, January 02, 2013 11:35 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/2/2013 Date In :
Time Out : 11:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2200

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT POLE DOUBLE CIRCUIT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 02, 2013 1:41 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/2/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, January 02, 2013 1:38 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/2/2013 Date In : 1/2/2013
Time Out : 11:18 Time In : 13:33

Time Zone : CST

Duration : 2 hours, 15 mins

Number of Customers Affected : 2200

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT POLE .. DOUBLE CIRCUIT

Follow-Up : CREW FLOATED CONDUCTOR REFERED FOR PERM. REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 10, 2013 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/9/13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Schwarz, John W
Sent: Wednesday, January 09, 2013 10:48 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/9/2013 Date In :
Time Out : 22:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2460

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 10, 2013 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/9/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, January 09, 2013 11:30 PM
To: dl Electric Outage MW Notification
Subject:) Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/9/2013 Date In : 1/9/2013
Time Out : 22:40 Time In : 23:18

Time Zone : CST

Duration : 0 hours, 38 mins

Number of Customers Affected : 2460

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD HEAD END CABLE 100% RESTORED @ 23:18

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/10/13 - Golden Valley
Power outage - Golden Valley.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, January 10, 2013 6:14 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In :
Time Out : 18:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 190

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/10/13 - Golden Valley - UPDATE
Power outage - Golden Valley - update.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, January 10, 2013 7:36 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In :
Time Out : 18:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 190

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : Wire down

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/10/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, January 10, 2013 8:03 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In : 1/10/2013
Time Out : 18:11 Time In : 20:00

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 190

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : Cap Bk 1067 bad / neutral down

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/12/13 - Eden Prairie
Power outage - Eden Prairie

Wendy

From: Ayers, Patrick S
Sent: Saturday, January 12, 2013 4:47 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/12/2013 Date In :
Time Out : 04:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 553

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:08 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/12/13 - Eden Prairie - POWER RESTORED
Power outage - Eden Prairie - power restored.

Wendy

From: Ayers, Patrick S
Sent: Saturday, January 12, 2013 5:57 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/12/2013 Date In : 1/12/2013
Time Out : 04:22 Time In : 05:26

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 553

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LD CTR -S2 FLASHED OVER INSIDE.TIE
BURNED UP IN LD CTR.NEED TO REPLACE LD CTR-S2

Follow-Up : SWITCHING TO RESTORE POWER.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/12/13 - Eden Prairie - POWER RESTORED -
UPDATE

Power restored - Eden Prairie - power restored/update.

Wendy

From: Ayers, Patrick S
Sent: Saturday, January 12, 2013 5:59 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/12/2013 Date In : 1/12/2013
Time Out : 04:22 Time In : 05:32

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 553

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FLASH IN LD CTR

Follow-Up : FEEDER BACK IN AS OF 0532.NEED TO ISOLATE SOME 1/0'S
FOR ISOLATION OF LD CTR-S2

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/13/12 - Brooklyn Center
Power outage - Brooklyn Center

Wendy

From: Peterson, Kenneth W
Sent: Sunday, January 13, 2013 9:19 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/13/2013 Date In :
Time Out : 08:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 94

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : none

Cause : BKR problem at sub on B ph

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/13/13 - Brooklyn Center - REVISED
REVISED - OUTAGE DATE WAS 1/13/13 AND NOT 1/13/12.

WENDY

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/13/12 - Brooklyn Center

Power outage - Brooklyn Center

Wendy

From: Peterson, Kenneth W
Sent: Sunday, January 13, 2013 9:19 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/13/2013 Date In :
Time Out : 08:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 94

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : none

Cause : BKR problem at sub on B ph

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 14, 2013 8:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/13/13 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, January 13, 2013 9:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/13/2013 Date In : 1/13/2013
Time Out : 08:44 Time In : 08:58

Time Zone : CST

Duration : 0 hours, 14 mins

Number of Customers Affected : 94

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : none

Cause : BKR problem at sub on B ph / placed back on transfer buss with

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 21, 2013 7:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/19/13 - Long Lake, Minnetonka, Orono,
Plymouth & Wayzata
Power outage - Long Lake, Minnetonka, Orono, Plymouth & Wayzata.

Wendy

From: Kittock, Joseph C
Sent: Saturday, January 19, 2013 2:47 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/19/2013 Date In :
Time Out : 14:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1431

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 22, 2013 2:59 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice Tree Report
Attachments: IMG_1070.JPG; IMG_1065.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Tuesday, January 22, 2013 2:54 PM
To: Hills, Thomas L; dl Electric Outage MW Notification
Subject: RE: Final Outage Notice Tree Report

Non-preventable
Small diameter branches from the upper canopy of a weeping willow broke due to strong winds and fell into phases.
Tree work last complete 10/2009

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Hills, Thomas L
Sent: Saturday, January 19, 2013 3:49 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/19/2013 Date In : 1/19/2013
Time Out : 14:41 Time In : 15:47

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1431

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 21, 2013 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/19/13 - Long Lake, Minnetonka, Orono, Plymouth & Wayzata - POWER RESTORED
Power outage - Long Lake, Minnetonka, Orono, Plymouth & Wayzata - power restored.

Wendy

From: Hills, Thomas L
Sent: Saturday, January 19, 2013 3:49 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/19/2013 Date In : 1/19/2013
Time Out : 14:41 Time In : 15:47

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1431

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 24, 2013 10:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/24/13 - Bloomington & Richfield
Power outage - Bloomington & Richfield.

Wendy

From: Ayers, Patrick S
Sent: Thursday, January 24, 2013 10:05 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In :
Time Out : 09:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 165

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT TIME,TROUBLEMAN ON SITE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 24, 2013 10:49 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/24/13 - Bloomington & Richfield - POWER RESTORED

Power outages - Bloomington & Richfield - power restored.

Wendy

From: Ayers, Patrick S
Sent: Thursday, January 24, 2013 10:07 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In : 1/24/2013
Time Out : 09:53 Time In : 10:00

Time Zone : CST

Duration : 0 hours, 7 mins

Number of Customers Affected : 165

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers :

LOCKED OUT Cause : 200 E FUSE IN LD CTR -D BLEW,C PHASE FUSE BLEW .THIS
AND TRIPPED

Follow-Up : TROUBLEMAN ON SITE,SWITCHING ON A DIFFERENT
RFO#320913.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 25, 2013 7:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/24/13 - Brooklyn Park
Power outage - Brooklyn Park.

Wendy

From: Beckius, John J
Sent: Thursday, January 24, 2013 5:25 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In :
Time Out : 17:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 194

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 25, 2013 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/24/13 - Brooklyn Park - POWER RESTORED
Power outage - Brooklyn Park - power restored.

Wendy

From: Beckius, John J
Sent: Thursday, January 24, 2013 6:41 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In : 1/24/2013
Time Out : 17:22 Time In : 17:54

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 194

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : FAILED HEAD END CABLE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 7:25 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/29/13 - Fridley & Minneapolis
Power outage - Fridley & Minneapolis

Wendy

From: Beckius, John J
Sent: Tuesday, January 29, 2013 6:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In :
Time Out : 05:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1559

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : tran #2 lockout

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 8:22 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/29/13 - Fridley - POWER RESTORED
Power outage - Fridley - power restored.

Wendy

From: Knutson, David A
Sent: Tuesday, January 29, 2013 8:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In : 1/29/2013
Time Out : 05:53 Time In : 07:58

Time Zone : CST

Duration : 2 hours, 5 mins

Number of Customers Affected : 38

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN

State : MN - Minnesota

Major Customers : none

Cause : still under investigation

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 7:26 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/29/13 - Columbia Heights & Minneapolis
Power outage - Columbia Heights & Minneapolis

Wendy

From: Beckius, John J
Sent: Tuesday, January 29, 2013 7:08 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In :
Time Out : 05:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1275

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : bus lockout out not

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 8:23 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/29/13 - Columbia Heights & Minneapolis - POWER RESTORED

Power outage - Columbia Heights & Minneapolis - power restored.

Wendy

From: Knutson, David A
Sent: Tuesday, January 29, 2013 8:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In : 1/29/2013
Time Out : 05:53 Time In : 08:10

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 1275

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : still under investigation

Follow-Up : tr 2 and bus 2 are back in also

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 31, 2013 7:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/30/13 - Minneapolis & Saint Louis Park
Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Beckius, John J
Sent: Wednesday, January 30, 2013 6:54 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/30/2013 Date In :
Time Out : 18:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2396

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 31, 2013 7:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/30/13 - Minneapolis & Saint Louis Park -
UPDATE

Power outage - Minneapolis & Saint Louis Park - update.

Wendy

From: Beckius, John J
Sent: Wednesday, January 30, 2013 7:09 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/30/2013 Date In :
Time Out : 18:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2396

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown also carrying 1857 customers on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 31, 2013 7:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/30/13 - Minneapolis & Saint Louis Park -
POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, January 30, 2013 8:15 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/30/2013 Date In : 1/30/2013
Time Out : 18:49 Time In : 20:06

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 4253

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable.

Follow-Up : All restored 2006.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 10, 2013 3:58 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/10/13 - Cottonwood, Granite Falls, Hanley Falls & Hazel Run
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run.

Wendy

From: Kaveny, Michael J
Sent: Thursday, January 10, 2013 3:22 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In :
Time Out : 15:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 860

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Operator and Trouble en-route. Non EMS Sub, calls indicate Breaker open.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/10/13 - Cottonwood, Granit Falls, Hanley Falls & Hazel Run - POWER RESTORED
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, January 10, 2013 4:51 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In : 1/10/2013
Time Out : 15:09 Time In : 16:44

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 860

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Breaker open on arrival at Sub, Trouble found nothing on Patrol, Closed Breaker at 16:44. 100% restored, In and holding at this time.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/10/13 - Cottonwood, Granite Falls, Hanley Falls & Hazel Run
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run.

Wendy

From: Kaveny, Michael J
Sent: Thursday, January 10, 2013 4:59 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In :
Time Out : 16:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 860

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN

State : MN - Minnesota

Major Customers : None

Cause : Opened Breaker back up manually by Operator. Operator reported
excessive amperage on breaker, and Transformer growling.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/10/13 - Cottonwood, Granite Falls,
Hanley Falls & Hazel Run - UPDATE
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - update.

Wendy

From: Kaveny, Michael J
Sent: Thursday, January 10, 2013 5:41 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In :
Time Out : 16:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 860

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL
RUN, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down near Hanley Falls per Police Officer, Breaker closed and energized 576
customers and most of Cottonwood at 17:23

Follow-Up : Remaining 284 customers out until wire back up.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 11, 2013 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 1/10/13 - Cottonwood, Granite Falls,
Hanley Falls & Hazel Run - POWER RESTORED
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - power restored.

Wendy

From: Vorachek, Kelly
Sent: Thursday, January 10, 2013 10:53 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 1/10/2013 Date In : 1/10/2013
Time Out : 16:52 Time In : 22:28

Time Zone : CST

Duration : 5 hours, 36 mins

Number of Customers Affected : 284

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL
RUN, MN

State : MN - Minnesota

Major Customers : N/A

Cause : OC884655 - Remaining 284 customers restored at 22:28 from switch
after crew put wire back up. 576 customers restored at 17:23 after trouble isolated and breaker closed.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 23, 2013 3:27 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
First Outage Notice - 1/23/13 - Albany, Avon, Collegeville & Saint Joseph
Power outage - Albany, Avon, Collegeville & Saint Joseph.

Wendy

From: Chase, Julie B
Sent: Wednesday, January 23, 2013 3:23 PM
To: dl Electric Outage NT Notification
Subject: Notice First Outage

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/23/2013 Date In :
Time Out : 15:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2696

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : OC 886673, 886674, 886675,886704, 886705 crews enroute

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 23, 2013 4:28 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
Second Outage Notice - 1/23/13 - Albany, Avon, Collegeville & Saint Joseph - UPDATE
Power outage - Albany, Avon, Collegeville & Saint Joseph - update.

Wendy

From: Chase, Julie B
Sent: Wednesday, January 23, 2013 3:43 PM
To: dl Electric Outage NT Notification
Subject: Notice Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/23/2013 Date In :
Time Out : 15:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2696

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : oc 886673, 886674, 886675, 886704, 886705

Follow-Up : 1237 customers restored at 1534, 1435 restored at 1535, 24 customers remain out of service, crews still investigating

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 23, 2013 4:42 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
Third Outage Notice - 1/23/13 - Albany, Avon, Collegeville & Saint Joseph - POWER RESTORED
Power outage - Albany, Avon, Collegeville & Saint Joseph - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, January 23, 2013 4:28 PM
To: dl Electric Outage NT Notification
Subject: Notice Third Outage

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 1/23/2013 Date In : 1/23/2013
Time Out : 15:12 Time In : 16:18

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 2696

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission Level Event. Remaining 24 customers restored at 16:18.

Follow-Up : Customers 100% Restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 8:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/26/13 - Buffalo Lake
Power outage - Buffalo Lake

Wendy

From: Bui, Tien V
Sent: Saturday, January 26, 2013 5:43 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/26/2013 Date In :
Time Out : 05:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 384

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : OC887150 PRE-ARRANGE OUTAGE RFO 320815 TO CONVERT
TO . OUTAGE WILL LAST APPROX TO AROUND 09:00 1/26

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 8:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/26/13 - Buffalo Lake - POWER RESTORED
Power outage - Buffalo Lake - power restored.

Wendy

From: Bui, Tien V
Sent: Saturday, January 26, 2013 9:33 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/26/2013 Date In : 1/26/2013
Time Out : 05:27 Time In : 07:13

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 384

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BFL021OC887150 PRE-ARRANGE OUTAGE RFO 320815 TO CONVERT
TO . CLOSE BREAKER AT 07:13 THE FEEDER IS HOT / CREW TO PICKUP
TAPS & CHECK ROTATION AT VARIOUS PLACES OF FEEDER.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 07, 2013 8:02 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/6/13 - Mankato
Power outage - Mankato.

Wendy

From: Goulet, Terry W
Sent: Sunday, January 06, 2013 12:11 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/6/2013 Date In :
Time Out : 11:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1252

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : OC883998 CREW & OPERATOR CALLED IN AND HEADING TOWARDS SUB

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 07, 2013 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/6/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Goulet, Terry W
Sent: Sunday, January 06, 2013 2:10 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/6/2013 Date In : 1/6/2013
Time Out : 11:46 Time In : 14:00

Time Zone : CST

Duration : 2 hours, 14 mins

Number of Customers Affected : 1252

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : OC883998 Bad pothead found on cable from Sub to mainline.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 24, 2013 3:39 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/24/13 - Kasota, Mankato,
North Mankato & Saint Peter
Power outage - Kasota, Mankato, North Mankato & Saint Peter.

Wendy

From: Bui, Tien V
Sent: Thursday, January 24, 2013 3:32 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In :
Time Out : 15:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3359

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KASOTA, MN; MANKATO, MN; NORTH MANKATO, MN; SAINT PETER,
MN

State : MN - Minnesota

Major Customers :

Cause : LOCKOUT OC886850, OC886852, OC886853, O886854
/ OPERATER ENROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 25, 2013 7:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/24/13 - Kasota, Mankato, North Mankato & Saint Peter - POWER RESTORED
Power outage - Kasota, Mankato, North Mankato & Saint Peter - power restored.

Wendy

From: Bui, Tien V
Sent: Thursday, January 24, 2013 4:23 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In : 1/24/2013
Time Out : 15:20 Time In : 16:00

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 3359

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KASOTA, MN; MANKATO, MN; NORTH MANKATO, MN; SAINT PETER, MN

State : MN - Minnesota

Major Customers :

Cause : OUTAGE TO OC886854, OC886853,
OC886850, OC886852. CREW FOUND PROBLEM AT , THE SWITCH CENTER
BURN UP CAUSE THE WHOLE TRANSFORM LOCK (POSS RELAY PROBLEM) - 319 CUST BACK IN
15:56, - 1643 CUST BACK IN 15:58, - 587 CUST BACKIN 15:58, - 732 CUST BACK IN
16:00 REMAINING 78 CUST OF WILL BE OUT UNTIL SWITCH CENTER TO BE REPLACE.

Follow-Up : CREW NEED TO REPLACE SWITCH CENTER.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 25, 2013 7:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 1/24/13 - Mankato & North Mankato -
POWER RESTORED/UPDATE

Power outage - Mankato & North Mankato - power restored/update.

Wendy

From: Kaveny, Michael J
Sent: Thursday, January 24, 2013 8:47 PM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 1/24/2013 Date In : 1/24/2013
Time Out : 15:20 Time In : 20:20

Time Zone : CST

Duration : 5 hours, 0 mins

Number of Customers Affected : 810

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : Switch Center Burned Up on Feeder, Crews Temporary energized 3
padmounts, remaining 78 customers restored at 20:20.

Follow-Up : Switch Center and wire will need to be replaced and spliced when more time permits.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 12:17 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/28/13 - Albert Lea, Clarks Grove, Ellendale & Hartland
Power outage - Albert Lea, Clarks Grove, Ellendale & Hartland.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, January 28, 2013 12:15 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/28/2013 Date In :
Time Out : 12:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 474

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBERT LEA, MN; CLARKS GROVE, MN; ELLENDALE, MN; HARTLAND,
MN

State : MN - Minnesota

Major Customers : None

Cause : Cause unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 2:04 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/28/13 - Albert Lea, Clarks Grove, Ellendale, Hartland - POWER RESTORED
Power outage - Albert Lea, Clarks Grove, Ellendale, Hartland - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, January 28, 2013 1:16 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/28/2013 Date In : 1/28/2013
Time Out : 12:07 Time In : 12:57

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 474

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBERT LEA, MN; CLARKS GROVE, MN; ELLENDALE, MN; HARTLAND,
MN

State : MN - Minnesota

Major Customers : None

Cause : sub fed from GRE, They had a static line fall into the transmission and tripped their line out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 12:34 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice *** Momentary Outage *** - 1/27/13 - Chisago City, Chisago Lake, Lindstrom & Wyoming
Power outage - Chisago City, Chisago Lake, Lindstrom & Wyoming.

Wendy

From: Gilland, William P
Sent: Sunday, January 27, 2013 7:59 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/27/2013 Date In : 1/27/2013
Time Out : 19:53 Time In : 19:53

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 2808

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : CHISAGO CITY, MN; CHISAGO LAKE, MN; LINDSTROM, MN; STACY, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : none

Cause : fdr trip

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 12:34 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/27/13 - Chisago City, Chisago Lake, Lindstrom & Wyoming
Power outage - Chisago City, Chisago Lake, Lindstrom & Wyoming.

Wendy

From: Chial, Terry L
Sent: Sunday, January 27, 2013 10:22 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/27/2013 Date In :
Time Out : 22:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2808

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : CHISAGO CITY, MN; CHISAGO LAKE, MN; LINDSTROM, MN; STACY, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : no

Cause : opened up bkr for t man to clear blown up recloser

Follow-Up : 10 minutes

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 28, 2013 12:36 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 1/27/13 - Chisago City, Chisago Lake, Lindstrom & Wyoming - POWER RESTORED
Power outage - Chisago City, Chisago Lake, Lindstrom & Wyoming - power restored.

Wendy

From: Chial, Terry L
Sent: Sunday, January 27, 2013 10:28 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/27/2013 Date In : 1/27/2013
Time Out : 22:19 Time In : 22:24

Time Zone : CST

Duration : 0 hours, 5 mins

Number of Customers Affected : 2808

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : CHISAGO CITY, MN; CHISAGO LAKE, MN; LINDSTROM, MN; STACY, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : no

Cause : cleared recloser

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 29, 2013 9:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice *** Momentary Outage *** -
1/29/13 - Fridley & Minneapolis - POWER RESTORED
Power outage - Fridley & Minneapolis - power restored.

Wendy

From: Beckius, John J
Sent: Tuesday, January 29, 2013 6:23 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/29/2013 Date In : 1/29/2013
Time Out : 05:53 Time In : 05:53

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 1708

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : tran #2 lockout

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/10/13 - Oak Park Heights & Stillwater
Power outage - Oak Park Heights & Stillwater.

Wendy

From: Abbott, Edward J
Sent: Sunday, February 10, 2013 10:01 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/10/2013 Date In :
Time Out : 09:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 613

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/10/13 - Oak Park Heights & Stillwater - POWER RESTORED

Power outage - Oak Park Heights & Stillwater - power restored.

Wendy

From: Abbott, Edward J
Sent: Sunday, February 10, 2013 11:08 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/10/2013 Date In : 2/10/2013
Time Out : 09:58 Time In : 11:01

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 613

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FOUND CAP BANK UNIT NEAR ALL
BURNT UP, CLEARED FROM THE FEEDER AND FEEDER BACK IN

Follow-Up : REFERED TO HAVE CAP BANK REPAIRED

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/10/13 - Forest Lake & Wyoming
Power outage - Forest Lake & Wyoming.

Wendy

From: Gilland, William P
Sent: Sunday, February 10, 2013 4:22 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/10/2013 Date In :
Time Out : 16:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 883

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/10/13 - Forest Lake & Wyoming - POWER RESTORED

Power outage - Forest Lake & Wyoming - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, February 10, 2013 5:38 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/10/2013 Date In : 2/10/2013
Time Out : 16:02 Time In : 17:34

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 883

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers :

down Cause : arrestors failed at burned and neut burned

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice -2/11/13 - Mendota & Woodbury
Power outage - Mendota & Woodbury.

Wendy

From: Gilland, William P
Sent: Monday, February 11, 2013 5:16 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/11/2013 Date In :
Time Out : 05:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1956

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : pole top burned off, wooddale/w-woolane

Follow-Up : rc closed and open

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 8:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/11/13 - Mendota & Woodbury - UPDATE
Power outage - Mendota & Woodbury - update.

Wendy

From: Abbott, Edward J
Sent: Monday, February 11, 2013 7:12 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/11/2013 Date In :
Time Out : 04:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1956

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : pole broke at . ALL 3 STEPDOWNSDOWN IN
ROAD. PICKED UP HALF OF FEEDER FEILD SWITCHING. CREW WILL BE ABLE TO DO
CUT IN SOME CANADIANS TOO PIK UP MOS T OF THE REMAINING CUSTOMERS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 10:57 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/11/13 - Mendota & Woodbury - POWER RESTORED

Power outage - Mendota & Woodbury - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, February 11, 2013 10:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/11/2013 Date In : 2/11/2013
Time Out : 04:58 Time In : 10:44

Time Zone : CST

Duration : 5 hours, 46 mins

Number of Customers Affected : 1956

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : POLE BROKE OFF AND STEP DOWNS DAMAGED AT
. CREW INSTALLED JUMPERS AND CUT OPEN LINE AND FEILD SWITCHED
TO PICK UP ALL REMAINING CUSTOMER EXCEPT 2 3 PHASE CUSTOMERS

Follow-Up : EVERYONE BACK IN EXPECT TWO 3 PHASE TUBES. THEY
WILL BE OUT UNTIL CREW INSTALLS NEW POLE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 11, 2013 12:55 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/11/13 - Arden Hills, Blaine, Circle Pines, Lexington, Lino Lakes, Mounds View, North Oaks, Roseville, St Paul, Shoreview, Vadnais Heights, WBL & Woodbury-POWER RESTORED
Power outage - Arden Hills, Blaine, Circle Pines, Lexington, Lino Lakes, Mounds View, North Oaks, Roseville, St Paul, Shoreview, Vadnais Heights, White Bear Lake & Woodbury - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, February 11, 2013 12:47 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/11/2013 Date In : 2/11/2013
Time Out : 11:53 Time In : 12:35

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 14098

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; CIRCLE PINES, MN;
LEXINGTON, MN; LINO LAKES, MN; MOUNDS VIEW, MN; NORTH OAKS, MN; ROSEVILLE, MN;
SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN; WHITE BEAR LAKE, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : TR3 A MOD FAILED WHILE SWITCHING.

Follow-Up : PARTICLE REST. TIME, RESTORATION TIMES TO FOLLOW

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 12, 2013 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/12/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Chial, Terry L
Sent: Tuesday, February 12, 2013 1:03 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/12/2013 Date In :
Time Out : 00:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2238

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : 2 feeders out double deck ,possable wire down .

Follow-Up : on route

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 12, 2013 7:49 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/12/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, February 12, 2013 1:54 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/12/2013 Date In : 2/12/2013
Time Out : 00:49 Time In : 01:34

Time Zone : CST

Duration : 0 hours, 45 mins

Number of Customers Affected : 243

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

DOWN ON Cause : AUTO LET LOOSE ON DOUBLE DECK . B PHASE FELL

Follow-Up : WILL REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 12, 2013 7:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/12/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Chial, Terry L
Sent: Tuesday, February 12, 2013 1:33 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/12/2013 Date In :
Time Out : 00:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1995

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : AUTO SLEAVE BURNED OPEN /CUT CLEAR AND
REENERGIZED

Follow-Up : SAME PLACE AS 12/21/ 2013 B PHASE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 12, 2013 7:49 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/12/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, February 12, 2013 1:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/12/2013
Time Out : 00:49

Date In : 2/12/2013
Time In : 01:41

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1995

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : AUTO SLEAVE BURNED OPEN

Follow-Up : CUT CLEAR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 01, 2013 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/1/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Anderson, Timothy K
Sent: Friday, February 01, 2013 6:56 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/1/2013 Date In :
Time Out : 6:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1955

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 01, 2013 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/1/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Hills, Thomas L
Sent: Friday, February 01, 2013 7:43 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/1/2013 Date In :
Time Out : 6:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1955

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down at

Follow-Up : Isolating to restore.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 01, 2013 8:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/1/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, February 01, 2013 8:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/1/2013 Date In : 2/1/2013
Time Out : 6:52 Time In : 08:10

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1955

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down at .

Follow-Up : All in 0810.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 7:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/6/13 - Plymouth
Power outage - Plymouth

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, February 06, 2013 7:23 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In :
Time Out : 07:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1636

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 8:25 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/6/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, February 06, 2013 8:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In : 2/6/2013
Time Out : 7:17 Time In : 8:03

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1636

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 3:53 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/6/13 - Brooklyn Park
Power outage - Brooklyn Park.

Wendy

From: Hills, Thomas L
Sent: Wednesday, February 06, 2013 2:18 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In :
Time Out : 14:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 194

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 3:54 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/6/13 - Brooklyn Park - UPDATE
Power outage - Brooklyn Park - update.

Wendy

From: Hills, Thomas L
Sent: Wednesday, February 06, 2013 2:37 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In :
Time Out : 14:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 194

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable. Head end.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 3:55 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/6/13 - Brooklyn Park - POWER RESTORED
Power outage - Brooklyn Park - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, February 06, 2013 3:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In : 2/6/2013
Time Out : 14:13 Time In : 14:59

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 194

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : None.

Cause : Cut cable. Head end.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 06, 2013 4:22 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/6/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Wednesday, February 06, 2013 4:21 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In :
Time Out : 16:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2790

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, February 07, 2013 7:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/6/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, February 06, 2013 5:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/6/2013 Date In : 2/6/2013
Time Out : 16:16 Time In : 17:30

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 2790

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:16 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/16/13 - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata
Power outage - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata.

Wendy

From: Hills, Thomas L
Sent: Saturday, February 16, 2013 10:57 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In :
Time Out : 22:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2560

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:16 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/16/13 - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - UPDATE
Power outage - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - update.

Wendy

From: Hills, Thomas L
Sent: Sunday, February 17, 2013 1:40 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In :
Time Out : 22:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2560

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Car hit pole.

Follow-Up : 2042 cust. in at 23:47, crew called in to replace pole for restoration of remainder.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:17 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/16/13 - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - POWER RESTORED
Power outage - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - POWER RESTORED

Wendy

From: Schwarz, John W
Sent: Sunday, February 17, 2013 11:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In : 2/17/2013
Time Out : 22:50 Time In : 09:55

Time Zone : CST

Duration : 11 hours, 5 mins

Number of Customers Affected : 2560

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BROKEN POLE.

Follow-Up : 2042 RESTORED @ 2342 2/16/2012,, REMAINING 518 CUSTOMERS
RESTORED @ 09:55. TODAY.. DELAY IN NOTIFICATION DUE TO A MICROSOFT OUTLOOK OUTAGE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/17/13 - Bloomington, Burnsville & Savage
Power outage - Bloomington, Burnsville & Savage.

Wendy

From: Hills, Thomas L
Sent: Sunday, February 17, 2013 7:36 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/17/2013 Date In :
Time Out : 19:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 21

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up : is partially isolated on existing RFO. 21 cust. out of power.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/17/13 - Bloomington, Burnsville & Savage - POWER RESTORED

Power outage - Bloomington, Burnsville & Savage - power restored.

Wendy

From: Hills, Thomas L
Sent: Sunday, February 17, 2013 10:43 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/17/2013 Date In : 2/17/2013
Time Out : 19:09 Time In : 22:38

Time Zone : CST

Duration : 3 hours, 29 mins

Number of Customers Affected : 21

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : Patrol ok.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 20, 2013 9:07 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/20/13 - Plymouth
Power outage - Plymouth

Wendy

From: Knutson, David A
Sent: Wednesday, February 20, 2013 8:50 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/20/2013 Date In :
Time Out : 08:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1635

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : undetermined at this time

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 20, 2013 9:27 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/20/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, February 20, 2013 9:25 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/20/2013 Date In : 2/20/2013
Time Out : 08:46 Time In : 09:21

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 1635

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : non

Cause : relay problem with breaker at sub

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 22, 2013 7:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/21/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Anderson, Timothy K
Sent: Thursday, February 21, 2013 6:43 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/21/2013 Date In :
Time Out : 18:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2410

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 22, 2013 7:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Thursday, February 21, 2013 8:43 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/21/2013 Date In : 2/21/2013
Time Out : 18:40 Time In : 20:37

Time Zone : CST

Duration : 1 hours, 57 mins

Number of Customers Affected : 2410

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : URD CABLE FAULT BTWN 4

Follow-Up : REFER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 25, 2013 8:23 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/24/13 - Coon Rapids
Power outage - Coon Rapids.

Wendy

From: Anderson, Timothy K
Sent: Sunday, February 24, 2013 10:28 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/24/2013 Date In :
Time Out : 10:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 605

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 25, 2013 8:24 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/4/13 - Coon Rapids - POWER RESTORED
Power outage - Coon Rapids - power restored.

Wendy

From: Anderson, Timothy K
Sent: Sunday, February 24, 2013 11:22 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/24/2013 Date In : 2/24/2013
Time Out : 10:20 Time In : 11:16

Time Zone : CST

Duration : 0 hours, 56 mins

Number of Customers Affected : 605

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : A PHASE ARRESTER BLOWN @ 2 SWITCH POT HEAD,ALSO 2 SWITCH
FLASHED OVER

Follow-Up : TRBLMN TO REFER ARRESTOR & SWITCH

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/16/13 - Saint Cloud & Sauk Rapids
Power outage - Saint Cloud & Sauk Rapids.

Wendy

From: Goulet, Terry W
Sent: Saturday, February 16, 2013 9:27 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In :
Time Out : 20:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : NA

Cause : It appears that we have C phase open close to Sub. Breaker did not operate, feeder is abnormal due to breaker & switch problems on feeder. Crew called in and waiting for them to get to site to verify problem and make repairs.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/16/13 - Saint Cloud & Sauk Rapids -
UPDATE

Power outage - Saint Cloud & Sauk Rapids - updated.

Wendy

From: Goulet, Terry W
Sent: Saturday, February 16, 2013 10:36 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In :
Time Out : 22:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : NA

Cause : C PHASE ON FEEDER DOWN ON . FEEDER ALSO
ABNORMAL WITH LOAD FROM . WE OPENED BKR TO ISOLATE DOWN WIRE AND RESTORE AS
MAY CUSTOMER ON BOTH FEEDERS AS POSSIBLE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 2/16/13 - Saint Cloud & Sauk Rapids - UPDATE
Power outage - Saint Cloud & Sauk Rapids - updated.

Wendy

From: Goulet, Terry W
Sent: Saturday, February 16, 2013 11:05 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In :
Time Out : 22:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : NA

Cause : BREAKER IS OPEN TO 2 FOR CREW TO PUT BACK UP WIRE
ON FEEDER. 2403 CUSTOMERS HAVE BEEN RESTORED VIA SWITCHING. CREW SHOULD HAVE WIRE
BACK UP WITH ALL CUSTOMERS RESTORED WITH IN THE HOUR.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 18, 2013 9:15 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Saint Cloud & Sauk Rapids - POWER RESTORED

Power outage - Saint Cloud & Sauk Rapids - power restored.

Wendy

From: Goulet, Terry W
Sent: Saturday, February 16, 2013 11:27 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/16/2013 Date In : 2/16/2013
Time Out : 22:19 Time In : 23:14

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 3245

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : NA

Cause : FEEDER WIRE HAS BEEN PUT BACK UP AND BREAKER CLOSED TO RESTORE THE FINAL 842 CUSTOMERS.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 13, 2013 9:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/13/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, February 13, 2013 9:07 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/13/2013 Date In : 2/13/2013
Time Out : 08:28 Time In : 08:51

Time Zone : CST

Duration : 0 hours, 23 mins

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : Switching error in the RFO 321304

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 08, 2013 10:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/8/13 - Plymouth
Power outage - Plymouth.

Wendy

From: Peterson, Kenneth W
Sent: Friday, February 08, 2013 9:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/8/2013 Date In :
Time Out : 09:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1637

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, February 08, 2013 3:24 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 2/8/13 - Plymouth -
POWER RESTORED

Power outage - momentary - Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, February 08, 2013 09:45
To: dl Electric Outage MW Notification
Subject: Final Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/8/2013 Date In : 2/8/2013
Time Out : 09:28 Time In : 09:31

Time Zone : CST

Duration : 0 hours, 3 mins

Number of Customers Affected : 1637

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : Relay problem with 5m110 BKR control

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 13, 2013 12:30 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/13/13 - Ellendale, Medford,
Meriden, Owatonna & Waseca - POWER RESTORED
Power outage - Ellendale, Medford, Meriden, Owatonna & Waseca - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, February 13, 2013 11:59 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/13/2013 Date In : 2/13/2013
Time Out : 11:37 Time In : 11:43

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 614

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELLENDALE, MN; MEDFORD, MN; MERIDEN, MN; OWATONNA, MN;
WASECA, MN

State : MN - Minnesota

Customers : None

Cause : Unknown at this time. Foreign utility was switching at the time power went out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 19, 2013 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/18/13 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo.

Wendy

From: Hills, Thomas L
Sent: Tuesday, February 19, 2013 12:00 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/18/2013 Date In :
Time Out : 23:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4519

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 19, 2013 7:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Momentary Outage *** Momentary Outage *** - 2/18/13 -
Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - power restored.

Wendy

From: Hills, Thomas L
Sent: Tuesday, February 19, 2013 1:43 AM
To: dl Electric Outage MW Notification
Subject: Momentary Outage *** Momentary Outage ***
Distribution System Status Outage Notification

Momentary Outage

Feeder/Bus :

Date Out : 2/19/2013 Date In : 2/19/2013
Time Out : 23:51 Time In : 23:51

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 4519

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : None

Cause : Two 100k Fuses blown and burned up at .

Follow-Up : on EMS opened at 2351, closed on it's own at 0127. was
actually closed at 2351 causing a momentary.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 08, 2013 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/7/13 -
Saint Paul
Power outage - Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Thursday, March 07, 2013 6:30 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/7/2013 Date In :
Time Out : 18:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7054

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 08, 2013 8:04 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/7/13 -
Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Thursday, March 07, 2013 7:10 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/7/2013 Date In : 3/7/2013
Time Out : 18:13 Time In : 18:19

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 7054

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : relay prob at sub

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, March 21, 2013 11:04 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/21/13 - Newport
Power outage - Newport.

Wendy

From: Chial, Terry L
Sent: Thursday, March 21, 2013 10:35 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/21/2013 Date In :
Time Out : 10:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 51

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers : was switched out prior to flash.

Cause : phase testing in switch gear .flash

Follow-Up : will post more info later

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, March 21, 2013 11:05 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/21/13 - Newport - POWER RESTORED
Power outage - Newport - power restored.

Wendy

From: Chial, Terry L
Sent: Thursday, March 21, 2013 10:55 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/21/2013 Date In : 3/21/2013
Time Out : 10:16 Time In : 10:51

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 51

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers : no at this time .switch out load before

Cause : flash

Follow-Up : phase testing ,flashed over

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:02 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/31/13 - White Bear Lake
Power outage - White Bear Lake

Wendy

From: Elden, Thomas L
Sent: Sunday, March 31, 2013 7:41 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In :
Time Out : 07:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2573

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : mn

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/31/13 - White Bear Lake - UPDATE
Power outage - White Bear Lake - update.

Wendy

From: Elden, Thomas L
Sent: Sunday, March 31, 2013 8:07 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In :
Time Out : 07:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2573

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : mn

Cause : at 07:59 we have 1042 customers back on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:04 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/31/13 - White Bear Lake - POWER RESTORED
Power outage - White Bear Lake - power restored.

Wendy

From: Elden, Thomas L
Sent: Sunday, March 31, 2013 8:43 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In : 3/31/2013
Time Out : 07:30 Time In : 08:31

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 2573

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : mn

Cause : troubleman patrolled line and it looked ok 07:59 1042 customers
were on and 08:31 2573 all customers were on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:15 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/31/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Monday, April 01, 2013 4:38 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In : 4/1/2013
Time Out : 15:43 Time In : 04:13

Time Zone : CST

Duration : 12 hours, 30 mins

Number of Customers Affected : 1

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : We had all four 480 voutl protectors fail in this vault..

Follow-Up : We replaced two protectors and came back in at 04:13 on
4/1/2013..

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:07 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/31/13 - Deephaven, Excelsior,
Greenwood, Minnetonka, SHorewood & Wayzata
Power outage - Deephaven, Excelsior, Greenwood, Minnetonka, Shorewood & Wayzata.

Wendy

From: Aspinwall, David P
Sent: Sunday, March 31, 2013 9:10 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In :
Time Out : 09:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3904

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN; MINNETONKA,
MN; SHOREWOOD, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : TR 1 LOCK

Follow-Up : OPERATOR IN ROUTE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:08 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/31/13 - Deephaven, Excelsior, Greenwood, Minnetonka, Shorewood & Wayzata - UPDATE
Power outage - Deephaven, Excelsior, Greenwood, Minnetonka, Shorewood & Wayzata - UPDATE.

Wendy

From: Aspinwall, David P
Sent: Sunday, March 31, 2013 10:23 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In :
Time Out : 09:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3904

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN; MINNETONKA, MN; SHOREWOOD, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SQUIRREL GOT INTO THE TIE SWITCH, AND
BKRS NEED TO BE TESTED. WILL ISOLATE THEM BKRS AND TR 1.

Follow-Up : WONT BE TO MUCH LONGER.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Deephaven, Excelsior, Minnetonka & Shorewood -
POWER RESTORED
Power outage - Deephaven, Excelsior, Minnetonka & Shorewood - power restored.

Wendy

From: Aspinwall, David P
Sent: Sunday, March 31, 2013 10:58 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In : 3/31/2013
Time Out : 09:04 Time In : 10:56

Time Zone : CST

Duration : 1 hours, 52 mins

Number of Customers Affected : 1294

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : RAT

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/31/13 - Deephaven, Excelsior, Greenwood & Shorewood - POWER RESTORED
Power outage - Deephaven, Excelsior, Greenwood & Shorewood - power restored.

Wendy

From: Aspinwall, David P
Sent: Sunday, March 31, 2013 11:12 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In : 3/31/2013
Time Out : 09:04 Time In : 11:11

Time Zone : CST

Duration : 2 hours, 7 mins

Number of Customers Affected : 1664

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN; SHOREWOOD,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : RAT

Follow-Up : THAT IS ALL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 08, 2013 8:05 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/7/13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Anderson, Timothy K
Sent: Thursday, March 07, 2013 8:22 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/7/2013 Date In :
Time Out : 19:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2782

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 08, 2013 8:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/7/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Thursday, March 07, 2013 8:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/7/2013 Date In : 3/7/2013
Time Out : 19:52 Time In : 20:52

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 2782

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : correction NO MAJORS

Cause : UNKNOWN

Follow-Up : PATROLED NOTHING FOUND

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/9/13 - Brooklyn Center, Brooklyn Park & Minneapolis
Power outage - Brooklyn Center, Brooklyn Park & Minneapolis

Wendy

From: Knutson, David A
Sent: Saturday, March 09, 2013 4:06 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/9/2013 Date In :
Time Out : 03:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1932

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : not sure at this time

Follow-Up : 2 men on the way

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/9/13 - Brooklyn Center, Brooklyn Park & Minneapolis - POWER RESTORED
Power outage - Brooklyn Center, Brooklyn Park & Minneapolis - power restored.

Wendy

From: Knutson, David A
Sent: Saturday, March 09, 2013 5:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/9/2013 Date In : 3/9/2013
Time Out : 03:55 Time In : 04:51

Time Zone : CST

Duration : 0 hours, 56 mins

Number of Customers Affected : 1932

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : cap bank

Follow-Up : will not close by has the load till we can get operator to sub

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:25 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/11/13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Schwarz, John W
Sent: Monday, March 11, 2013 7:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/11/2013 Date In :
Time Out : 07:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 765

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:27 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/11/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, March 11, 2013 8:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/11/2013 Date In : 3/11/2013
Time Out : 07:35 Time In : 08:09

Time Zone : CST

Duration : 0 hours, 34 mins

Number of Customers Affected : 765

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 15, 2013 9:07 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/5/13 - Saint Louis Park - POWER RESTORED
Power outage - Saint Louis Park - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, March 14, 2013 1:01 PM
To: Karolevitz, Paul W; Jaede, Wendy L
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/5/2013 Date In : 3/5/2013
Time Out : 13:58 Time In : 14:13

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 456

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Fused cutout broke and is laying across x-arm. Intentional to clear for trouble

Follow-Up : replaced cutout. only customers from sub to the 2 switch were out

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 19, 2013 1:21 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/19/13 - Golden Valley & Saint Louis Park
Power outage - Golden Valley & Saint Louis Park.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, March 19, 2013 1:15 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/19/2013 Date In :
Time Out : 13:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1224

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 19, 2013 2:02 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/19/13 - Golden Valley & Saint Louis Park -
UPDATE

Power outage - Golden Valley & Saint Louis Park - update.

Wendy

From: Aspinwall, David P
Sent: Tuesday, March 19, 2013 1:37 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/19/2013 Date In :
Time Out : 13:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1224

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAR SMASHED INTO THE POLE, DRIVER OKAY.

Follow-Up : WILL HAVE POWER BACK ON VERY SOON!

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 19, 2013 2:02 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/19/13 - Golden Valley & Saint Louis Park -
POWER RESTORED
Power outage - Golden Valley & Saint Louis Park - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, March 19, 2013 1:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/19/2013 Date In : 3/19/2013
Time Out : 13:12 Time In : 13:44

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 1224

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : VEHICLE HIT POLE,DAMAGE TO U-GAURD & CABLE

Follow-Up : ISOLATE,REFER FOR REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, March 21, 2013 11:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/21/13 - Independence, Long Lake, Maple Plain, Media, Minnetrista, Mound, North Mankato, Orono & Wayzata
Power outage - Independence, Long Lake, Maple Plain, Media, Minnetrista, Mound, North Mankato, Orono & Wayzata.

Wendy

From: Knutson, David A
Sent: Thursday, March 21, 2013 11:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/21/2013 Date In :
Time Out : 10:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2813

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; LONG LAKE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : AT SUB IS OPENING AND CLOSING ON IT'S OWN. TRBL IN
THE PROCESS OF FEILD SWITCHING AND

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, March 21, 2013 11:30 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/21/13 - Independence, Long Lake, Maple Plain, Media, Minnetrista, Mound, North Mankato, Orono & Wayzata - POWER RESTORED
Power outage - Independence, Long Lake, Maple Plain, Media, Minnetrista, Mound, North Mankato, Orono & Wayzata - power restored.

Wendy

From: Knutson, David A
Sent: Thursday, March 21, 2013 11:25 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/21/2013 Date In : 3/21/2013
Time Out : 10:55 Time In : 11:23

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 2813

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; LONG LAKE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : MOD OPEN AND CLOSING ON IT'S OWN AT THE SUB

Follow-Up : FIELD SWITCHED AND EVERYBODY BACK ON
OPERATORS ON THEIR WAY TO SUB

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 26, 2013 8:44 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/25/13 - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park
Power outage - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park

Wendy

From: Peterson, Kenneth W
Sent: Monday, March 25, 2013 4:37 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/25/2013 Date In :
Time Out : 16:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2056

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 26, 2013 8:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/25/13 - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park - POWER RESTORED

Power outage - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, March 25, 2013 5:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/25/2013 Date In : 3/25/2013
Time Out : 16:35 Time In : 17:23

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2056

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : A ph arrestor blew at the BKR in SUB / damaged the A ph pothead

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, March 27, 2013 7:53 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/26/13 - Eden Prairie
Power outage - Eden Prairie

Wendy

From: Anderson, Timothy K
Sent: Tuesday, March 26, 2013 10:23 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/26/2013 Date In :
Time Out : 22:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, March 27, 2013 7:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/26/13 - Eden Prairie - POWER RESTORED
Power outage - Eden Prairie - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, March 26, 2013 11:16 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/26/2013 Date In : 3/26/2013
Time Out : 22:06 Time In : 23:12

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : CABLE FAULT BTW

Follow-Up : REFER BIDDLE & REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 29, 2013 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/29/13 - Bloomington, Burnsville & Savage
Power outage - Bloomington, Burnsville & Savage

Wendy

From: Hills, Thomas L
Sent: Friday, March 29, 2013 6:44 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/29/2013 Date In :
Time Out : 06:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 21

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 29, 2013 8:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/29/13 - Bloomington, Burnsville & Savage - POWER RESTORED

Power outage - Bloomington, Burnsville & Savage - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, March 29, 2013 8:14 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/29/2013 Date In : 3/29/2013
Time Out : 06:37 Time In : 08:08

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 21

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : Patrol ok.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 7:57 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/30/13 - Coon Rapids & Fridley
Coon Rapids & Fridley

Wendy

From: Peterson, Kenneth W
Sent: Saturday, March 30, 2013 4:34 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In :
Time Out : 04:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Broken pole 3 mol 63 / tie was closed when broken pole let loose

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 7:58 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Coon Rapids & Fridley - POWER RESTORED
Power outage - Coon Rapids & Fridley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, March 30, 2013 4:54 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In : 3/30/2013
Time Out : 04:23 Time In : 04:44

Time Zone : CST

Duration : 0 hours, 21 mins

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Broken pole 3 mol 63 / tie was closed while switching to isolate when the 3 mol 63 pole went phase to phase

Follow-Up : Isolated 3 mol 63 while feeders were out

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/30/13 - Fridley, Minneapolis & Spring Lake Park
Power outage - Fridley, Minneapolis & Spring Lake Park

Wendy

From: Peterson, Kenneth W
Sent: Saturday, March 30, 2013 4:32 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In :
Time Out : 04:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1606

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN; SPRING LAKE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : broken pole 3 mol 63

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 7:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/30/13 - Fridley, Minneapolis & Spring Lake Park - POWER RESTORED

Power outage - Fridley, Minneapolis & Spring Lake Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, March 30, 2013 5:05 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In : 3/30/2013
Time Out : 04:22 Time In : 04:54

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 1606

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN; SPRING LAKE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Broken pole 3 mol 63 / when isolating pole phases arced in the heavy rain causing feeder to lockout

isolated Follow-Up : Feeder was tied to at the time of the lockout / both are back in / 3 mol 63 is

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:00 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/30/13 - Golden Valley, Minneapolis & Robbinsdale
Power outage - Golden Valley, Minneapolis & Robbinsdale

Wendy

From: Hills, Thomas L
Sent: Saturday, March 30, 2013 8:30 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In :
Time Out : 08:26 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 689

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:01 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/30/13 - Golden Valley, Minneapolis & Robbinsdale -
POWER RESTORED

Power outage - Golden Valley, Minneapolis & Robbinsdale - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, March 30, 2013 9:41 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/30/2013 Date In : 3/30/2013
Time Out : 08:26 Time In : 09:33

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 689

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : head end cable fault

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 01, 2013 8:09 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/31/13 - Deephaven, Excelsior, Greenwood, Minnetonka, Shorewood & Wayzata - POWER RESTORED
Power outage - Deephaven, Excelsior, Greenwood, Minnetonka, Shorewood & Wayzata - power restored.

Wendy

From: Aspinwall, David P
Sent: Sunday, March 31, 2013 10:53 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2013 Date In : 3/31/2013
Time Out : 09:04 Time In : 10:51

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 946

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN; MINNETONKA, MN; SHOREWOOD, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : RAT

Follow-Up : BUS TIE CLOSED AND 61 BKR IS BACK IN.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 01, 2013 2:25 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/1/13 - Foley, Saint Cloud, Sartell & Sauk Rapids
Power outage - Foley, Saint Cloud, Sartell & Sauk Rapids.

Wendy

From: Goulet, Terry W
Sent: Friday, March 01, 2013 2:23 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/1/2013 Date In :
Time Out : 14:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7677

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOLEY, MN; SAINT CLOUD, MN; SARTELL, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : Low side breaker opened on TR# 3. Crew working in Sub and had nothing to do with outage. Troublemens enroute

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 01, 2013 2:39 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/1/13 - Foley, Saint Cloud, Sartell
& Sauk Rapids - POWER RESTORED
Power outage - Foley, Saint Cloud, Sartell & Sauk Rapids - power restored.

Wendy

From: Goulet, Terry W
Sent: Friday, March 01, 2013 2:31 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/1/2013 Date In : 3/1/2013
Time Out : 14:02 Time In : 14:25

Time Zone : CST

Duration : 0 hours, 23 mins

Number of Customers Affected : 7677

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOLEY, MN; SAINT CLOUD, MN; SARTELL, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : Relay crew looked over and closed in breaker @ 1425. Crew still enroute and will check over sub.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 15, 2013 11:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/15/13 - Brownton
Power outage - Brownton.

Wendy

From: Chase, Julie B
Sent: Friday, March 15, 2013 10:37 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/15/2013 Date In :
Time Out : 10:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 56

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BROWNTON, MN; BROWNTOWN, MN

State : MN - Minnesota

Major Customers :

Cause : OC895370 - intentional for construction work, outage scheduled by area

Follow-Up :

Eilers, Rebecca D

From: Preston, Carly
Sent: Friday, March 15, 2013 2:42 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: Second Outage Notice 3/15/13 Power Restored BROWNTOWN, MN
3/15/13 Power Restored
BROWNTOWN, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 F: 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Friday, March 15, 2013 12:15 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/15/2013 Date In : 3/15/2013
Time Out : 10:30 Time In : 11:56

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 56

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BROWNTON, MN; BROWNTOWN, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional for Construction work. RFO 321838. 100% Restored.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 18, 2013 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/18/13 - Atwater, Grove City & Paynesville

Let's try this again.

Power outage - Atwater, Grove City & Paynesville

Wendy

From: Vorachek, Kelly
Sent: Monday, March 18, 2013 6:30 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/18/2013 Date In :
Time Out : 06:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 648

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ATWATER, MN; GROVE CITY, MN; PAYNESVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : OC895699 & 895700 - Transmission Event - cause unknown - crew enroute.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 18, 2013 8:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/18/13 - Atwater, Grove City & Paynesville - POWER RESTORED
Power outage - Atwater, Grove City & Paynesville - power restored.

Wendy

From: Vorachek, Kelly
Sent: Monday, March 18, 2013 8:29 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/18/2013 Date In : 3/18/2013
Time Out : 06:12 Time In : 08:21

Time Zone : CST

Duration : 2 hours, 9 mins

Number of Customers Affected : 648

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ATWATER, MN; GROVE CITY, MN; PAYNESVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : OC895699 & 895700 - Transmission event - cause unknown - restored all Xcel customers via switching at 08:21

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/11/13 - Altura, Elba, Minneiska,
Minnesota City, Rollingstone & Weaver
Power outage - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver.

Wendy

From: Chase, Julie B
Sent: Monday, March 11, 2013 3:29 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/11/2013 Date In :
Time Out : 03:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1004

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALTURA, MN; ELBA, MN; MINNEISKA, MN; MINNESOTA CITY, MN;
ROLLINGSTONE, MN; WEAVER, MN

State : MN - Minnesota

Major Customers :

Cause : oc894450 snow in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 11, 2013 8:30 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/11/13 - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver - POWER RESTORED
Power outage - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver - power restored.

Wendy

From: Goulet, Terry W
Sent: Monday, March 11, 2013 5:45 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/11/2013 Date In : 3/11/2013
Time Out : 03:13 Time In : 05:31

Time Zone : CST

Duration : 2 hours, 18 mins

Number of Customers Affected : 1004

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALTURA, MN; ELBA, MN; MINNEISKA, MN; MINNESOTA CITY, MN;
ROLLINGSTONE, MN; WEAVER, MN

State : MN - Minnesota

Major Customers : NA

Cause : OC894450, DPC live out, isolated problem and line restored by switching.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, March 15, 2013 9:00 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/13/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Goulet, Terry W
Sent: Wednesday, March 13, 2013 12:05 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/13/2013 Date In : 3/13/2013
Time Out : 10:50 Time In : 11:18

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 227

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : OC894900 Outage caused by switching on . Mapping and viewer
incorrect and customers fed out out of load center was outaged due to switches mapped wrong

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, March 27, 2013 7:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 3/26/13 - Green Isle
Power outage - Green Isle

Wendy

From: Chase, Julie B
Sent: Tuesday, March 26, 2013 10:18 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 3/26/2013 Date In :
Time Out : 22:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 288

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GREEN ISLE, MN

State : MN - Minnesota

Major Customers :

Cause : OC897173, crew being called in

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, March 27, 2013 7:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/26/13 - Green Isle - POWER
RESTORED

Power outage - Green Isle - power restored.

Wendy

From: Chase, Julie B
Sent: Wednesday, March 27, 2013 12:02 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/26/2013 Date In : 3/26/2013
Time Out : 22:10 Time In : 23:42

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 288

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GREEN ISLE, MN

State : MN - Minnesota

Major Customers :

Cause : OC 897173

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 09, 2013 12:50 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/9/13 - Cottage Grove, Grey Cloud Island & Saint Paul Park - POWER RESTORED
Power outage - Cottage Grove, Grey Cloud Island & Saint Paul Park - power restored.

Wendy

From: Driscoll, Paul M
Sent: Tuesday, April 09, 2013 12:17 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In : 4/9/2013
Time Out : 11:53 Time In : 12:02

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 2259

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; GREY CLOUD IS, MN; SAINT PAUL PARK, MN

State : MN - Minnesota

Major Customers :

Cause : At our switch was on fire..The feeder also had
about 1/3rd of ...

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 11, 2013 11:14 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/11/13 - Cottage Grove, Grey Cloud Is & Saint Paul Park - POWER RESTORED
Power outage - Cottage Grove, Grey Cloud Is & Saint Paul Park - power restored.

Wendy

From: Gilland, William P
Sent: Thursday, April 11, 2013 10:59 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/11/2013 Date In : 4/11/2013
Time Out : 09:23 Time In : 10:21

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 2903

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; GREY CLOUD IS, MN; SAINT PAUL PARK, MN

State : MN - Minnesota

Major Customers :

Cause : vehicle caught low wire/low wire flipped into fdr and burned wire
down

Follow-Up : back into at 10:21 was carrying approx 650 cust of
on an planned RFO. All but 20 of those cust's restored at 10:58

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, April 13, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/13/13 - Falcon Heights & Saint Paul
Power outage - Falcon Heights & Saint Paul

Wendy

From: Driscoll, Paul M
Sent: Saturday, April 13, 2013 2:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/13/2013 Date In :
Time Out : 02:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1780

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Unknown..

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, April 13, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/13/13 - Falcon Heights & Saint Paul - POWER RESTORED

Power outage - Falcon Heights & Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, April 13, 2013 4:04 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/13/2013 Date In : 4/13/2013
Time Out : 02:33 Time In : 03:56

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1780

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : C phase pothead failed on our switch..

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, April 13, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/13/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul.

Wendy

From: Gilland, William P
Sent: Saturday, April 13, 2013 7:05 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/13/2013 Date In :
Time Out : 07:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2398

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, April 13, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/13/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Saturday, April 13, 2013 8:08 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/13/2013 Date In : 4/13/2013
Time Out : 07:00 Time In : 07:59

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 2398

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : def cable

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/22/13 - Cottage Grove & Woodbury
Power outage - Cottage Grove & Woodbury.

Wendy

From: Gilland, William P
Sent: Monday, April 22, 2013 11:31 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In :
Time Out : 23:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 30, 2013 9:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice Correction - 4/22/13 - Cottage Grove & Woodbury - UPDATE/POWER RESTORED

Correction from the outage notifications that were sent on 4/23/13.

Power outage - Cottage Grove & Woodbury - power restored.

Sorry for the delay!

Wendy

From: LaCasse, Joseph S
Sent: Friday, April 26, 2013 3:54 PM
To: Jaede, Wendy L
Cc: LaCasse, Joseph S
Subject: Final Outage Notice Correction
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In : 4/23/2013
Time Out : 23:28 Time In : 01:19

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 3864

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder at

Follow-Up : was picking up all of due to a construction project at sub.

Fault was on RRK63.

Partially restored, at 00:53 restoring 2101 customers. Remaining 1763 customers on
restored at 1:19.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Bayport, Lakeland, Oak Park Heights,
Stillwater & W Lakeland Twp
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 12:45 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 00:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1802

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:06 AM
To: 'staff, cao (PUC)'; dl Customer Advocate Team
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - POWER RESTORED
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 2:19 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 00:37 Time In : 01:55

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1802

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches on fdr on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - POWER RESTORED
CORRECTION - FAILED TO INITIALLY SEND IT TO DOUG RENIER.

WENDY

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:06 AM
To: 'staff, cao (PUC)'; dl Customer Advocate Team
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - POWER RESTORED

Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 2:19 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 00:37 Time In : 01:55

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1802

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches on fdr on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Cottage Grove & Woodbury
Power outage - Cottage Grove & Woodbury.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 2:28 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 02:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 30, 2013 9:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Cottage Grove & Woodbury -
UPDATE/POWER RESTORED

Correction from the outage notifications that were sent on 4/23/13.

Power outage - Cottage Grove & Woodbury - power restored.

Sorry for the delay!

Wendy

From: LaCasse, Joseph S
Sent: Friday, April 26, 2013 3:59 PM
To: Jaede, Wendy L
Cc: LaCasse, Joseph S
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 02:24 Time In : 03:43

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 3864

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree branches falling on feeder near .

Follow-Up : Restored at 02:53 - 2101 customers. Restored at 03:43 - remaining 1763
customers restored at that time.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Cottage Grove & Woodbury -
POWER RESTORED

Power outage - Cottage Grove & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 3:12 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 02:24 Time In : 02:53

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree on .

Follow-Up : is switched unto removed from and
restored. to be energized when tree is removed

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 4/23/13 - Cottage Grove & Woodbury -
POWER RESTORED - UPDATE
Power outage - Cottage Grove & Woodbury - power restored - update.

Wendy

From: Gilland, William P
Sent: Tuesday, April 23, 2013 4:01 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 02:24 Time In : 03:43

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 3864

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : large tree branch on fdr at

Follow-Up :

Eilers, Rebecca D

From: Preston, Carly
Sent: Monday, April 29, 2013 8:09 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 4/26/13 Outage INVER GROVE HEIGHTS, MN;
INVER GROVE, MN
4/26/13 Outage

INVER GROVE HEIGHTS, MN; INVER GROVE, MN

Carly Preston

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive St. Paul, MN 55113

P: 651.639.4367 F: 651.639.4322

E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Elden, Thomas L
Sent: Friday, April 26, 2013 4:15 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/26/2013 Date In :

Time Out : 15:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3505

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : opened and closed that picked up
1570 customers also at 15:44

Follow-Up :

Eilers, Rebecca D

From: Preston, Carly
Sent: Monday, April 29, 2013 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 4/26/13 Power Restored INVER GROVE HEIGHTS, MN; INVER GROVE, MN
4/26/13 Power Restored

INVER GROVE HEIGHTS, MN; INVER GROVE, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 F: 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Elden, Thomas L
Sent: Friday, April 26, 2013 5:44 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/26/2013 Date In : 4/26/2013

Time Out : 15:44 Time In : 16:51

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 3505

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : bad cable at

Follow-Up : have a crew on to repair

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 03, 2013 2:05 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/3/13 - Bloomington & Eagan
Power outage - Bloomington & Eagan.

Wendy

From: Davis, Percyell
Sent: Wednesday, April 03, 2013 1:48 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/3/2013 Date In :
Time Out : 13:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2265

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 03, 2013 2:49 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/3/13 - Bloomington & Eagan - POWER RESTORED
Power outage - Bloomington & Eagan - power restored.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, April 03, 2013 2:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/3/2013 Date In : 4/3/2013
Time Out : 13:37 Time In : 14:40

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2265

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up : Patrol and reset auto gear.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 04, 2013 12:33 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/4/13 - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato
Power outage - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato.

Wendy

From: Schwarz, John W
Sent: Thursday, April 04, 2013 12:27 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/4/2013 Date In :
Time Out : 14:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1423

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown at this time.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 04, 2013 1:03 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/4/13 - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - POWER RESTORED
Power outage - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - power restored.

Wendy

From: Schwarz, John W
Sent: Thursday, April 04, 2013 1:02 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/4/2013 Date In : 4/4/2013
Time Out : 12:13 Time In : 12:56

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 1423

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : None

Cause : Construction crew had an incident.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 08, 2013 8:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/6/13 - Eden Prairie & Edina
Power outage - Eden Prairie & Edina.

Wendy

From: Aspinwall, David P
Sent: Saturday, April 06, 2013 7:01 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/6/2013 Date In :
Time Out : 18:54 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 327

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME.

Follow-Up : WILL PATROL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 08, 2013 8:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/6/13 - Eden Prairie & Edina - POWER RESTORED

Power outage - Eden Prairie & Edina - power restored.

Wendy

From: Aspinwall, David P
Sent: Saturday, April 06, 2013 7:52 PM
To: dl Electric Outage MW Notification
Subject: EDP-EDEN PRAIRIE (094) Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/6/2013 Date In : 4/6/2013
Time Out : 18:54 Time In : 19:45

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 327

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : SQUIRREL CONTACT AT THE SWITCH, NO MAJOR DAMAGE

DONE.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 08, 2013 8:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/8/13 - Minneapolis & Saint Louis Park
Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Hills, Thomas L
Sent: Monday, April 08, 2013 6:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/8/2013 Date In :
Time Out : 06:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2392

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Trouble enroute.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 08, 2013 8:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/8/13 - Minneapolis & Saint Louis Park -
UPDATE

Power outage - Minneapolis & Saint Louis Park - update.

Wendy

From: Hills, Thomas L
Sent: Monday, April 08, 2013 7:24 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/8/2013 Date In :
Time Out : 06:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2392

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Insulator failed at

Follow-Up : 58 cust. rest 0704, 2308 cust. rest 0713. Crew to replace insulator to restore remaining 26 customers. Crew on the way.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 08, 2013 8:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/8/13 - Minneapolis & Saint Louis Park -
POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, April 08, 2013 7:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 4/8/2013	Date In : 4/8/2013
Time Out : 06:09	Time In : 07:48

Time Zone : CST
Duration : 1 hours, 39 mins
Number of Customers Affected : 2392
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Insulator failed at

Follow-Up : All restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 09, 2013 1:17 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4//9/13 - Eden Prairie & Edina
Power outage - Eden Prairie & Edina.

Wendy

From: Knutson, David A
Sent: Tuesday, April 09, 2013 1:08 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In :
Time Out : 13:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 215

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : troublemen on the way

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 09, 2013 2:07 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/9/13 - Eden Prairie & Edina - POWER RESTORED
Power outage - Eden Prairie & Edina - power restored.

Wendy

From: Knutson, David A
Sent: Tuesday, April 09, 2013 2:02 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In : 4/9/2013
Time Out : 13:04 Time In : 13:59

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 215

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : patrolled feeder nothing found breaker in and holding

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 10, 2013 1:54 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/10/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Wednesday, April 10, 2013 1:50 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/10/2013 Date In :
Time Out : 13:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4420

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown. Trouble to patrol.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/11/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Kittock, Joseph C
Sent: Thursday, April 11, 2013 11:16 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/11/2013 Date In :
Time Out : 23:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4421

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/11/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Kittock, Joseph C
Sent: Friday, April 12, 2013 12:16 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In : 4/12/2013
Time Out : 23:04 Time In : 23:50

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 367

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/11/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Friday, April 12, 2013 12:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In : 4/12/2013
Time Out : 23:04 Time In : 23:51

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 4055

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/12/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Friday, April 12, 2013 7:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In : 4/12/2013
Time Out : 6:19 Time In : 7:01

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 621

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : INTENTIONAL TO CLEAR VAULT FIRE 40 SERIES

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:21 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/11/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Friday, April 12, 2013 1:52 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/11/2013 Date In :
Time Out : 23:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Fire in 480V network Vault causing outage to entire vault. (86 Lockout)

Follow-Up : Crew being called in.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:22 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/12/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Hills, Thomas L
Sent: Friday, April 12, 2013 4:51 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In :
Time Out : 23:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Fire in 480V network Vault causing outage to entire vault. (86 Lockout)

Follow-Up : Secondary fuses burned at protector. Crew to cut in the clear to restore.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/12/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, April 12, 2013 8:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In : 4/12/2013
Time Out : 06:19 Time In : 07:55

Time Zone : CST

Duration : 1 hours, 36 mins

Number of Customers Affected : 172

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : VAULT FIRE

Follow-Up : ALL CUST. RESTORED AS OF 07:55

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, April 13, 2013 7:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/12/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Knutson, David A
Sent: Friday, April 12, 2013 11:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/12/2013 Date In : 4/12/2013
Time Out : 05:59 Time In : 22:15

Time Zone : CST

Duration : 16 hours, 16 mins

Number of Customers Affected : 114

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : VAULT FIRE

Follow-Up : WAS THE ONLY OUTAGE CUSTOMER COUNT NOT CORRECT
 ARE BACK ON IN THAT VAULT AND HAS TRANSFERED ALL THEIR LOAD
BACK TO OUR SYSTEM

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 9:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 4-15-13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Babb, Randall J
Sent: Monday, April 15, 2013 6:44 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In :
Time Out : 06:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1266

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down between

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 16, 2013 8:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice- REVISED - 4/11/13 - 4/12/13 - Minneapolis -
POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Lund, Lisa M
Sent: Tuesday, April 16, 2013 8:37 AM
To: Lund, Lisa M; Jaede, Wendy L
Subject: FW: Final Outage Notice- Revised.

This Outage notification was originally sent with the incorrect dates and times. The times and dates are revised below:

From: Knutson, David A
Sent: Friday, April 12, 2013 23:35
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/11/2013	Date In : 4/12/2013
Time Out : 23:27	Time In : 22:15

Time Zone : CST

Duration : 22 hours, 42 mins

Number of Customers Affected : 114

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : VAULT FIRE

Follow-Up : WAS THE ONLY OUTAGE CUSTOMER COUNT NOT CORRECT
AND ARE BACK ON IN THAT VAULT AND HAS TRANSFERED ALL THEIR LOAD
BACK TO OUR SYSTEM

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/18/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Thursday, April 18, 2013 9:46 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 21:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1011

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Trouble to patrol.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/18/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Hills, Thomas L
Sent: Thursday, April 18, 2013 11:29 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 21:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1011

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Crossarm burned up at

Follow-Up : 960 cust. restored at 23:26 / crew being called in to replace crossarm and restore remainder.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/18/13 - 4/18/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, April 19, 2013 4:32 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In : 4/19/2013
Time Out : 21:43 Time In : 04:30

Time Zone : CST

Duration : 6 hours, 47 mins

Number of Customers Affected : 1011

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Crossarm burned up at .

Follow-Up : All restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/22/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Peterson, Kenneth W
Sent: Monday, April 22, 2013 10:07 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In :
Time Out : 22:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3384

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear tree off feeder

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 26, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0020.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Friday, April 26, 2013 7:56 AM
To: Peterson, Kenneth W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable
Elm tree bent into the conductors due to heavy snow.
Feeder last work 5/2008 and scheduled to be worked in 2013.

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Peterson, Kenneth W
Sent: Monday, April 22, 2013 10:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/22/2013

Date In : 4/22/2013

Time Out : 22:05

Time In : 22:20

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 3384

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree on feeder at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/22/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, April 22, 2013 10:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In : 4/22/2013
Time Out : 22:05 Time In : 22:20

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 3384

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree on feeder at Removed Tree

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:14 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Minnetrista, Mound, Shorewood & Spring Park
Power outage - Minnetrista, Mound, Shorewood & Spring Park.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, April 23, 2013 12:35 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 00:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1952

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,
MN

State : MN - Minnesota

Major Customers : None

Cause : Opened to clear feeder to put unfused tap wire up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Minnetrista, Mound, Shorewood & Spring Park - POWER RESTORED

Power outage -Minnetrista, Mound, Shorewood & Spring Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, April 23, 2013 5:25 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 00:32 Time In : 00:40

Time Zone : CST

Duration : 0 hours, 8 mins

Number of Customers Affected : 1952

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,
MN

State : MN - Minnesota

Major Customers : none

Cause : Unfused tap wire off the feeder was down opened from the to clear

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Knutson, David A
Sent: Tuesday, April 23, 2013 4:33 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 04:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 519

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : broken feeder pole

Follow-Up : crew on site dumped feeder to put pole holding truck on back on soon

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Knutson, David A
Sent: Tuesday, April 23, 2013 5:46 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 04:28 Time In : 05:42

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 519

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown possible plow truck

Follow-Up : pole holding truck installed all back on

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, April 23, 2013 7:17 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 7:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2944

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 8:20 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Bloomington - UPDATE
Power outage - Bloomington - update.

Wendy

From: Babb, Randall J
Sent: Tuesday, April 23, 2013 8:11 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 07:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2944

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : , broken street light pole. Trouble to clear.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 9:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Babb, Randall J
Sent: Tuesday, April 23, 2013 8:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 07:14 Time In : 08:50

Time Zone : CST

Duration : 1 hours, 36 mins

Number of Customers Affected : 2944

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : , broken street light pole. Trouble to clear

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 3:25 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/24/13 - Brooklyn Park, Maple Grove & Osseo
Power outage - Brooklyn Park, Maple Grove & Osseo.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, April 24, 2013 3:07 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/24/2013 Date In :
Time Out : 15:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 171

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO,
MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 4:23 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/24/13 - Brooklyn Park, Maple Grove & Osseo -
POWER RESTORED

Power outage - Brooklyn Park, Maple Grove & Osseo - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, April 24, 2013 4:06 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/24/2013 Date In : 4/24/2013
Time Out : 15:05 Time In : 16:03

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 171

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO,
MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN CAUSE FOR TRIP.TROUBLE PATROLLED FEEDER
FOUND NOTHING.

Follow-Up :

Eilers, Rebecca D

From: Preston, Carly
Sent: Monday, April 29, 2013 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 4/28/13 Outage MAYER, MN; WATERTOWN
TWP, MN; WATERTOWN, MN

4/28/13 Outage

MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

Carly Preston

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive St. Paul, MN 55113

P: 651.639.4367 F: 651.639.4322

E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, April 28, 2013 5:40 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/28/2013 Date In :
Time Out : 05:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1350

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : None

Cause : Report of car hit pole on

Follow-Up :

Eilers, Rebecca D

From: Preston, Carly
Sent: Monday, April 29, 2013 8:11 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 4/28/13 Outage Update
4/28/13 – Outage Update

MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 **F:** 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Sunday, April 28, 2013 7:22 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/28/2013 Date In :
Time Out : 05:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1350

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit feeder pole pole is broken in half

Follow-Up : trouble onsite going to float phases should be able to get power restored with in 1/2

hr

Eilers, Rebecca D

From: Preston, Carly
Sent: Monday, April 29, 2013 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 4/28/13 Power Restored
4/28/13 Power Restored

MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 **F:** 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Sunday, April 28, 2013 8:12 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/28/2013 Date In : 4/28/2013
Time Out : 05:25 Time In : 08:08

Time Zone : CST

Duration : 2 hours, 43 mins

Number of Customers Affected : 1350

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WATERTOWN TWP, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit pole

Follow-Up : floated phases lowered neutral. trouble feels okay till monday am for pole
replacement

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 9:30 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/15/13 - Blomkest, Cosmos &
Lake Lillian
Power outage - Blomkest, Cosmos & Lake Lillian.

Wendy

From: Bui, Tien V
Sent: Monday, April 15, 2013 12:19 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In :
Time Out : 00:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 714

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BLOMKEST, MN; COSMOS, MN; LAKE LILLIAN, MN

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION LEVEL EVENT 69KV OR ABOVE OUT / THIS
IS TRANSMISSION EVENT NO FURTHER INFO FROM DISTRIBUTION. CALL TSO FOR INFO.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 9:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/15/13 - Blomkest, Cosmos &
Lake Lillian - POWER RESTORED
Power outage - Blomkest, Cosmos & Lake Lillian - power restored.

Wendy

From: Bui, Tien V
Sent: Monday, April 15, 2013 1:58 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In : 4/15/2013
Time Out : 00:14 Time In : 01:53

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 714

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BLOMKEST, MN; COSMOS, MN; LAKE LILLIAN, MN

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION LEVEL EVENT POWER RESTORE AT 01:53 /
IF INFORMATION REQUIRE CALL TSO FOR CAUSE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 16, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/15/13 - Clements, Cobden, Evan,
Morgan, Morton, Redwood Falls & Sleepy Eye
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye.

Wendy

From: Kaveny, Michael J
Sent: Monday, April 15, 2013 7:15 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In :
Time Out : 19:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON,
MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 16, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/15/13 - Clements, Cobden,
Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - POWER RESTORED
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, April 15, 2013 8:34 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In : 4/15/2013
Time Out : 19:05 Time In : 20:25

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON,
MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : Found blown arresters in

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 18, 2013 2:00 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/18/13 - Champlin, Dayton, Maple Grove, Osseo & Rogers
Power outage - Champlin, Dayton, Maple Grove, Osseo & Rogers.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 1:50 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 13:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1303

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN; OSSEO, MN;
ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, getting Trouble enroute

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 18, 2013 2:45 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/18/13 - Champlin, Dayton, Maple Grove, Osseo & Rogers - POWER RESTORED
Power outage - Champlin, Dayton, Maple Grove, Osseo & Rogers - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 2:23 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 13:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1303

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN; OSSEO, MN;
ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause : 911 Reports broken pole from Semi on , Trouble en-route to confirm
and try to isolate.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 18, 2013 2:55 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/18/13 - Champlin, Dayton, Maple Grove, Osseo & Rogers - CORRECTION - UPDATE

Power outage - Champlin, Dayton, Maple Grove, Osseo & Rogers - update.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 2:23 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 13:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1303

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN; OSSEO, MN;
ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause : 911 Reports broken pole from Semi on , Trouble en-route to confirm and
try to isolate.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 18, 2013 2:56 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 4/18/13 - Champlin, Dayton, Maple Grove, Osseo & Rogers - POWER RESTORED
Power outage - Champlin, Dayton, Maple Grove, Osseo & Rogers - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 2:52 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In : 4/18/2013
Time Out : 13:47 Time In : 14:48

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 1303

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN; OSSEO, MN;
ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause : Troublemans cleared up conductor from broken pole and re-energized. 100%
restored.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Hector
Power outage - Hector.

Wendy

From: Medellin, Victor J
Sent: Tuesday, April 23, 2013 7:19 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 19:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 688

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : HECTOR, MN

State : MN - Minnesota

Major Customers : NONE

Cause : INTENTIONAL TO CLEAR BROKEN POLE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Hector - POWER RESTORED
Power outage - Hector - power restored.

Wendy

From: Vorachek, Kelly
Sent: Wednesday, April 24, 2013 2:50 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 19:11 Time In : 19:26

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 688

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : HECTOR, MN

State : MN - Minnesota

Major Customers : N/A

Cause : OC909867 - Intentional Outage to isolate broken pole - POLE REPLACED, FINAL 3
CUSTOMERS RESTORED AT 02:21 4/24

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Hector - POWER RESTORED
Power outage - Hector - power restored.

Wendy

From: Vorachek, Kelly
Sent: Wednesday, April 24, 2013 2:50 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 19:11 Time In : 19:26

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 688

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : HECTOR, MN

State : MN - Minnesota

Major Customers : N/A

Cause : OC909867 - Intentional Outage to isolate broken pole - POLE REPLACED, FINAL 3
CUSTOMERS RESTORED AT 02:21 4/24

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 09, 2013 10:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/9/13 - Edgerton
Power outage - Edgerton.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, April 09, 2013 10:44 AM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In :
Time Out : 09:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 672

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN

State : SD - South Dakota

Major Customers : None

Cause : Non EMS Sub, Troubleman found Breaker open, reports galloping conductors and floaters, will begin repairs and knocking off ice..

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 11, 2013 9:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/9/13 - Edgerton - POWER RESTORED
Power outage - Edgerton - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 11, 2013 9:36 AM
To: dl Electric Outage SD Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In : 4/9/2013
Time Out : 09:24 Time In : 15:45

Time Zone : CST

Duration : 6 hours, 21 mins

Number of Customers Affected : 673

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN

State : SD - South Dakota

Major Customers : None

Cause : Floating and galloping conductors. Crews made repairs, removed ice and restored.

Follow-Up : Final outage alert was missed on Tuesday.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 10, 2013 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/9/13 - Chandler & Lake Wilson
Power outage - Chandler & Lake Wilson.

Wendy

From: Reinschmidt, Brad A
Sent: Tuesday, April 09, 2013 7:53 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 4/9/2013	Date In :
Time Out : 11:12	Time In :

Time Zone : CST
Duration :
Number of Customers Affected : 179
For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870
Communities Affected : CHANDLER, MN; LAKE WILSON, MN
State : SD - South Dakota
Major Customers : None
Cause : Ice storm
Follow-Up : Non RTU sub

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 12, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/9/13 - Chandler & Lake Wilson - POWER RESTORED

Power outage - Chandler & Lake Wilson - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, April 11, 2013 4:13 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In : 4/11/2013
Time Out : 11:12 Time In : 15:39

Time Zone : CST

Duration : 52 hours, 27 mins

Number of Customers Affected : 179

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : NONE

Cause : 1 MILE OF POLES AND WIRE DOWN REPAIRS
COMPLETE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 10, 2013 7:51 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/9/13 - Chandler & Lake Wilson
Power outage - Chandler & Lake Wilson.

Wendy

From: Peterson, Mark S
Sent: Tuesday, April 09, 2013 5:19 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In :
Time Out : 14:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 173

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : none

Cause : CREW DISPATCHED TO RECLOSER OUTAGE FOUND
BREAKER OPEN AT SUB. NON RTU SUB

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 10, 2013 7:52 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/9/13 - Chandler & Lake Wilson - POWER RESTORED

Power outage - Chandler & Lake Wilson - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Tuesday, April 09, 2013 7:38 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/9/2013 Date In : 4/9/2013
Time Out : 14:47 Time In : 19:28

Time Zone : CST

Duration : 4 hours, 41 mins

Number of Customers Affected : 173

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : None

Cause : Lines down from ice storm, crew made repairs and restored power

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 8:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/14/13 - Florence, Holland, Ihlen, Jasper, Pipestone, Ruthton, Trosky, Tyler & Woodstock
Power outage - Florence, Holland, Ihlen, Jasper, Pipestone, Ruthton, Trosky, Tyler & Woodstock.

Wendy

From: Vorachek, Kelly
Sent: Sunday, April 14, 2013 4:20 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/14/2013 Date In :
Time Out : 16:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1111

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FLORENCE, MN; HOLLAND, MN; IHLEN, MN; JASPER, MN;
PIPESTONE, MN; RUTHTON, MN; TROSKY, MN; TYLER, MN; WOODSTOCK, MN

State : SD - South Dakota

Major Customers : N/A

Cause : OC906260 - Intentional outage to de-energize feeder to repair 6 broken pole tops from earlier storm. RFO 322563

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 8:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Florence, Holland, Ihlen, Jasper, Pipestone, Ruthton, Trosky, Tyler & Woodstock - POWER RESTORED
Power outage - Florence, Holland, Ihlen, Jasper, Pipestone, Ruthton, Trosky, Tyler & Woodstock - power restored.
Wendy

From: Peterson, Mark S
Sent: Sunday, April 14, 2013 6:58 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/14/2013 Date In : 4/14/2013
Time Out : 16:13 Time In : 18:47

Time Zone : CST

Duration : 2 hours, 34 mins

Number of Customers Affected : 1111

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FLORENCE, MN; HOLLAND, MN; IHLEN, MN; JASPER, MN; PIPESTONE, MN; RUTHTON, MN; TROSKY, MN; TYLER, MN; WOODSTOCK, MN

State : SD - South Dakota

Major Customers : NONE

Cause : INTENTIONAL OUTAGE TO FEEDER TO REPLACE 6 DAMAGED POLES JUST OUTSIDE SUB.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 11, 2013 7:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/10/13 - Kellogg, Lake City, Reads Landing & Wabasha
Power outage - Kellogg, Lake City, Reads Landing & Wabasha.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, April 10, 2013 7:11 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/10/2013 Date In :
Time Out : 19:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 884

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KELLOGG, MN; LAKE CITY, MN; READS LANDING, MN; WABASHA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : not determined

Follow-Up : crew called in

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 11, 2013 7:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/10/13 - Kellogg, Lake City, Reads
Landing & Wabasha - UPDATE
Power outage - Kellogg, Lake City, Reads Landing & Wabasha - update.

Wendy

From: Medellin, Victor J
Sent: Wednesday, April 10, 2013 10:36 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/10/2013 Date In :
Time Out : 18:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 884

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KELLOGG, MN; LAKE CITY, MN; READS LANDING, MN;
WABASHA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SQUIRREL GOT ACROSS A DISC BREAKING THE BUSHINGS
AND BLOWING 2 HIGH SIDE 69KV FUSES CREW IN PROCESS OF ISOLATING BREAKER
AND BROKEN INSULATORS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, April 11, 2013 7:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 4/10/13 - Kellogg, Lake City, Reads
Landing & Wabasha - POWER RESTORED
Power outage - Kellogg, Lake City, Reads Landing & Wabasha - power restored.

Wendy

From: Medellin, Victor J
Sent: Wednesday, April 10, 2013 11:53 PM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 4/10/2013 Date In : 4/10/2013
Time Out : 19:00 Time In : 23:45

Time Zone : CST

Duration : 4 hours, 45 mins

Number of Customers Affected : 884

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KELLOGG, MN; LAKE CITY, MN; READS LANDING, MN;
WABASHA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : ISOLATED A DISC IN SUB ON CUSTOMERS ON C
BYPASS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/14/13 -
Gaylord
Power outage - Gaylord.

Wendy

From: Vorachek, Kelly
Sent: Sunday, April 14, 2013 8:13 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/14/2013 Date In :
Time Out : 07:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1217

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GAYLORD, MN

State : MN - Minnesota

Major Customers :

Cause : - Transmission Event - Cause unknown - Ice / Snow - Crew
and Operator enroute

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 15, 2013 8:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: TRANSMISSION-SE (CRF-CRYSTAL FOODS, GAY-GAYLORD) Second Outage Notice - 4/14/13 - Gaylord - POWER RESTORED

Power outage - Gaylord - power restored.

Wendy

From: Vorachek, Kelly
Sent: Sunday, April 14, 2013 9:13 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/14/2013 Date In : 4/14/2013

Time Out : 07:53 Time In : 08:58

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 1217

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GAYLORD, MN

State : MN - Minnesota

Major Customers :

Cause : - Transmission Event - Cause unknown - Ice / Snow - Crew
restored via switching @ 08:58

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 16, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/15/13 - Essig & New Ulm
Power outage - Essig & New Ulm.

Wendy

From: Kaveny, Michael J
Sent: Monday, April 15, 2013 7:14 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In :
Time Out : 19:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 33

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ESSIG, MN; NEW ULM, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 16, 2013 7:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/15/13 - Essig & New Ulm - POWER
RESTORED

Power outage - Essig & New Ulm - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, April 15, 2013 8:05 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/15/2013 Date In : 4/15/2013
Time Out : 19:05 Time In : 19:42

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 33

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ESSIG, MN; NEW ULM, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, still patrolling transmission line. Town of Morgan still out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/18/13 - Courtland
Power outage - Courtland.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 6:40 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 17:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 382

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COURTLAND, MN

State : MN - Minnesota

Major Customers : None

Cause : Suspect breaker open, Non EMS Sub, wire down reported by Courtland Fire Dept.
Trouble and Operator en-route.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/18/13 - Courtland - POWER RESTORED
Power outage - Courtland - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, April 18, 2013 8:39 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In : 4/18/2013
Time Out : 17:51 Time In : 19:30

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 382

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COURTLAND, MN

State : MN - Minnesota

Major Customers : None

Cause : Operator found Breaker in and holding. Outage Calls are from several tap outages, wire down at one Troubleman is on now and several more in the town of Courtland. Reports of Galloping conductors.

Follow-Up : Non EMS Sub. Difficult to determine if Breaker is open.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Faribault
Power outage - Faribault.

Wendy

From: Vorachek, Kelly
Sent: Tuesday, April 23, 2013 12:05 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 23:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1463

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Feeder operated 3 times and locked out, crew patrolling now

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 2:02 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: _2013.04.23 (1).JPG; _2013.04.23.jpg
FYI....

From: Johnson, Fletcher L
Sent: Tuesday, April 23, 2013 1:19 PM
To: Vorachek, Kelly; dl Electric Outage SE Notification
Subject: RE: Tree Report

Preventable. Ash tree bent into lines due to heavy snow load. Tree had 6'-8' of clearance from lines prior to snow, but likely would have been pruned on maintenance. Line last worked by tree crews April 2009 (4 growing seasons ago). Next VM cycle maintenance work forecasted for 2014.

Fletcher Johnson

Xcel Energy

Vegetation Management Supervisor II

O: 651.639.4590 **C:** 612.418.9761 **F:** 612.573.1856

From: Vorachek, Kelly
Sent: Tuesday, April 23, 2013 12:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In : 4/23/2013
Time Out : 23:46 Time In : 00:10

Time Zone : CST

Duration : 0 hours, 24 mins

Number of Customers Affected : 1463

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Crew found tree bent over into feeder from wet snow at
cleared off and closed breaker by RC

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/22/13 - Faribault - POWER RESTORED
Power outage - Faribault - power restored.

Wendy

From: Vorachek, Kelly
Sent: Tuesday, April 23, 2013 12:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/22/2013 Date In : 4/23/2013
Time Out : 23:46 Time In : 00:10

Time Zone : CST

Duration : 0 hours, 24 mins

Number of Customers Affected : 1463

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Crew found tree bent over into feeder from wet snow at ,
cleared off and closed breaker by RC

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 4/23/13 - Faribault - CORRECTION - 4/22/13
fyi

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Faribault

Power outage - Faribault.

Wendy

From: Vorachek, Kelly
Sent: Tuesday, April 23, 2013 12:05 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 23:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1463

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Feeder operated 3 times and locked out, crew patrolling now

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 9:41 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/23/13 - Dundas & Northfield
Power outage - Dundas & Northfield.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, April 23, 2013 9:40 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 09:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1616

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, calling Trouble and Sub operator.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 12:08 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/23/13 - Dundas & Northfield - UPDATE
Power outage - Dundas & Northfield - update.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, April 23, 2013 11:22 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 09:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1616

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : Crew found Burned and Damaged Sw Center near _____, Crew isolated
Sw Center, Breaker closed and Tie with _____ Feeder closed at 11:12. 3 Large Transformers remain out near
, crew field switching these in.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 23, 2013 1:01 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 4/23/13 - Dundas & Northfield - Update
Power outage - Dundas & Northfield - update.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, April 23, 2013 12:48 PM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In :
Time Out : 09:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1616

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : 2 Customers remain out yet, Servicemaster and 2 Transformers for
Switch Center is burned up and this 3 tub loop feeds back on itself at . Crew in process of grounding and
changing Switch Center.

Follow-Up : Load cables tested good, per Fault Finding Equipment.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 24, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Fourth Outage Notice - 4/23/13 - Dundas & Northfield - POWER RESTORED

Power outage - Dundas & Northfield - power restored.

Wendy

From: Medellin, Victor J
Sent: Tuesday, April 23, 2013 5:13 PM
To: dl Electric Outage SE Notification
Subject: Fourth Outage Notice

Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 09:35 Time In : 17:07

Time Zone : CST

Duration : 7 hours, 32 mins

Number of Customers Affected : 1616

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : BURNT UP SW CENTER REPLACED AND REMAINING 2
CUSTOMERS RESTORED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 30, 2013 9:06 AM
To: 'staff, cao (PUC)'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/23/13 - Cottage Grove & Woodbury -
UPDATE/POWER RESTORED

Correction from the outage notifications that were sent on 4/23/13.

Power outage - Cottage Grove & Woodbury - power restored.

Sorry for the delay!

Wendy

From: LaCasse, Joseph S
Sent: Friday, April 26, 2013 4:05 PM
To: Jaede, Wendy L
Cc: LaCasse, Joseph S
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/23/2013 Date In : 4/23/2013
Time Out : 3:48 Time In : 07:08

Time Zone : CST

Duration : 3 hours, 20 mins

Number of Customers Affected : 2098

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree branches continue to fall on feeder near .

Follow-Up : restored at 03:51 - Momentary for 2101 customers
 restored at 04:53 - 1676 customers
Remaining 87 customers restored at 07:08

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 30, 2013 9:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Momentary Outage *** Momentary Outage *** Correction - 4/22/13
- Cottage Grove & Woodbury - POWER RESTORED

Correction from the outage notifications that were sent on 4/23/13.

Power outage - Cottage Grove & Woodbury - power restored.

Sorry for the delay!

Wendy

From: LaCasse, Joseph S
Sent: Friday, April 26, 2013 3:47 PM
To: Jaede, Wendy L
Cc: LaCasse, Joseph S
Subject: Momentary Outage *** Momentary Outage *** Correction

Distribution System Status Outage Notification

Momentary Outage

Feeder/Bus :

Date Out : 4/22/2013 Date In : 4/22/2013
Time Out : 20:44 Time In : 20:46

Time Zone : CST

Duration : 0 hours, 2 mins

Number of Customers Affected : 3861

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree branches hitting line.

substation. Follow-Up : was carrying all of due to a construction project at the

RCSII Relay reclosed after 2 minutes. Referred to Relay Department for maintenance.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 4/18/13 - Forest Lake & Wyoming
Power outage - Forest Lake & Wyoming.

Wendy

From: Chial, Terry L
Sent: Thursday, April 18, 2013 5:59 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In :
Time Out : 17:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 887

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers :

Cause : opened to clear guy off of feeder ,tso also opened up
line

Follow-Up : will clear and reenergize.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, April 19, 2013 4:02 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** 4/18/13 - Forest Lake & Wyoming - POWER RESTORED
Power outage - Forest Lake & Wyoming - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, April 19, 2013 3:50 PM
To: Jaede, Wendy L
Subject: Final Outage Notice *** Momentary Outage ***
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/18/2013 Date In : 4/18/2013
Time Out : 17:55 Time In : 18:00

Time Zone : CST

Duration : 0 hours, 5 mins

Number of Customers Affected : 887

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers :

Cause : Opened feeder breaker for troubleman to clear guy wire off of feeder.

Follow-Up : None.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 7:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Cottage Grove & Hastings
Power outage - Cottage Grove & Hastings.

Wendy

From: Abbott, Edward J
Sent: Thursday, May 02, 2013 4:16 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 04:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1385

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 09, 2013 10:19 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: photo.jpg
FYI.....

From: Johnson, Fletcher L
Sent: Thursday, May 09, 2013 10:13 AM
To: Johnson, Fletcher L; Weidenfeller, Bradley M; dl Electric Outage ME Notification
Subject: RE: Tree Report

[Photo attached. Sorry for multiple emails.](#)

Fletcher Johnson

Xcel Energy

Vegetation Management Supervisor II

O: 651.639.4590 C: 612.418.9761 F: 612.573.1856

From: Johnson, Fletcher L
Sent: Thursday, May 09, 2013 10:11 AM
To: Weidenfeller, Bradley M; dl Electric Outage ME Notification
Subject: RE: Tree Report

See below.

From: Weidenfeller, Bradley M
Sent: Thursday, May 09, 2013 9:55 AM
To: Johnson, Fletcher L; Ryberg, Sara C
Cc: Brown, Ann C; 'Schweisthal, Scott'
Subject: FW: Final Outage Notice

Non –preventable

Pine trees tops leaning and breaking due to heavy snow
Feeder last worked [March 2009](#). Next planned to work 4th quarter 2013

Brad Weidenfeller

Xcel Energy | Responsible By Nature

Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369

P: 763-493-1827 C: 320-250-2541 F: 763-493-1840

E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, May 02, 2013 6:05 AM
To: dl Electric Outage ME Notification

Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013

Date In : 5/2/2013

Time Out : 04:11

Time In : 05:48

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 1385

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : mn

Cause : trees on line

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5-2/13 - Cottage Grove & Hastings - POWER RESTORED

Power outage - Cottage Grove & Hastings - power restored.

Wendy

From: Elden, Thomas L
Sent: Thursday, May 02, 2013 6:05 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 04:11 Time In : 05:48

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 1385

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : mn

Cause : trees on line

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 1:45 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/14/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Tuesday, May 14, 2013 1:15 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/14/2013 Date In :
Time Out : 13:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1925

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 16, 2013 11:52 AM
To: 'staff, cao (PUC)'; Doughty, Kathryn L
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: image.jpg
FYI...Tree report!

Wendy

From: Johnson, Fletcher L
Sent: Thursday, May 16, 2013 11:43 AM
To: Elden, Thomas L; dl Electric Outage ME Notification
Subject: RE: Tree Report

Preventable. tree grew into lines from below. Tree work last completed Aug 2009; next forecasted tree work 2014.

Fletcher Johnson

Xcel Energy

Vegetation Management Supervisor II
3115 Centre Pointe Drive, Roseville, MN 55113
O: 651.639.4590 C: 612.418.9761 F: 612.573.1856
E: Fletcher.L.Johnson@xcelenergy.com

XCELENERGY.COM

From: Elden, Thomas L
Sent: Tuesday, May 14, 2013 2:13 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/14/2013 Date In : 5/14/2013
Time Out : 13:05 Time In : 13:49

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 1925

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : trees got neutral into primary will need neutral put back up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 2:37 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/14/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Tuesday, May 14, 2013 2:13 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/14/2013 Date In : 5/14/2013
Time Out : 13:05 Time In : 13:49

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 1925

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : trees got neutral into primary will need neutral put back up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 11:24 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Birchwood, Dellwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, St. Paul, Stillwater, White Bear Lake & Willernie
Power outage - Birchwood, Dellwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, St. Paul, Stillwater, White Bear Lake & Willernie.

Wendy

From: Gilland, William P
Sent: Friday, May 17, 2013 11:11 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 10:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 6697

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BIRCHWOOD, MN; DELLWOOD, MN; LAKE ELMO, MN;
MAHTOMEDI, MN; MAPLEWOOD, MN; OAKDALE, MN; PINE SPRINGS, MN; SAINT PAUL,
MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN; WILLERNIE, MN

State : MN - Minnesota

Major Customers :

Cause : contractor contact in sub/no injury/equip damaged and needs to be
cleared

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 12:38 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/18/13 - Birchwood, Dellwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, St. Paul, Stillwater, White Bear Lake & Willernie - POWER RESTORED
Power outage - Birchwood, Dellwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, St. Paul, Stillwater, White Bear Lake & Willernie - power restored.

Wendy

From: Gilland, William P
Sent: Friday, May 17, 2013 11:59 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 10:32 Time In : 11:56

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 6697

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BIRCHWOOD, MN; DELLWOOD, MN; LAKE ELMO, MN; MAHTOMEDI, MN; MAPLEWOOD, MN; OAKDALE, MN; PINE SPRINGS, MN; SAINT PAUL, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN; WILLERNIE, MN

State : MN - Minnesota

Major Customers :

Cause : contact energized bus/no injuries

Follow-Up : cleared damaged equipment/energized bus & feeders

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 3:37 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Friday, May 17, 2013 3:32 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 15:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1548

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/17/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - POWER RESTORED
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Friday, May 17, 2013 5:59 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 15:28 Time In : 16:52

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1548

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : 1547 customers are back on is the only
customer that is out

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:14 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/17/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - POWER RESTORED/UPDATE
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - power restored/update.

Wendy

From: Elden, Thomas L
Sent: Saturday, May 18, 2013 12:14 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/18/2013
Time Out : 15:28 Time In : 00:10

Time Zone : CST

Duration : 8 hours, 42 mins

Number of Customers Affected : 1548

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : everyone is back on at 00:10 5/18/10

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 10:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/18/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - POWER RESTORED/UPDATE
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - power restored/update.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 10:22 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 15:20 Time In : 16:30

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1548

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN;
SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : XARM FROM TOP DECK BURNED OFF CAUSING FEEDER TO FALL
ON LOWER DECK.CUT JUMPERS AT TAP THAT FELL AT LOWER DECK .CLOSED FEEDER
16:30 PICKING UP EVERYONE BUT . CLOSED IN JUMPERS TO
AT 23:59

Follow-Up : CREW REPLACED ARMS AND CLOSED JUMPERS ,TOTAL
RESTORE 00:10 ON 5 18 2013

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:16 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/17/13 - Roseville, Saint Anthony & Saint Paul -
POWER RESTORED

Power outage - Roseville, Saint Anthony & Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 6:08 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 17:23 Time In : 17:29

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 435

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

MN

Communities Affected : ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL,

State : MN - Minnesota

Major Customers :

Cause : opens to clear top deckfeeder off of lower deck feeder

Follow-Up : no

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 8:59 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/18/13 - Eagan & Inver Grove Heights
Power outage - Eagan & Inver Grove Heights.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 8:27 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In :
Time Out : 08:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 927

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown at this time/lightning

Follow-Up : bus 1 out at substation

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 9:12 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/18/13 - Eagan & Inver Grove Heights -
POWER RESDTORED
Power outage - Eagan & Inver Grove Heights - power restored.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 9:05 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 08:16 Time In : 08:53

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 927

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : lightning strike close to sub.

Follow-Up : TR 1 BUS 1 LOCKOUT.POSSABLE RELAY ISSUES.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/18/13 - Newport, Saint Paul Park & Woodbury
Power outage - Newport, Saint Paul Park & Woodbury.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 11:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In :
Time Out : 11:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1773

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY,
MN

State : MN - Minnesota

Major Customers :

Cause : ???

Follow-Up : //

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0037.JPG; IMG_0035.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, May 22, 2013 8:00 AM
To: Chial, Terry L; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-preventable
Aspen tree uprooted and fell into phases.
Tree was outside the normal maintenance zone (20ft from conductors).
Tree appeared healthy.
Feeder last worked 10/2010.

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Chial, Terry L
Sent: Saturday, May 18, 2013 11:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/18/2013

Date In :

Time Out : 11:27

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1773

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

MN

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY,

State : MN - Minnesota

Major Customers :

Cause : ???

Follow-Up : //

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/18/13 - Newport, Saint Paul Park & Woodbury -
POWER RESTORED

Power outage - Newport, Saint Paul Park & Woodbury - power restored.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 12:01 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 11:27 Time In : 11:43

Time Zone : CST

Duration : 0 hours, 16 mins

Number of Customers Affected : 1773

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY,
MN

State : MN - Minnesota

Major Customers :

Cause : on line .picked up 1221 customers switching out
section of feeder.

Follow-Up : will remove tree and pick up remaining 552 customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/18/13 - Newport, Saint Paul Park & Woodbury -
POWER RESTORED/UPDATE

Power outage - Newport, Saint Paul Park & Woodbury - power restored/update.

Wendy

From: Chial, Terry L
Sent: Saturday, May 18, 2013 12:23 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 11:27 Time In : 11:56

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 1773

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY,
MN

State : MN - Minnesota

Major Customers :

Cause : tree om feeder at

Follow-Up : removed tree and restored remaining customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/19/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Sunday, May 19, 2013 3:26 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In :
Time Out : 15:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 637

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0034.JPG; IMG_0032.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, May 22, 2013 7:53 AM
To: Abbott, Edward J; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-preventable
Large Cottonwood limb broke from a city tree during a storm due to internal decay.
No outward sign of decay on limb present.
Limb appeared healthy.
Feeder last worked 7/2009

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Abbott, Edward J
Sent: Sunday, May 19, 2013 4:11 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 5/19/2013
Time Out : 15:19

Date In :
Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 637

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT . FIELD SWITCHED TO
PICK UP 1/2 OF FEEDER. REMAINDER WILL BE OUT UNTIL TREE CREW CLEARS TREE.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/19/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Sunday, May 19, 2013 3:52 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In :
Time Out : 15:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 637

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : LARGE TREE ON FEEDER AT . WILL FEED
SWITCH BUT PART OF FEEDER WILL BE OUT UNTIL TREE CREW CAN CLEAR TREE

Follow-Up : CALLED FOR TREE CREW

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 5/19/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Sunday, May 19, 2013 4:11 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In :
Time Out : 15:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 637

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT . FIELD SWITCHED TO
PICK UP 1/2 OF FEEDER. REMAINDER WILL BE OUT UNTIL TREE CREW CLEARS TREE.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/19/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Sunday, May 19, 2013 8:06 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In : 5/19/2013
Time Out : 15:19 Time In : 19:59

Time Zone : CST

Duration : 4 hours, 40 mins

Number of Customers Affected : 637

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE CREW CLEARED TREE OFF FEEDER AND TROUBLE
SWITCHED IN FIELD AND FEEDER IS 100% IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 12:32 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/22/13 - Lake Elmo, Mendota Heights, Oakdale & Woodbury - POWER RESTORED
Power outage - Lake Elmo, Mendota Heights, Oakdale & Woodbury - power restored.

Wendy

From: Elden, Thomas L
Sent: Wednesday, May 22, 2013 12:05 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/22/2013 Date In : 5/22/2013
Time Out : 11:33 Time In : 11:45

Time Zone : CST

Duration : 0 hours, 12 mins

Number of Customers Affected : 11802

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MENDOTA, MN; OAKDALE, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Switch failed at sub during swiching.

Follow-Up : restored at 11:41 - 2760 cutomers restored
restored at 11:45 - remaining 8042 customers restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/26/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 8:13 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In :
Time Out : 07:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 10824

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT
PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : LOAD SHED OPERATED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 24, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/23/13 - Shoreview
Power outage - Shoreview.

Wendy

From: Chial, Terry L
Sent: Thursday, May 23, 2013 5:30 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/23/2013 Date In :
Time Out : 17:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 397

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : unknown at this time

Follow-Up : will respond

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 24, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/23/13 - Shoreview - POWER RESTORED
Power outage - Shoreview - power restored.

Wendy

From: Chial, Terry L
Sent: Thursday, May 23, 2013 6:33 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/23/2013 Date In : 5/23/2013
Time Out : 17:25 Time In : 18:29

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 397

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : head cable sub to 1 switch total restored at 1829

Follow-Up : switched out and refered to biddle.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED

Power outage - Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 8:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 07:38 Time In : 08:30

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 3257

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNDER FREQ. LOADSHED RELAY TRIP

Follow-Up : RELAY CREW TO BE CALLED IN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED

Power outage - Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 8:56 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 07:38 Time In : 08:30

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 927

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNDER FREQ. LOADSHED RELAY TRIP

Follow-Up : RELAY CREW TO BE CALLED IN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 8:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 07:38 Time In : 08:43

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 2636

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNDER FREQ. LOADSHED RELAY TRIP

Follow-Up : RELAY CREW TO BE CALLED IN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - power restored.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 9:00 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 07:38 Time In : 08:33

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : UNDER FREQ. LOADSHED RELAY TRIP

Follow-Up : RELAY CREW TO BE CALLED IN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Wolf, Terry K
Sent: Sunday, May 26, 2013 9:02 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 07:38 Time In : 08:34

Time Zone : CST

Duration : 0 hours, 56 mins

Number of Customers Affected : 2197

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNDER FREQ. LOADSHED RELAY TRIP

Follow-Up : RELAY CREW TO BE CALLED IN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 9:56 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/28/13 - Dellwood, Grant, Hugo, Saint Paul & White Bear Lake
Power outage - Dellwood, Grant, Hugo, Saint Paul & White Bear Lake.

Wendy

From: Abbott, Edward J
Sent: Tuesday, May 28, 2013 9:55 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/28/2013 Date In :
Time Out : 09:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2723

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : DELLWOOD, MN; GRANT, MN; HUGO, MN; SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOW AT THIS TIME, TROUBLE IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 10:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/28/13 - Dellwood, Grant, Hugo, Saint Paul & White Bear - UPDATE
Power outage - Dellwood, Grant, Hugo, Saint Paul & White Bear - update.

Wendy

From: Abbott, Edward J
Sent: Tuesday, May 28, 2013 10:34 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/28/2013 Date In :
Time Out : 09:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2723

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : DELLWOOD, MN; GRANT, MN; HUGO, MN; SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : CITY HIT FEEDER CABLE, PERSON FLASHED, INFORMED SUPERVISOR, IN PROCESS OF FIELD SWITCHING

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 11:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/28/13 - Dellwood, Grant, Hugo, Saint Paul & White Bear - POWER RESTORED
Power outage - Dellwood, Grant, Hugo, Saint Paul & White Bear - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, May 28, 2013 10:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/28/2013 Date In : 5/28/2013
Time Out : 09:47 Time In : 10:54

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 2723

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : DELLWOOD, MN; GRANT, MN; HUGO, MN; SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : CITY WORKER HIT FEEDER CABLE, FIELD SWITCHED TO GET EVERYONE BACK ON

Follow-Up : REFERRED TO . TO REPAIR FEEDER CABLE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 10:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/3/13 - Plymouth
Power outage - Plymouth.

Wendy

From: Ayers, Patrick S
Sent: Friday, May 03, 2013 10:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/3/2013 Date In :
Time Out : 10:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1635

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : NEEDED TO OPEN FEEDER POLE. EMERGENCY INTENTIONAL OUTAGE. . FOR CREW, BROKEN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 10:59 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/3/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, May 03, 2013 10:45 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/3/2013 Date In : 5/3/2013
Time Out : 10:14 Time In : 10:39

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 1635

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUST RESTORED AS OF1039

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Momentary Outage - 5/28/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Schwarz, John W
Sent: Tuesday, May 28, 2013 11:04 PM
To: dl Electric Outage MW Notification
Subject: Momentary Outage
Distribution System Status Outage Notification

Momentary Outage

Feeder/Bus :

Date Out : 5/28/2013 Date In :
Time Out : 22:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1446

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/28/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Schwarz, John W
Sent: Tuesday, May 28, 2013 11:56 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/28/2013 Date In :
Time Out : 22:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1446

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BALLOONS IN FEEDER BURNT DOWN ALL THREE PHASES @
FEEDER IS ON ALLEY ARMS, 811 CUSTOMERS RESTORED BY AUTO RECLOSING @
22:53. REMAINING 635 CUSTOMERS CANNOT BE RESTORED UNTILL THE FEEDER IS REPAIRED. CREW
IS BEING CALLED IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/28/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Cedar, Daren A
Sent: Wednesday, May 29, 2013 6:54 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/28/2013 Date In : 5/29/2013
Time Out : 22:53 Time In : 05:31

Time Zone : CST

Duration : 6 hours, 38 mins

Number of Customers Affected : 1446

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BALLOONS IN FEEDER BURNT DOWN ALL THREE PHASES @
FEEDER IS ON ALLEY ARMS, 811 CUSTOMERS RESTORED BY AUTO RECLOSING @ 22:53.
REMAINING 635 CUSTOMERS CANNOT BE RESTORED UNTILL THE FEEDER IS REPAIRED. CREW IS BEING
CALLED IN

Follow-Up : Crew repaired perm.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 11:46 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/31/13 - Saint Louis Park
Power outage - Saint Louis Park.

Wendy

From: Knutson, David A
Sent: Friday, May 31, 2013 10:55 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In :
Time Out : 10:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1558

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : trouble on the way

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 3:41 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/31/13 - Saint Louis Park - POWER
RESTORED/UPDATE

Power outage - Saint Louis Park - power restored/update.

Wendy

From: Knutson, David A
Sent: Friday, May 31, 2013 3:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In : 5/31/2013
Time Out : 10:52 Time In : 14:59

Time Zone : CST

Duration : 4 hours, 7 mins

Number of Customers Affected : 1558

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN ON FEEDER

Follow-Up : ALL BACK ON

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 12:04 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/31/13 - Saint Louis Park - POWER
RESTORED

Power outage - Saint Louis Park - power restored.

Wendy

From: Knutson, David A
Sent: Friday, May 31, 2013 11:53 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In : 5/31/2013
Time Out : 10:52 Time In : 11:31

Time Zone : CST

Duration : 0 hours, 39 mins

Number of Customers Affected : 1558

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : recloser [trip saver] did not operate. Wire down on load side of recloser

Follow-Up : 166 still out on load side of recloser till repairs can be made. New job created for
recloser

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 06, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/4/13 - Albany, Avon & Saint Joseph
Power outage - Albany, Avon & Saint Joseph.

Wendy

From: Peterson, Mark S
Sent: Saturday, May 04, 2013 4:29 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/4/2013 Date In :
Time Out : 01:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1437

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : Crew in route

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 06, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/4/13 - Albany, Avon & Saint Joseph - UPDATE
Power outage - Albany, Avon & Saint Joseph - update.

Wendy

From: Goulet, Terry W
Sent: Saturday, May 04, 2013 6:19 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/4/2013 Date In :
Time Out : 01:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1437

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : 2 phases down, Wire burnt down at hot line clamps on cap bank.
Jumpers cut open and 1313 customers have been restored. is still out and will be out until wire is
put back up. 124 customers are still out

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 06, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/4/13 - Albany, Avon & Saint Joseph - POWER RESTORED

Power outage - Albany, Avon & Saint Joseph - power restored.

Wendy

From: Goulet, Terry W
Sent: Saturday, May 04, 2013 9:31 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/4/2013 Date In : 5/4/2013
Time Out : 01:25 Time In : 08:30

Time Zone : CST

Duration : 7 hours, 5 mins

Number of Customers Affected : 1437

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : Final 124 customer restored @ 0830

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/13/13 - Saint Cloud
Power outage - Saint Cloud.

Wendy

From: Kaveny, Michael J
Sent: Monday, May 13, 2013 9:10 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/13/2013 Date In :
Time Out : 21:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2752

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, Trouble en-route.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/13/13 - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Kaveny, Michael J
Sent: Monday, May 13, 2013 9:45 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/13/2013 Date In : 5/13/2013
Time Out : 21:05 Time In : 21:38

Time Zone : CST

Duration : 0 hours, 33 mins

Number of Customers Affected : 2752

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Semi hit Down-Guy on . Trouble cleared and closed
breaker. 100% restored.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 2:42 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/14/13 - Saint Cloud
Power outage - Saint Cloud.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, May 14, 2013 2:17 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/14/2013 Date In :
Time Out : 14:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2752

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown. Trouble en-route.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 2:42 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/14/13 - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, May 14, 2013 2:35 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/14/2013 Date In : 5/14/2013
Time Out : 14:12 Time In : 14:26

Time Zone : CST

Duration : 0 hours, 14 mins

Number of Customers Affected : 2752

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Semi struck another down guy in same spot as previous outage last night, road construction in area.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 3:17 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Saint Cloud
Power outage - Saint Cloud.

Wendy

From: Kaveny, Michael J
Sent: Friday, May 17, 2013 2:34 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 14:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3828

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, Both Breakers are locked out. Trouble en-route. TR2 Isolated and BUS
Tie closed.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 3:18 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/17/13 - Saint Cloud - Update
Power outage - Saint Cloud - update.

Wendy

From: Lund, Lisa M
Sent: Friday, May 17, 2013 2:53 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 14:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3828

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Double deck pole fire at intersection of . In the process of
isolating damage and restoring customers.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 4:24 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Outage Notice - 5/17/13 - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Kaveny, Michael J
Sent: Friday, May 17, 2013 4:11 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 14:23 Time In : 16:03

Time Zone : CST

Duration : 1 hours, 40 mins

Number of Customers Affected : 3828

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Pole fire West of Substation, Double Circuit, Crews lifted top Circuit and holding with truck until Pole changed.

Follow-Up : St Cloud Hospital restored by Troubleman at 15:04, Automated switches did not operate. Breakdown Sw opened, however Tie did not close by RC.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 17, 2013 4:36 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Albany,
Avon, Freeport, Glyndon, Holdingford, Melrose & New Munich
Power outage - Albany, Avon, Freeport, Glyndon, Holdingford, Melrose & New Munich.

Wendy

From: Kaveny, Michael J
Sent: Friday, May 17, 2013 4:31 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 16:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2857

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; FREEPORT, MN; GLYNDON, MN;
HOLDINGFORD, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, Transmission Level Event.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/17/13 - Albany,
Avon, Freeport, Glyndon, Holdingford, Melrose & New Munich - POWER RESTORED
Power outage - Albany, Avon, Freeport, Glyndon, Holdingford, Melrose & New Munich - power restored.

Wendy

From: Kaveny, Michael J
Sent: Friday, May 17, 2013 4:43 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 16:13 Time In : 16:35

Time Zone : CST

Duration : 0 hours, 22 mins

Number of Customers Affected : 2857

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; FREEPORT, MN; GLYNDON, MN;
HOLDINGFORD, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission Level Event, was energized at 16:17, and was energized at
16:35. 100% restored.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:07 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Freeport, Melrose & New Munich
Power outage - Freeport, Melrose & New Munich.

Wendy

From: Kaveny, Michael J
Sent: Friday, May 17, 2013 6:16 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 16:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 286

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FREEPORT, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers : None

Cause : Pole fire. Non EMS Sub. Trouble on scene.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:08 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/17/13 - Freeport, Melrose & New Munich -
UPDATE

Power outage - Freeport, Melrose & New Munich - update.

Wendy

From: Vorachek, Kelly
Sent: Friday, May 17, 2013 9:00 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 16:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 286

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FREEPORT, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Transmission Pole fire - crew will need to replace pole. Transmission is isolated and crew is working to restore feeder at this time.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/17/13 - Freeport, Melrose & New Munich -
POWER RESTORED

Power outage - Freeport, Melrose & New Munich - power restored.

Wendy

From: Vorachek, Kelly
Sent: Friday, May 17, 2013 11:34 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 18:30 Time In : 23:20

Time Zone : CST

Duration : 4 hours, 50 mins

Number of Customers Affected : 286

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FREEPORT, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Crew was able to temporary repairs to feeder and get it energized at
23:20. T-Storm in area now may replace pole at later time.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 23, 2013 3:57 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/23/13 - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill
Power outage - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 23, 2013 3:54 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/23/2013 Date In :
Time Out : 15:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2404

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELGRADE, MN; EDEN VALLEY, MN; GROVE CITY, MN;
MELROSE, MN; PAYNESVILLE, MN; REGAL, MN; RICHMOND, MN; ROSCOE, MN; SAINT
MARTIN, MN; SPRING HILL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAUSE UNKNOWN CREW BEING CALLED OUT TO
INVESTIGATE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 24, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/23/13 - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill - POWER RESTORED
Power outage - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 23, 2013 4:16 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/23/2013 Date In : 5/23/2013
Time Out : 15:48 Time In : 16:05

Time Zone : CST

Duration : 0 hours, 17 mins

Number of Customers Affected : 2404

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELGRADE, MN; EDEN VALLEY, MN; GROVE CITY, MN;
MELROSE, MN; PAYNESVILLE, MN; REGAL, MN; RICHMOND, MN; ROSCOE, MN; SAINT
MARTIN, MN; SPRING HILL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAUSE STILL UNDER INVESTIGATION FIELD RECLOSURE
FAILED TO OPERATE CREW MANUALLY OPENED RECLOSURE AND WE CLOSED
BREAKER VIA SCADA 1721 CUSTOMERS RESTORED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 24, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 5/23/13 - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill - POWER RESTORED/UPDATE
Power outage - Belgrade, Eden Valley, Grove City, Melrose, Paynesville, Regal, Richmond, Roscoe, Saint Martin & Spring Hill - power restored - update.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 23, 2013 5:41 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 5/23/2013 Date In : 5/23/2013
Time Out : 15:48 Time In : 17:14

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 2404

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELGRADE, MN; EDEN VALLEY, MN; GROVE CITY, MN;
MELROSE, MN; PAYNESVILLE, MN; REGAL, MN; RICHMOND, MN; ROSCOE, MN; SAINT
MARTIN, MN; SPRING HILL, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK CAUGHT NUETRAL WRAPPING IT AROUND PRIMARY
BURNING IT DOWN CREW MADE PER REPAIRS LAST 683 CUSTOMERS RESTORED @ 17:14

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 16, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/15/13 - Balaton & Garvin
Power outage - Balaton & Garvin.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, May 15, 2013 6:05 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/15/2013 Date In :
Time Out : 17:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 510

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BALATON, MN; GARVIN, MN

State : SD - South Dakota

Major Customers : None

Cause : XCEL Contract crew had jumper break while transferring conductor. Feeder locked out. Trouble en-route, no injuries.

Follow-Up : This feeder is carrying customers that were on this feeder has been
converted to , but viewer still has active.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 16, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/15/13 - Balaton & Garvin - POWER RESTORED

Power outage - Balaton & Garvin - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, May 15, 2013 7:47 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/15/2013 Date In : 5/15/2013
Time Out : 17:44 Time In : 19:22

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 510

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BALATON, MN; GARVIN, MN

State : SD - South Dakota

Major Customers : None

Cause : Jumper fell and locked Breaker out at Sub, Trouble cleared jumper, but was unable to get breaker closed, troubleshooting determined Breaker at Sub is bad. Isolated on .

Follow-Up : Customer are carried by .

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 30, 2013 2:45 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/30/13 - Balaton & Garvin
Power outage - Balaton & Garvin.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 30, 2013 2:02 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/30/2013 Date In :
Time Out : 13:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 543

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BALATON, MN; GARVIN, MN

State : SD - South Dakota

Major Customers : None

Cause : Unknown, Transmission Level Event.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 30, 2013 2:51 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/30/13 - Balaton & Garvin - POWER RESTORED

Power outage - Balaton & Garvin - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 30, 2013 2:49 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/30/2013 Date In : 5/30/2013
Time Out : 13:48 Time In : 14:40

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 543

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BALATON, MN; GARVIN, MN

State : SD - South Dakota

Major Customers : None

Cause : Transmission Level Event. Customers 100% Restored.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 02, 2013 4:30 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 04:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1999

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HEAVY SNOW IN AREA CREW ENROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 2:32 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Sorry for the delay....

Power outage - Red Wing - power restored.

Wendy

From: Goulet, Terry W
Sent: Friday, May 03, 2013 2:19 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 04:23 Time In : 07:42

Time Zone : CST

Duration : 3 hours, 19 mins

Number of Customers Affected : 1999

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : Outage due to wet heavy snow and tree down on feeder. Partial restoration of 939 customers @ 0546 and final customers restored @ 0742

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 1:47 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: outage investgation - Tree Report
Attachments: photo.jpg
FYI..tree report.

Wendy

From: Puhmann, Rodney D
Sent: Tuesday, May 14, 2013 1:37 PM
To: Goulet, Terry W; dl Electric Outage SE Notification
Subject: RE: outage investgation

Non preventable line last trimmed 11/6/2010. Large hackberry 36 feet south of line fell into feeder. Tree has been removed all that remains is the stump.

Rod Puhmann

Xcel Energy

Supervisor, Vegetation Management

210 Lime Street, PO Box 1090, Mankato, MN 56001

P: 507.387.9621 C: 507.676.2228 F: 507.387.9604

E: rodney.d.puhmann@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this e-mail.

From: Goulet, Terry W
Sent: Friday, May 03, 2013 2:19 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013

Date In : 5/2/2013

Time Out : 04:23

Time In : 07:42

Time Zone : CST

Duration : 3 hours, 19 mins

Number of Customers Affected : 1999

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : Outage due to wet heavy snow and tree down on feeder. Partial restoration of 939 customers @ 0546 and final customers restored @ 0742

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Frontenac, Lake City &
Red Wing
Power outage - Frontenac, Lake City & Red Wing.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 02, 2013 5:24 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 05:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 718

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FRONTENAC, MN; LAKE CITY, MN; RED WING, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Frontenac, Lake City
& Red Wing - POWER RESTORED
Power outage - Frontenac, Lake City & Red Wing - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 8:05 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

TRANSMISSION-SE Second Outage Notice
Feeder/Bus : FRO-FRONTENAC

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 05:20 Time In : 07:53

Time Zone : CST

Duration : 2 hours, 33 mins

Number of Customers Affected : 718

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FRONTENAC, MN; LAKE CITY, MN; RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event, restored at 0753

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 12:17 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Goodhue, Lake City & Mount Pleasant
Power outage - Goodhue, Lake City & Mount Pleasant.

Wendy

From: Vorachek, Kelly
Sent: Thursday, May 02, 2013 12:07 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 06:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 189

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - NON RTU SUB, Crew had recloser outage job and cleared tree off
feeder and found Breaker Open at SUB - tried to close at 11:50 locked back open - patrolling feeder now. Wet
heavy snow

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 1:45 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Tree Report
Attachments: photo.JPG
FYI...Tree report.

Wendy

From: Puhmann, Rodney D
Sent: Tuesday, May 14, 2013 1:13 PM
To: Vorachek, Kelly; dl Electric Outage SE Notification
Subject: RE: Second Outage Notice

Non preventable outage on circuit last trimmed 10/20/12. Uprooted cottonwood tree 65' west of line fell thru feeder.

Rod Puhmann
Xcel Energy
Supervisor, Vegetation Management
210 Lime Street, PO Box 1090, Mankato, MN 56001
P: 507.387.9621 C: 507.676.2228 F: 507.387.9604
E: rodney.d.puhmann@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this e-mail.

From: Vorachek, Kelly
Sent: Thursday, May 02, 2013 3:19 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 06:35 Time In : 14:58

Time Zone : CST

Duration : 8 hours, 23 mins

Number of Customers Affected : 189

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Tree into feeder by from wet snow - Unable to pick up cold load with breaker, had to open several reclosers to get breaker to close and stay in.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 4:01 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Goodhue, Lake City & Mount Pleasant -
POWER RESTORED

Power outage - Goodhue, Lake City & Mount Pleasant - power restored.

Wendy

From: Vorachek, Kelly
Sent: Thursday, May 02, 2013 3:19 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 06:35 Time In : 14:58

Time Zone : CST

Duration : 8 hours, 23 mins

Number of Customers Affected : 189

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Tree into feeder by from wet snow - Unable to pick up cold
load with breaker, had to open several reclosers to get breaker to close and stay in.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 9:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Wanamingo & Zumbrota
Power outage - Wanamingo & Zumbrota.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 9:03 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 08:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2006

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : WANAMINGO, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional for Crew to clear trees burning on Feeder outside Sub, Tom M is on site.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 11:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Tree Report
Attachments: photo.jpg
FYI...tree report.

Wendy

From: Puhmann, Rodney D
Sent: Tuesday, May 14, 2013 11:26 AM
To: Kaveny, Michael J; dl Electric Outage SE Notification
Subject: RE: Second Outage Notice

Non preventable line last worked 12/5/2009. Outage caused by evergreen tree 18 feet east of line being waited down and leaning into line. In photo it is the second or rear tree by the yield sign. Top of tree has burnt branches that do not show up in photo

Rod Puhmann
Xcel Energy
Supervisor, Vegetation Management
210 Lime Street, PO Box 1090, Mankato, MN 56001
P: 507.387.9621 C: 507.676.2228 F: 507.387.9604
E: rodney.d.puhmann@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this e-mail.

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 9:16 AM
To: dl Electric Outage SE Notification
Subject: ZUM-ZUMBROTA (022) Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 08:58 Time In : 09:10

Time Zone : CST

Duration : 0 hours, 12 mins

Number of Customers Affected : 2006

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : WANAMINGO, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear tree off, restored at 0910.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 9:18 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Wanamingo & Zumbrota - POWER RESTORED

Power outage - Wanamingo & Zumbrota - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 9:16 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 08:58 Time In : 09:10

Time Zone : CST

Duration : 0 hours, 12 mins

Number of Customers Affected : 2006

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : WANAMINGO, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear tree off, restored at 0910.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 9:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Goulet, Terry W
Sent: Thursday, May 02, 2013 9:34 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 09:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 402

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : Breaker open / Snow storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, May 02, 2013 5:12 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 09:09 Time In : 16:53

Time Zone : CST

Duration : 7 hours, 44 mins

Number of Customers Affected : 402

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : 100% COMPLETE 96 CUSTOMERS RESTORED 13:49
REMAINING 306 @ 16:53

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 12:08 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Goulet, Terry W
Sent: Thursday, May 02, 2013 9:35 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :

Time Out : 09:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2101

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : Feeder lock / Snow Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 14, 2013 1:46 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: outage investigation - Tree Report
Attachments: photo.JPG
FYI...tree report.

Wendy

From: Puhmann, Rodney D
Sent: Tuesday, May 14, 2013 1:29 PM
To: Goulet, Terry W; dl Electric Outage SE Notification
Subject: RE: outage investigation

Non-preventable outage on line last trimmed 3/29/13. Picture is from top of hill behind and you can see Box Elder tree laying across the grass under the 3 phase line.. Previous side trim was done by helicopter and side clearances are still good. The 10 to 12 inch tree was out of trim zone and had a broken trunk.

Rod Puhmann
Xcel Energy
Supervisor, Vegetation Management
210 Lime Street, PO Box 1090, Mankato, MN 56001
P: 507.387.9621 C: 507.676.2228 F: 507.387.9604
E: rodney.d.puhmann@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this e-mail.

From: Goulet, Terry W
Sent: Thursday, May 02, 2013 11:34 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 09:28 Time In : 10:52

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 2101

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : TREES AND WIRE DOWN AND CLEARED UP AND BREAKER

CLOSED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 12:04 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Goulet, Terry W
Sent: Thursday, May 02, 2013 11:34 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 09:28 Time In : 10:52

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : TREES AND WIRE DOWN AND CLEARED UP AND BREAKER

CLOSED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 12:15 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 11:28 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 11:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 678

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Snow storm in area.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 1:07 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 1:04 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 11:19 Time In : 12:59

Time Zone : CST

Duration : 1 hours, 40 mins

Number of Customers Affected : 678

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Patrol found nothing. Suspect problem with

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Peterson, Mark S
Sent: Thursday, May 02, 2013 10:53 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 22:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/2/13 - Red Wing - UPDATE
Power outage - Red Wing - update.

Wendy

From: Peterson, Mark S
Sent: Friday, May 03, 2013 12:50 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 22:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : none

Cause : found tree on line 2 spans east of . Opened switch and
restored power to 2023 customers @ 0041. 78 customers still out until tree is removed.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 16, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/15/13 - Northfield
Power outage - Northfield.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, May 15, 2013 4:21 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/15/2013 Date In :
Time Out : 16:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1113

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : De-Energized Feeder for Crews to safely clear up 2 broken poles on feeder. Poles were broken earlier this afternoon after vehicle towing large boat hooked Cable TV, breaking poles and tearing down wire.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 16, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/15/13 - Northfield - POWER RESTORED
Power outage - Northfield - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, May 15, 2013 5:10 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/15/2013 Date In : 5/15/2013
Time Out : 16:14 Time In : 17:03

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 1113

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional for Crews to clear Broken Poles, no breakdown switches or ties. Crews will be working until poles replaced on both sides of and Feeder secured.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/26/13 - Fountain City,
Goodview, Minnesota City & Winona
Power outage - Fountain City, Goodview, Minnesota City & Winona.

Wendy

From: Peterson, Mark S
Sent: Sunday, May 26, 2013 12:54 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In :
Time Out : 00:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5946

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOUNTAIN CITY, WI; GOODVIEW, MN; MINNESOTA
CITY, MN; WINONA, MN

State : MN - Minnesota

Major Customers :

Cause : Lockout. Sub out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/26/13 - Fountain City,
Goodview, Minnesota City & Winona - UPDATE
Power outage - Fountain City, Goodview, Minnesota City & Winona - update.

Wendy

From: Peterson, Mark S
Sent: Sunday, May 26, 2013 2:04 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In :
Time Out : 00:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5946

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOUNTAIN CITY, WI; GOODVIEW, MN; MINNESOTA
CITY, MN; WINONA, MN

State : MN - Minnesota

Major Customers :

Cause : Possum found on the 12.5kv Bus. Troubleman is
looking over equipment for damage.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/26/13 - Fountain City,
Goodview, Minnesota City & Winona - POWER RESTORED
Power outage - Fountain City, Goodview, Minnesota City & Winona - power restored.

Wendy

From: Peterson, Mark S
Sent: Sunday, May 26, 2013 3:41 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/26/2013 Date In : 5/26/2013
Time Out : 00:40 Time In : 03:31

Time Zone : CST

Duration : 2 hours, 51 mins

Number of Customers Affected : 5946

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOUNTAIN CITY, WI; GOODVIEW, MN; MINNESOTA CITY,
MN; WINONA, MN

State : MN - Minnesota

Major Customers :

CARRIED BY Cause : POSSUM GOT ONTO CT'S ON . ALL LOAD IS BEING
UNTIL CAN BE LOOKED AT AND CT'S CLEANED UP.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/29/13 - Dakota, Dresbach,
Hokah, LaCrescent & LaCrosse
Power outage - Dakota, Dresbach, Hokah, LaCrescent & LaCrosse.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, May 29, 2013 12:28 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/29/2013 Date In :
Time Out : 00:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3423

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DAKOTA, MN; DRESBACH, MN; HOKAH, MN; LA CRESCENT, MN; LA
CROSSE, WI

State : MN - Minnesota

Major Customers : None

Cause : Undetermined at this time.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/29/13 - Dakota, Dresbach,
Hokah, LaCrescent & LaCrosse - UPDATE
Power outage - Dakota, Dresbach, Hokah, LaCrescent & LaCrosse - update.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, May 29, 2013 1:29 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/29/2013 Date In :
Time Out : 00:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3423

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DAKOTA, MN; DRESBACH, MN; HOKAH, MN; LA CRESCENT, MN; LA
CROSSE, WI

State : MN - Minnesota

Major Customers : None

Cause : Cap and pin insulator damaged on top of sta aux. Bull snake had crawled up on cap
and pin and caused a flash, tripping out the transmission line. Power should be restored by 0230.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 29, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 5/29/13 - Dakota, Dresbach, Hokah, LaCrescent & LaCrosse - POWER RESTORED
Power outage - Dakota, Dresbach, Hokah, LaCrescent & LaCrosse - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Wednesday, May 29, 2013 2:51 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 5/29/2013 Date In : 5/29/2013
Time Out : 00:14 Time In : 02:26

Time Zone : CST

Duration : 2 hours, 12 mins

Number of Customers Affected : 3423

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : DAKOTA, MN; DRESBACH, MN; HOKAH, MN; LA CRESCENT, MN; LA CROSSE, WI

State : MN - Minnesota

Major Customers : None

Cause : Animal contact in substation.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 9:00 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/18/13 - Edina & Lino Lakes
Power outage - Edina & Lino Lakes.

Wendy

From: Schwarz, John W
Sent: Saturday, May 18, 2013 8:57 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In :
Time Out : 08:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; LINO LAKES, MN

State : MN - Minnesota

Major Customers : NONE

GROUND @ Cause : BREAKER OPENED BY RC TO CLEAR C PHASE FEEDER ON THE
1391 CUSTOMERS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 9:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: 769 - 5/18/13 - Edina & Lino Lakes - POWER RESTORED
Power outage - Edina & Lino Lakes - power restored.

Wendy

From: Schwarz, John W
Sent: Saturday, May 18, 2013 9:10 AM
To: dl Electric Outage MW Notification
Subject:

Distribution System Status Outage Notification

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 07:59 Time In : 08:57

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1391

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; LINO LAKES, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 769 CUSTOMERS RESTORED @ 08:57 BY SWITCHING, CREWS ON SITE TO
REPLASE THE C PHASE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 9:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/18/13 - Edina & Lino Lakes - POWER RESTORED/UPDATE

Power outage - Edina & Lino Lakes - power restored/update.

Wendy

From: Schwarz, John W
Sent: Saturday, May 18, 2013 9:34 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 07:59 Time In : 09:31

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 1391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; LINO LAKES, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE WAS DOWN @
AND ALL CUSTOMERS RESTORED @ 09:51

. PHASE IS RESTORED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/19/13 - Minneapolis
OK lets try this again!

Power outage - Minneapolis.

Wendy

From: Babb, Randall J
Sent: Sunday, May 19, 2013 7:18 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In :
Time Out : 06:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 498

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Trouble in route

Follow-Up : feeding

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/19/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Sunday, May 19, 2013 9:12 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In : 5/19/2013
Time Out : 06:41 Time In : 09:06

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 498

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Lightning strike damaged pole equipment. Wire burned open at a different location.

Follow-Up : Troublemakers made permanent repair of pole equipment and crew repaired wire.
Source of .

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/22/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Wednesday, May 22, 2013 5:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/22/2013 Date In :
Time Out : 04:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 498

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Feed is Cause unknown.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/22/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Wednesday, May 22, 2013 6:26 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/22/2013 Date In : 5/22/2013
Time Out : 04:31 Time In : 06:13

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 498

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Faulted head end cable on source of .

Follow-Up : Biddle and repair cable.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 4:12 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/20/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Kittock, Joseph C
Sent: Monday, May 20, 2013 4:09 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/20/2013 Date In : 5/20/2013
Time Out : 13:02 Time In : 14:13

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 840

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Not a lock/ burnt open jumper between the #1 - #21 sw.'s

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 4:19 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/20/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, May 20, 2013 4:13 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/20/2013 Date In : 5/20/2013
Time Out : 13:02 Time In : 14:13

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 840

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Not a lock/ burnt open jumper between the #1 - #21 sw.'s

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 13, 2013 3:30 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/13/13 - Plymouth
Power outage - Plymouth.

Wendy

From: Knutson, David A
Sent: Monday, May 13, 2013 3:16 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/13/2013 Date In :
Time Out : 15:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 451

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up : TROUBLE MEN ON THE WAY

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 13, 2013 3:49 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/13/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, May 13, 2013 3:48 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/13/2013 Date In : 5/13/2013
Time Out : 15:11 Time In : 15:47

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 545

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers :

Cause : Bad Headend cable

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 13, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/10/13 - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown
Power outage - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown.

Wendy

From: Knutson, David A
Sent: Friday, May 10, 2013 6:54 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/10/2013 Date In :
Time Out : 18:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3870

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN; OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : installing mobile transformer mobile transformer failed

Follow-Up : putting load back on sub transformer as of now

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 13, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/10/13 - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown - POWER RESTORED
Power outage - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown - power restored.

Wendy

From: Knutson, David A
Sent: Friday, May 10, 2013 7:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/10/2013 Date In : 5/10/2013
Time Out : 18:45 Time In : 18:55

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 3870

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN; OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : mobil transformer failed

Follow-Up : load is back on sub transformer all should be back on

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 13, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/10/13 - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown - POWER RESTORED/UPDATE
Power outage - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown - power restored/update.

Wendy

From: Anderson, Timothy K
Sent: Friday, May 10, 2013 8:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/10/2013 Date In : 5/10/2013
Time Out : 18:45 Time In : 18:55

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 3870

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN; OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FOLLOW UO TO OUTAGE AT SUB. REWIRED CT'S ON MOBILE TO HANDLE
LOAD.

Follow-Up : MOBILE ENERGIZED AND CARRYING LOAD 20:21

Eilers, Rebecca D

From: Anderson, Timothy K
Sent: Friday, May 10, 2013 8:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/10/2013 Date In : 5/10/2013
Time Out : 18:45 Time In : 18:55

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 3870

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN; OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FOLLOW UO TO OUTAGE AT SUB. REWIRED CT'S ON MOBILE TO
HANDLE LOAD.

Follow-Up : MOBILE ENERGIZED AND CARRYING LOAD 20:21

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/19/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Babb, Randall J
Sent: Sunday, May 19, 2013 6:54 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In :
Time Out : 06:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1339

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Troublemaker in route; Unknown.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/19/13 - Minneapolis - POWER RESTORED

From: Babb, Randall J
Sent: Sunday, May 19, 2013 9:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2013 Date In : 5/19/2013
Time Out : 06:41 Time In : 09:06

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 1336

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Lightning strike damaged pole equipment. Wire burned open at a different location.

Follow-Up : Troublemakers made permanent repair of pole equipment and crew repaired wire.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 7:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/22/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Wednesday, May 22, 2013 4:35 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/22/2013 Date In :
Time Out : 04:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1336

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 22, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/22/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Wednesday, May 22, 2013 6:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/22/2013 Date In : 5/22/2013
Time Out : 04:31 Time In : 06:13

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 1336

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Faulted head end cable.

Follow-Up : Biddle and repair cable.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/24/13 - Newport
Power outage - Newport.

Wendy

From: Gilland, William P
Sent: Friday, May 24, 2013 9:11 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/24/2013 Date In :
Time Out : 21:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 28, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 5/24/13 - Red Rock - POWER RESTORED
Power outage - Red Rock - power restored.

Wendy

From: Gilland, William P
Sent: Friday, May 24, 2013 10:27 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/24/2013 Date In : 5/24/2013
Time Out : 21:06 Time In : 21:53

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 7

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers :

Cause : head end cable failed

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 12:18 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/31/13 - New Hope
Power outage - New Hope.

Wendy

From: Davis, Percyell
Sent: Friday, May 31, 2013 11:46 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In :
Time Out : 11:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1280

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : NEW HOPE, MN

State : MN - Minnesota

Major Customers : none

Cause : unkown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 12:16 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 5/31/13 - New Hope -
POWER RESTORED

Power outage - New Hope - power restored.

Wendy

From: Davis, Percyell
Sent: Friday, May 31, 2013 11:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In : 5/31/2013
Time Out : 11:37 Time In : 11:40

Time Zone : CST

Duration : 0 hours, 3 mins

Number of Customers Affected : 1280

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : NEW HOPE, MN

State : MN - Minnesota

Major Customers : none

Cause : relay in sub working open wrong breaker

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Bloomington
Power outage - Bloomington

Wendy

From: Knutson, David A
Sent: Saturday, May 18, 2013 5:57 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In :
Time Out : 05:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2048

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : Bloomington

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : troubleman on the way

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:19 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/17/13 - Richfield - Update
Power outage - Richfield - update.

Wendy

From: Aspinwall, David P
Sent: Saturday, May 18, 2013 6:41 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In :
Time Out : 05:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 0

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : 90% OF FEEDER BACK IN AT 0632, ONE STRETCH OF OH LEFT TO PATROL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:20 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/17/13 - Richfield - POWER RESTORED
Power outage - Richfield - power restored.

Wendy

From: Aspinwall, David P
Sent: Saturday, May 18, 2013 7:05 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/18/2013 Date In : 5/18/2013
Time Out : 05:48 Time In : 06:56

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 0

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD

State : MN - Minnesota

Major Customers : NONE.

Cause : SQUIRREL CONTACT AT CAP BNK,

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/17/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul.

Wendy

From: Kittock, Joseph C
Sent: Friday, May 17, 2013 5:02 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In :
Time Out : 16:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 689

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : wire down south of the

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, May 18, 2013 7:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/17/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - POWER RESTORED
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - power restored.

Wendy

From: Kittock, Joseph C
Sent: Friday, May 17, 2013 5:09 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/17/2013 Date In : 5/17/2013
Time Out : 16:41 Time In : 16:59

Time Zone : CST

Duration : 0 hours, 18 mins

Number of Customers Affected : 689

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : wire down south of the #5 sw.

Follow-Up : Metro East feeder except for the west area and # count. . This is metro

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/20/13 - Bloomington, Minneapolis,
Richfield & Wold Chamberlan
Power outage - Bloomington, Minneapolis, Richfield & Wold Chamberlan.

Wendy

From: Peterson, Kenneth W
Sent: Monday, May 20, 2013 7:03 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/20/2013 Date In :
Time Out : 07:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 57

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN; RICHFIELD, MN; WOLD
CHAMBERLAI, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 20, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/20/13 - Bloomington, Minneapolis,
Richfield & Wold Chamberlan - UPDATE
Power outage - Bloomington, Minneapolis, Richfield & Wold Chamberlan - update.

Wendy

From: Peterson, Kenneth W
Sent: Monday, May 20, 2013 8:12 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/20/2013 Date In :
Time Out : 07:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 57

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN; RICHFIELD, MN; WOLD
CHAMBERLAI, MN

State : MN - Minnesota

Major Customers : none

Cause : Arrestors blew on A & Bph at the / Neutrals burned open on potheads

Follow-Up : Isolating Cable

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 12:32 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/31/13 - Saint Louis Park
Power outage - Saint Louis Park

Wendy

From: Knutson, David A
Sent: Friday, May 31, 2013 12:23 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In :
Time Out : 12:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1558

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN ON FEEDER

Follow-Up : PATROLLING REST OF FEEDER NOW

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 12:59 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/31/13 - Saint Louis Park - POWER RESTORED

Power outage - Saint Louis Park - power restored.

Wendy

From: Anderson, Timothy K
Sent: Friday, May 31, 2013 12:58 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In : 5/31/2013
Time Out : 12:03 Time In : 12:39

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 1558

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN

Follow-Up : ENERGIZED SUB TO

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 31, 2013 1:44 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 5/31/13 - Saint Louis Park - POWER
RESTORED/UPDATE

Power outage - Saint Louis Park - power restored/update.

Wendy

From: Anderson, Timothy K
Sent: Friday, May 31, 2013 1:41 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 5/31/2013 Date In : 5/31/2013
Time Out : 12:03 Time In : 13:22

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1558

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN

Follow-Up : NORTH END OF FEEDER RESTORED TO
TILL WIRE BACK UP

JUMPERS OPEN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 02, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 5/2/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Kaveny, Michael J
Sent: Thursday, May 02, 2013 7:19 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In :
Time Out : 07:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3161

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Snow Storm in area. This feeder was carrying part of
which is out with Crew Patrolling.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 8:32 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Peterson, Mark S
Sent: Friday, May 03, 2013 2:13 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/3/2013
Time Out : 22:38 Time In : 02:05

Time Zone : CST

Duration : 3 hours, 27 mins

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : none

Cause : Final 78 customers back on @ 0205. Restored 2023 customers @

0041

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 03, 2013 2:02 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/2/13 - Red Wing - POWER RESTORED
Sorry for the delay...

Power outage - Red Wing - power restored.

Wendy

From: Goulet, Terry W
Sent: Friday, May 03, 2013 1:51 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/2/2013 Date In : 5/2/2013
Time Out : 07:12 Time In : 07:52

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 2101

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NA

Cause : Outage due to heavy wet snow and trees on feeder.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 3:20 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/3/13 - Eagan & Inver Grove Heights
Heights
Power outage -- Eagan & Inver Grove Heights.

Wendy

From: Elden, Thomas L
Sent: Monday, June 03, 2013 2:50 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/3/2013 Date In :
Time Out : 14:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3709

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : wire down at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 3:22 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/3/13 - Eagan & Inver
Grove Heights - UPDATE
Power outage - Eagan & Inver Grove Heights - update.

Wendy

From: Elden, Thomas L
Sent: Monday, June 03, 2013 3:19 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/3/2013 Date In :
Time Out : 14:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3709

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : wire down 3122 customers are back on at 15:09

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 3:53 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 6/3/13 - Eagan & Inver Grove Heights - POWER RESTORED
Power outage - Eagan & Inver Grove Heights - power restored.

Wendy

From: Elden, Thomas L
Sent: Monday, June 03, 2013 3:51 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/3/2013 Date In : 6/3/2013
Time Out : 14:23 Time In : 15:44

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 3709

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : wire down

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 07, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/7/13 - Maplewood & Saint Paul
Power outage - Maplewood & Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Friday, June 07, 2013 6:27 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/7/2013 Date In :
Time Out : 06:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 916

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 07, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/7/13 - Maplewood & Saint Paul - POWER RESTORED

Power outage - Maplewood & Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Friday, June 07, 2013 7:11 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/7/2013 Date In : 6/7/2013
Time Out : 06:19 Time In : 07:07

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 916

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bad urd cable from sub to

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:43 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice- 6/8/2013 Bayport, Lakeland, Oak Park Heights,
Stillwater, Lakeland TWP
Power Outage - BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN;
STILLWATER, MN; W LAKELAND TWP, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Saturday, June 08, 2013 23:52
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/8/2013 Date In :
Time Out : 23:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1809

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:45 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Power Restored- 6/9/2013 Bayport, Lakeland, Oak Park Heights,
Stillwater, Lakeland

Power Restored- BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN;
STILLWATER, MN; W LAKELAND TWP, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (651) 639-4322

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Sunday, June 09, 2013 05:15
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/8/2013

Date In : 6/9/2013

Time Out : 23:45

Time In : 00:52

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1809

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers :

Cause : patrol found nothing/will patrol during daylight

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 11, 2013 3:27 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/11/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 11, 2013 3:19 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/11/2013 Date In : 6/11/2013
Time Out : 13:40 Time In : 15:04

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1883

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : noe

open, Cause : c phase jumper burned open at approx 13:40,sw would not
bkr opened so jumper laying on neut could be removed

Follow-Up : crew to make repairs tonight

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/11/13 - Inver Grove Heights, Inver Grove & South Saint Paul
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul.

Wendy

From: Gilland, William P
Sent: Tuesday, June 11, 2013 4:45 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/11/2013 Date In :
Time Out : 16:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1833

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/11/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 11, 2013 5:51 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/11/2013 Date In : 6/11/2013
Time Out : 16:37 Time In : 17:45

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 1833

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : truck broke feeder pole at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 13, 2013 7:28 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/12/13 - Maplewood, Saint Paul & Woodbury
Power outage - Maplewood, Saint Paul & Woodbury.

Wendy

From: Gilland, William P
Sent: Wednesday, June 12, 2013 7:46 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In :
Time Out : 19:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2712

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 9:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Tree Report

Attachments: image.jpeg; image.jpeg; image.jpeg



image.jpeg (813 KB)



image.jpeg (568 KB)



image.jpeg (816 KB)

FYI...Tree report.

Wendy

-----Original Message-----

From: Weidenfeller, Bradley M
Sent: Monday, June 17, 2013 9:37 AM
To: dl Electric Outage ME Notification
Cc: Ryberg, S er L
Subject: FW: Second Outage Notice

Brad Weidenfeller

Xcel Energy | Responsible By Nature

Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369

P: 763-493-1827 C: 320-250-2541 F: 763-493-1840

E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

-----Original Message-----

From: Schumal, Bill [mailto:BSchumal@wrighttree.com]
Sent: Thursday, June 13, 2013 1:35 PM
To: Johnson, Fletcher L
Cc: Weidenfel le, Christopher D
Subject: Re: Second Outage Notice

[cid:AE3E0A6A-2D97-4EBA-83FE-31588EBBF425]

[cid:9875F39C-E0A1-489F-80E2-44EFBB9CD799]

[cid:05B906AB-8F33-4876-B2ED-9C5B59D5F3F3]

8" limb 30 ft long broke away from basswood at trunk. I can't see burn marks on limb as is still hung in secondary. Looks like it was within normal trim zone prior to failure. Other overhang exists, a lot of it. Last years' outage debris is still here a span away. It appears to have either black rot/ decay or burn marks on the trunk.

Should I get a boom to get it off the secondary or do you want to look at it first?
Page 418 of 1336

Sent from my iPhone

Bill Schumal
Wright Tree Service
General Foreman
612-867-9157

On Jun 13, 2013, at 10:42 AM, "Johnson, Fletcher L"
<Fletcher.L.Johnson@xcelenergy.com<mailto:Fletcher.L.Johnson@xcelenergy.com>> wrote:

Hey - not sure if Brad may have sent this out to one of you for investigation. If not, can you guys look at this today and reply back with what you find?

Fletcher Johnson
Xcel Energy
Vegetation Management Supervisor II
O: 651.639.4590 C: 612.418.9761 F: 612.573.1856

From: Gilland, William P
Sent: Wednesday, June 12, 2013 8:44 PM
To: dl El igation
Subject: Second Outage Notice

Distribution System Status Outage

Notification

Second Outage Notice

Date Out : 6/12/2013 Date In : 6/12/2013
Time Out : 19:40 Time In : 20:20

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 2712

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651)

229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branch on

Follow-Up :

NOTICE: This email (including attachments) is covered by the Electronic Communications Privacy Act, 18 U.S.C. §§ 2510-2522, is confidential, and may be legally privileged. If you are not the intended recipient, you are hereby notified that any retention, dissemination, distribution, or copying of this communication is strictly prohibited. Please reply to the sender that you have received the message in error and then delete it. Any views or opinions presented are solely those of the author and do not

necessarily represent those of the company.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 14, 2013 10:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: image.jpeg
FYI...tree report.

Wendy

From: Johnson, Fletcher L
Sent: Friday, June 14, 2013 9:58 AM
To: Gilland, William P; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-Preventable. Basswood limb broke at trunk. Limb was 8" diameter and ~30' long; may have had decay at point of break. Tree work last completed on span as part of VM Maintenance Map in Sept 2009. Next maintenance work forecasted for 2014.

Fletcher Johnson

Xcel Energy

Vegetation Management Supervisor II

O: 651.639.4590 C: 612.418.9761 F: 612.573.1856

From: Gilland, William P
Sent: Wednesday, June 12, 2013 8:44 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/12/2013

Date In : 6/12/2013

Time Out : 19:40

Time In : 20:20

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 2712

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branch on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 13, 2013 7:29 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/12/13 - Maplewood, Saint Paul & Woodbury - POWER RESTORED

Power outage - Maplewood, Saint Paul & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Wednesday, June 12, 2013 8:44 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In : 6/12/2013
Time Out : 19:40 Time In : 20:20

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 2712

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branch on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 14, 2013 3:12 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/14/13 - Maplewood, Newport, Saint Paul & Woodbury
Power outage - Maplewood, Newport, Saint Paul & Woodbury

Wendy

From: Gilland, William P
Sent: Friday, June 14, 2013 3:09 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

RRK-RED ROCK First Outage Notice
Feeder/Bus : 082

Date Out : 6/14/2013 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2601

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/14/13 - Maplewood, Newport, Saint Paul & Woodbury - UPDATE
Power outage - Maplewood, Newport, Saint Paul & Woodbury - Update.

Wendy

From: Gilland, William P
Sent: Friday, June 14, 2013 4:28 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/14/2013 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2601

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : multiple tree branches at tore fdr phase
down, jumpers are being cut open to restore most cust's. At this time approx 80% of cust's are
back in service.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 7:49 AM
To: 'staff, cao (PUC)'; dl Customer Advocate Team
Cc: 'staff, cao (PUC)'
Subject: FW: Third Outage Notice - 6/14/13 - Maplewood, Newport, Saint Paul & Woodbury - POWER RESTORED
Power outage - Maplewood, Newport, Saint Paul & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Friday, June 14, 2013 5:08 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/14/2013 Date In : 6/14/2013
Time Out : 14:56 Time In : 16:51

Time Zone : CST

Duration : 1 hours, 55 mins

Number of Customers Affected : 2601

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches fell on fdr

Follow-Up : all cust's restored as of 16:51/OH crew on site to make repairs

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 3:43 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: _tree.pdf
FYI...Tree report.

Wendy

From: Johnson, Fletcher L
Sent: Monday, June 17, 2013 3:18 PM
To: Gilland, William P; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-Preventable. Dead red oak limb broke from ~75' away, hit adjacent healthy ash tree on hillside causing ash to uproot and hit lines. In photo, note position and distance of conductors from start of domino effect. Tree work completed on circuit Dec 2012.

Fletcher Johnson

Xcel Energy

Vegetation Management Supervisor II

O: 651.639.4590 C: 612.418.9761 F: 612.573.1856

From: Gilland, William P
Sent: Friday, June 14, 2013 5:08 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/14/2013

Date In : 6/14/2013

Time Out : 14:56

Time In : 16:51

Time Zone : CST

Duration : 1 hours, 55 mins

Number of Customers Affected : 2601

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches fell on fdr

Follow-Up : all cust's restored as of 16:51/OH crew on site to make repairs

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 18, 2013 7:32 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/17/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul.

Wendy

From: Gilland, William P
Sent: Monday, June 17, 2013 4:30 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/17/2013 Date In :
Time Out : 16:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2392

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 18, 2013 7:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/17/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - POWER RESTORED

Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Monday, June 17, 2013 5:33 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/17/2013 Date In : 6/17/2013
Time Out : 16:25 Time In : 17:28

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2392

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : def cable betw.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 4:03 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/20/13 - Afton, Lake Elmo, Lake St Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Woodbury

Power outage - Afton, Lake Elmo, Lake St Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Woodbury.

Wendy

From: Elden, Thomas L
Sent: Thursday, June 20, 2013 3:42 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/20/2013 Date In :
Time Out : 15:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 12156

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; LAKE ELMO, MN; LAKE ST CROIX, MN;
LAKELAND SHORES, MN; LAKELAND, MN; LK ST CROIX BCH, MN; SAINT CROIX BCH,
MN; SAINT MARYS POINT, MN; SAINT PAUL, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 11:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/20/13 - Afton, Lake Elmo, Lake St Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Marys Point, Saint Paul, Stillwater & Woodbury - POWER RESTORED

Power outage - Afton, Lake Elmo, Lake St Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Marys Point, Saint Paul, Stillwater & Woodbury - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 28, 2013 11:21 AM
To: Jaede, Wendy L; LaCasse, Joseph S
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/20/2013 Date In : 6/20/2013
Time Out : 15:31 Time In : 16:05

Time Zone : CST

Duration : 0 hours, 34 mins

Number of Customers Affected : 12156

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; LAKE ELMO, MN; LAKE ST CROIX, MN; LAKELAND SHORES, MN; LAKELAND, MN; LK ST CROIX BCH, MN; SAINT CROIX BCH, MN; SAINT MARYS POINT, MN; SAINT PAUL, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Failed 'A' disconnect in substation.

Follow-Up : Partial Restoration: customers restored on a momentary via intelliteam switch
1 B switch closing to restore 6034 customers. , 5989 customers restored on a momentary when
intelliteam switch switch closed. The remaining 133 customers were restored when the breaker
was closed at 16:05.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 3:54 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maple Grove - POWER RESTORED
Power outage - Maple Grove - power restored

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 3:39 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:33 Time In : 15:32

Time Zone : CST

Duration : 11 hours, 59 mins

Number of Customers Affected : 2781

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAPLE GROVE, MN

State : MN - Minnesota

Major Customers : none

Cause : 2 Broken poles is carried by

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:04 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Mendota Hts, Saint Paul, Sunfish Lake & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Mendota Hts, Saint Paul, Sunfish Lake & West Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:25 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 3:52 Time In : 09:51

Time Zone : CST

Duration : 5 hours, 59 mins

Number of Customers Affected : 2391

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree on feeder @ . Storm in the area.

Follow-Up : Crews removed tree and CC closed breaker to restore feeder.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:49 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Falcon Heights, Maplewood & Saint Paul -
POWER RESTORED

Power outage - Falcon Heights, Maplewood & Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:04 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:53 Time In : 10:05

Time Zone : CST

Duration : 6 hours, 12 mins

Number of Customers Affected : 2337

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in the area.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:27 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 12:18 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:57 Time In : 09:01

Time Zone : CST

Duration : 5 hours, 4 mins

Number of Customers Affected : 2635

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in the area.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Little Canada, Maplewood, Saint Paul & Vadnais Heights
Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:16 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:54 Time In : 07:35

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 2032

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL, MN; VADNAIS
HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in the area.

Follow-Up : Partial Restoration
Closed Bkr @ 6:29; Closed @7:18; Closed tie @ 7:35 to bring in remaining customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:56 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Little Canada, Maplewood, Saint Paul & Vadnais Heights - POWER RESTORED
UPDATE - POWER RESTORED

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Little Canada, Maplewood, Saint Paul & Vadnais Heights

Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:16 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :
Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:54 Time In : 07:35

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 2032

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in the area.

Follow-Up : Partial Restoration

Closed Bkr @ 6:29; Closed @7:18; Closed tie @ 7:35 to bring in remaining customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maplewood, Newport, Saint Paul & Woodbury - POWER RESTORED
Power outage - Maplewood, Newport, Saint Paul & Woodbury - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:31 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:55 Time In : 08:52

Time Zone : CST

Duration : 4 hours, 57 mins

Number of Customers Affected : 2602

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in the area.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:14 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maplewood, Newport, Saint Paul & Woodbury - POWER RESTORED
Power outage - Maplewood, Newport, Saint Paul & Woodbury - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:46 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:55 Time In : 08:52

Time Zone : CST

Duration : 4 hours, 57 mins

Number of Customers Affected : 2602

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree on feeder.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:54 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:22 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:56 Time In : 07:26

Time Zone : CST

Duration : 3 hours, 30 mins

Number of Customers Affected : 506

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in the area

Follow-Up : Partial restoration:
Bkr closed @6:14 picking up feeder to the ; Closed tie @ 7:26 to
restore remaining customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:18 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - North Oaks, Saint Paul, White Bear Lake - POWER RESTORED

Power outage - North Oaks, Saint Paul, White Bear Lake - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:50 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:02 Time In : 07:26

Time Zone : CST

Duration : 3 hours, 24 mins

Number of Customers Affected : 1062

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NORTH OAKS, MN; SAINT PAUL, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree on feeder @

the Follow-Up : Opened and closed Bkr@ 06:54 restoring 465 customers. Closed
 @ 7:26 restoring remaining 597 customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:19 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6-21-13 - White Bear Lake - POWER
RESTORED

Power outage - White Bear Lake - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:57 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:02 Time In : 05:39

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 2552

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : Patrolled feeder and restored 100% @ 5:39.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:39 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Farmington & Lakeville - POWER RESTORED

Power outage - Farmington & Lakeville - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:15 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:01 Time In : 06:25

Time Zone : CST

Duration : 2 hours, 24 mins

Number of Customers Affected : 927

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN; LAKEVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in the area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:34 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Roseville & Saint Paul - POWER RESTORED

Power outage - Roseville & Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:24 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:28 Time In : 07:11

Time Zone : CST

Duration : 2 hours, 43 mins

Number of Customers Affected : 128

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Arrestor blown at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Mendota Heights, New Brighton & Saint Anthony - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Mendota Heights, New Brighton & Saint Anthony

Power outage - Mendota Heights, New Brighton & Saint Anthony.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:32 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 19:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1864

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Mendota Heights, New Brighton & Saint Anthony - POWER RESTORED
Power outage - Mendota Heights, New Brighton & Saint Anthony - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 5:26 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 17:12

Time Zone : CST

Duration : 21 hours, 13 mins

Number of Customers Affected : 1864

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER , PARTIAL RESTORATION WAS
DONE. 100% AT 17:12

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:46 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Mendota Heights, New Brighton & Saint Anthony - POWER RESTORED/UPDATE

Power outage - Mendota Heights, New Brighton & Saint Anthony - power restored/update.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:17 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 09:39

Time Zone : CST

Duration : 13 hours, 40 mins

Number of Customers Affected : 948

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER ON

Follow-Up : OPEN FEEDER AND PARTIAL RESTORATION OF 948 CUSTOMERS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Falcon Heights & Saint Paul - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Falcon Heights & Saint Paul

Power outage - Falcon Heights & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:24 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1780

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/23/13 - Falcon Heights & Saint Paul - POWER RESTORED

Power outage - Falcon Heights & Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Sunday, June 23, 2013 10:34 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:06 Time In : 11:34

Time Zone : CST

Duration : 15 hours, 28 mins

Number of Customers Affected : 1781

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Wire down over

Follow-Up : Partial restoration: Closed Bkr @ 9:35 restoring 644 customers; Closed @ 10:43 restoring 754 customers; remaining 382 customers restored @ 11:34 for 100% restoration.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Roseville & Saint Paul - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Roseville & Saint Paul

Power outage - Roseville & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:22 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3237

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:51 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Roseville & Saint Paul - POWER RESTORED

Power outage - Roseville & Saint Paul - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:31 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:08 Time In : 08:27

Time Zone : CST

Duration : 12 hours, 19 mins

Number of Customers Affected : 3237

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ISSUES AT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 10:24 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:12 Time In : 08:27

Time Zone : CST

Duration : 12 hours, 15 mins

Number of Customers Affected : 1000

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Cause not determined. Storm in area.

Follow-Up : Patrolled feeder and found nothing.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Saint Paul - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul

Power outage - Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:30 AM
To: dl Electric Outage ME Notification
Subject: SHP-SHEPARD (072) First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 19:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1921

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:46 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/22/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:23 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 19:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1922

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : TREES ON LINE AT

Follow-Up : ENERGIZED UP TO RESTORED 1100 CUSTOMERS BACK AT 08:30

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 9:26 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 08:54

Time Zone : CST

Duration : 12 hours, 55 mins

Number of Customers Affected : 1922

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Trees on line @

Follow-Up : Restored 837 cust @ 830.
Restored remaining 1084 customers @ 8:54.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:00 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3039

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 9:35 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 20:05

Time Zone : CST

Duration : 24 hours, 6 mins

Number of Customers Affected : 3039

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees on feeder @ ; wire down west of

Follow-Up : Partial restoration:
Restored 2209 customers @ 2:19; Restored remaining 830 customers @ 20:05.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/22/13 - Lake Elmo, Maplewood & Oakdale
Power outage - Lake Elmo, Maplewood & Oakdale.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:39 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2312

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:44 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Lake Elmo, Maplewoode& Oakdale -
POWER RESTORED

Power outage - Lake Elmo, Maplewood & Oakdale - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:14 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:11 Time In : 09:51

Time Zone : CST

Duration : 13 hours, 40 mins

Number of Customers Affected : 2312

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ISSUES ON , LINE CUT OPEN FOR FINAL

REPAIRS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Roseville & Saint Anthony
Power outage - Roseville & Saint Anthony.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 9:53 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1110

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT ANTHONY, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in the area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Roseville, Saint Anthony - POWER RESTORED

Power outage - Roseville & Saint Anthony - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 3:45 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:00 Time In : 15:37

Time Zone : CST

Duration : 19 hours, 37 mins

Number of Customers Affected : 1110

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN; SAINT ANTHONY, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : PATROLLED AND RECLOSED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights
Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:25 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:01 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2040

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - POWER RESTORED
Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 9:52 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 20:01 Time In : 22:34

Time Zone : CST

Duration : 2 hours, 33 mins

Number of Customers Affected : 2040

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees on feeder @

Follow-Up : 100% restored @ 22:34.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Mendota Heights, Saint Paul & West Saint Paul

Power outage - Mendota Heights, Saint Paul & West Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:06 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1801

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 03, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: *6/21 outage* Final Outage Notice - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED/UPDATE
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored/update.

Wendy

From: LaCasse, Joseph S
Sent: Tuesday, July 02, 2013 5:41 PM
To: LaCasse, Joseph S; Jaede, Wendy L
Subject: *6/21 outage* Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/23/2013
Time Out : 20:04 Time In : 23:08

Time Zone : CST

Duration : 51 hours, 4 mins

Number of Customers Affected : 1803

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees and wire down &

Follow-Up : Partial Restore: Closed tie switch @ 8:08 to pick up 1280 customers.
Closed Bkr up to @ 08:45 to pick up 250 customers. repaired feeder and closed jumper on 6/23 @
23:08 to restore remaining 272 customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul
Power outage - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:09 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1650

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; FRIDLEY, MN; MOUNDS VIEW, MN; NEW BRIGHTON, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:48 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Falcon Heights & Saint Paul - POWER RESTORED

Power outage - Falcon Heights & Saint Paul - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:28 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:06 Time In : 08:21

Time Zone : CST

Duration : 12 hours, 15 mins

Number of Customers Affected : 1781

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FOUND NEUT DOWN AT , CLEARED AND RE-ENERGIZED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul

Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:19 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1518

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis, New Brighton, Roseville, Saint Anthony, Saint Paul & St Anthony - POWER RESTORED
Power outage - Minneapolis, New Brighton, Roseville, Saint Anthony, Saint Paul & St Anthony - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:34 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:18 Time In : 11:33

Time Zone : CST

Duration : 15 hours, 15 mins

Number of Customers Affected : 1518

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : PARTOLLED FDR, FOUND NO CAUSE, RE-ENERGIZED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Afton, Cottage Grove, Hastings & Woodbury
Power outage - Afton, Cottage Grove, Hastings & Woodbury.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:16 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3017

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; COTTAGE GROVE, MN; HASTINGS, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Afton, Cottage Grove, Hastings & Woodbury -
POWER RESTORED
Power outage - Afton, Cottage Grove, Hastings & Woodbury - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 6:30 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:05 Time In : 01:08

Time Zone : CST

Duration : 5 hours, 3 mins

Number of Customers Affected : 6933

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; COTTAGE GROVE, MN; HASTINGS, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Lightning.

Follow-Up : carrying prior to event. Partial restoration: Intelliteam
sw opened and Bkr closed @20:06 restoring 261 customers with a momentary event. Closed
@ 00:55 to restore 2756 customers, closed tie sw @ 1:08 to restore remaining 3916
customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Saint Paul - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul

Power outage - Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:26 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1792

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:47 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED/UPDATE

Power outage - Saint Paul - power restored/update.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:25 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:27 Time In : 09:32

Time Zone : CST

Duration : 13 hours, 5 mins

Number of Customers Affected : 1793

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ISSUES

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul
Power outage - Saint Paul

Wendy

From: Abbott, Edward J
Sent: Friday, June 21, 2013 10:15 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1000

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:23 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3341

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:03 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:48 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:16 Time In : 00:17

Time Zone : CST

Duration : 4 hours, 1 mins

Number of Customers Affected : 3341

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE DOWN BEHIND

Follow-Up : ISOLATED AND RESTORED BY SWITCHING

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Saint Paul - POWER
RESTORED

Power outage - Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:45 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 20:19 Time In : 20:28

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 2660

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : Downtown St. Paul network.

Cause : To be determined. Storm in area.

Follow-Up : Operator en-route to the sub to retrieve targets. Network, , and
restored at 20:28. remains out and noted on separate outage notification.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Oak Park Heights & Stillwater - DATE CORRECTION
CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Oak Park Heights & Stillwater

Power outage - Oak Park Heights & Stillwater.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:14 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2146

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:05 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Oak Park Heights & Stillwater - POWER RESTORED

Power outage - Oak Park & Stillwater - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:50 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:25 Time In : 01:14

Time Zone : CST

Duration : 4 hours, 49 mins

Number of Customers Affected : 2146

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT

Follow-Up :

Eilers, Rebecca D

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:50 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:25 Time In : 01:14

Time Zone : CST

Duration : 4 hours, 49 mins

Number of Customers Affected : 2146

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 01, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/30/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Moehnke, Thomas H
Sent: Sunday, June 30, 2013 9:51 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/30/2013 Date In :
Time Out : 09:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 999

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : z

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 01, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/30/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Moehnke, Thomas H
Sent: Sunday, June 30, 2013 11:50 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/30/2013 Date In : 6/30/2013
Time Out : 09:47 Time In : 11:40

Time Zone : CST

Duration : 1 hours, 53 mins

Number of Customers Affected : 999

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : miso

Cause : def cbl btwn and

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/22/13 - Inver Grove Heights & Inver Grove -
DATE CORRECTION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 6/21/13 - Inver Grove Heights & Inver Grove - DATE
CORRECTION

CORRECTION - OUTAGE DATE - 6/22/13 AND NOT 6/21/13. SORRY FOR THE CONFUSION

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Inver Grove Heights & Inver Grove

Power outage - Inver Grove Heights & Inver Grove.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 12:17 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 20:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3512

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:29 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Inver Grove Heights & Inver Grove -
POWER RESTORED

Power outage - Inver Grove Heights & Inver Grove - power restored.

Wendy

From: Plummer, Charles H
Sent: Saturday, June 22, 2013 1:45 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:28 Time In : 12:31

Time Zone : CST

Duration : 16 hours, 3 mins

Number of Customers Affected : 3513

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : FLASHED OVER LOAD CENTER, ISOLATED AND RESTORED HEAD END

FEEDER

Follow-Up : I TEAM OPERATED CORRECTLY, ALL CUSTOMER PAST
RESTORED BY AUTO TRANSFER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:33 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Afton, Cottage Grove, Hastings, Lake Elmo, Lake St. Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Stillwater

Power outage - Afton, Cottage Grove, Hastings, Lake Elmo, Lake St. Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Stillwater.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 1:19 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 04:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 9055

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; COTTAGE GROVE, MN; HASTINGS, MN; LAKE ELMO, MN; LAKE ST CROIX, MN; LAKELAND SHORES, MN; LAKELAND, MN; LK ST CROIX BCH, MN; SAINT CROIX BCH, MN; SAINT MARYS POINT, MN; SAINT PAUL, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in the area.

Follow-Up : was carrying and .
 and were restored @ 7:30. currently being patrolled and will be energized with
feeder breaker.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:31 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Afton, Cottage Grove, Hastings, Lake Elmo, Lake St. Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Woodbury - POWER RESTORED

Power outage - Afton, Cottage Grove, Hastings, Lake Elmo, Lake St. Croix, Lakeland Shores, Lakeland, Lk St Croix Bch, Saint Croix Bch, Saint Mary's Point, Saint Paul, Stillwater & Woodbury - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 2:28 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:11 Time In : 14:14

Time Zone : CST

Duration : 10 hours, 3 mins

Number of Customers Affected : 9055

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; COTTAGE GROVE, MN; HASTINGS, MN; LAKE ELMO, MN; LAKE ST CROIX, MN; LAKELAND SHORES, MN; LAKELAND, MN; LK ST CROIX BCH, MN; SAINT CROIX BCH, MN; SAINT MARYS POINT, MN; SAINT PAUL, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Storm in area.

Follow-Up : was carrying and .
 and were restored @ 7:30. currently being patrolled and will be

energized with feeder breaker.

was carrying and .
and were restored @ 7:30. currently being patrolled and will be energized
with feeder breaker. Remaining customers energized by 14:14. Partial restoration times to
follow.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:11 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maplewood & Saint Paul - POWER RESTORED

Power outage - Maplewood & Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 11:30 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 4:39 Time In : 09:15

Time Zone : CST

Duration : 4 hours, 36 mins

Number of Customers Affected : 2513

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in the area.

Follow-Up : Partial Restore

Closed Bkr @ 8:16 to pick up feeder to the . Closed @9:15 to restore remainder of the feeder.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis & Saint Paul
Power outage - Minneapolis & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:22 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2566

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in area

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/22/13 - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - POWER RESTORED
Power outage - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 1:58 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In : 6/23/2013
Time Out : 23:49 Time In : 01:47

Time Zone : CST

Duration : 1 hours, 58 mins

Number of Customers Affected : 1788

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : branches on feeder

Follow-Up : bkr closed to at 23:55-1340 cust in. closed at 01:47
to pick up 448 custs.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Little Canada, Roseville & Saint Paul
Power outage - Little Canada, Roseville & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 9:56 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2892

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Dellwood, Mahtomedi, Pine Springs, Saint Paul, Stillwatr, White Bear Lake & Willernie
Power outage - Dellwood, Mahtomedi, Pine Springs, Saint Paul, Stillwater, White Bear Lake & Willernie.

Wendy

From: Wolf, Terry K
Sent: Friday, June 21, 2013 9:04 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3272

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : DELLWOOD, MN; MAHTOMEDI, MN; PINE SPRINGS, MN; SAINT PAUL, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN; WILLERNIE, MN

State : MN - Minnesota

Major Customers : n/a

Cause : storm

Follow-Up : patrol feeder

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:30 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2232

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 0 - Maplewood, Newport, Saint Paul & Woodbury
Power outage - Maplewood, Newport, Saint Paul & Woodbury.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 6:22 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 06:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2602

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/23/13 - Maplewood, Newport, Saint Paul & Woodbury - POWER RESTORED
Power outage - Maplewood, Newport, Saint Paul & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 8:03 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 06:16 Time In : 07:52

Time Zone : CST

Duration : 1 hours, 36 mins

Number of Customers Affected : 2602

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches at

Follow-Up : iteam operated at this picked up 1479 cust's at 06:16. The
remaining 1123 custs came on at 07:52

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Bayport, Lakeland, Oak Park Heights,
Stillwater & Lakeland Twp
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & Lakeland Twp.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 6:49 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 06:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/23/13 - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - POWER RESTORED
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 8:18 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 06:36 Time In : 08:13

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers :

Cause : tree at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Lake Elmo, Oakdale & Woodbury
Power outage - Lake Elmo, Oakdale & Woodbury.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 6:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 06:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4120

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/23/13 - Lake Elmo, Oakdale & Woodbury -
POWER RESTORED

Power outage - Lake Elmo, Oakdale & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 7:15 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 06:16 Time In : 07:00

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 4121

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : arrestor blew at

06:16, Follow-Up : iteam operated at and tie with aft closed at
closed at 07:00

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis, Mounds View & Spring Lake Park
Lake Park
Power outage - Minneapolis, Mounds View & Spring Lake Park.

Wendy

From: Abbott, Edward J
Sent: Friday, June 21, 2013 10:14 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2895

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MINNEAPOLIS, MN; MOUNDS VIEW, MN; SPRING LAKE
PARK, MN

State : MN - Minnesota

Major Customers : na

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Bayport, Lakeland, Oak Park Heights,
Stillwater & W Lakeland Twp
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater & W Lakeland Twp.

Wendy

From: Abbott, Edward J
Sent: Friday, June 21, 2013 10:16 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Oak Park Heights & Stillwater
Power outage - Oak Park Heights & Stillwater.

Wendy

From: Abbott, Edward J
Sent: Friday, June 21, 2013 10:17 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 914

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 29, 2013 9:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/29/13 - Gem Lake, White Bear Lake, White Bear Lk - POWER RESTORED
Power outage - Gem Lake, White Bear Lake, White Bear Lk - power restored.

Wendy

From: Moehnke, Thomas H
Sent: Saturday, June 29, 2013 6:47 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/29/2013 Date In : 6/29/2013
Time Out : 05:41 Time In : 06:30

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 1345

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : 11

Cause : tree on fdr @ .

Follow-Up : remove tree no need for patrol will retrieve targets

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 11:38 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 06:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 837

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : head end cable failed

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/23/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, June 23, 2013 12:41 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 06:35 Time In : 12:36

Time Zone : CST

Duration : 6 hours, 1 mins

Number of Customers Affected : 837

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : cable at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/23/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED

Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Sunday, June 23, 2013 6:53 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 15:56 Time In : 16:39

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 1799

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : fault on head cable

Follow-Up : switched out and restored

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, June 23, 2013 7:51 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 19:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3538

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : unknow

Follow-Up : patrolling

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/23/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED

Sorry for the delay!

Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: LaCasse, Joseph S
Sent: Friday, July 12, 2013 3:32 PM
To: Jaede, Wendy L; LaCasse, Joseph S
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 19:41 Time In : 21:40

Time Zone : CST

Duration : 1 hours, 59 mins

Number of Customers Affected : 3549

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Failed head end cable.

Follow-Up : Partial restore:

Closed
remaining 1 customer.

@ 20:33 restoring 3548 customers. Closed

@ 21:40 restoring the

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 2:51 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/25/13 - Eagan
Power outage - Eagan.

Wendy

From: Chial, Terry L
Sent: Tuesday, June 25, 2013 2:49 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In :
Time Out : 14:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME

Follow-Up : WILL PATROL AND REENERGIZE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 9:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/25/13 - Eagan - POWER RESTORED
Sorry for the delay....

Power outage - Eagan - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, June 25, 2013 4:03 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In : 6/25/2013
Time Out : 14:43 Time In : 15:45

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : CABLE BAD URD

Follow-Up : WILL REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 12:55 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Lake Elmo, Oakdale & Woodbury
Power outage - Lake Elmo, Oakdale & Woodbury.

Wendy

From: LaCasse, Joseph S
Sent: Wednesday, June 26, 2013 12:52 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 12:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4121

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None.

Cause : Unknown.

Follow-Up : To be patrolled. Partial restore to via RC switches @ 12:21
restoring 583 Customers. Restored from via RC switches @ 12:22 restoring 1670
customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 3:20 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/26/13 - Lake Elmo, Oakdale & Woodbury -
POWER RESTORED

Power outage - Lake Elmo, Oakdale & Woodbury - power restored.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, June 26, 2013 2:25 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 12:14 Time In : 13:57

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 1670

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Lightning

Follow-Up : This was from the switch out..

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, June 26, 2013 5:30 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 17:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1921

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown...

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/26/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, June 26, 2013 6:15 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 17:18 Time In : 18:09

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 1921

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Our troublemen took a limb off feeder lines at

Follow-Up : N/A

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, June 26, 2013 11:46 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 23:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2063

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Unknwon..

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/26/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Thursday, June 27, 2013 12:39 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/27/2013
Time Out : 23:40 Time In : 00:29

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 2063

For information about this alert, contact : T;F;
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Head end cable failed...

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/27/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Chial, Terry L
Sent: Thursday, June 27, 2013 7:26 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/27/2013 Date In :
Time Out : 19:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1159

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown

Follow-Up : will repair

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/27/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Thursday, June 27, 2013 7:49 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/27/2013 Date In : 6/27/2013
Time Out : 19:21 Time In : 19:35

Time Zone : CST

Duration : 0 hours, 14 mins

Number of Customers Affected : 1159

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : head end cable

Follow-Up : cleared and referred.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 29, 2013 9:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/29/13 - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury
Power outage - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury.

Wendy

From: Moehnke, Thomas H
Sent: Saturday, June 29, 2013 5:39 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/29/2013 Date In :
Time Out : 05:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4719

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; LAKE ELMO, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : a

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 29, 2013 9:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/29/13 - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury - POWER RESTORED

Power outage - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury - power restored.

Wendy

From: Moehnke, Thomas H
Sent: Saturday, June 29, 2013 6:26 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/29/2013 Date In : 6/29/2013
Time Out : 05:18 Time In : 06:15

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 4719

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : AFTON, MN; LAKE ELMO, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : C phase arrestor @ the

Follow-Up : will retrieve target @ sub

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 29, 2013 9:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/29/13 - Gem Lake, White Bear Lake, White Bear Lk
Lk
Power outage - Gem Lake, White Bear Lake, White Bear Lk.

Wendy

From: Moehnke, Thomas H
Sent: Saturday, June 29, 2013 6:54 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/29/2013 Date In :
Time Out : 05:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1345

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : a

Cause : tree on on at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 03, 2013 10:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0188.JPG; IMG_0186.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, July 03, 2013 10:39 AM
To: Moehnke, Thomas H; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-preventable
Ash limb cracked and fell into black walnut causing both to cross over conductors on a candle stick 3 phase.
Last VM work date: 8/10/2011

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Moehnke, Thomas H
Sent: Saturday, June 29, 2013 6:47 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/29/2013 Date In : 6/29/2013
Time Out : 05:41 Time In : 06:30

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 1345

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR
LK, MN

State : MN - Minnesota

Major Customers : 11

Cause : tree on fdr @

Follow-Up : remove tree no need for patrol will retrieve targets

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/1/13 - Brooklyn Park, Crystal, Maple Grove & New Hope
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope.

Wendy

From: Davis, Percyell
Sent: Saturday, June 01, 2013 9:04 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In :
Time Out : 08:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1598

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:46 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/1/13 - Brooklyn Park, Crystal, Maple Grove & New Hope - POWER RESTORED
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope - power restored.

Wendy

From: Davis, Percyell
Sent: Saturday, June 01, 2013 9:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In : 6/1/2013
Time Out : 08:57 Time In : 09:28

Time Zone : CST

Duration : 0 hours, 31 mins

Number of Customers Affected : 1598

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAR HIT POLE PHASE GOT TOGETHER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 05, 2013 10:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/5/13 - Minnetrista, Mound, Shorewood & Spring Park
Power outage - Minnetrista, Mound, Shorewood & Spring Park.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 05, 2013 10:04 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In :
Time Out : 09:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2341

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 05, 2013 1:01 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/5/13 - Minnetrista, Mound, Shorewood & Spring Park
- POWER RESTORED/UPDATE

Power outage - Minnetrista, Mound, Shorewood & Spring Park - power restored/update.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 05, 2013 11:31 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In : 6/5/2013
Time Out : 09:14 Time In : 11:10

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 2341

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,

State : MN - Minnesota

Major Customers : NONE

Cause : CORECTION FINAL NOTICE TRESS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 05, 2013 2:00 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0039.JPG
FYI...

From: Loiselle, Christopher D
Sent: Wednesday, June 05, 2013 1:52 PM
To: Cedar, Daren A; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable
Ash tree grew into conductors and equipment.
Last work date 12/2008
Scheduled to be worked in 2013

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Cedar, Daren A
Sent: Wednesday, June 05, 2013 11:31 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In : 6/5/2013
Time Out : 09:14 Time In : 11:10

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 2341

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,

State : MN - Minnesota

Major Customers : NONE

Cause : CORECTION FINAL NOTICE TRESS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:30 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/5/13 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - UPDATE
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - update.

Wendy

From: Schwarz, John W
Sent: Wednesday, June 05, 2013 5:52 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In :
Time Out : 17:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4523

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:32 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/5/13 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove, Minneapolis & Osseo - UPDATE
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - update.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 05, 2013 7:27 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In :
Time Out : 17:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 9112

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : STILL UNKNOWN, PATROLLING FEEDERS.

Follow-Up : IS BEING CARRIED BY , RELAY DOING TEST SETTINGS ON
. DMS SECTIONALIZED BETWEEN AND
SW OPENED UP ALSO, BRK IS HOT TO THE 2 SW.UNABLE TO OPERATE DMS SWITCHES BY RC
NO TECHNOLOGICAL AREA ASSIGNED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/5/13 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 05, 2013 9:19 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 6/5/2013 Date In : 6/5/2013
Time Out : 17:34 Time In : 21:12

Time Zone : CST

Duration : 3 hours, 38 mins

Number of Customers Affected : 4523

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : .

Cause : FAULTED FEEDER CABLE 2-3 SW.

Follow-Up : FDR 100% RESTORED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/5/13 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 05, 2013 9:19 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 6/5/2013	Date In : 6/5/2013
Time Out : 17:34	Time In : 21:12

Time Zone : CST
Duration : 3 hours, 38 mins
Number of Customers Affected : 4523
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : .

Cause : FAULTED FEEDER CABLE 2-3 SW.

Follow-Up : FDR 100% RESTORED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:29 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/5/13 - Brooklyn Park, Minneapolis & Osseo
Power outage - Brooklyn Park, Minneapolis & Osseo.

Wendy

From: Schwarz, John W
Sent: Wednesday, June 05, 2013 5:47 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In :
Time Out : 17:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4589

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOW @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 06, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Brooklyn Park, Minneapolis & Osseo -
POWER RESTORED

Power outage - Brooklyn Park, Minneapolis & Osseo - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 05, 2013 9:36 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/5/2013 Date In : 6/5/2013
Time Out : 17:34 Time In : 21:31

Time Zone : CST

Duration : 3 hours, 57 mins

Number of Customers Affected : 4589

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : FAULTED FEEDER CABLE , TIED TOGETHER.

Follow-Up : 100% RESTORED, STARTED PROCESS TO GET CABLE REPAIRED
TONIGHT.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/9/2013 OUTAGE Excelsior, Mtka Beach, Nacarre, Orono, Shorewood, Tonka Bay, Wayzata
Power Outage- EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 14:09
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In :
Time Out : 14:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 226

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO,

MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to close jumpers.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 7:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice 6/9/2013- EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN
Power Restored- EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 14:22
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In : 6/9/2013
Time Out : 14:07 Time In : 14:20

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 226

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO,

MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to close jumpers.

Follow-Up : All restored at 1420.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:48 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/9/2013- Chanassen, Excelsior, Mtka, Nacarre, Orono, Shorewood, Tonka Bay, Wayzata
Power Outage- CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 06:56
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In :
Time Out : 06:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2713

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;

NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : 13.8kv Bus 1 Lockout, .

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 7:52 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice 6/9/2013- Update: Chan, Excelsior, Mtka
Beach, Navarre, Orono, Shorewood, Tonka Bay, Wayzata
Outage Update - CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN;
ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 08:11
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In :
Time Out : 06:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2713

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;

NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree fell on poles. BKR failure relays operated taking out and 69KV Bus. . Two Broken feeder

Follow-Up : BKR closed at 0752 restoring 1136 cust., Jumpers cut open, 107 cust. will be out until repairs are made. 1470 cust. on will be restored shortly.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:50 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: POWER RESTORED 6/9/2013- Chan, Excelsior, Mtka Beach,
Navarre, Orono, Shorewood, Tonka Bay, Wayzata
Power Restored- CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN;
ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 14:29
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In : 6/9/2013
Time Out : 06:45 Time In : 14:20

Time Zone : CST

Duration : 7 hours, 35 mins

Number of Customers Affected : 2713

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;

NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree fell on poles. BKR failure relays operated taking out and 69KV Bus. . Two Broken feeder

Follow-Up : BKR closed at 0752 restoring 1136 cust. 1470 cust. on restored at 08:51. Remaining 107 cust. restored at 1420.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 7:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice 6/9/2013- EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN
Power Restored- EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 14:22
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In : 6/9/2013
Time Out : 14:07 Time In : 14:20

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 226

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO,

MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to close jumpers.

Follow-Up : All restored at 1420.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 8:00 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Tree Report
Attachments: IMG_0040.JPG; IMG_0042.JPG
FYI Tree Report

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Loiselle, Christopher D
Sent: Monday, June 10, 2013 12:17
To: Hills, Thomas L; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-Preventable
Large basswood limb broke due to internal decay.
No outward signs of decay pocket.
Tree had full, green canopy.
Tree pruned to full extent on last cycle.
Last worked 3/2012

Christopher Loiselle

Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Hills, Thomas L
Sent: Sunday, June 09, 2013 2:29 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

3/24/2014

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2013 Date In : 6/9/2013

Time Out : 06:45 Time In : 14:20

Time Zone : CST

Duration : 7 hours, 35 mins

Number of Customers Affected : 2713

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;
NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree fell on . Two Broken feeder
poles. BKR failure relays operated taking out and 69KV Bus.

Follow-Up : BKR closed at 0752 restoring 1136 cust. 1470 cust. on restored
at 08:51. Remaining 107 cust. restored at 1420.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 8:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice 6/10/2013- GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN
Outage Update - GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Monday, June 10, 2013 23:49
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/10/2013 Date In :
Time Out : 23:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 687

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : troublemen on the way correct time of start is 2337

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, June 11, 2013 8:15 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice 6/11/2013 Power Restored GOLDEN VALLEY, MN;
MINNEAPOLIS, MN; ROBBINSDALE, MN
Power Restored- GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Tuesday, June 11, 2013 00:10
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2013 Date In : 6/11/2013
Time Out : 23:37 Time In : 00:05

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 687

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : BAD HEAD END CABLE SUB TO

Follow-Up : CHECKING SW GEAR AT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 10:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/12/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, June 12, 2013 10:37 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In :
Time Out : 10:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 6337

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 1:27 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/12/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - POWER RESTORED
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - power restored.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, June 12, 2013 1:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In : 6/12/2013
Time Out : 10:25 Time In : 12:14

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 2498

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : non

Cause : arrestors blown at two locations past the #9 sw.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 1:47 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/12/13 - Golden Valley, Minnetonka & Saint Louis Park
Power outage - Golden Valley, Minnetonka & Saint Louis Park.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 12, 2013 1:42 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In :
Time Out : 13:26 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 609

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : broken pole had to close feeder tie and open only
609 customers out

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 2:25 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/12/13 - Golden Valley, Minnetonka & Saint Louis Park - POWER RESTORED
Power outage - Golden Valley, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, June 12, 2013 2:13 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 6/12/2013	Date In : 6/12/2013
Time Out : 13:26	Time In : 14:05

Time Zone : CST

Duration : 0 hours, 39 mins

Number of Customers Affected : 609

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : BROKEN POLE OPENED UP PART OF FEEDER TO CUT POLE IN CLEAR

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/15/13 - Brooklyn Park & Osseo
Power outage - Brooklyn Park & Osseo.

Wendy

From: Schwarz, John W
Sent: Saturday, June 15, 2013 4:33 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/15/2013 Date In :
Time Out : 16:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1100

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 12:17 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0054.JPG; IMG_0056.JPG
FYI....tree report.

Wendy

From: Loiselle, Christopher D
Sent: Monday, June 17, 2013 12:15 PM
To: Knutson, David A; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable

Ash tree grew into and next to conductors, crossing conductors during storm.
Work last complete 4/2009 as part of VM maintenance map

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Knutson, David A
Sent: Saturday, June 15, 2013 6:16 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/15/2013

Date In : 6/15/2013

Time Out : 16:29

Time In : 18:12

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 1100

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : trees on feeder

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 17, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Brooklyn Park & Osseo - POWER RESTORED
Power outage - Brooklyn Park & Osseo - power restored.

Wendy

From: Knutson, David A
Sent: Saturday, June 15, 2013 6:16 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/15/2013 Date In : 6/15/2013
Time Out : 16:29 Time In : 18:12

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 1100

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : trees on feeder

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/19/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Davis, Percyell
Sent: Wednesday, June 19, 2013 7:11 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2013 Date In :
Time Out : 19:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 509

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/19/13 - Minneapolis - POWER RESTORED
Let's try this again!

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:43 AM
To: 'staff, cao (PUC)'
Subject: FW: Final Outage Notice - 6/19/13 - Minneapolis - POWER RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, June 19, 2013 8:24 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2013 Date In : 6/19/2013
Time Out : 19:08 Time In : 20:18

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 509

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT GUY WIRE ON PHASE BURNED DOWN.

Follow-Up : O.H. CREW OUT IN FIELD USED TO REPAIR PERMENTLY.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/19/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Davis, Percyell
Sent: Wednesday, June 19, 2013 9:48 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2013 Date In :
Time Out : 20:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2549

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, June 19, 2013 11:10 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2013 Date In : 6/19/2013
Time Out : 21:44 Time In : 22:55

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1822

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : double fault

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/19/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, June 19, 2013 11:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2013 Date In : 6/19/2013
Time Out : 21:44 Time In : 23:01

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 729

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Double fault

Follow-Up : Momentary on due to seperate cable faults

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13- Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria.

Wendy

From: Kittock, Joseph C
Sent: Friday, June 21, 2013 2:23 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2500

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown...intella-team opened at the #9 sw.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - POWER RESTORED
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - power restored.

Wendy

From: Kittock, Joseph C
Sent: Friday, June 21, 2013 4:47 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:07 Time In : 04:30

Time Zone : CST

Duration : 2 hours, 23 mins

Number of Customers Affected : 2500

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : non

Cause : tree on wire past the #9 sw.

Follow-Up :

Eilers, Rebecca D

From: Kittock, Joseph C
Sent: Friday, June 21, 2013 4:47 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:07 Time In : 04:30

Time Zone : CST

Duration : 2 hours, 23 mins

Number of Customers Affected : 2500

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : non

Cause : tree on wire past the #9 sw.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:39 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Eden Prairie - POWER RESTORED
Power outage - Eden Prairie - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 7:04 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:38 Time In : 07:00

Time Zone : CST

Duration : 3 hours, 22 mins

Number of Customers Affected : 2821

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree Branch on line

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:47 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Plymouth - POWER RESTORED

Power restored - Minneapolis & Plymouth - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 7:28 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 **Date In :** 6/21/2013
Time Out : 03:36 **Time In :** 07:26

Time Zone : CST

Duration : 3 hours, 50 mins

Number of Customers Affected : 2569

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE BRANCHES AT VARIOUS LOCATIONS

Follow-Up : FEEDER BACK IN AFTER PATROL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis & Robbinsdale
Power outage - Minneapolis & Robbinsdale

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:21 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2764

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Robbinsdale - POWER RESTORED

Power outage - Minneapolis & Robbinsdale - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:11 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:46 Time In : 08:08

Time Zone : CST

Duration : 4 hours, 22 mins

Number of Customers Affected : 2765

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : lightning

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Crystal, Minneapolis & New Hope
Power outage - Crystal, Minneapolis & New Hope.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:20 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2504

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Crystal, Minneapolis & New Hope -
POWER RESTORED

Power outage - Crystal, Minneapolis & New Hope - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:14 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:46 Time In : 08:12

Time Zone : CST

Duration : 4 hours, 26 mins

Number of Customers Affected : 2504

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Watertown Twp, Watertown & Wayzata
Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Watertown Twp, Watertown & Wayzata.

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 6:53 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 05:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4712

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN;
EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS,
MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN;
WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : UNKNOWN

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:37 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 05:44 Time In : 08:32

Time Zone : CST

Duration : 2 hours, 48 mins

Number of Customers Affected : 4712

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree in wire at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Golden Valley & Minneapolis
Power outage - Golden Valley & Minneapolis

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:18 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2950

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:44 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:45 Time In : 08:38

Time Zone : CST

Duration : 4 hours, 53 mins

Number of Customers Affected : 2950

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : wire down broken pole at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:21 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minnetonka & Plymouth
Power outage - Minnetonka & Plymouth

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 5:36 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 774

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME/POSSIBLE LIGHTING/WIND/RAIN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:00 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minnetonka & Plymouth - POWER RESTORED

Power outage - Minnetonka & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:30 Time In : 08:54

Time Zone : CST

Duration : 5 hours, 24 mins

Number of Customers Affected : 774

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Deephaven, Minnetonka,
Wayzata & Woodland
Power outage - Deephaven, Minnetonka, Wayzata & Woodland.

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 5:48 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4131

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN;
WOODLAND, MN

State : MN - Minnesota

Major Customers : UNKNOWN

Cause : TR#2 LOCKOUT AT SUB

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Deephaven, Minnetonka, Wayzata & Woodland - POWER RESTORED

Power outage - Deephaven, Minnetonka, Wayzata & Woodland - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 8:58 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:29 Time In : 08:50

Time Zone : CST

Duration : 5 hours, 21 mins

Number of Customers Affected : 1658

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : none

Cause : sw bad

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Corcoran, Hamel, Medina,
Minneapolis & Plymouth
Power outage - Corcoran, Hamel, Medina, Minneapolis & Plymouth

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 5:29 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2586

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN;
MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Corcoran, Hamel, Medina, Minneapolis & Plymouth - POWER RESTORED
Power outage - Corcoran, Hamel, Medina, Minneapolis & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 10:32 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:28 Time In : 10:29

Time Zone : CST

Duration : 7 hours, 1 mins

Number of Customers Affected : 2586

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN;
PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:51 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Crystal, Golden Valley & Robbinsdale
Power outage - Crystal, Golden Valley & Robbinsdale

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 7:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 07:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2021

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; ROBBINSDALE,
MN

State : MN - Minnesota

Major Customers : UNKNOWN

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Crystal, Golden Valley & Robbinsdale -
POWER RESTORED

Power outage - Crystal, Golden Valley & Robbinsdale - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 10:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 07:30 Time In : 10:48

Time Zone : CST

Duration : 3 hours, 18 mins

Number of Customers Affected : 2021

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : Jumpers burned open

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Deephaven, Minnetonka & Wayzata -
POWER RESTORED

Power outage - Deephaven, Minnetonka & Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 23, 2013 6:41 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 03:29 Time In : 21:42

Time Zone : CST

Duration : 42 hours, 13 mins

Number of Customers Affected : 917

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Independence, Maple Plain, Medina, Minnetrista, Mound, Mound & North Mankato
Power outage - Independence, Maple Plain, Medina, Minnetrista, Mound, Mound & North Mankato.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 10:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 10:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1414

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : clear for constuction / broken pole wire down

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:22 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - POWER RESTORED
Power outage - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 11:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 10:40 Time In : 11:45

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 1414

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : wire down outside sub

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:22 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - POWER RESTORED
Power outage - Independence, Maple Plain, Medina, Minnetrista, Mound & North Mankato - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 11:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 10:40 Time In : 11:45

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 1414

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : INDEPENDENCE, MN; MAPLE PLAIN, MN; MEDINA, MN; MINNETRISTA, MN; MOUND, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : wire down outside sub

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 3:57 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maple Grove - POWER RESTORED
Power outage - Maple Grove - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 3:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:33 Time In : 15:32

Time Zone : CST

Duration : 11 hours, 59 mins

Number of Customers Affected : 197

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAPLE GROVE, MN

State : MN - Minnesota

Major Customers : none

Cause : Broken poles

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:45 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Maple Grove
Power outage - Maple Grove

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 2:44 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2781

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAPLE GROVE, MN

State : MN - Minnesota

Major Customers : None

Cause : Broken poles / Feeder was carried by until is energized

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 3:54 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Maple Grove - POWER RESTORED
Power outage - Maple Grove - power restored

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 3:39 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:33 Time In : 15:32

Time Zone : CST

Duration : 11 hours, 59 mins

Number of Customers Affected : 2781

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAPLE GROVE, MN

State : MN - Minnesota

Major Customers : none

Cause : 2 Broken poles is carried by

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Saturday, June 22, 2013 6:30 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 06:22

Time Zone : CST

Duration : 10 hours, 30 mins

Number of Customers Affected : 2410

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Edina, Minneapolis & Richfield - POWER RESTORED

Power outage - Edina, Minneapolis & Richfield - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 7:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:55 Time In : 07:05

Time Zone : CST

Duration : 11 hours, 10 mins

Number of Customers Affected : 3220

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 8:46 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:55 Time In : 08:41

Time Zone : CST

Duration : 12 hours, 46 mins

Number of Customers Affected : 3719

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : tree branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Brooklyn Park, Crystal, Minneapolis & New Hope -
POWER RESTORED

Power outage - Brooklyn Park, Crystal, Minneapolis & New Hope - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 8:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:48 Time In : 08:33

Time Zone : CST

Duration : 12 hours, 45 mins

Number of Customers Affected : 2902

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE,
MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Columbia Heights, Fridley & Minneapolis - POWER RESTORED
Power outage - Columbia Heights, Fridley & Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 9:37 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:58 Time In : 09:33

Time Zone : CST

Duration : 13 hours, 35 mins

Number of Customers Affected : 1687

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 9:41 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:55 Time In : 09:38

Time Zone : CST

Duration : 13 hours, 43 mins

Number of Customers Affected : 2791

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 9:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:39 Time In : 09:47

Time Zone : CST

Duration : 14 hours, 8 mins

Number of Customers Affected : 1909

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 10:05 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Crystal, Golden Valley, Minneapolis & New Hope - POWER RESTORED

Power outage - Crystal, Golden Valley, Minneapolis & New Hope - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 10:03 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:49 Time In : 10:00

Time Zone : CST

Duration : 14 hours, 11 mins

Number of Customers Affected : 2143

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE,
MN

State : MN - Minnesota

Major Customers :

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 10:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Fridley - POWER RESTORED
Power outage - Fridley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 10:07 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:51 Time In : 10:05

Time Zone : CST

Duration : 14 hours, 14 mins

Number of Customers Affected : 969

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 10:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 10:23 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 10:19

Time Zone : CST

Duration : 14 hours, 27 mins

Number of Customers Affected : 5756

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 10:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Saint Anthony - POWER RESTORED

Power outage - Minneapolis & Saint Anthony - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 10:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 10:49

Time Zone : CST

Duration : 14 hours, 50 mins

Number of Customers Affected : 1579

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 11:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 10:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:53 Time In : 10:54

Time Zone : CST

Duration : 15 hours, 1 mins

Number of Customers Affected : 4615

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 11:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Saint Anthony - POWER RESTORED

Power outage - Minneapolis & Saint Anthony - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 11:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:59 Time In : 11:09

Time Zone : CST

Duration : 15 hours, 10 mins

Number of Customers Affected : 4034

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 11:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 11:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:57 Time In : 11:31

Time Zone : CST

Duration : 15 hours, 34 mins

Number of Customers Affected : 2111

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Corcoran, Hamel, Media, Minneapolis & Plymouth
Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth.

Wendy

From: Babb, Randall J
Sent: Friday, June 21, 2013 10:09 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2586

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN;
PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 12:04 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Corcoran, Hamel, Medina, Minneapolis & Plymouth - POWER RESTORED
Power outage - Corcoran, Hamel, Medina, Minneapolis & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 11:54 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:39 Time In : 11:39

Time Zone : CST

Duration : 16 hours, 0 mins

Number of Customers Affected : 2586

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN;
PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : branch

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 12:05 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 11:59 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:57 Time In : 11:55

Time Zone : CST

Duration : 15 hours, 58 mins

Number of Customers Affected : 1334

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : leaning pole / refered

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:43 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Plymouth & Wayzata - POWER RESTORED

Power outage - Plymouth & Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 12:17 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:44 Time In : 12:07

Time Zone : CST

Duration : 16 hours, 23 mins

Number of Customers Affected : 952

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:43 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 1:02 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 12:53

Time Zone : CST

Duration : 17 hours, 1 mins

Number of Customers Affected : 1249

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 1:50 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Plymouth - POWER RESTORED

Power outage - Minneapolis & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 1:28 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:39 Time In : 13:25

Time Zone : CST

Duration : 17 hours, 46 mins

Number of Customers Affected : 1846

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:02 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 1:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 13:31

Time Zone : CST

Duration : 17 hours, 39 mins

Number of Customers Affected : 4157

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:07 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 1:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 13:31

Time Zone : CST

Duration : 17 hours, 39 mins

Number of Customers Affected : 4157

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 2:06 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Columbia Heights, Fridley & Minneapolis - POWER RESTORED

Power outage - Columbia Heights, Fridley & Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 1:55 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:53 Time In : 13:51

Time Zone : CST

Duration : 17 hours, 58 mins

Number of Customers Affected : 1614

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Edina, Hopkins, Minneapolis & Saint Louis Park - POWER RESTORED
Power outage - Edina, Hopkins, Minneapolis & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 3:39 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:53 Time In : 14:51

Time Zone : CST

Duration : 18 hours, 58 mins

Number of Customers Affected : 39

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : # 2 opened closed

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:) Final Outage Notice - 6/21/13 - Saint Louis Park - POWER RESTORED
Power outage - Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 3:40 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:50 Time In : 15:09

Time Zone : CST

Duration : 19 hours, 19 mins

Number of Customers Affected : 1040

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:14 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Brooklyn Center, Minneapolis & Robbinsdale - POWER RESTORED
Power outage - Brooklyn Center, Minneapolis & Robbinsdale - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 3:41 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:50 Time In : 15:20

Time Zone : CST

Duration : 19 hours, 30 mins

Number of Customers Affected : 2200

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - POWER RESTORED
Power outage - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 8:53 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 08:50

Time Zone : CST

Duration : 12 hours, 58 mins

Number of Customers Affected : 2832

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 3:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:46 Time In : 15:17

Time Zone : CST

Duration : 19 hours, 31 mins

Number of Customers Affected : 151

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : none

Cause : Branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Long Lake, Maple Plain, Orono & Wayzata -
POWER RESTORED

Power outage - Long Lake, Maple Plain, Orono & Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 4:02 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:24 Time In : 08:14

Time Zone : CST

Duration : 11 hours, 50 mins

Number of Customers Affected : 1391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MAPLE PLAIN, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Wayzata - POWER RESTORED
Power outage - Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 4:49 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:43 Time In : 16:05

Time Zone : CST

Duration : 20 hours, 22 mins

Number of Customers Affected : 835

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Wayzata - POWER RESTORED
Power outage - Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 4:49 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:43 Time In : 16:05

Time Zone : CST

Duration : 20 hours, 22 mins

Number of Customers Affected : 835

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Burnsville & Savage - POWER RESTORED
Power outage - Burnsville & Savage - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 5:55 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:58 Time In : 17:50

Time Zone : CST

Duration : 21 hours, 52 mins

Number of Customers Affected : 1927

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers : none

Cause : branch

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley, Minneapolis & Robbinsdale -
POWER RESTORED

Power outage - Golden Valley, Minneapolis & Robbinsdale - power restored.

Wendy

From: Babb, Randall J
Sent: Saturday, June 22, 2013 6:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:51 Time In : 17:53

Time Zone : CST

Duration : 22 hours, 2 mins

Number of Customers Affected : 690

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm; tree contact.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 6:20 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:51 Time In : 18:03

Time Zone : CST

Duration : 22 hours, 12 mins

Number of Customers Affected : 156

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : broken poles

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis & Saint Louis Park -
POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 6:22 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 20:09 Time In : 17:56

Time Zone : CST

Duration : 21 hours, 47 mins

Number of Customers Affected : 2385

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley & Saint Louis Park -
POWER RESTORED

Power outage - Golden Valley & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 7:26 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:52 Time In : 19:21

Time Zone : CST

Duration : 23 hours, 29 mins

Number of Customers Affected : 29

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : lightning

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED
Power outage - Minnetonka, Plymouth, Wayzata & Woodland - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 8:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:45 Time In : 20:08

Time Zone : CST

Duration : 24 hours, 23 mins

Number of Customers Affected : 1328

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : none

Cause : tree

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minnetonka - POWER RESTORED
Power outage - Minnetonka - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 23, 2013 6:40 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:45 Time In : 19:55

Time Zone : CST

Duration : 24 hours, 10 mins

Number of Customers Affected : 1640

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley, Minneapolis & Saint Louis Park - POWER RESTORED

Power outage - Golden Valley, Minneapolis & Saint Louis Park - power restored.

Wendy

From: Babb, Randall J
Sent: Sunday, June 23, 2013 6:40 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 07:52 Time In : 08:30

Time Zone : CST

Duration : 24 hours, 38 mins

Number of Customers Affected : 491

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 11:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Deephaven, Minnetonka & Wayzata -
POWER RESTORED

Power outage - - Deephaven, Minnetonka & Wayzata - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 10:59 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:29 Time In : 10:57

Time Zone : CST

Duration : 7 hours, 28 mins

Number of Customers Affected : 917

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 23, 2013 6:43 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:49 Time In : 21:19

Time Zone : CST

Duration : 25 hours, 30 mins

Number of Customers Affected : 636

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6-23-13 - Saint Louis Park - POWER
RESTORED

Power outage - Saint Louis Park- power restored.

Wendy

From: Knutson, David A
Sent: Sunday, June 23, 2013 6:49 AM
To: dl Electric Outage MW Notification
Subject: 3) Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 04:51 Time In : 06:42

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 2660

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : branch on wires trouble man removed branch patrolled feeder rest of feeder okay

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Golden Valley & Minneapolis
Power outage - Golden Valley & Minneapolis.

Wendy

From: Babb, Randall J
Sent: Sunday, June 23, 2013 6:45 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 05:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2074

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unown ; Troubleman in route.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/23/13 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Sunday, June 23, 2013 7:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 05:47 Time In : 07:16

Time Zone : CST

Duration : 1 hours, 29 mins

Number of Customers Affected : 2073

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 23, 2013 4:19 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/23/2013
Time Out : 19:53 Time In : 14:55

Time Zone : CST

Duration : 43 hours, 2 mins

Number of Customers Affected : 2419

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : bad switch

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Babb, Randall J
Sent: Sunday, June 23, 2013 8:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/23/2013
Time Out : 22:39 Time In : 20:31

Time Zone : CST

Duration : 45 hours, 52 mins

Number of Customers Affected : 30

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/24/13 - Golden Valley & Minneapolis
Power outage - Golden Valley & Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Monday, June 24, 2013 4:01 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In :
Time Out : 03:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2073

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE OF FEEDER DOWN AND BURNING AT
,NEEDED TO OPEN FEEDER.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/24/13 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Monday, June 24, 2013 5:39 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In : 6/24/2013
Time Out : 03:59 Time In : 05:35

Time Zone : CST

Duration : 1 hours, 36 mins

Number of Customers Affected : 2073

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER TRBLMAN
REMOVED TREE

Follow-Up : PATROL FEEDER,REMOVED TREE,SWITCH TO RESTORE
POWER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/24/13 - Crystal, Golden Valley, Minneapolis,
New Hope & Plymouth
Power outage - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth.

Wendy

From: Hills, Thomas L
Sent: Monday, June 24, 2013 5:58 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In :
Time Out : 17:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3427

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/24/13 - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth - POWER RESTORED
Power outage - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth - power restored.

Wendy

From: Ayers, Patrick S
Sent: Monday, June 24, 2013 6:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In : 6/24/2013
Time Out : 17:52 Time In : 18:41

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 3427

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : CUTOUT BROKE WHILE CLOSING
.THIS WAS ON

Follow-Up : REPLACED CUTOUT,CHECKED ON CREW,RESTORED POWER TO FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/24/13 - Hamel, Medina, Minneapolis,
Plymouth & Wayzata
Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata.

Wendy

From: Hills, Thomas L
Sent: Monday, June 24, 2013 11:06 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In :
Time Out : 23:01 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3331

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : TR 2 Lockout

Follow-Up : Operator on the way to check TR 2.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/24/13 - Hamel, Medina, Minneapolis,
Plymouth & Wayzata - POWER RESTORED
Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata - power restored.

Wendy

From: Hills, Thomas L
Sent: Tuesday, June 25, 2013 12:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In : 6/25/2013
Time Out : 23:01 Time In : 00:11

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 3331

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Lockout and BKR Relay Malfunction.

Follow-Up : Isolated BKR. Restored using 69KV TR 1.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 2:35 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/25/13 - Crystal, New Hope & Plymouth
Power outage - Crystal, New Hope & Plymouth.

Wendy

From: Cedar, Daren A
Sent: Tuesday, June 25, 2013 2:26 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In :
Time Out : 14:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1160

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TROUBLE IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 3:14 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/25/13 - Crystal, New Hope & Plymouth -
POWER RESTORED
Power outage - Crystal, New Hope & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, June 25, 2013 3:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In : 6/25/2013
Time Out : 14:13 Time In : 15:04

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 1160

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : 200 K fault

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 3:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 03:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1561

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BUSS 2 LOCK AT SUB

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 3:44 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 03:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2076

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : UNKNOWN AT TIME

Cause : BUSS #2 LOCKOUT AT SUB

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 4:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 03:32 Time In : 04:45

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 1561

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT TIME,BUSS LOCK AT SUB ON BUSS

SECTION 2

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 4:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 03:32 Time In : 04:46

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 2076

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME .BUSS LOCK AT BUSS SECTION#2

Follow-Up : RESTORED POWER VIA SWITCHING

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 11:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Edina
Power outage - Edina.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 26, 2013 11:11 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 11:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 28

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : in route

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 11:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/26/13 - Edina - POWER RESTORED
Power outage - Edina - power restored.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 26, 2013 11:50 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 11:03 Time In : 11:31

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 2

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : bad cable to tie

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 12:40 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Edina - POWER RESTORED/UPDATE
Power outage - Edina - power restored/update.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 26, 2013 11:53 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In : 6/25/2013
Time Out : 11:03 Time In : 11:38

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 26

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : bad cable to tie

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 12:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Edina - POWER RESTORED/UPDATE - DATE CORRECTION

Power outage - Edina - power restored/update - date correction.

Wendy

From: Cedar, Daren A
Sent: Wednesday, June 26, 2013 12:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 11:03 Time In : 11:38

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 2

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : none

Cause : bad cable to tie

Follow-Up : date correction

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 4:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Coon Rapids & Fridley
Power outage - Coon Rapids & Fridley.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, June 26, 2013 4:27 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 16:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1063

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 5:13 PM
To: 'staff, cao (PUC)'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Coon Rapids & Fridley - POWER RESTORED/UPDATE
Power outage - Coon Rapids & Fridley - power restored/update.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 26, 2013 5:12 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 16:18 Time In : 17:04

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1063

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : TREE TRIMMER MISTAKE, NO ONE INJURED.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 26, 2013 5:00 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Coon Rapids & Fridley - POWER RESTORED

Power outage - Coon Rapids & Fridley - power restored.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, June 26, 2013 4:28 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 16:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1912

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Coon Rapids & Fridley - POWER RESTORED/UPDATE
Power outage - Coon Rapids & Woodbury - power restored/update.

Wendy

From: Aspinwall, David P
Sent: Wednesday, June 26, 2013 5:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 6/26/2013	Date In : 6/26/2013
Time Out : 16:18	Time In : 17:05

Time Zone : CST
Duration : 0 hours, 47 mins
Number of Customers Affected : 1912
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369
Communities Affected : COON RAPIDS, MN; FRIDLEY, MN
State : MN - Minnesota
Major Customers :
Cause : TREE TRIMMER MISTAKE, NO ONE INJURED.
Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/26/13 - Minneapolis & Saint Louis Park
Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 9:01 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In :
Time Out : 19:54 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2381

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : RESTORING FEEDER TO NORMAL IN FIELD AND C PHASE
DEAD.

Follow-Up : SWITCHED TO RETURN POWER.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 27, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/26/13 - Minneapolis & Saint Louis Park -
POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, June 26, 2013 9:03 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/26/2013 Date In : 6/26/2013
Time Out : 19:54 Time In : 20:17

Time Zone : CST

Duration : 0 hours, 23 mins

Number of Customers Affected : 2381

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE DEAD OUT OF BKR,CUST. OUT ON C PHASE

Follow-Up : RETURNED BACK AS WAS WITH BKR
SWITCHED OUT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/28/13 - Edina & Minnetonka
Power outage - Edina & Minnetonka.

Wendy

From: Hills, Thomas L
Sent: Friday, June 28, 2013 2:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/28/2013 Date In :
Time Out : 02:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 651

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 28, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/28/13 - Edina & Minnetonka - POWER RESTORED
Power outage - Edina & Minnetonka - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, June 28, 2013 4:30 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/28/2013 Date In : 6/28/2013
Time Out : 02:32 Time In : 04:00

Time Zone : CST

Duration : 1 hours, 28 mins

Number of Customers Affected : 651

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : BAD HEAD END CABLE .EDA SUB TO

Follow-Up : SWITCHED TO RESTORE POWER.NOTE- BKR WOULD
NOT OPERATE AT SUB RELAY OR BKR ISSUES.REFERRED TO BKR/RELAY.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 25, 2013 1:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/25/13 - Hopkins & Minnetonka
Power outage - Hopkins & Minnetonka.

Wendy

From: Kittock, Joseph C
Sent: Tuesday, June 25, 2013 1:39 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In :
Time Out : 13:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1507

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 03, 2013 3:16 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/25/13 - Hopkins & Minnetonka - POWER RESTORED

Sorry for the delay...

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Lund, Lisa M
Sent: Wednesday, July 03, 2013 2:48 PM
To: Jaede, Wendy L; Lund, Lisa M
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2013 Date In : 6/25/2013
Time Out : 13:29 Time In : 17:10

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 455

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed head end cable.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 12:19 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/20/13 -
Glenwood, Villard & Westport
Power outage - Glenwood, Villard & Westport.

Wendy

From: Peterson, Mark S
Sent: Thursday, June 20, 2013 11:15 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/20/2013 Date In :
Time Out : 11:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 370

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; VILLARD, MN; WESTPORT, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN CREW IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 20, 2013 12:26 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/20/13 -
Glenwood, Villard & Westport - POWER RESTORED
Power outage - Glenwood, Villard & Westport - power restored.

Wendy

From: Kaveny, Michael J
Sent: Thursday, June 20, 2013 12:24 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/20/2013 Date In : 6/20/2013
Time Out : 11:08 Time In : 12:20

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 370

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; VILLARD, MN; WESTPORT, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event, restored at 1205, restored at 1220.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Glenwood, Lowry & Starbuck - POWER RESTORED

Power outage - Glenwood & Starbuck - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 8:24 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 01:17 Time In : 07:35

Time Zone : CST

Duration : 6 hours, 18 mins

Number of Customers Affected : 1152

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HIGH SIDE FUSE BLOWN ON TX IN SUB. BREAKER FAILED TO OPEN WHEN FEEDER SLAPPED TOGETHER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 3:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Osakis - UPDATE
Power outage - Osakis - update (power not restored).

Wendy

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 3:58 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Osakis - POWER RESTORED

Power outage - Osakis - power restored.

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 3:54 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1028

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : OSAKIS, MN

State : MN - Minnesota

Major Customers : none

Cause : feeder found open on non rtu sub. lots of storm damage.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Cold Spring, Rockville, Saint Cloud, Saint Joseph & Waite Park - POWER RESTORED
Power outage - Cold Spring, Rockville, Saint Cloud, Saint Joseph & Waite Park - POWER RESTORED.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:56 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:39 Time In : 02:52

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 635

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COLD SPRING, MN; ROCKVILLE, MN; SAINT CLOUD, MN; SAINT JOSEPH, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud & Waite Park
Power outage - Saint Cloud & Waite Park

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:41 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4141

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Saint Cloud & Waite Park - POWER RESTORED

Power outage - Saint Cloud & Waite Park - power restored.

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 6:27 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:41 Time In : 06:16

Time Zone : CST

Duration : 3 hours, 35 mins

Number of Customers Affected : 4141

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCHES ON LINE. CREW CLEARED UP AND ENERGIZED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud
Power outage - Saint Cloud

Wendy

From: Vorachek, Kelly
Sent: Friday, June 21, 2013 4:15 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2743

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : - T-Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 10:26 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:41 Time In : 10:11

Time Zone : CST

Duration : 7 hours, 30 mins

Number of Customers Affected : 2743

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : STORM MULTIPLE TREES ON LINE 1675 CUSTOMERS
RESTORED @10:11 1068 STILL OUT UNTIL CREW MAKES REPAIRS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud & Sauk Rapids
Power outage - Saint Cloud & Sauk Rapids

Wendy

From: Vorachek, Kelly
Sent: Friday, June 21, 2013 4:45 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1544

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Cause Unknown T-Storm, will patrol ASAP

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/21/13 - Saint Cloud & Sauk Rapids -
POWER RESTORED

Power outage - Saint Cloud & Sauk Rapids - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 5:46 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:43 Time In : 17:38

Time Zone : CST

Duration : 14 hours, 55 mins

Number of Customers Affected : 1544

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : storm damage

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:14 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Foley, Saint Cloud & Sauk Rapids
Power outage - Foley, Saint Cloud & Sauk Rapids.

Wendy

From: Vorachek, Kelly
Sent: Friday, June 21, 2013 4:54 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2716

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOLEY, MN; SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : - Cause unknown, T-Storm / will patrol ASAP

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 9:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Foley, Saint Cloud & Sauk Rapids -
POWER RESTORED
Power outage - Foley, Saint Cloud & Sauk Rapids - POWER RESTORED

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 8:06 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:44 Time In : 07:49

Time Zone : CST

Duration : 5 hours, 5 mins

Number of Customers Affected : 2716

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOLEY, MN; SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : STORM IN AREA 2504 CUSTOMERS RESTORED @ 07:49
CREW STILL PATROLLING BEYOND THE 3 SWITCH 212 CUSTOMERS STILL OUT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 1:30 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 6/21/13 - Foley, Saint Cloud & Sauk Rapids -
POWER RESTORED

Power outage - Foley, Saint Cloud & Sauk Rapids - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 12:32 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:44 Time In : 12:29

Time Zone : CST

Duration : 9 hours, 45 mins

Number of Customers Affected : 2716

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FOLEY, MN; SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : REMAINING 212 CUSTOMERS RESTORED @ 12:29

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW:
First Outage Notice - 6/21/13 - Albany, Avon, Collegeville & Saint Joseph
Power outage - Albany, Avon, Collegeville & Saint Joseph.

Wendy

From: Vorachek, Kelly
Sent: Friday, June 21, 2013 4:01 AM
To: dl Electric Outage NT Notification
Subject: Notice First Outage

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2687

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION EVENT - MAJOR STORM - BEING PATROLLED NOW

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW:
Second Outage Notice - 6/21/13 - Albany, Avon, Collegeville & Saint Joseph - POWER RESTORED
Power outage - Albany, Avon, Collegeville & Saint Joseph - power restored.

Wendy

From: Vorachek, Kelly
Sent: Friday, June 21, 2013 4:23 AM
To: dl Electric Outage NT Notification
Subject: Notice Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:44 Time In : 04:10

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 2687

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission Event / T-Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 2:13 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Freeport, Melrose & New Munich
Power outage - Freeport, Melrose & New Munich.

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 1:44 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 287

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FREEPORT, MN; MELROSE, MN; NEW MUNICH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : NON RTU SUB FOUND BREAKER OPEN. BROKEN
TRANSMISSION POLES WITH UNDERBUILD.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Albany & Avon
Power outage - Albany & Avon.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:18 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1021

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Albany & Avon - POWER RESTORED
Power outage - Albany & Avon - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 9:44 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:06 Time In : 09:35

Time Zone : CST

Duration : 6 hours, 29 mins

Number of Customers Affected : 1021

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON LINE OUTSIDE SUB DUE TO STORM IN AREA

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:13 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Clear Lake, Clearwater & Saint Cloud
Power outage - Clear Lake, Clearwater & Saint Cloud

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:50 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4550

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEAR LAKE, MN; CLEARWATER, MN; SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 10:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/13 - Clear Lake, Clearwater & Saint Cloud -
POWER RESTORED

Power outage - Clear Lake, Clearwater & Saint Cloud - power restored.

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 10:55 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:21 Time In : 09:49

Time Zone : CST

Duration : 6 hours, 28 mins

Number of Customers Affected : 4550

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEAR LAKE, MN; CLEARWATER, MN; SAINT CLOUD,
MN

State : MN - Minnesota

Major Customers :

Cause : TREES DOWN ON FEEDER IN MULTIPLE AREAS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 8:14 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Cold Spring - POWER RESTORED
Power outage - Cold Spring - power restored.

Wendy

From: Peterson, Mark S
Sent: Saturday, June 22, 2013 8:06 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 03:36 Time In : 07:06

Time Zone : CST

Duration : 27 hours, 30 mins

Number of Customers Affected : 1969

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COLD SPRING, MN

State : MN - Minnesota

Major Customers : none

Cause : non rtu sub .Crew found high side fuse blown B phase on
. Crew refused and re-energized.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Becker, Clear Lake & Monticello
Power outage - Becker, Clear Lake & Monticello

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 6:56 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 06:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 18

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; CLEAR LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:57 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Becker, Clear Lake & Monticello - POWER RESTORED

Power outage - Becker, Clear Lake & Monticello - power restored.

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 7:52 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 06:20 Time In : 07:42

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 241

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; CLEAR LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : none

Cause : trees and wire down multiple areas

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Glenwood, Lowry & Starbuck
Power outage - Glenwood, Lowry & Starbuck.

Wendy

From: Vorachek, Kelly
Sent: Saturday, June 22, 2013 7:26 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 18:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1152

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - NON RTU SUB, Operator found Breaker open at SUB, suspect it went out 1800 last night by call pattern - found broken insulator being repaired now.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 9:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Glenwood, Lowry & Starbuck - POWER RESTORED

Power outage - Glenwood, Lowry & Starbuck - power restored.

Wendy

From: Vorachek, Kelly
Sent: Saturday, June 22, 2013 8:39 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 18:00 Time In : 08:21

Time Zone : CST

Duration : 14 hours, 21 mins

Number of Customers Affected : 1151

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Replace broken insulator and closed breaker at SUB @ 08:21

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Belgrade - POWER RESTORED
Power outage - Belgrade - power restored.

Wendy

From: Vorachek, Kelly
Sent: Sunday, June 23, 2013 6:22 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In : 6/23/2013
Time Out : 04:42 Time In : 05:45

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 451

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELGRADE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Phase from feeder laying on ground burning, crew opened breaker @
04:42 and Disconnects to isolate, restored breaker @ 04:57 restoring 218 customers - remaining 233
restored at 05:45

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:52 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/1/13 - Edgerton, Hatfield & Pipestone
Power outage - Edgerton, Hatfield & Pipestone.

Wendy

From: Chase, Julie B
Sent: Saturday, June 01, 2013 8:15 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In :
Time Out : 18:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 722

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN; HATFIELD, MN; PIPESTONE, MN

State : SD - South Dakota

Major Customers :

Cause : hi side tr fuse blown in substation, operator on site, non scada
sub.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:53 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/1/13 - Edgerton, Hatfield & Pipestone -
POWER RESTORED
Power outage - Edgerton, Hatfield & Pipestone - power restored.

Wendy

From: Chase, Julie B
Sent: Saturday, June 01, 2013 8:36 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In : 6/1/2013
Time Out : 18:13 Time In : 20:24

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 722

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN; HATFIELD, MN; PIPESTONE, MN

State : SD - South Dakota

Major Customers :

Cause : A phase 69kv fuse blown on TR #1. Possible bird contact on
A Phase regulator

Follow-Up : Refused 69kv fuse and re-energized TR restoring all customers

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 12, 2013 4:47 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/12/13 - Edgerton, Hatfield & Pipestone
Power outage - Edgerton, Hatfield & Pipestone.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, June 12, 2013 4:44 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In :
Time Out : 16:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 723

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN; HATFIELD, MN; PIPESTONE, MN

State : SD - South Dakota

Major Customers : None

Cause : Unknown, Non EMS Sub, calls indicate problem at Sub. Trouble and Operator En-
route.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 13, 2013 7:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/12/13 - Edgerton, Hatfield & Pipestone
- UPDATE
Power outage - Edgerton, Hatfield & Pipestone - update.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, June 12, 2013 5:55 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In :
Time Out : 16:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 723

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN; HATFIELD, MN; PIPESTONE, MN

State : SD - South Dakota

Major Customers : None

Cause : Trouble found A Phase Hi-Side Fuse blown at Sub. Visual check appears all ok.
Trouble will open Breakers, Working with TSO to isolate Sub and Re-fuse.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 13, 2013 7:27 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 6/12/13 - Edgerton, Hatfield & Pipestone -
POWER RESTORED
Power outage - Edgerton, Hatfield & Pipestone - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, June 12, 2013 7:02 PM
To: dl Electric Outage SD Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/12/2013 Date In : 6/12/2013
Time Out : 16:25 Time In : 18:53

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 723

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : EDGERTON, MN; HATFIELD, MN; PIPESTONE, MN

State : SD - South Dakota

Major Customers : None

Cause : Trouble found A Phase fuse blown on . Visible inspection found nothing abnormal, Sub operator found remains of bird nest in A Phase Reg Wildlife Protection. 100% Restored.

Follow-Up : Will submit EM&P Report.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/1/13 - Winona
Power outage - Winona.

Wendy

From: Chase, Julie B
Sent: Saturday, June 01, 2013 7:29 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In :
Time Out : 19:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3214

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : WINONA, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 03, 2013 8:50 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/1/13 - Winona - POWER RESTORED
Power outage - Winona - power restored.

Wendy

From: Chase, Julie B
Sent: Saturday, June 01, 2013 11:04 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/1/2013 Date In : 6/1/2013
Time Out : 19:12 Time In : 23:02

Time Zone : CST

Duration : 3 hours, 50 mins

Number of Customers Affected : 3214

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : WINONA, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : Transformer Breakers in sub will not operate via SCADA or Locally. Field switched feeders in.

1056 cust restored at 2240, 190 cust restored at 2249

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 07, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/7/13 - Mankato
Power outage - Mankato

Wendy

From: Chase, Julie B
Sent: Friday, June 07, 2013 8:26 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/7/2013 Date In : 6/7/2013
Time Out : 08:11 Time In : 08:18

Time Zone : CST

Duration : 0 hours, 7 mins

Number of Customers Affected : 1644

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : , accidental line contact by Xcel Energy crew

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 07, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/7/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, June 07, 2013 8:29 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/7/2013 Date In : 6/7/2013
Time Out : 08:11 Time In : 08:18

Time Zone : CST

Duration : 0 hours, 7 mins

Number of Customers Affected : 1644

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : accidental line contact by Xcel Energy crew

Follow-Up : no injuries reported

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:30 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/8/2013 Faribault
Power Outage- Faribault

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Saturday, June 08, 2013 14:12
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/8/2013 Date In :
Time Out : 14:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1081

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers :

Cause : crews to be called in

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, June 10, 2013 1:46 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Power Restored 6/8/2013 Faribault

Power Restored-
FARIBAULT, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (651) 639-4322

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Saturday, June 08, 2013 16:10
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/8/2013 Date In : 6/8/2013
Time Out : 14:07 Time In : 16:00

Time Zone : CST

Duration : 1 hours, 53 mins

Number of Customers Affected : 1081

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : faulted cable between and

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Mankato
Power outage - Mankato

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:21 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 04:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1900

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, June 21, 2013 7:09 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 04:17 Time In : 06:51

Time Zone : CST

Duration : 2 hours, 34 mins

Number of Customers Affected : 1899

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : SEVERAL TREES ON LINE CREW CLEARED 100% RESTORED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:08 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Elko New Market, Elko, Jordan, Prior Lake, Shakopee & Webster
Power outage - Elko New Market, Elko, Jordan, Prior Lake, Shakopee & Webster.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 7:48 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5200

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; JORDAN, MN; PRIOR LAKE, MN;
SHAKOPEE, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Elko
New Market, Elko, Jordan, Prior Lake, Shakopee & Webster - POWER RESTORED
Power outage - Elko New Market, Elko, Jordan, Prior Lake, Shakopee & Webster - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 9:06 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 19:37 Time In : 20:55

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 5200

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; JORDAN, MN; PRIOR LAKE, MN;
SHAKOPEE, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Jordan, Prior Lake & Shakopee
Shakopee
Power outage - Jordan, Prior Lake & Shakopee.
Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 9:31 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4281

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : JORDAN, MN; PRIOR LAKE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers :

Cause : storm damage

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Jordan, Prior Lake
& Shakopee - POWER RESTORED
Power outage -- Jordan, Prior Lake & Shakopee - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 9:45 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 20:55 Time In : 21:31

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 4281

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : JORDAN, MN; PRIOR LAKE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers :

Cause : storms

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minnetonka & Wayzata
Power outage - Minnetonka & Wayzata

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 5:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1608

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:24 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Minnetonka, Plymouth, Wayzata & Woodland
Power outage - Minnetonka, Plymouth, Wayzata & Woodland.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 5:42 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1326

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:09 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Crystal Bay, Long Lake, Orono & Wayzata
Power outage - Crystal Bay, Long Lake, Orono & Wayzata.

Wendy

From: Babb, Randall J
Sent: Friday, June 21, 2013 8:33 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1287

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Long Lake, Minnetonka, Orono,
Plymouth & Wayzata
Power outage - Long Lake, Minnetonka, Orono, Plymouth & Wayzata.

Wendy

From: Babb, Randall J
Sent: Friday, June 21, 2013 9:19 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1435

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 3:11 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/22/13 - Minneapolis & Plymouth
Power outage - Minneapolis & Plymouth.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 3:01 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 14:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1846

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:52 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Crystal, Golden Valley, New Hope & Robbinsdale
Power outage - Crystal, Golden Valley, New Hope & Robbinsdale.

Wendy

From: Ayers, Patrick S
Sent: Friday, June 21, 2013 7:40 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 07:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1743

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN;
ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : UNKNOWN

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 12:48 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Golden Valley
Power outage - Golden Valley

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 11:03 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 10:54 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 668

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minnetrista, Mound, Shorewood & Spring Park
Power outage - Minnetrista, Mound, Shorewood & Spring Park.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 7:31 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2336

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,
MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW:) First Outage Notice - 6/21/13 - Albany & Avon
Power outage - Albany & Avon

Wendy

From: Peterson, Mark S
Sent: Friday, June 21, 2013 6:00 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 05:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1021

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN

State : MN - Minnesota

Major Customers :

Cause : locked out storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/24/13 - Golden Valley & Minneapolis
Power outage - Golden Valley & Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Monday, June 24, 2013 3:57 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/24/2013 Date In :
Time Out : 03:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2073

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE FEEDER DOWN AT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 9:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 4:47 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/22/2013
Time Out : 19:51 Time In : 16:30

Time Zone : CST

Duration : 20 hours, 39 mins

Number of Customers Affected : 3590

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Edina & Richfield
Power outage - Edina & Richfield

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:26 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 981

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:32 AM
To: 'staff, cao (PUC)'; dl Customer Advocate Team
Cc: 'staff, cao (PUC)'
Subject: FW: First Outage Notice - 6/21/13 - Edina, Minneapolis & Richfield
Power outage - Edina, Minneapolis & Richfield.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:22 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2770

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:22 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis & Plymouth
Power outage - Minneapolis & Plymouth.

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 5:41 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2569

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Plymouth
Power outage - Plymouth

Wendy

From: Knutson, David A
Sent: Sunday, June 23, 2013 8:11 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1478

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : trees

Follow-Up : trouble working on now somehow got missed never upgraded to feeder lock

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Roseville
Power outage - Roseville.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:27 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1981

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEVILLE, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Red Wing
Power outage - Red Wing

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:39 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 04:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1987

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:06 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Friday, June 21, 2013 6:59 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 18:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2391

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS TIME, TROUBLE IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 24, 2013 9:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:) First Outage Notice - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, June 23, 2013 4:18 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 15:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1801

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown

Follow-Up : will find and repair asap

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:22 AM
To: 'staff, cao (PUC)'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Falcon Heights, Roseville & Saint Paul
Power outage - Falcon Heights, Roseville & Saint Paul.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:11 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1421

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/21/13 - Falcon Heights, Roseville & Saint Paul - UPDATE
Power outage - Falcon Heights, Roseville & Saint Paul - Update.

Wendy

From: LaCasse, Joseph S
Sent: Saturday, June 22, 2013 9:48 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 19:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1421

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees on feeder and wire down @ .

Follow-Up : Partial restoration:
Restored 1199 customers @ 08:32. Referred to Tree and Const.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 22, 2013 7:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Arden Hills & Roseville
Power outage - Arden Hills & Roseville.

Wendy

From: LaCasse, Joseph S
Sent: Friday, June 21, 2013 10:05 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 20:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 645

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; ROSEVILLE, MN

State : MN - Minnesota

Major Customers : None.

Cause : Storm in area.

Follow-Up : To be patrolled.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud, Saint Joseph, Sartell & Waite Park
Power outage - Saint Cloud, Saint Joseph, Sartell & Waite Park.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:55 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1771

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAINT JOSEPH, MN; SARTELL, MN; WAITE PARK,
MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/22/13 - Fort Snelling & Minneapolis
Power outage - Fort Snelling & Minneapolis

Wendy

From: Peterson, Kenneth W
Sent: Saturday, June 22, 2013 7:55 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 19:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1454

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FORT SNELLING, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 11:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/23/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 23, 2013 11:31 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/23/2013 Date In :
Time Out : 11:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1545

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : clear for construction

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:36 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Minneapolis
Power outage - Minneapolis

Wendy

From: Peterson, Kenneth W
Sent: Friday, June 21, 2013 6:27 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 03:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3378

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Sunday, June 23, 2013 10:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/22/13 - Saint Paul, South Saint Paul & West Saint Paul
Power outage - Saint Paul, South Saint Paul & West Saint Paul.

Wendy

From: Wolf, Terry K
Sent: Saturday, June 22, 2013 9:12 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/22/2013 Date In :
Time Out : 21:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3261

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up : patrol

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud & Sauk Rapids
Power outage - Saint Cloud & Sauk Rapids.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:32 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 03:04 Time In : 03:10

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 3218

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud, Sauk Rapids & Waite Park
Power outage - Saint Cloud, Sauk Rapids & Waite Park.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 3:24 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In :
Time Out : 02:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 9345

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : weather events affecting feeders in the St. Cloud/Paynesville/Albany area
more details to be forthcoming

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 21, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/21/13 - Saint Cloud, Sauk Rapids & Waite Park - POWER RESTORED
Power outage - Saint Cloud, Sauk Rapids & Waite Park - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, June 21, 2013 4:27 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/21/2013 Date In : 6/21/2013
Time Out : 02:43 Time In : 02:52

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 9345

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Inver Grove Heights, Inver Grove & South Saint Paul
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul,

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 8:31 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 08:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : storm

Cause : unknown

Follow-Up : will patrol

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 9:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/9/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 9:24 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:27 Time In : 09:15

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree on feeder

Follow-Up : called crew to remove large tree

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 10:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 7/9/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED/UPDATE
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored/update.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 10:27 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:27 Time In : 09:15

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree on feeder 80% in tree crew is working on it

Follow-Up : no

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 11:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/9/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED/UPDATE
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored/update.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 11:41 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:27 Time In : 09:15

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : TREE FELL ON FEEDER

Follow-Up : RESTORED 100%11:15

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 12:04 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - TREE REPORT
Attachments: photo.jpg; photo.JPG; photo.jpg; 20130711103629.pdf
FYI...Tree Report

From: Weidenfeller, Bradley M
Sent: Monday, July 15, 2013 11:44 AM
To: dl Electric Outage ME Notification
Cc: Brown, Ann C; Johnson, Fletcher L
Subject: RE: Final Outage Notice

Ash 25 foot from line
10" co-dominate section failed
Strong winds and storms
Non-preventable

Brad Weidenfeller
Xcel Energy | Responsible By Nature
Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369
P: 763-493-1827 C: 320-250-2541 F: 763-493-1840
E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 11:41 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:27 Time In : 09:15

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2194

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : TREE FELL ON FEEDER

Follow-Up : RESTORED 100%11:15

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/7/13 - Birchwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, Saint Paul, White Bear Lake & White Bear LK - POWER RESTORED

Power outage - Birchwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, Saint Paul, White Bear Lake & White Bear LK.

Wendy

From: Chial, Terry L
Sent: Sunday, July 07, 2013 7:35 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/7/2013 Date In : 7/7/2013
Time Out : 18:59 Time In : 19:15

Time Zone : CST

Duration : 0 hours, 16 mins

Number of Customers Affected : 3427

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BIRCHWOOD, MN; LAKE ELMO, MN; MAHTOMEDI, MN;
MAPLEWOOD, MN; OAKDALE, MN; PINE SPRINGS, MN; SAINT PAUL, MN; WHITE BEAR
LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : trees earlier i sent alert for disregard it is

Follow-Up : clearig up

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/7/13 - Birchwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, Saint Paul, White Bear Lake & White Bear LK - POWER RESTORED/UPDATE

Power outage - Birchwood, Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs, Saint Paul, White Bear Lake & White Bear LK - power restored/update.

Wendy

From: Chial, Terry L
Sent: Sunday, July 07, 2013 8:14 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/7/2013 Date In : 7/7/2013
Time Out : 18:59 Time In : 19:25

Time Zone : CST

Duration : 0 hours, 26 mins

Number of Customers Affected : 3427

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BIRCHWOOD, MN; LAKE ELMO, MN; MAHTOMEDI, MN;
MAPLEWOOD, MN; OAKDALE, MN; PINE SPRINGS, MN; SAINT PAUL, MN; WHITE BEAR
LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : tree fell took down feeder at was carrying

Follow-Up : will repair tonight

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 10:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7-9-13 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 10:44 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 10:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up : WORKING ON IT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 11:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7-9-13 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - POWER RESTORED

Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 11:18 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 10:37 Time In : 11:08

Time Zone : CST

Duration : 0 hours, 31 mins

Number of Customers Affected : 1807

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : PHASE BURNED DOWN AT

Follow-Up : WILL REPAIR ASAP

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 11:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Eagan
Power outage - Eagan.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 11:39 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 11:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up : WILL RESPONED ASAP

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 12:51 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/9/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, July 09, 2013 12:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 11:23 Time In : 12:05

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : BLOWN CABLE

Follow-Up : REFERED TO

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/12/13 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul
Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul.

Wendy

From: Chial, Terry L
Sent: Friday, July 12, 2013 4:02 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/12/2013 Date In :
Time Out : 16:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1708

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : UNKNOWN AT THIS TIME

Follow-Up : WILL RESPONED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/12/13 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - UPDATE
Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - update.

Wendy

From: Chial, Terry L
Sent: Friday, July 12, 2013 4:56 PM
To: dl Electric Outage ME Notification
Subject: RLK-ROGERS LAKE (069) Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/12/2013 Date In :
Time Out : 16:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1708

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : STILL PATROLLING FEEDER

Follow-Up : NO

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 11:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice-Tree Report - 7/12/13
Attachments: .jpg
FYI...Tree report.

Wendy

From: Weidenfeller, Bradley M
Sent: Friday, July 19, 2013 11:43 AM
To: dl Electric Outage ME Notification
Cc: Johnson, Fletcher L
Subject: FW: Final Outage Notice-Tree Report

Dead pine fell into elm pushing into feeder.
Last trim date 3-20-2009 next planned work 2014.
Strong winds
Non-preventable

Brad Weidenfeller
Xcel Energy | Responsible By Nature
Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369
P: 763-493-1827 C: 320-250-2541 F: 763-493-1840
E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Friday, July 12, 2013 5:35 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/12/2013 Date In : 7/12/2013
Time Out : 16:00 Time In : 17:31

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 1708

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : TREE FELL ACROSS FEEDER AT

Follow-Up : CLEARED BY TMAN AND REENERGIZED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:) Final Outage Notice - 7/12/13 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Friday, July 12, 2013 5:35 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/12/2013 Date In : 7/12/2013
Time Out : 16:00 Time In : 17:31

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 1708

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : TREE FELL ACROSS FEEDER AT

Follow-Up : CLEARED BY TMAN AND REENERGIZED.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:06 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/14/13 - Newport
Power outage - Newport.

Wendy

From: Driscoll, Paul M
Sent: Sunday, July 14, 2013 8:03 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/14/2013 Date In :
Time Out : 19:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 51

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown.This is one of our 5 feeders going to ..The
other 4 feeders look fine...

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:06 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice -- 7/14/13 - Newport - POWER RESTORED
Power outage - Newport - power restored.

Wendy

From: Driscoll, Paul M
Sent: Sunday, July 14, 2013 10:05 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/14/2013 Date In : 7/14/2013
Time Out : 19:49 Time In : 21:36

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 51

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers :

Cause : Feeder cable failed from ..

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 4:07 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Eagan
Power outage - Eagan.

Wendy

From: Chial, Terry L
Sent: Wednesday, July 17, 2013 3:17 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 15:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : will patrol

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 4:07 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/17/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Chial, Terry L
Sent: Wednesday, July 17, 2013 4:00 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In : 7/17/2013
Time Out : 15:10 Time In : 15:57

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : HEAD END CABLE SUB TO

Follow-Up : WILL MAKE REPAIRS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/18/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Gilland, William P
Sent: Thursday, July 18, 2013 7:24 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/18/2013 Date In :
Time Out : 19:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3339

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 7/18/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Thursday, July 18, 2013 7:54 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/18/2013 Date In : 7/18/2013
Time Out : 19:17 Time In : 19:46

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 3339

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : Head end cable failure in ductwork

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Chial, Terry L
Sent: Wednesday, July 17, 2013 11:43 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 23:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 997

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown

Follow-Up : on route

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/18/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Thursday, July 18, 2013 12:07 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2013 Date In : 7/18/2013
Time Out : 23:36 Time In : 23:52

Time Zone : CST

Duration : 0 hours, 16 mins

Number of Customers Affected : 997

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : MISO

Cause : BAD CABLE

Follow-Up : REFERED TO AND REPAIR .

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/18/13 - Lake Elmo, Maplewood & Oakdale
Power outage - Lake Elmo, Maplewood & Oakdale.

Wendy

From: Chial, Terry L
Sent: Friday, July 19, 2013 1:50 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/19/2013 Date In :
Time Out : 01:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2311

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : responding

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/19/13 - Lake Elmo, Maplewood & Oakdale - DATE
CORRECTION

Power outage - Lake Elmo, Maplewood & Oakdale - date correction.

Wendy

From: Chial, Terry L
Sent: Friday, July 19, 2013 1:50 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/19/2013 Date In :
Time Out : 01:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2311

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : responding

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 19, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/19/13 - Lake Elmo, Maplewood & Oakdale -
POWER RESTORED

Power outage - Lake Elmo, Maplewood & Oakdale - power restored.

Wendy

From: Chial, Terry L
Sent: Friday, July 19, 2013 3:33 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/19/2013 Date In : 7/19/2013
Time Out : 01:40 Time In : 02:27

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 2311

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers :

Cause : tree branch at

Follow-Up : remove tree and restored feeder

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:38 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Falcon Heights, Roseville, Saint Paul
Power outage - Falcon Heights, Roseville, Saint Paul .

Wendy

From: Gilland, William P
Sent: Saturday, July 20, 2013 8:09 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/20/2013 Date In :
Time Out : 20:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 855

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:39 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/20/13 - Falcon Heights, Roseville, Saint Paul
- POWER RESTORED

Power outage - Falcon Heights, Roseville, Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Saturday, July 20, 2013 9:23 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/20/2013 Date In : 7/20/2013
Time Out : 20:04 Time In : 20:55

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 855

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

MN

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL,

State : MN - Minnesota

Major Customers :

Cause : 200e's flashed over in

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:46 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/22/13 - North Oaks, Shoreview, Vadnais Heights & White Bear Lake

Power outage -- North Oaks, Shoreview, Vadnais Heights & White Bear Lake.

Wendy

From: Abbott, Edward J
Sent: Monday, July 22, 2013 2:02 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In :
Time Out : 01:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1372

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up : PATROLING FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:47 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/22/13 - North Oaks, Shoreview, Vadnais Heights & White Bear Lake - UPDATE
Power outage - North Oaks, Shoreview, Vadnais Heights & White Bear Lake - update.

Wendy

From: Abbott, Edward J
Sent: Monday, July 22, 2013 2:41 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In :
Time Out : 01:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1372

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON LINR ON
TROUBLE TO CLEAR TREE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:48 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/22/13 - North Oaks, Shoreview, Vadnais Heights & White Bear Lake - POWER RESTORED

Power outage - North Oaks, Shoreview, Vadnais Heights & White Bear Lake - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, July 22, 2013 3:02 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In : 7/22/2013
Time Out : 01:53 Time In : 03:00

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1372

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON FEEDER WAS CLEARED BY TROUBLEMEN AND FEEDER BACK IN

Follow-Up : NO FURTHER WORK NEEDED

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:58 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0194.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Monday, July 22, 2013 12:53 PM
To: Abbott, Edward J; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-preventable
Large oak limb, 30ft from conductors, outside VM maintenance corridor, broke due to internal decay.
Limb looked healthy.
Last VM worked date, 2/25/2012

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Abbott, Edward J
Sent: Monday, July 22, 2013 3:02 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In : 7/22/2013
Time Out : 01:53 Time In : 03:00

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1372

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN; VADNAIS
HEIGHTS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON FEEDER WAS CLEARED BY TROUBLEMEN AND
FEEDER BACK IN

Follow-Up : NO FURTHER WORK NEEDED

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/23/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Tuesday, July 23, 2013 12:51 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In :
Time Out : 00:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : UNKNOWN

Follow-Up : TROUBLE TO PATROL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/23/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Tuesday, July 23, 2013 1:51 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In :
Time Out : 00:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TROUBLEMAN PATROLLING FEEDER, HAD TO COME FROM
HASTINGS WERE HE WAS WORKING ON LARGE OUTAGE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 7/23/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Tuesday, July 23, 2013 1:59 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In :
Time Out : 00:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : CLEAR UP TO THE SWITCH. OPENED THE
AND BKR IN AT SUB PICKING UP 1400 CUSTOMERS. TROUBLE TO PATROL THE
FEEDER BEHIND THE FOR PROBLEM.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/23/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, July 23, 2013 3:31 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In : 7/23/2013
Time Out : 00:43 Time In : 03:23

Time Zone : CST

Duration : 2 hours, 40 mins

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : POSSIBLE BAD URD FEEDER CABLE AT END OF FEEDER.
OPENED IS LOCATED AND
SWITCH GEAR AUTO TRANSFERRED SO EVERYONE BACK IN

Follow-Up : REFERRED TO HAVE RELAY BIDDLE THAT PEICE OF
FEEDER CABLE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Minnetonka, Plymouth, Wayzata & Woodland
Power outage - Minnetonka, Plymouth, Wayzata & Woodland.

Wendy

From: Schwarz, John W
Sent: Tuesday, July 09, 2013 8:05 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 08:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1327

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 10, 2013 3:11 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, July 10, 2013 2:58 PM
To: Babb, Randall J; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable
Unable to locate limb
Based on Troubleman comments it was a broken limb from within the maintenance zone
Last worked 2/2009

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Babb, Randall J
Sent: Tuesday, July 09, 2013 9:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013	Date In : 7/9/2013
Time Out : 08:03	Time In : 09:02

Time Zone : CST

Duration : 0 hours, 59 mins

3/25/2014

Number of Customers Affected : 1327

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact.

Follow-Up : Troublemaker removed branch and patrolled complete feeder line.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 9:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/9/13 - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED

Power outage - Minnetonka, Plymouth, Wayzata & Woodland - power restored.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 09, 2013 9:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:03 Time In : 09:02

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1327

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact.

Follow-Up : Troublemaker removed branch and patrolled complete feeder line.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Burnsville
Power outage - Burnsville.

Wendy

From: Schwarz, John W
Sent: Tuesday, July 09, 2013 8:23 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 08:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1091

For information about this alert, contact :
For follow-up information or questions, contact : Paul (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 10:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/9/13 - Burnsville - POWER RESTORED
Power outage - Burnsville - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, July 09, 2013 10:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:22 Time In : 10:12

Time Zone : CST

Duration : 1 hours, 50 mins

Number of Customers Affected : 1091

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : lightning

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Long Lake, Minnetonka, Orono,
Plymouth & Wayzata
Power outage - Long Lake, Minnetonka, Orono, Plymouth & Wayzata.

Wendy

From: Schwarz, John W
Sent: Tuesday, July 09, 2013 8:21 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 08:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1434

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 3:11 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0420.jpg
FYI...tree report!

Wendy

From: Loiselle, Christopher D
Sent: Tuesday, July 09, 2013 2:35 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable
Boxelder trunk broke at limb union
No visible decay present
Last VM date 10/2009

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, July 09, 2013 10:43 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013

Date In : 7/9/2013

Time Out : 08:19

Time In : 10:37

Time Zone : CST

Duration : 2 hours, 18 mins

3/25/2014

Number of Customers Affected : 1434

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE REMOVER FROM THE FEEDER @ . 100% RESTORED
@ 10:37 A.M.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 10:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7-9-13 - Long Lake, Minnetonka, Orono,
Plymouth & Wayzata - POWER RESTORED
Power outage - Long Lake, Minnetonka, Orono, Plymouth & Wayzata - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, July 09, 2013 10:43 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 08:19 Time In : 10:37

Time Zone : CST

Duration : 2 hours, 18 mins

Number of Customers Affected : 1434

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LONG LAKE, MN; MINNETONKA, MN; ORONO, MN; PLYMOUTH, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE REMOVER FROM THE FEEDER @ 100% RESTORED
@ 10:37 A.M.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/11/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Aspinwall, David P
Sent: Thursday, July 11, 2013 2:17 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In :
Time Out : 02:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1829

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : UNKNOWN AT THIS TIME.

Follow-Up : WORKING ON IT.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/11/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Aspinwall, David P
Sent: Thursday, July 11, 2013 3:23 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In : 7/11/2013
Time Out : 02:08 Time In : 03:15

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1829

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : FAULTED CABLE BETWEEN THE 4 AND 5 SWITCH.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/11/13 - Eden Prairie & Edina
Power outage - Eden Prairie & Edina.

Wendy

From: Aspinwall, David P
Sent: Thursday, July 11, 2013 2:56 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In :
Time Out : 02:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 323

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME.

Follow-Up : WORKING ON IT.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/11/13 - Eden Prairie & Edina - POWER RESTORED

Power outage - Eden Prairie & Edina - power restored.

Wendy

From: Aspinwall, David P
Sent: Thursday, July 11, 2013 3:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In : 7/11/2013
Time Out : 02:46 Time In : 03:48

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 323

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : LIGHTNING ARRESTER LET LOOSE AT THE 15 SWITCH.

Follow-Up : THE 14 SWITCH WOULD BE A GOOD SPOT FOR FAULT INDICATORS.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/13/13 - Brooklyn Center & Minneapolis
Power outage - Brooklyn Center & Minneapolis.

Wendy

From: Schwarz, John W
Sent: Saturday, July 13, 2013 4:44 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In :
Time Out : 03:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1187

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/13/13 - Brooklyn Center & Minneapolis - POWER RESTORED

Power outage - Brooklyn Center & Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, July 13, 2013 12:25 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In : 7/13/2013
Time Out : 04:37 Time In : 08:07

Time Zone : CST

Duration : 3 hours, 30 mins

Number of Customers Affected : 1186

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Arrester at Blew Tree Branches

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/13/13 - Golden Valley
Power outage - Golden Valley.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, July 13, 2013 6:09 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In :
Time Out : 05:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 151

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/13/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, July 13, 2013 12:28 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In : 7/13/2013
Time Out : 05:58 Time In : 06:50

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 151

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : None

Cause : Watetr flooded load ctr at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/13/13 - Minneapolis & Saint Anthony
Power outages - Minneapolis & Saint Anthony.

Wendy

From: Schwarz, John W
Sent: Saturday, July 13, 2013 4:22 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In :
Time Out : 03:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4035

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/13/13 - Minneapolis & Saint Anthony - POWER RESTORED

Power outage - Minneapolis & Saint Anthony - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Saturday, July 13, 2013 12:39 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In : 7/13/2013
Time Out : 03:58 Time In : 06:52

Time Zone : CST

Duration : 2 hours, 54 mins

Number of Customers Affected : 4034

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : possible lighting. nothing found on patrol

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/13/13 - Plymouth
Power outage - Plymouth.

Wendy

From: Schwarz, John W
Sent: Saturday, July 13, 2013 4:20 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

PKL-PARKERS LAKE First Outage Notice
Feeder/Bus : 062

Date Out : 7/13/2013 Date In :
Time Out : 03:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 350

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 8:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/13/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - Plymouth.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, July 13, 2013 3:09 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/13/2013 Date In : 7/13/2013
Time Out : 03:45 Time In : 14:47

Time Zone : CST

Duration : 11 hours, 2 mins

Number of Customers Affected : 212

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire Down

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/14/13 - Eden Prairie
Power outage - Eden Prairie

Wendy

From: Schwarz, John W
Sent: Sunday, July 14, 2013 2:49 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/14/2013 Date In :
Time Out : 02:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2100

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 15, 2013 9:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/14/13 - Eden Prairie - POWER RESTORED
Power outage - Eden Prairie - power restored.

Wendy

From: Schwarz, John W
Sent: Sunday, July 14, 2013 4:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/14/2013 Date In : 7/14/2013
Time Out : 02:44 Time In : 04:00

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 2100

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LD CRT FLASHED OVER WHILE LOOKING FOR A FAULT. 2000
CUSTOMERS IN @ 03:00 ALL BUT 6 TR'S RESTORED AT 04:00 CREW CALLED IN FOR REPAIRS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 10:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/16/13 - Eden Prairie, Hopkins & Minnetonka -
UPDATE
Power outage - Eden Prairie, Hopkins & Minnetonka - update.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, July 17, 2013 10:17 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In :
Time Out : 21:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 862

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Correction to earlier notification - "A" phase line burnt down at
this caused a momentary trip on whole feeder.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 10:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/16/13 - Eden Prairie, Hopkins & Minnetonka -
POWER RESTORED
Power outage - Eden Prairie, Hopkins & Minnetonka - power restored.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, July 17, 2013 10:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In : 7/17/2013
Time Out : 21:44 Time In : 00:28

Time Zone : CST

Duration : 2 hours, 44 mins

Number of Customers Affected : 862

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : "A" phase wire burnt down.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 4:32 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Knutson, David A
Sent: Wednesday, July 17, 2013 4:23 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 16:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : WILL PATROL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/17/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Knutson, David A
Sent: Wednesday, July 17, 2013 5:45 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 16:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE POTHEAD BURNED UP AT TIE AUTO LET
LOOSE ON FEEDER HOT UP TO THE PICKED UP 20
CUSTOMERS CREW ON SITE TO PUT UP WIRE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/17/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, July 17, 2013 6:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In : 7/17/2013
Time Out : 16:18 Time In : 18:41

Time Zone : CST

Duration : 2 hours, 23 mins

Number of Customers Affected : 554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE WIRE DOWN AT
TIE SWITCH BAD

Follow-Up : ISOLTED FEEDER,O.H.CREW PUT FEEDER WIRE BACK
UP.ISOLATED BAD FEEDER TIE SWITCH,PATROLLED OUT FEEDER FOUND MORE
ISSUES ON O.H WIRE DOWN AT .NEED X ARMS REPLACED
AND MAYBE POLE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Bloomington & Richfield
Power outage - Bloomington & Richfield.

Wendy

From: Knutson, David A
Sent: Wednesday, July 17, 2013 6:13 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 18:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2767

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLE ON THE WAY

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Bloomington & Richfield - DUPLICATE
Power outage - Bloomington & Richfield - duplicate.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, July 17, 2013 6:14 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 18:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2767

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/17/13 - Bloomington & Richfield - POWER RESTORED

Power outage - Bloomington & Richfield - power restored.

Wendy

From: Knutson, David A
Sent: Wednesday, July 17, 2013 7:51 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In : 7/17/2013
Time Out : 18:07 Time In : 19:46

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 2767

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : C PHASE OFF PIN LYING ON ARM INSTALLED BLANKET UNDER PHASE AND

REFERRED

Follow-Up : BETWEEN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:21 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/19/13 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata
Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata.

Wendy

From: Anderson, Timothy K
Sent: Saturday, July 20, 2013 12:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/19/2013 Date In :
Time Out : 23:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1956

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 1:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice
Attachments: IMG_0195.JPG; IMG_0197.JPG; IMG_0198.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Monday, July 22, 2013 1:15 PM
To: Anderson, Timothy K; dl Electric Outage MW Notification
Subject: RE: Final Outage Notice

Non-preventable
Cottonwood trunk broke due to internal decay in lower trunk
Tree was outside the VM maintenance corridor – 75ft away from conductors
Tree looked healthy, green crown
Last VM date 2/25/2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Anderson, Timothy K
Sent: Saturday, July 20, 2013 2:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/19/2013

Date In : 7/20/2013

Time Out : 23:55

Time In : 02:22

Time Zone : CST

Duration : 2 hours, 27 mins

3/25/2014

Number of Customers Affected : 1956

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER

Follow-Up : PATROL REMOVE TREE FROM FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:22 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/19/13 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - POWER RESTORED
Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - power restored.

Wendy

From: Anderson, Timothy K
Sent: Saturday, July 20, 2013 2:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/19/2013 Date In : 7/20/2013
Time Out : 23:55 Time In : 02:22

Time Zone : CST

Duration : 2 hours, 27 mins

Number of Customers Affected : 1956

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER

Follow-Up : PATROL REMOVE TREE FROM FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:28 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/20/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Saturday, July 20, 2013 5:32 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/20/2013 Date In :
Time Out : 17:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5768

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:30 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/20/13 - Minneapolis - UPDATE/POWER RESTORED

Power outage - Minneapolis - update/restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, July 20, 2013 6:37 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/20/2013 Date In : 7/20/2013
Time Out : 17:27 Time In : 18:24

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 3245

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : bad head end cable

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:29 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/2/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Anderson, Timothy K
Sent: Saturday, July 20, 2013 7:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

SOU-SOUTHTOWN Final Outage Notice
Feeder/Bus : 083

Date Out : 7/20/2013 Date In : 7/20/2013
Time Out : 17:27 Time In : 19:11

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 5768

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED HEAD END CABLE

Follow-Up : REFER FOR BIDDLE & REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:31 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: Final Outage Notice - 7/2/13 - Minneapolis - UPDATE/POWER RESTORED - CORRECTION
CORRECTION - POWER OUTAGE - MINNEAPOLIS - UPDATE/POWER RESTORED.

WENDY

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:29 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/2/13 - Minneapolis - UPDATE

Power outage - Minneapolis - update.

Wendy

From: Anderson, Timothy K
Sent: Saturday, July 20, 2013 7:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 7/20/2013	Date In : 7/20/2013
Time Out : 17:27	Time In : 19:11

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 5768

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED HEAD END CABLE

Follow-Up : REFER FOR BIDDLE & REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/22/13 - Golden Valley, Minnetonka & Saint Louis Park
Power outage - Golden Valley, Minnetonka & Saint Louis Park.

Wendy

From: Knutson, David A
Sent: Monday, July 22, 2013 5:29 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In :
Time Out : 17:26 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1047

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : INTERCHANGE INVESTORS LLC

Cause : unknown trouble on the way

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 24, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0200.JPG; IMG_0199.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Tuesday, July 23, 2013 3:25 PM
To: Kittock, Joseph C; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable
Boxelder has the trunk crack due to internal decay
Tree was across the street from the conductors
No outward visible signs of decay present along trunk, tree had full green canopy
Last VM work date 8/2010

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Kittock, Joseph C
Sent: Monday, July 22, 2013 6:38 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In : 7/22/2013
Time Out : 17:26 Time In : 18:32

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1047

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell across feeder at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/22/13 - Golden Valley, Minnetonka & Saint Louis Park - POWER RESTORED
Power outage - Golden Valley, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, July 22, 2013 6:38 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 7/22/2013 Date In : 7/22/2013
Time Out : 17:26 Time In : 18:32

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1047

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell across feeder at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 12:13 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/23/13 - Brooklyn Park, Minneapolis & Osseo
Power outage - Brooklyn Park, Minneapolis & Osseo.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 23, 2013 11:44 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In :
Time Out : 11:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1025

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown, Troublemans patrolling mainline at this time.

Follow-Up : opened.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 12:15 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/23/13 - Brooklyn Park, Minneapolis
& Osseo - UPDATE
Power outage - Brooklyn Park, Minneapolis & Osseo - update.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 23, 2013 11:59 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In :
Time Out : 11:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1025

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : Cut feeder cable by contractor at

Follow-Up : Troubleman in process of isolation.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 23, 2013 2:07 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/23/13 - Brooklyn Park, Minneapolis & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Minneapolis & Osseo - power restored.

Wendy

From: Cedar, Daren A
Sent: Tuesday, July 23, 2013 12:45 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/23/2013 Date In : 7/23/2013
Time Out : 11:14 Time In : 12:36

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1025

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MINNEAPOLIS, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : CUT FEEDER CABLE BETWEEN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 25, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/24/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, July 24, 2013 9:05 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/24/2013 Date In :
Time Out : 20:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 892

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : pot head, B phase burnt open.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 25, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/24/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, July 24, 2013 9:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2013 Date In : 7/24/2013
Time Out : 20:14 Time In : 20:49

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 892

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : pot head, B phase burnt open.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 26, 2013 11:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/26/13 - Golden Valley
Power outage - Golden Valley.

Wendy

From: Ayers, Patrick S
Sent: Friday, July 26, 2013 10:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/26/2013 Date In :
Time Out : 10:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 16

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 26, 2013 11:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/26/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, July 26, 2013 10:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/26/2013 Date In : 7/26/2013
Time Out : 10:39 Time In : 10:48

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 16

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CONTRACT RELAY CREW WORKING AT MEL SUB ON
REPLACEMENT OF BKR OPENED WRONG SET OF RELAY SWITCHES
CAUSING TRIP OF BKR

Follow-Up : TALKED WITH RELAY CREW AT SUB.CLOSED BKR R.C.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 31, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/30/13 - Fridley & Minneapolis
Power outage - Fridley & Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 30, 2013 4:09 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In :
Time Out : 16:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 177

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 31, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/30/13 - Fridley & Minneapolis - POWER RESTORED

Power outage - Fridley & Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 30, 2013 5:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In : 7/30/2013
Time Out : 16:02 Time In : 17:10

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 177

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : GOOSE IN WIRES AT .

Follow-Up : PATROLLED FEEDER, ISOLATED WIRE DOWN .CLOSED
BKR.WIRE DOWN IS ON FEEDER.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 31, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/30/13 - Fridley & Minneapolis
Power outage - Fridley & Minneapolis

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 30, 2013 4:08 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In :
Time Out : 16:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 921

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 31, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 7/30/13 - Fridley & Minneapolis - POWER RESTORED

Power outage - Fridley & Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 30, 2013 5:17 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In : 7/30/2013
Time Out : 16:02 Time In : 17:09

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 921

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : GOOSE IN WIRES AT

Follow-Up : PATROLLED FEEDER, ISOLATED WIRE DOWN AT
.ALL BUT 7CUST ARE IN AS OF 1709.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 31, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/30/13 - Fridley & Minneapolis - POWER RESTORED/UPDATE

Power outage - Fridley & Minneapolis - power restored/update.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 30, 2013 6:20 PM
To: dl Electric Outage MW Notification
Subject: RIV-RIVERSIDE (063) Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In : 7/30/2013
Time Out : 16:02 Time In : 18:15

Time Zone : CST

Duration : 2 hours, 13 mins

Number of Customers Affected : 921

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN

Follow-Up : LAST 7 CUST RESTORED AS OF 1815

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 01, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/31/13 - Coon Rapids & Fridley
Power outage - Coon Rapids & Fridley.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, July 31, 2013 5:08 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/31/2013 Date In :
Time Out : 17:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1063

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 01, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/31/13 - Coon Rapids & Fridley - POWER RESTORED

Power outage - Coon Rapids & Fridley - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, July 31, 2013 6:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/31/2013 Date In : 7/31/2013
Time Out : 17:06 Time In : 18:37

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 1063

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE BAD FROM TO TIE AND

Follow-Up : THIS FEEDER LOCK TOOK LONGER TO RESTORE DUE TO BKR NOT OPERATING FROM CONTROL CENTER.NEEDED OPERATOR TO OPERATE BKR FIRST,THEN CONTROL CENTER WAS ABLE TO CLOSE.REFERRED BKR TO RELAY.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/5/13 - Saint Cloud & Sauk Rapids
Power outage - Saint Cloud & Sauk Rapids.

Wendy

From: Vorachek, Kelly
Sent: Friday, July 05, 2013 2:32 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/5/2013 Date In :
Time Out : 13:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2472

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : - Tree into feeder at
switch opened and isolated problem leaving 1660 customers still out / Opened the to isolate tree
down & closed at 14:14 picking up 55 customers / crew working on clearing tree to restore final 1605
customers.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice *** Momentary Outage *** 7/5/13 - Saint Cloud -
POWER RESTORED

Power outage - momentary - Saint Cloud - power restored.

Wendy

From: Kaveny, Michael J
Sent: Friday, July 05, 2013 13:43
To: dl Electric Outage NT Notification
Subject: First Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/5/2013 Date In : 7/5/2013
Time Out : 13:40 Time In : 13:40

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 2472

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : Trip and Reclose, .

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/9/13 - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye.

Wendy

From: Chase, Julie B
Sent: Tuesday, July 09, 2013 6:45 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In :
Time Out : 06:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers :

Cause : non SCADA sub, T-Storm in area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 09, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/9/13 - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - POWER RESTORED
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - power restored.

Wendy

From: Chase, Julie B
Sent: Tuesday, July 09, 2013 7:59 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/9/2013 Date In : 7/9/2013
Time Out : 06:22 Time In : 07:47

Time Zone : CST

Duration : 1 hours, 25 mins

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers :

Cause : Thunderstorm in area

Follow-Up : lightning

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 25, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/24/13 - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins
Power outage - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins.

Wendy

From: Medellin, Victor J
Sent: Wednesday, July 24, 2013 6:20 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/24/2013 Date In :
Time Out : 18:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3450

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ANNANDALE, MN; DASSEL, MN; KIMBALL, MN;
KINGSTON, MN; SOUTH HAVEN, MN; WATKINS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION OUTAGE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 25, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/24/13 - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins - POWER RESTORED
Power outage - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins - power restored.

Wendy

From: Medellin, Victor J
Sent: Wednesday, July 24, 2013 6:55 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/24/2013 Date In : 7/24/2013
Time Out : 18:08 Time In : 18:45

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 3450

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ANNANDALE, MN; DASSEL, MN; KIMBALL, MN; KINGSTON, MN; SOUTH HAVEN, MN; WATKINS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 2976 CUSTOMERWS RESTORED @ 18:45 474 CUSTOMERS STILL
OUT TRANSMISSION EVENT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 25, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/24/13 - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins - POWER RESTORED/UPDATE
Power outage - Annandale, Dassel, Kimball, Kingston, South Haven & Watkins - power restored/update.

Wendy

From: Medellin, Victor J
Sent: Wednesday, July 24, 2013 7:53 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2013 Date In : 7/24/2013
Time Out : 18:08 Time In : 19:41

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 3443

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ANNANDALE, MN; DASSEL, MN; KIMBALL, MN; KINGSTON, MN; SOUTH HAVEN, MN; WATKINS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CORRECTION 3443 CUSTOMERS AFFECTED 2834 RESTORED
@18:45 474 RESTORED @19:36 REMAINING 135 RESTORED @ 19:42

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 29, 2013 9:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/29/13 - Clements, Cobden, Evan, Morgan, Morton,
Redwood Falls & Sleepy Eye
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, July 29, 2013 8:42 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/29/2013 Date In :
Time Out : 08:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON,
MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown at this time

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 29, 2013 9:49 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/29/13 - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - UPDATE
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - update.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, July 29, 2013 9:37 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/29/2013 Date In :
Time Out : 08:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : Found wire down on ground...crew putting wire back up....power should be restored in the next 30 min

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 29, 2013 10:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/29/13 - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - POWER RESTORED
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Monday, July 29, 2013 9:59 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/29/2013 Date In : 7/29/2013
Time Out : 08:34 Time In : 09:35

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 1125

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN; MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : wire fell down near the sub

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 30, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:
First Outage Notice - 7/30/13 - Albany, Avon, Collegeville & Saint Joseph
Power outage - Albany, Avon, Collegeville & Saint Joseph.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, July 30, 2013 6:33 AM
To: dl Electric Outage NT Notification
Subject:
Notice

First Outage

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In :
Time Out : 06:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2686

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission Level Event.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 30, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:
Second Outage Notice - 7/30/13 - Albany, Avon, Collegeville & Saint Joseph - UPDATE
Power outage - Albany, Avon, Collegeville & Saint Joseph - update.

Wendy

From: Johnson, Michael A
Sent: Tuesday, July 30, 2013 7:26 AM
To: dl Electric Outage NT Notification
Subject:
Notice

Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In :
Time Out : 06:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2686

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : transmission level event, trouble still patrolling

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 30, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW:
Final Outage Notice - 7/30/13 - Albany, Avon, Collegeville & Saint Joseph - POWER RESTORED
Power outage - Albany, Avon, Collegeville & Saint Joseph - power restored.

Wendy

From: Johnson, Michael A
Sent: Tuesday, July 30, 2013 7:52 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/30/2013 Date In : 7/30/2013
Time Out : 06:24 Time In : 07:44

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 2686

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBANY, MN; AVON, MN; COLLEGEVILLE, MN; SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers :

Cause : transmission level event; 100% restored

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 26, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/26/13 - Tracy
Power outage - Tracy.

Wendy

From: Medellin, Victor J
Sent: Friday, July 26, 2013 2:15 AM
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/26/2013 Date In :
Time Out : 02:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 701

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : TRACY, MN

State : SD - South Dakota

Major Customers : NONE

Cause : SCHEDULED OUTAGE FOR SUBSTATION WORK. REPLACE
INSULATORS & BYPASS SW.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, July 26, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/26/13 - Tracy - POWER RESTORED
Power outage - Tracy - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, July 26, 2013 3:07 AM
To: dl Electric Outage SD Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/26/2013 Date In : 7/26/2013
Time Out : 02:00 Time In : 02:28

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 701

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : TRACY, MN

State : SD - South Dakota

Major Customers : NONE

Cause : SCHEDULED OUTAGE RESTORED. REPAIRS
COMPLETE AT SUB.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 02, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/2/13 - Jordan, Prior Lake & Shakopee
Power outage - Jordan, Prior Lake & Shakopee.

Wendy

From: Johnson, Michael A
Sent: Tuesday, July 02, 2013 7:53 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/2/2013 Date In :
Time Out : 07:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2440

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : JORDAN, MN; PRIOR LAKE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN; TROUBLE ENROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 02, 2013 9:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/2/13 - Jordan, Prior Lake & Shakopee -
UPDATE

Power outage - Jordan, Prior Lake & Shakopee - update.

Wendy

From: Johnson, Michael A
Sent: Tuesday, July 02, 2013 8:47 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/2/2013 Date In :
Time Out : 07:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2440

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : JORDAN, MN; PRIOR LAKE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BACKHOE TORE DOWN PHASE AND NEUTRAL, NO INJURIES, ETR OF 30

MINUTES

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 02, 2013 9:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/2/13 - Jordan, Prior Lake & Shakopee -
POWER RESTORED

Power outage - Jordan, Prior Lake & Shakopee - power restored.

Wendy

From: Johnson, Michael A
Sent: Tuesday, July 02, 2013 9:05 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/2/2013 Date In : 7/2/2013
Time Out : 07:47 Time In : 09:01

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 2440

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : JORDAN, MN; PRIOR LAKE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN; 100% RESTORED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 03, 2013 3:44 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/3/13 - Elko New Market, Elko & Webster
Power outage - Elko New Market, Elko & Webster.

Wendy

From: Medellin, Victor J
Sent: Wednesday, July 03, 2013 3:37 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/3/2013 Date In :
Time Out : 15:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 923

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAUSE UNKOWN AT THIS TIME CREW BEING CALLED IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/3/13 - Elko New Market, Elko & Webster - POWER RESTORED

Power outage - Elko New Market, Elko & Webster - power restored.

Wendy

From: Vorachek, Kelly
Sent: Wednesday, July 03, 2013 6:01 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :

Date Out : 7/3/2013 Date In : 7/3/2013
Time Out : 15:30 Time In : 17:50

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 923

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Cause unknown - Patrol found nothing, no comments from customer calls, operator closed breaker by local control and held.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/11/13 - Northfield - POWER RESTORED
Power outage - Northfield - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, July 11, 2013 2:04 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In : 7/11/2013
Time Out : 01:30 Time In : 01:55

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 1109

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

loose at Cause : Intentional outage to put wire back up. Phase fell down when automatic sleeve let

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 11, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/11/13 - Northfield - POWER
RESTORED/UPDATE

Power outage - Northfield - power restored/update.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, July 11, 2013 3:49 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/11/2013 Date In : 7/11/2013
Time Out : 01:30 Time In : 01:55

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 2053

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire fell down at

Follow-Up : Corrected customer count to 2053. feeding customers to the 8-
switch on

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/22/13 - Red Wing
Power outage - Red Wing.

Wendy

From: Goulet, Terry W
Sent: Monday, July 22, 2013 12:05 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In :
Time Out : 23:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : Cause unknown at this time. Crew called in, weather is fair.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:43 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/21/13 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Goulet, Terry W
Sent: Monday, July 22, 2013 2:22 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/21/2013 Date In : 7/22/2013
Time Out : 23:49 Time In : 02:08

Time Zone : CST

Duration : 2 hours, 19 mins

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : FOUND BAD 400MCM P&L CALE BETWEEN
CUSTOMERS BETWEEN SUB & 2 SW BACK IN @ 0058. REMAINING RESTORED @ 0208

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:44 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 7/21/13 - Red Wing - DATE CORRECTION
I believe this should be 7/21/13 as the start date instead of 7/22/13 as indicated on the final report just sent.

Wendy

From: Jaede, Wendy L
Sent: Monday, July 22, 2013 12:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/22/13 - Red Wing

Power outage - Red Wing.

Wendy

From: Goulet, Terry W
Sent: Monday, July 22, 2013 12:05 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/22/2013 Date In :
Time Out : 23:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 409

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : Cause unknown at this time. Crew called in, weather is fair.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, July 18, 2013 1:29 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/18/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, July 18, 2013 1:28 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/18/2013 Date In :
Time Out : 13:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2423

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 24, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 7/18/13 - Minneapolis -
POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, July 18, 2013 1:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice *** Momentary Outage ***
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2013 Date In : 7/18/2013
Time Out : 13:24 Time In : 13:29

Time Zone : CST

Duration : 0 hours, 5 mins

Number of Customers Affected : 2423

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Load Relief Over current

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 1:12 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/17/13 - Inver Grove Heights, Inver Grove & South Saint Paul
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Wednesday, July 17, 2013 12:50 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 12:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1833

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 4:03 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/17/13 - Inver Grove Heights, Inver Grove & South Saint Paul - UPDATE
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - update.

Wendy

From: Chial, Terry L
Sent: Wednesday, July 17, 2013 2:49 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In :
Time Out : 12:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1833

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown

Follow-Up : patrolling line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 4:04 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/17/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Wednesday, July 17, 2013 3:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In : 7/17/2013
Time Out : 12:43 Time In : 15:12

Time Zone : CST

Duration : 2 hours, 29 mins

Number of Customers Affected : 1833

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown

Follow-Up : still patolling line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 9:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/16/13 - Minnetonka & Wayzata
Power outage - Minnetonka & Wayzata.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 16, 2013 3:43 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In :
Time Out : 03:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1605

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown at this time. Troubleman patrolling mainline.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 9:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/16/13 - Minnetonka & Wayzata - UPDATE
Power outage - Minnetonka & Wayzata - update.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 16, 2013 4:47 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In :
Time Out : 03:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1605

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact on mainline. Troubleman in process of removing tree.

Follow-Up : Partial restoration of 719 customers at 0438.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 11:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0426.jpg; IMG_0428.jpg
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Tuesday, July 16, 2013 11:50 AM
To: Babb, Randall J; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Willow tree uprooted due to flooded site location.
Tree appeared healthy
Last VM work date 4/2010

The tree has been cleared away from the line to prevent further issues.

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Babb, Randall J
Sent: Tuesday, July 16, 2013 5:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

GNL-GLEN LAKE Final Outage Notice
Feeder/Bus : 062

Date Out : 7/16/2013 Date In : 7/16/2013
Time Out : 03:32 Time In : 04:53

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 1605

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact to mainline.

Follow-Up : Troublemaker removed tree limb and restoration to remaining 886 customers was restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 9:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/16/13 - Minnetonka & Wayzata - POWER RESTORED

Power outage - Minnetonka & Wayzata - power restored.

Wendy

From: Babb, Randall J
Sent: Tuesday, July 16, 2013 5:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In : 7/16/2013
Time Out : 03:32 Time In : 04:53

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 1605

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact to mainline.

Follow-Up : Troublemaker removed tree limb and restoration to remaining 886 customers was restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/7/13 - Falcon Heights, Lake Elmo, Maplewood, Oakdale & Saint Paul
Power outage - Falcon Heights, Lake Elmo, Maplewood, Oakdale & Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, July 07, 2013 7:02 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/7/2013 Date In :
Time Out : 19:01 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2542

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; LAKE ELMO, MN;
MAPLEWOOD, MN; OAKDALE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown at this time

Follow-Up : trees

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 4:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice - 7/7/13 - Falcon Heights, Lake Elmo, Maplewood,
Oakdale & Saint Paul

FYI....This one was a mistake.

The outage was actually on which was sent out shortly after this one.

This notification can be disregarded.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jaede, Wendy L
Sent: Monday, July 08, 2013 9:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/7/13 - Falcon Heights, Lake Elmo, Maplewood,
Oakdale & Saint Paul

Power outage - Falcon Heights, Lake Elmo, Maplewood, Oakdale & Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, July 07, 2013 7:02 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/7/2013
Time Out : 19:01

Date In :
Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2542

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; LAKE ELMO, MN;
MAPLEWOOD, MN; OAKDALE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown at this time

Follow-Up : trees

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/17/13 - Glencoe, Nya, Plato & Winsted - POWER RESTORED

Power outages - Glencoe, Nya, Plato & Winsted - power restored.

Wendy

From: Babb, Randall J
Sent: Wednesday, July 17, 2013 5:42 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/17/2013 Date In : 7/17/2013
Time Out : 00:16 Time In : 02:51

Time Zone : CST

Duration : 2 hours, 35 mins

Number of Customers Affected : 418

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GLENCOE, MN; NYA, MN; PLATO, MN; WINSTED, MN

State : MN - Minnesota

Major Customers : None

Cause : Scheduled outage ; Transmission wrecking out 69KV and building new line into substation.

Follow-Up : Outages arranged per RFO 325381.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 3:12 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/16/13 -
Minneapolis
Power outage - Minneapolis.

Wendy

From: Aspinwall, David P
Sent: Tuesday, July 16, 2013 3:09 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 19302

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : TR 2 BUS LOCK.

Follow-Up : OPERATORS EN ROUTE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 4:21 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/16/13 -
Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Aspinwall, David P
Sent: Tuesday, July 16, 2013 4:16 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In : 7/16/2013
Time Out : 14:56 Time In : 16:06

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 19302

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : A PHASE 72 CH BKR DISC FLASH INTO BT 2-3, CAUSE UNKNOWN AT THIS
TIME.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, July 16, 2013 3:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Momentary Outage - 7/16/13 -
Minneapolis & Saint Paul
Power outage - Minneapolis & Saint Paul.

Wendy

From: Aspinwall, David P
Sent: Tuesday, July 16, 2013 3:38 PM
To: dl Electric Outage MW Notification
Subject: Momentary Outage

Distribution System Status Outage Notification

Momentary Outage

Feeder/Bus :

Date Out : 7/16/2013 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 23206

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : TR 2 BUS LOCK TRIPPED THE BUS SECTION 3.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, July 17, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary
Outage *** 7/16/13 - Minneapolis & Saint Paul - POWER RESTORED
Power outage - Minneapolis & Saint Paul - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, July 16, 2013 5:03 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice *** Momentary
Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2013 Date In : 7/16/2013
Time Out : 14:56 Time In : 14:56

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 23206

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Disc flashed on ch that flashed into causing a trip on

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Farmington
Power outage - Farmington.

Wendy

From: Chial, Terry L
Sent: Monday, August 05, 2013 2:36 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 579

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : will patrol

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/5/13 - Farmington - UPDATE
Power outage - Farmington - update.

Wendy

From: Chial, Terry L
Sent: Monday, August 05, 2013 4:07 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 579

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up : PATROLLING AT THIS TIME

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 8/5/13 - Farmington - UPDATE
Power outage - Farmington - update.

Wendy

From: Abbott, Edward J
Sent: Monday, August 05, 2013 5:55 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 579

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : THE CDV ALERT SHOULD HAVE BEEN FOR VMR

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Fourth Outage Notice - 8/5/13 - Farmington - UPDATE
Power outage - Farmington - update.

Wendy

From: Abbott, Edward J
Sent: Monday, August 05, 2013 6:40 AM
To: dl Electric Outage ME Notification
Subject: Fourth Outage Notice

Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 579

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : FOUND A PIN BLOWN OFF STEEL TRANSMISSION POLE
ATTACHED TO OUR FEEDER. HAS TO GO TO SHOP TO GET ONE AND INSTALL IT; WILL
PROBABLY TAKE ANOTHER 30 TO 40 MINUTES

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Farmington - POWER RESTORED
Power outage - Farmington - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, August 05, 2013 7:12 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 02:21 Time In : 06:18

Time Zone : CST

Duration : 3 hours, 57 mins

Number of Customers Affected : 579

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : AT PIN FOR JUMPER BLOWN OUT
AND JUMPER RESTING AGAINST STEEL TOWER. TROUBLE REPLACED PIN AND
FEEDER BACK IN.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, August 06, 2013 10:45 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:51 Time In : 21:08

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 1276

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : BROKEN POLE
TROUBLE FIELD SWITCHED TO BRING IN FEEDER

Follow-Up : REFERRED FOR CREW TO REPLACE POLE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:54 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, August 06, 2013 10:41 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:52 Time In : 20:42

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 1276

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : TREE BROKE POLE AT _____, TREE
CREW AND CREW CALLED IN AND FIELD SWITCHED TO BRING FEEDER BACK IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Eagan
Power outage - Eagan.

Wendy

From: Chial, Terry L
Sent: Tuesday, August 06, 2013 8:00 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 329

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers : no

Cause : storm

Follow-Up : patrolling

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, August 06, 2013 11:30 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:51 Time In : 21:08

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 329

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BROKEN POLE AT
TROUBLE FIELD SWITCHED TO BRING IN FEEDER

Follow-Up : REFERRED TO HAVE CREW RELACE, CREW CALLED IN AND
WILL WORK ON THIS TONIGHT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Eagan
Power outage - Eagan.

Wendy

From: Chial, Terry L
Sent: Tuesday, August 06, 2013 8:02 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1276

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : storm

Follow-Up : patrolling

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 10:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Tree Report
Attachments: IMG_0131.jpg; IMG_0130.jpg
FYI...tree report.

Wendy

From: Weidenfeller, Bradley M
Sent: Thursday, August 08, 2013 10:25 AM
To: Chial, Terry L; dl Electric Outage ME Notification
Subject: RE: First Outage Notice

Non-preventable
Cottonwood limb 11" dia failed, no signs of decay
Feeder last worked 8-2009 scheduled 2014
Strong storms and winds

Brad Weidenfeller
Xcel Energy | Responsible By Nature
Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369
P: 763-493-1827 C: 320-250-2541 F: 763-493-1840
E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, August 06, 2013 8:02 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1276

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : storm

Follow-Up : patrolling

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Inver Grove Heights, Inver Grove & South Saint Paul
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul.

Wendy

From: Chial, Terry L
Sent: Tuesday, August 06, 2013 8:08 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 20:01 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1830

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : storm

Follow-Up : patrolling

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/6/13 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, August 07, 2013 6:58 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 20:01 Time In : 21:50

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 1830

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A large tree took down our feeder between ...

Follow-Up : We are going to need a tree crew and an overhead crew to get this feeder back...

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second O utage Notice
Attachments: photo 1.jpg; photo 2.jpg
FYI...tree report.

Wendy

From: Weidenfeller, Bradley M
Sent: Friday, August 09, 2013 8:26 AM
To: Driscoll, Paul M; dl Electric Outage ME Notification
Subject: RE: Second O utage Notice

Non-preventable
11" dia. Boxelder failed outside of trim area, no signs of decay.
Last time worked 6-2009 scheduled 2014.
Strong winds and storms.

Brad Weidenfeller
Xcel Energy | Responsible By Nature
Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369
P: 763-493-1827 C: 320-250-2541 F: 763-493-1840
E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Driscoll, Paul M
Sent: Wednesday, August 07, 2013 6:58 AM
To: dl Electric Outage ME Notification
Subject: Second O utage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/6/2013
Time Out : 20:01

Date In : 8/6/2013
Time In : 21:50

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 1830

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A large tree took down our feeder between ...

Follow-Up : We are going to need a tree crew and an overhead crew to get
this feeder back...

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Eagan
Power outage - Eagan.

Wendy

From: Abbott, Edward J
Sent: Tuesday, August 06, 2013 10:29 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 22:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 289

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN, TROUBLE TO PATROL

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Abbott, Edward J
Sent: Wednesday, August 07, 2013 12:05 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 22:21 Time In : 23:45

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 289

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : BAD FEEDER CABLE PAST SWITCHED OUT AND
FEEDER BACK IN

Follow-Up : RELAY WILL NEED TO BIDDLE FEED INTO DELTA AND
UNISYS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, August 16, 2013 8:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/15/13 - Eagan
Power outage - Eagan.

Wendy

From: Gilland, William P
Sent: Thursday, August 15, 2013 11:36 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/15/2013 Date In :
Time Out : 11:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 154

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 16, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice- 8/15/2013 Eagan POWER RESTORED
Power Restored- Eagan

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Thursday, August 15, 2013 12:44
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/15/2013

Date In : 8/15/2013

Time Out : 11:24

Time In : 12:41

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 154

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : cable failure

Follow-Up :

Eilers, Rebecca D

From: Barraza, Angela
Sent: Thursday, August 22, 2013 11:09 AM
To: consumer.puc@state.mn.us; doug.renier@state.mn.us
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice

Angela Barraza

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

1800 Larimer St, Ste 1500 Denver, CO 80202

P: 303-294-2103 **F:** 303-294-2393

E: angela.barraza@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT – CONTAINS TRADE SECRET DATA/PRIVATE DATE ON INDIVIDUALS

From: Driscoll, Paul M
Sent: Thursday, August 22, 2013 7:39 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/22/2013

Date In :

Time Out : 08:24

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2139

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A Donavon crew stringing in a new line got onto our feeder. We had the breaker on "one shot". Nobody was hurt..

Follow-Up :

Eilers, Rebecca D

From: Barraza, Angela
Sent: Thursday, August 22, 2013 11:09 AM
To: consumer.puc@state.mn.us; doug.renier@state.mn.us
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice

Angela Barraza

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

1800 Larimer St, Ste 1500 Denver, CO 80202

P: 303-294-2103 **F:** 303-294-2393

E: angela.barraza@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT – CONTAINS TRADE SECRET DATA/PRIVATE DATE ON INDIVIDUALS

From: Driscoll, Paul M
Sent: Thursday, August 22, 2013 8:38 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/22/2013

Date In : 8/22/2013

Time Out : 08:24

Time In : 09:25

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 2139

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : At a crew got on our
feeder.The feeder was on manual,nobody was hurt.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 2:07 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/29/2013- POWER OUTAGE EAGAN,INVER GROVE HEIGHTS,MENDOTA HEIGHTS,MENDOTA HTS,SAINT PAUL
EAGAN, MN; INVER GROVE HEIGHTS, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Thursday, August 29, 2013 12:51
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 12:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 200

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 3:45 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/29/2013 POWER RESTORED EAGAN, INVER GROVE HEIGHTS, MENDOTA HEIGHTS, MENDOTA HTS, SAINT PAUL

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

8/29/2013- POWER RESTORED EAGAN, MN; INVER GROVE HEIGHTS, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN

From: Abbott, Edward J
Sent: Thursday, August 29, 2013 14:32
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 12:45 Time In : 14:07

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 200

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BAD FDR CABLE BETWEEN
HIT SWITCH GEAR LO1 WHICH HAD FDR CABLE IN IT AT
FEEDER BACK IN WITH FEILD SWITCHING

ALSO CAR

Follow-Up : WILL NEED TO DO ADDITIONAL SWITCHING TO PICK UP
SOME DISTRUBUTION 3 PHASE CUSTOMERS

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 02, 2013 8:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice 8/2/2013- Eden Prairie, Minnetonka
Power Outage- Eden Prairie and Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Kenneth W
Sent: Thursday, August 01, 2013 19:46
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 8/1/2013	Date In :
Time Out : 19:46	Time In :

Time Zone : CST
Duration :
Number of Customers Affected : 2309
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 02, 2013 9:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice - 8/1/2013 Eden Prairie and Minnetonka
Second Outage Notice - Eden Prairie and Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Friday, August 02, 2013 02:25
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :

Date Out : 8/1/2013	Date In : 8/2/2013
Time Out : 19:46	Time In : 02:07

Time Zone : CST

Duration : 6 hours, 21 mins

Number of Customers Affected : 454

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : car hit pole

Follow-Up : mid-span dead ends (canadians) were cut into O.H. line...185 customers still out until pole is changed out.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 02, 2013 9:01 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice - 8/1/2013 Eden Prairie and Minnetonka
Outage Update - Eden Prairie and Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Kenneth W
Sent: Thursday, August 01, 2013 20:42
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :

Date Out : 8/1/2013 Date In :
Time Out : 19:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2309

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Car accident broke pole at

Follow-Up : Feeder in up to picked up 1670 customers at 2017 / 639 out

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 02, 2013 9:04 AM
To: 'staff, cao (PUC)'
Cc: 'doug.renier@state.mn.us'; dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/1/2013 Eden Prairie and Minnetonka POWER RESTORED

Power Outage Eden Prairie and Minnetonka - Power Restored

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Friday, August 02, 2013 04:49
To: dl Electric Outage MW Notification
Subject: WSG-WEST GATE (061) Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/1/2013 Date In : 8/2/2013
Time Out : 19:46 Time In : 04:37

Time Zone : CST

Duration : 8 hours, 51 mins

Number of Customers Affected : 185

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : car hit pole

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/3/13 - Burnsville
Power outage - Burnsville.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, August 03, 2013 8:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/3/2013 Date In :
Time Out : 08:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1091

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/3/13 - Burnsville - UPDATE
Power outage - Burnsville - update.

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 03, 2013 9:21 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/3/2013 Date In :
Time Out : 8:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1091

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LC L9 BURNTUP

Follow-Up : ISOLATE L9, BKR WILL NOT CLOSE BY RC,WILL TRY OPERATOR AT
SUB TO CLOSE LOCAL. TRY TO RESTORE WITH FIELD TIE. CAUSE OF MOMENTARY.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/3/13 - Burnsville - POWER RESTORED
Power outage - Burnsville - power restored.

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 03, 2013 9:37 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2013 Date In : 8/3/2013
Time Out : 8:31 Time In : 9:29

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1091

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LC L9 FAILURE

Follow-Up : ISOLATE L9,RESTORE BY FIELD TIE,REFER FOR REPAIR.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 4:22 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 03:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1038

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

reclosure . Cause : Intellateam expanded outage from the . Presently out from 1 -

Follow-Up : unknown

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/5/13 -Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - UPDATE

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - update/cancel previous notification (see below).

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 5:11 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 03:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1038

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : Cancel the previous notification - opened again @ 0505.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 5:01 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 03:52 Time In : 04:55

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 1038

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up : Closed the (Hot sub. to the).

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 5:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 03:52 Time In : 05:21

Time Zone : CST

Duration : 1 hours, 29 mins

Number of Customers Affected : 1038

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : troublemen investigating step-down bank at the load side of the .

Follow-Up : This accounts for customers from the only.
Still out from the - reclosure.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Aspinwall, David P
Sent: Monday, August 05, 2013 6:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 05:43 Time In : 06:14

Time Zone : CST

Duration : 0 hours, 31 mins

Number of Customers Affected : 4723

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : ARRESTERS

Follow-Up : .

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 10:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Aspinwall, David P
Sent: Monday, August 05, 2013 10:14 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 09:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3727

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BUS SECTION 2 LOCKOUT, CAUSE UNKNOWN AT THIS TIME.

Follow-Up : WILL KNOW MORE SOON.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 05, 2013 11:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, August 05, 2013 11:34 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 09:50 Time In : 11:11

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 3727

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Failed breaker.

Follow-Up : All restored at 11:11.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 2:47 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 597+

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : Intella team - too VRC, lock out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - UPDATE

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - update.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 3:26 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 848

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : Correction to previous notification -# count should read 848.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, August 06, 2013 7:09 AM
To: Karolevitz, Paul W; Jaede, Wendy L
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 02:13 Time In : 03:52

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 848

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : arresters

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED/UPDATE

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored/update.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, August 06, 2013 7:12 AM
To: Karolevitz, Paul W; Jaede, Wendy L
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In : 8/5/2013
Time Out : 03:53 Time In : 04:55

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 1038

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : breaker opened again. customers out from the 13 switch to the reclose. more arresters

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 9:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Golden Valley & Plymouth
Power outage - Golden Valley & Plymouth.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, August 06, 2013 9:03 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 08:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SWITCH BURNED UP-AMPACS AT SWITCH
BAD,NEUTRAL WIRE DOWN.NEEDED TO ISOLATE SWITCH AND FEEDER

Follow-Up : SWITCH TO ISOLATE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 9:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 8/6/13 - Golden Valley & Plymouth - POWER RESTORED
Power outage - Golden Valley & Plymouth - power restored.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, August 06, 2013 9:05 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 08:57 Time In : 08:59

Time Zone : CST

Duration : 0 hours, 2 mins

Number of Customers Affected : 283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SWITCHED TO RESTORE POWER .ISOLATED

SWITCH

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Noticen - 8/6/13 - Minneapolis & Richfield
Power outage - Minneapolis & Richfield.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:33 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2053

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Minneapolis & Richfield - POWER RESTORED
Power outage - Minneapolis & Richfield - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 9:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:40 Time In : 21:22

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 2053

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE REMOVED BETWEEN 100% IN @ 21:22

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:58 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0278.JPG; IMG_0279.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:33 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Silver maple limb broke due to high winds
No visible defects at break point
Tree pruned to full extent
Last VM date 11/2012, work completed as part of VM maintenance map

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 9:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/6/2013

Time Out : 19:40

Time In : 21:22

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 2053

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE REMOVED BETWEEN

100% IN @ 21:22

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata
Power outage - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, August 06, 2013 7:15 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2539

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 7:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - POWER RESTORED
Power outage - Excelsior, Long Lake, Minnetrista, Mound, Orono, Spring Park & Wayzata - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 9:43 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:13 Time In : 21:34

Time Zone : CST

Duration : 2 hours, 21 mins

Number of Customers Affected : 2539

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE & BROKEN POLE ON TAP STILL OUT ON

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 11:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI..tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 11:28 AM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Spruce tree uprooted during storm
Last VM date 1/2012

No pictures due to active Xcel work zone, with flagging, to repair wire.
Also, tree debris was being removed, only stump left.

Christopher Loiselle
Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 9:43 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/6/2013

Time Out : 19:13

Time In : 21:34

Time Zone : CST

Duration : 2 hours, 21 mins

Number of Customers Affected : 2539

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; LONG LAKE, MN; MINNETRISTA, MN; MOUND, MN;
ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE & BROKEN POLE ON . TAP STILL OUT ON

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 10:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:47 Time In : 22:07

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 1306

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 100 % IN @ 22:07 BRANCH'S ALL OVER THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 1:00 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree report
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:54 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree report

VM inspected entire feeder line
Did not conclusively find tree which may have caused the outage
Last VM date 10/2008
Feeder to be worked in 4th quarter of 2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 10:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:47 Time In : 22:07

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 1306

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 100 % IN @ 22:07 BRANCH'S ALL OVER THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - power restored
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 10:58 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:47 Time In : 22:55

Time Zone : CST

Duration : 3 hours, 8 mins

Number of Customers Affected : 2623

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH'S ON THE FEEDER SEVERAL LOCATIONS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:58 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:28 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

VM inspected entire feeder line
Did not conclusively find tree which may have caused outage
Found several trees which tops sheered off by high winds
Trees pruned to full extent
Last VM date 4/2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 10:58 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:47 Time In : 22:55

Time Zone : CST

Duration : 3 hours, 8 mins

Number of Customers Affected : 2623

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH'S ON THE FEEDER SEVERAL LOCATIONS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 11:20 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:46 Time In : 23:14

Time Zone : CST

Duration : 3 hours, 28 mins

Number of Customers Affected : 655

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON THE FEEDER BY THE SWITCH

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:35 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3355

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 1:00 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:50 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable
Unable to locate limb
Based on Troubleman comments it was a broken limb from within the maintenance zone
Last VM date 4/2010

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 11:20 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:46 Time In : 23:14

Time Zone : CST

Duration : 3 hours, 28 mins

Number of Customers Affected : 655

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON THE FEEDER BY THE SWITCH

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Bloomington
Power outage - Bloomington

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:38 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 619

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 11:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:48 Time In : 23:48

Time Zone : CST

Duration : 4 hours, 0 mins

Number of Customers Affected : 619

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH'S ON THE FEEDER ...SEVERAL LOCATIONS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:45 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

VM inspected entire feeder line
Did not conclusively find tree which may have caused outage
Tree pruned to full extent
Last VM date 9/2012, completed as part of VM maintenance map

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 11:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:48 Time In : 23:48

Time Zone : CST

Duration : 4 hours, 0 mins

Number of Customers Affected : 619

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH'S ON THE FEEDER ...SEVERAL LOCATIONS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 06, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/5/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata.

Wendy

From: Kittock, Joseph C
Sent: Monday, August 05, 2013 2:47 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/5/2013 Date In :
Time Out : 02:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 597+

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : Intella team - too VRC, lock out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Eden Prairie, Hopkins & Minnetonka
Power outage - Eden Prairie, Hopkins & Minnetonka.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:31 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2092

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Eden Prairie, Hopkins & Minnetonka -
POWER RESTORED
Power outage - Eden Prairie, Hopkins & Minnetonka - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 12:18 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:32 Time In : 00:13

Time Zone : CST

Duration : 4 hours, 41 mins

Number of Customers Affected : 2092

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 11:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: TREE REPORT
Attachments: IMG_0267.JPG; IMG_0268.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 11:37 AM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: TREE REPORT

Non-preventable

Maple limb failed
Signs of internal decay at break point
Limb appeared healthy
Last worked 6/2010

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 12:18 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:32 Time In : 00:13

Time Zone : CST

Duration : 4 hours, 41 mins

Number of Customers Affected : 2092

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:08 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Edina, Hopkins, Minnetonka & Saint Louis Park
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:26 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2388

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 12:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:31 Time In : 00:22

Time Zone : CST

Duration : 4 hours, 51 mins

Number of Customers Affected : 2388

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON THE FEEDR

Follow-Up : 1854 IN @ 23:54 REMAINING 534 CUSTOMERS RESTORED @ 00:22

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0272.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:09 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-Preventable

Ash limb broke
Prior to failure, defects not visible
Rope and chain added later

Tree pruned to full extent
Last VM date 1/2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 12:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/7/2013

Time Out : 19:31

Time In : 00:22

3/27/2014

Time Zone : CST

Duration : 4 hours, 51 mins

Number of Customers Affected : 2388

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON THE FEEDR

Follow-Up : 1854 IN @ 23:54 REMAINING 534 CUSTOMERS RESTORED @ 00:22

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:47 Time In : 00:34

Time Zone : CST

Duration : 4 hours, 47 mins

Number of Customers Affected : 2253

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON LINE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0280.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:41 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Ash uprooted
No defect visible
Tree pruned to full extent
Last VM date 4/2012

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/7/2013

Time Out : 19:47

Time In : 00:34

Time Zone : CST

Duration : 4 hours, 47 mins

Number of Customers Affected : 2253

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : TREE ON LINE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:36 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2130

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:04 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2016
Time Out : 19:46 Time In : 23:34

Time Zone : CST

Duration : 26307 hours, 48 mins

Number of Customers Affected : 2130

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 1121 CUSTOMERS IN @ 22:58,,, 981 CUSTOMERS IN @ 23:34

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Wednesday, August 07, 2013 6:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/6/2013
Time Out : 19:46 Time In : 23:34

Time Zone : CST

Duration : 3 hours, 48 mins

Number of Customers Affected : 2130

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : none

Cause : storm. 1121 customers in @ 22:58. 981 in @ 23:34

Follow-Up : This is a correction on the restored time.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Hopkins & Minnetonka
Power outage - Hopkins & Minnetonka.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:27 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 456

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Hopkins & Minnetonka - POWER RESTORED

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:31 Time In : 01:35

Time Zone : CST

Duration : 6 hours, 4 mins

Number of Customers Affected : 456

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON THE FEEDER

Follow-Up : 8 CUSTOMERS IN @ 01:22 THE REMAINING 447 CUSTOMERS RESTORED @

01:35

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 11:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: TREE REPORT
FYI...tree report.

Wendy

From: Loisel, Christopher D
Sent: Thursday, August 08, 2013 11:42 AM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: WSG-WEST GATE (351) TREE REPORT

VM inspected entire feeder line. Did not conclusively find tree which may have caused outage
Last VM date 5/2010

Christopher Loisel
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loisel@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:31 Time In : 01:35

Time Zone : CST

Duration : 6 hours, 4 mins

Number of Customers Affected : 456

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON THE FEEDER

Follow-Up : 8 CUSTOMERS IN @ 01:22 THE REMAINING 447 CUSTOMERS RESTORED @

01:35

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Bloomington
Power outage - Bloomington

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:37 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7632

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers :

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington - POWER RESTORED
Power outages - Bloomington - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:47 Time In : 01:30

Time Zone : CST

Duration : 5 hours, 43 mins

Number of Customers Affected : 1450

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCHS ON THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:36 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

VM inspected entire feeder line
Did not conclusively find tree which mat have caused outage
Last VM date 4/2010

Christopher Loiselle
Xcel Energy

Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 1:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:47 Time In : 01:30

Time Zone : CST

Duration : 5 hours, 43 mins

Number of Customers Affected : 1450

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCHS ON THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Bloomington, Edina & Minneapolis
Power outage - Bloomington, Edina & Minneapolis.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:33 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 766

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Bloomington, Edina & Minneapolis - POWER RESTORED

Power outage - Bloomington, Edina & Minneapolis - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 2:03 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:40 Time In : 02:00

Time Zone : CST

Duration : 6 hours, 20 mins

Number of Customers Affected : 766

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:57 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: TREE REPORT
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:24 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: TREE REPORT

VM inspected entire feeder line.
Did not conclusively find tree which may have caused outage
Last VM date 3/2010

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 2:03 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:40 Time In : 02:00

Time Zone : CST

Duration : 6 hours, 20 mins

Number of Customers Affected : 766

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON THE FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Edina & Minnetonka
Power outage - Edina & Minnetonka.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:32 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 650

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Edina & Minnetonka - POWER RESTORED
Power outage - Edina & Minnetonka - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 2:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

EDA-EDINA Final Outage Notice
Feeder/Bus : 088

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:37 Time In : 02:53

Time Zone : CST

Duration : 7 hours, 16 mins

Number of Customers Affected : 650

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:22 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0276.JPG; IMG_0277.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:21 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Willow limb broke
No signs of defect at break point
Last VM date 1/2009

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 2:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/7/2013

Time Out : 19:37

Time In : 02:53

Time Zone : CST

Duration : 7 hours, 16 mins

Number of Customers Affected : 650

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/7/13 - Saint Louis Park
Power outage - Saint Louis Park.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 3:05 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/7/2013 Date In :
Time Out : 01:54 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2662

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PATROLING FEEDER TROUBLEMAN FOUND THE ONE SWITCH OPEN & THE
LOCK CUT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 9:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Saint Louis Park - POWER RESTORED

Power outage - Saint Louis Park - power restored.

Wendy

From: NSP MN Feeder Alerts
Sent: Wednesday, August 07, 2013 9:54 AM
To: Jaede, Wendy L
Subject: FW: Final Outage Notice

This is the final one. We had a momentary at 23:39. It turned out that when our field responders went out there because we were getting outages on that feeder. Someone had vandalized the 1 switch and opened it. So the outage had to go back 23:39.

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 3:58 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 23:40 Time In : 03:52

Time Zone : CST

Duration : 4 hours, 12 mins

Number of Customers Affected : 2662

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BROKEN INSOLATER @ & JUMPERS CUT OPEN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/6/13 - Hopkins & Minnetonka
Power outage - Hopkins & Minnetonka.

Wendy

From: Schwarz, John W
Sent: Tuesday, August 06, 2013 8:25 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In :
Time Out : 19:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1547

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Hopkins & Minnetonka - POWER RESTORED

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 4:32 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:29 Time In : 04:29

Time Zone : CST

Duration : 9 hours, 0 mins

Number of Customers Affected : 1547

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, August 08, 2013 12:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0275.JPG
FYI...tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, August 08, 2013 12:16 PM
To: Schwarz, John W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable

Elm limb broke
No visible signs of defects at break point
Last VM date 3/2010

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 4:32 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/7/2013

Time Out : 19:29

Time In : 04:29

Time Zone : CST

Duration : 9 hours, 0 mins

3/27/2014

Number of Customers Affected : 1547

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE ON FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 9:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/13 - Edina, Hopkins & Saint Louis Park -
POWER RESTORED
Power outage - Edina, Hopkins & Saint Louis Park - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, August 07, 2013 4:49 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2013 Date In : 8/7/2013
Time Out : 19:37 Time In : 04:35

Time Zone : CST

Duration : 8 hours, 58 mins

Number of Customers Affected : 1639

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : JUMPER BURNT OPEN ON A BUCKARM POLE, ONLY 22 CUSTOMERS OUT..
RESTORED 04:34

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 9:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/7/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Wednesday, August 07, 2013 7:48 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/7/2013 Date In :
Time Out : 07:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2729

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, August 07, 2013 9:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/7/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, August 07, 2013 9:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/7/2013 Date In : 8/7/2013
Time Out : 07:42 Time In : 09:12

Time Zone : CST

Duration : 1 hours, 30 mins

Number of Customers Affected : 2729

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : UNKNOWN, NOTHING FOUND ON PATROL.

Follow-Up : THAT IS ALL.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/12/13 - Hamel, Medina, Plymouth & Wayzata
Power outage - Hamel, Medina, Plymouth & Wayzata.

Wendy

From: Anderson, Timothy K
Sent: Monday, August 12, 2013 11:43 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/12/2013 Date In :
Time Out : 23:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1496

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/12/13 - Hamel, Medina, Plymouth & Wayzata -
POWER RESTORED

Power outage - Hamel, Medina, Plymouth & Wayzata - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, August 13, 2013 1:18 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/12/2013 Date In : 8/13/2013
Time Out : 23:31 Time In : 00:47

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 1496

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE FAULT BTWN

Follow-Up : ISO. REFER BIDDLE/REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/13/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, August 13, 2013 12:13 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/13/2013 Date In :
Time Out : 00:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1910

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/13/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, August 13, 2013 2:31 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/13/2013 Date In : 8/13/2013
Time Out : 00:04 Time In : 02:26

Time Zone : CST

Duration : 2 hours, 22 mins

Number of Customers Affected : 1910

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE FAULT BTWN

Follow-Up : ISO. REFER BIDDLE/REPAIR

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 15, 2013 9:16 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice 8/15/2013- EDINA, MN; MINNEAPOLIS, MN;
RICHFIELD, MN - POWER OUTAGE
Power Outage - EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Thursday, August 15, 2013 01:08
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/15/2013 Date In :
Time Out : 00:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2070

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 15, 2013 9:17 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice 8/15/2013 - EDINA, MN; MINNEAPOLIS, MN;
RICHFIELD, MN - POWER RESTORED
Power Restored - EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Thursday, August 15, 2013 03:06
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/15/2013 Date In : 8/15/2013
Time Out : 00:43 Time In : 03:00

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 2070

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : KITE & STRING IN FEEDER

Follow-Up : PATROL,REMOVE OBJECTS, OK

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, August 16, 2013 10:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/16/13 - Crystal, New Hope & Plymouth
Power outage - Crystal, New Hope & Plymouth.

Wendy

From: Hills, Thomas L
Sent: Friday, August 16, 2013 10:16 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/16/2013 Date In :
Time Out : 10:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1161

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, August 16, 2013 11:08 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/16/13 - Crystal, New Hope & Plymouth -
POWER RESTORED
Power outage - Crystal, New Hope & Plymouth - POWER RESTORED

Wendy

From: Hills, Thomas L
Sent: Friday, August 16, 2013 11:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/16/2013 Date In : 8/16/2013
Time Out : 10:11 Time In : 11:01

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 1161

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Patrol ok.

Follow-Up : No reclose on

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/18/13 - Chanhassen
Power outage - Chanhassen.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 8:16 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In :
Time Out : 20:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 596

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:12 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/18/13 - Chanhassen
Power outage - Chanhassen.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 8:18 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In :
Time Out : 20:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 348

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/18/13 - Chanhassen, Edgerton, Excelsior & Shorewood
Power outage - Chanhassen, Edgerton, Excelsior & Shorewood.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 8:17 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In :
Time Out : 20:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2325

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD,
MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/18/13 - Chanhassen, Edgerton, Excelsior & Shorewood - POWER RESTORED
Power outage - Chanhassen, Edgerton, Excelsior & Shorewood - power restored.

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 9:21 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In : 8/18/2013
Time Out : 20:05 Time In : 21:10

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 3269

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD,
MN

State : MN - Minnesota

Major Customers :

Cause : LDC L burned up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/18/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 8:45 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In :
Time Out : 20:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2004

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/18/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 9:57 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In : 8/18/2013
Time Out : 20:37 Time In : 21:32

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 2004

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Feeder cable at bad

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/18/13 - Minneapolis - POWER
RESTORED/UPDATE

Power outage - Minneapolis - power restored/update.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, August 18, 2013 9:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/18/2013 Date In : 8/18/2013
Time Out : 20:37 Time In : 21:49

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 2004

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : feeder cable at bad picked up final 1871 customers

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 9:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/21/13 - Minneapolis & Saint Louis Park
Sorry for the delay.

Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, August 21, 2013 4:56 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/21/2013 Date In :
Time Out : 15:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2559

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONNE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Barraza, Angela
Sent: Thursday, August 22, 2013 10:39 AM
To: 'doug.renier@state.mn.us'; 'consumer.puc@state.mn.us'
Subject: FW: Second Outage Notice

Angela Barraza

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
1800 Larimer St, Ste 1500 Denver, CO 80202
P: 303-294-2103 **F:** 303-294-2393;
E: angela.barraza@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT – CONTAINS TRADE SECRET DATA/PRIVATE DATE ON INDIVIDUALS

From: Ayers, Patrick S
Sent: Wednesday, August 21, 2013 4:34 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/21/2013 Date In :
Time Out : 16:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2559

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD FEEDER CABLE FROM THE

Follow-Up : NEED TO SW TO RESTORE POWER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 9:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Noticen - 8/21/13 - Minneapolis & Saint Louis Park -
POWER RESTORED

Sorry for the delay!

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, August 21, 2013 6:34 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/21/2013 Date In : 8/21/2013
Time Out : 16:52 Time In : 18:26

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 2559

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD FEEDER CABLE

Follow-Up : DID VARIOUS FEEDER SWITCHING IN ORDER TO RESTORE
POWER. LOAD ISSUES WITH FEEDERS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 9:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/22/13 - Hopkins & Saint Louis Park
Sorry for the delay.

Power outage - Hopkins & Saint Louis Park.

Wendy

From: Hills, Thomas L
Sent: Thursday, August 22, 2013 4:53 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/22/2013 Date In :
Time Out : 04:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1414

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree at

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 9:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/22/13 - Hopkins & Saint Louis Park -
UPDATE

Sorry for the delay.

Power outage - Hopkins & Saint Louis Park - update.

Wendy

From: Hills, Thomas L
Sent: Thursday, August 22, 2013 5:54 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/22/2013 Date In :
Time Out : 04:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1414

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree at

Follow-Up : Tree crew called in to remove branch. 292 cust. in at 0548. Remainder to be restored after branch removal.

Eilers, Rebecca D

From: Barraza, Angela
Sent: Thursday, August 22, 2013 10:43 AM
To: consumer.puc@state.mn.us; doug.renier@state.mn.us
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice

Angela Barraza
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
1800 Larimer St, Ste 1500 Denver, CO 80202
P: 303-294-2103 **F:** 303-294-2393
E: angela.barraza@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT – CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Thursday, August 22, 2013 6:59 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/22/2013 Date In : 8/22/2013
Time Out : 04:39 Time In : 07:54

Time Zone : CST

Duration : 3 hours, 15 mins

Number of Customers Affected : 1414

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree at .

Follow-Up : Tree crew called in to remove branch. 292 cust. in at 0548. all in at

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/25/2013- Power Outage - Minneapolis
Power Outage- Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, August 25, 2013 22:28
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 8/25/2013	Date In :
Time Out : 21:52	Time In :

Time Zone : CST
Duration :
Number of Customers Affected : 3372
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/25/2013- POWER RESTORED - Minneapolis
8/25/2013- Power Restored Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Sunday, August 25, 2013 23:58
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 8/25/2013	Date In : 8/25/2013
Time Out : 21:52	Time In : 23:39

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 3372

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed head end cable.

Follow-Up :

Eilers, Rebecca D

From: Weidenfeller, Bradley M
Sent: Friday, August 09, 2013 8:26 AM
To: Driscoll, Paul M; dl Electric Outage ME Notification
Subject: RE: Second O utage Notice

Attachments: photo 1.jpg; photo 2.jpg

Non-preventable

11" dia. Boxelder failed outside of trim area, no signs of decay.

Last time worked 6-2009 scheduled 2014.

Strong winds and storms.

Brad Weidenfeller

Xcel Energy | Responsible By Nature

Supervisor 1, Vegetation Mgmt Transmission

8701 Monticello LN N, Maple Grove, MN 55369

P: 763-493-1827 C: 320-250-2541 F: 763-493-1840

E: bradley.m.weidenfeller@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Driscoll, Paul M
Sent: Wednesday, August 07, 2013 6:58 AM
To: dl Electric Outage ME Notification
Subject: Second O utage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/6/2013

Date In : 8/6/2013

Time Out : 20:01

Time In : 21:50

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 1830

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A large tree took down our feeder between ...

Follow-Up : We are going to need a tree crew and an overhead crew to get this feeder back...

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013- Power Outage/Restored - Minneapolis
8/26/2013- Power Outage/Restored- Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Monday, August 26, 2013 00:46
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 8/26/2013	Date In : 8/26/2013
Time Out : 00:08	Time In : 00:14

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 1179

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Load relief error.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:06 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013- Power Outage - Minneapolis
8/26/2013- Power Outage Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Monday, August 26, 2013 02:26
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 8/26/2013 Date In :
Time Out : 01:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4164

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cabl. 2 switch to the 6 switch.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013- Power Restored - Minneapolis
8/26/2013- Power Restored Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Monday, August 26, 2013 02:41
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013

Time Out : 01:09 Time In : 02:28

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 4164

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable. 2 switch to the 6 switch

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 3:56 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013 - Power Outage Bloomington
8/26/2013- Power Outage, Bloomington

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Monday, August 26, 2013 15:42
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In :
Time Out : 15:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2701

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 4:53 PM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013 - Power Restored Bloomington
8/26/2013- Power Restored Bloomington

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Monday, August 26, 2013 16:50
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/26/2013

Date In : 8/26/2013

Time Out : 15:38

Time In : 16:39

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 2701

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : DID NOT FIND ANY THING WRONG

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013 POWER OUTAGE Minneapolis
8/26/2013- Power Outage Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Monday, August 26, 2013 23:00
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013

Date In :

Time Out : 22:54

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:37 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/26/2013 UPDATE Minneapolis
8/26/2013- UPDATE Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, August 27, 2013 00:22
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013

Time Out : 22:54 Time In : 23:35

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 967

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: 'doug.renier@state.mn.us'
Subject: FW: Third Outage Notice 8/26/2013 UPDATE Minneapolis
8/26/2013 Update Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, August 27, 2013 00:23
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

ALD-ALDRICH Third Outage Notice
Feeder/Bus : 085

Date Out : 8/26/2013 Date In : 8/26/2013
Time Out : 22:54 Time In : 23:44

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 1263

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:39 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013 POWER RESTORED Minneapolis
8/26/2013 - Power Restored Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, August 27, 2013 00:25
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013

Time Out : 22:54 Time In : 23:47

Time Zone : CST

Duration : 0 hours, 53 mins

Number of Customers Affected : 1379

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 4:52 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013 - POWER OUTAGE - Eden Prairie
8/26/2013- Power Outage, Eden Prairie

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Babb, Randall J
Sent: Monday, August 26, 2013 16:26
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013

Date In :

Time Out : 16:21

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1740

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up : Troubleman in route

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013 - POWER RESTORED EDEN PRAIRIE, MN
Power Restored - EDEN PRAIRIE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Babb, Randall J
Sent: Tuesday, August 27, 2013 06:04
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 8/27/2013	Date In : 8/27/2013
Time Out : 16:21	Time In : 17:21

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 1740

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : None

Cause : Head end cable fault.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/27/2013- Power Outage- EDEN PRAIRIE
8/27/2013- Power Outage EDEN PRAIRIE

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Tuesday, August 27, 2013 16:36
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 16:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1816

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/27/2013 - Outage Update - EDEN PRAIRIE
8/27/2013- Update EDEN PRAIRIE

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Babb, Randall J
Sent: Tuesday, August 27, 2013 18:00
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 16:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1816

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Head end cable fault.

Follow-Up : Switching

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:02 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/27/2013 POWER RESTORED EDEN PRAIRIE
8/27/2013- Power Restored EDEN PRAIRIE

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, August 27, 2013 18:47
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In : 8/27/2013

Time Out : 16:33 Time In : 18:36

Time Zone : CST

Duration : 2 hours, 3 mins

Number of Customers Affected : 735

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : non

Cause : head end cable fault

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 12:19 PM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/28/2013 POWER OUTAGE Minneapolis, Saint Louis Park
8/28/2013- POWER OUTAGE Minneapolis, St Louis Park

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Wednesday, August 28, 2013 11:45
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In :
Time Out : 11:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4629

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Emergency fire call. Troubleman on the way.

Follow-Up : No breaker operation.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 1:55 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/28/2013 Outage Update Minneapolis, St Louis Park
8/28/2013- Outage Update, Minneapolis and St Louis Park

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Wednesday, August 28, 2013 12:59
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/28/2013	Date In :
Time Out : 11:13	Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4629

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Feeder line down east of the 3 switch. Automatic sleeve on burned open.

Follow-Up : 98% restored, working on remainder.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/28/2013- POWER RESTORED Mpls, St Louis Park

8/28/2013 - Power Restored Mpls, St Louis Park

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Wednesday, August 28, 2013 14:07
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013

Time Out : 11:13 Time In : 13:50

Time Zone : CST

Duration : 2 hours, 37 mins

Number of Customers Affected : 4629

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Feeder line down east of the 3 switch. Automatic sleeve on . burned open

Follow-Up : Repaired permanent.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:20 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/28/2013 Outage Update CHANHASSEN, MN;
EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD, MN
8/28/2013- Outage Update CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD,
MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 15:25
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013

Time Out : 14:46 Time In : 15:17

Time Zone : CST

Duration : 0 hours, 31 mins

Number of Customers Affected : 2325

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD,

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT WIRE AT

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:19 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/28/2013 POWER OUTAGE
CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD, MN
8/28/2013- Power Outage CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 14:51
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In :

Time Out : 14:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3323

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD,

MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN OPERATOR ON WAY

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:21 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/28/2013- Outage Update CHANHASSEN, MN
8/28/2013- Outage Update CHANHASSEN, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 15:27
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013

Time Out : 14:46 Time In : 15:16

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 401

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN

State : MN - Minnesota

Major Customers :

Cause : TRUCK HIT WIRE AT

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:23 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice 8/28/2013- POWER RESTORED CHANHASSEN, MN
8/28/2013- POWER RESTORED CHANHASSEN, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 17:22
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013

Time Out : 14:46 Time In : 15:23

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 597

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN

State : MN - Minnesota

Major Customers :

Cause : TRUCK HIT WIRES AT

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:24 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/28/2013- POWER RESTORED CHANHASSEN, MN
8/28/2013- POWER RESTORED CHANHASSEN, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 17:25
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013
Time Out : 14:46 Time In : 15:16

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 401

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN

State : MN - Minnesota

Major Customers :

Cause : TRUCK HIT WIRES AT

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 3:48 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/29/2013 POWER OUTAGE Bloomington
8/29/2013- POWER OUTAGE Bloomington

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Thursday, August 29, 2013 15:12
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 8/29/2013	Date In :
Time Out : 15:02	Time In :

Time Zone : CST
Duration :

Number of Customers Affected : 1975

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 12:19 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/29/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Anderson, Timothy K
Sent: Thursday, August 29, 2013 4:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 15:02 Time In : 15:57

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 2895

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE FAULT HEAD END CABLE

Follow-Up : REFER FOR BIDDLE & REPAIR. CORRECTION ON CUST. COUNT FROM 1ST
NOTIFICATION, CARRYING PART OF

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 7:22 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/29/2013- POWER OUTAGE BLOOMINGTON, MN; BURNSVILLE, MN
8/29/2013- POWER OUTAGE BLOOMINGTON, MN; BURNSVILLE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Thursday, August 29, 2013 16:48
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 16:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 410

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 12:22 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/29/13 - Bloomington & Burnsville - POWER RESTORED

Power outage - Bloomington & Burnsville - power restored.

Wendy

From: Kittock, Joseph C
Sent: Thursday, August 29, 2013 7:15 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 16:40 Time In : 18:54

Time Zone : CST

Duration : 2 hours, 14 mins

Number of Customers Affected : 355

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 7:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice 8/29/2013 Outage UPDATE BLOOMINGTON, MN; BURNSVILLE, MN
8/29/2013 Outage Update BLOOMINGTON, MN; BURNSVILLE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Thursday, August 29, 2013 20:13
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 16:40 Time In : 20:07

Time Zone : CST

Duration : 3 hours, 27 mins

Number of Customers Affected : 17

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : non

Cause : Wire down north of

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 7:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/29/2013- POWER RESTORED
BLOOMINGTON, MN; BURNSVILLE, MN
8/29/2013- POWER RESTORED BLOOMINGTON, MN; BURNSVILLE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Thursday, August 29, 2013 21:09
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/29/2013	Date In : 8/29/2013
Time Out : 16:40	Time In : 21:04

Time Zone : CST

Duration : 4 hours, 24 mins

Number of Customers Affected : 2016

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : non

Cause : Automatic sleeve burnt down .

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 3:00 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/30/2013- POWER OUTAGE
MINNETONKA, MN

Follow Up Flag: Follow up

Flag Status: Red

8/30/2013- Power Outage MINNETONKA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Friday, August 30, 2013 14:11
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/30/2013

Date In :

Time Out : 14:07

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1001

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : unknown at this time trouble on the way

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, September 03, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/30/2013 POWER RESTORED MINNETONKA, MN
8/30/2013 POWER RESTORED MINNETONKA, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Friday, August 30, 2013 15:21
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 8/30/2013	Date In : 8/30/2013
Time Out : 14:07	Time In : 15:14

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1001

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Failed head end cable.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/10/13 - Saint Cloud
Power outage - Saint Cloud

Wendy

From: Reinschmidt, Brad A
Sent: Saturday, August 10, 2013 12:23 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/10/2013 Date In :
Time Out : 12:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2746

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/10/13 - Saint Cloud - UPDATE
Power outage - Saint Cloud - update.

Wendy

From: Reinschmidt, Brad A
Sent: Saturday, August 10, 2013 1:44 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/10/2013 Date In :
Time Out : 12:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2746

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : feeder cable failed btw sub and the switch

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/10/13 - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Saturday, August 10, 2013 2:58 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/10/2013 Date In : 8/10/2013
Time Out : 12:11 Time In : 14:41

Time Zone : CST

Duration : 2 hours, 30 mins

Number of Customers Affected : 2746

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers :

Cause : found manhole covers blown off by sub. faulted feeder cable btw sub and
switch.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/13/13 - Buffalo Lake
Power outage - Buffalo Lake.

Wendy

From: Peterson, Mark S
Sent: Tuesday, August 13, 2013 12:23 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/13/2013 Date In :
Time Out : 00:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 386

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO LAKE, MN

State : MN - Minnesota

Major Customers : none

Cause : INTENTIONAL

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, August 13, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/13/13 - Buffalo Lake - POWER RESTORED
Power outage - Buffalo - power restored.

Wendy

From: Medellin, Victor J
Sent: Tuesday, August 13, 2013 5:04 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/13/2013 Date In : 8/13/2013
Time Out : 00:00 Time In : 03:10

Time Zone : CST

Duration : 3 hours, 10 mins

Number of Customers Affected : 386

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO LAKE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : INTENTIONAL

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 16, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/15/2013 Glenwood, Villard - Power Restored
8/15/2013- Glenwood and Villard - Power Restored

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Medellin, Victor J
Sent: Thursday, August 15, 2013 14:03
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/15/2013 Date In : 8/15/2013
Time Out : 13:41 Time In : 13:48

Time Zone : CST

Duration : 0 hours, 7 mins

Number of Customers Affected : 319

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; VILLARD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : INTENTIONAL TO MAKE REPAIRS

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage
Notice - 8/16/13 - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly
Power outage - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly.

Wendy

From: Medellin, Victor J
Sent: Friday, August 16, 2013 11:55 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/16/2013 Date In :
Time Out : 23:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3885

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; COKATO, MN; DELANO, MN; HOWARD LAKE, MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage
Notice - 8/16/13 - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - POWER RESTORED
Power outage - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - power restored.

Wendy

From: Medellin, Victor J
Sent: Saturday, August 17, 2013 1:39 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/16/2013 Date In : 8/17/2013
Time Out : 23:49 Time In : 01:31

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 3885

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; COKATO, MN; DELANO, MN; HOWARD LAKE, MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 10:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/22/13 - Rice, Saint Cloud, Sartell & Sauk Rapids - POWER RESTORED

Sorry for the delay.

Power outage - Rice, Saint Cloud, Sartell & Sauk Rapids - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, August 22, 2013 10:49 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/22/2013 Date In : 8/22/2013

Time Out : 22:29 Time In : 22:38

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 1635

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RICE, MN; SAINT CLOUD, MN; SARTELL, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional outage to clear 34.5kv . Found blown arresters and bushings on

ocr.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013- Power Outage- SAINT CLOUD, MN;
SAUK RAPIDS, MN
8/26/2013- Power Outage SAINT CLOUD, MN; SAUK RAPIDS, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Monday, August 26, 2013 02:02
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In :
Time Out : 01:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4347

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : oc (fdr also carrying part of -load relief and faulted head end
cable) crew being called in

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 8:05 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/26/2013- Power Restored - SAINT CLOUD, MN; SAUK RAPIDS, MN
8/26/2013- Power Restored SAINT CLOUD, MN; SAUK RAPIDS, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Monday, August 26, 2013 06:35
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013
Time Out : 01:54 Time In : 05:42

Time Zone : CST

Duration : 3 hours, 48 mins

Number of Customers Affected : 4347

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : FINAL CUSTOMER REENERGIZED AFTER CABLE FAULT BETWEEN
& @ 0542 / FEEDERS ABNORMAL DUE TO FAULT A COUPLE OF WEEKS AGO THAT HAS NOT
BEEN REPAIRED ON .

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/27/2013- POWER OUTAGE-
BECKER, BIG LAKE, CLEAR LAKE, MONTICELLO
8/27/2013- Power Outage. BECKER, MN; BIG LAKE, MN; CLEAR LAKE, MN; MONTICELLO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Tuesday, August 27, 2013 16:09
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 15:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1136

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; BIG LAKE, MN; CLEAR LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/27/2013- POWER RESTORED-
BECKER,BIG LAKE, CLEAR LAKE, MONTICELLO
8/27/2013- Power Restored BECKER, MN; BIG LAKE, MN; CLEAR LAKE, MN; MONTICELLO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Tuesday, August 27, 2013 16:39
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In : 8/27/2013

Time Out : 15:31 Time In : 16:09

Time Zone : CST

Duration : 0 hours, 38 mins

Number of Customers Affected : 1136

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; BIG LAKE, MN; CLEAR LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : truck damaged 2 poles

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/27/2013- Power Outage GLENWOOD, MN; LOWRY, MN; STARBUCK, MN
8/27/2013- Power Outage GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Tuesday, August 27, 2013 19:32
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 17:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1150

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers :

Cause : Truck hit pole at Starbuck

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:05 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/27/2013- Outage Update GLENWOOD, MN;
LOWRY, MN; STARBUCK, MN
8/27/2013 Outage Update GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Tuesday, August 27, 2013 23:08
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :

Time Out : 17:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1150

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Opened jumpers on feeder at
at 20:22 restoring 870 customers. 140 left out until pole changed.

and closed Breaker

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:06 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice 8/27/2013 Outage Update GLENWOOD, MN; LOWRY, MN; STARBUCK, MN
8/27/2013- Outage Update GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Tuesday, August 27, 2013 23:29
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 17:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1150

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Crew had replaced pole and planned to open switch
to safely close jumpers at Switch went phase to phase when opening and locked breaker out
at SUB. Crew closing jumpers and appears switch will need to be jumpered out also for repairs.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/27/2013- POWER RESTORED GLENWOOD, MN;
LOWRY, MN; STARBUCK, MN
8/27/2013- Power Restored GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Wednesday, August 28, 2013 00:32
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In : 8/27/2013
Time Out : 17:27 Time In : 23:50

Time Zone : CST

Duration : 6 hours, 23 mins

Number of Customers Affected : 1150

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - All customers restored at 23:50

Follow-Up : Burned up switch is jumpered out, will track repair on

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/29/2013- POWER OUTAGE MONTEVIDEO, MN
8/29/2013- POWER OUTAGE MONTEVIDEO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Thursday, August 29, 2013 04:26
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 03:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1335

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTEVIDEO, MN

State : MN - Minnesota

Major Customers :

Cause : (11MVA) appears to have burned open A phase inside the TR - 69KV voltage is good on high side of TR but A phase is dead on 12.5KV. No way to carry load from MTV SUB would need mobile installed.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/29/2013 POWER RESTORED
MONTEVIDEO, MN
8/29/2013- POWER RESTORED MONTEVIDEO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Thursday, August 29, 2013 08:05
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 03:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 467

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTEVIDEO, MN

State : MN - Minnesota

Major Customers :

Cause : A Phase is burned open internally. Mobile Sub is en-route.

Follow-Up : Update: 467 A Phase customers affected. Unable to Field Switch. Momentary to all
Customers on Substation will be needed later today, when Mobile Sub is placed into service, and damaged
is isolated for repairs. Estimated Restoration Time 15:00 Today.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 2:08 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Fourth Outage Notice 8/29/2013 OUTAGE UPDATE MONTEVIDEO, MN
8/29/2013 OUTAGE UPDATE MONTEVIDEO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Thursday, August 29, 2013 13:19
To: dl Electric Outage NT Notification
Subject: Fourth Outage Notice

Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 03:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1335

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTEVIDEO, MN

State : MN - Minnesota

Major Customers :

Cause : failed - A Phase out at 0318 (467 customers).

Follow-Up : 868 B & C Phase customers outaged for safety reasons (limited clearance in sub for mobile installation) at 1230

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 7:24 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/29/2013 POWER RESTORED
MONTEVIDEO, MN
8/29/2013 POWER RESTORED MONTEVIDEO, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Thursday, August 29, 2013 19:42
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 03:18 Time In : 19:30

Time Zone : CST

Duration : 16 hours, 12 mins

Number of Customers Affected : 1335

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTEVIDEO, MN

State : MN - Minnesota

Major Customers :

Cause : Mobile SUB was energized and picked up first section of load at 19:20 and all
customers restored at 19:30

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:08 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/27/2013 POWER OUTAGE CHANDLER,
HADLEY, IONA, LAKE WILSON, SLAYTON,
8/27/2013 Power Outage CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN; SLAYTON,
MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Tuesday, August 27, 2013 19:56
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In :
Time Out : 19:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 370

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN;
SLAYTON, MN

State : SD - South Dakota

Major Customers :

Cause : 69kv fuse blown in the sub, single phasing started at 1900

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/27/2013 POWER RESTORED CHANDLER, HADLEY, IONA, LAKE WILSON, SLAYTON, 8/27/2013 CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN; SLAYTON, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Vorachek, Kelly
Sent: Wednesday, August 28, 2013 01:20
To: dl Electric Outage SD Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/27/2013 Date In : 8/28/2013

Time Out : 19:45 Time In : 01:05

Time Zone : CST

Duration : 5 hours, 20 mins

Number of Customers Affected : 370

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN;

SLAYTON, MN

State : SD - South Dakota

Major Customers : N/A

Cause : 493 - 12.5KV Current Transformers flashed over and blew 69KV high
side fuse. Isolated 69KV and SUB on . Jumpered out CT's and removed, replaced 69KV fuse and
energized at 01:05

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice -
8/11/13 - Belle Plaine, Carver, Colonge, Jordan, Lonsdale, New Prague, Shakopee, Veseli & Webster
Power outage - Belle Plaine, Carver, Cologne, Jordan, Lonsdale, New Prague, Shakopee, Veseli & Webster.

Wendy

From: Medellin, Victor J
Sent: Sunday, August 11, 2013 3:13 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/11/2013 Date In : 8/11/2013
Time Out : 14:46 Time In : 14:52

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 6302

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN;
COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN;
VESELI, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT 3173 CUSTOMERS RESTORED @ 14:52
3129 CUSTOMERS STILL OUT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 12, 2013 8:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/11/13 -
Belle Plaine, Carver, Cologne, Jordan, Lonsdale, New Prague, Shakopee, Veseli & Webster - POWER
RESTORED/UPDATE

Power outage - Belle Plaine, Carver, Cologne, Jordan, Lonsdale, New Prague, Shakopee, Veseli & Webster - power restored/update.

Wendy

From: Medellin, Victor J
Sent: Sunday, August 11, 2013 3:55 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/11/2013 Date In : 8/11/2013
Time Out : 14:46 Time In : 15:42

Time Zone : CST

Duration : 0 hours, 56 mins

Number of Customers Affected : 6302

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN;
COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN;
VESELI, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANS EVENT REMAINING 3129 CUSTOMERS RESTORED 15:42

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/17/13 - Mankato, North Mankato & South Bend
Power outage - Mankato, North Mankato & South Bend.

Wendy

From: Peterson, Mark S
Sent: Saturday, August 17, 2013 6:34 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/17/2013 Date In :
Time Out : 06:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5295

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

MN Communities Affected : MANKATO, MN; NORTH MANKATO, MN; SOUTH BEND,

State : MN - Minnesota

Major Customers : none

Cause : 86 lockout

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/17/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Vorachek, Kelly
Sent: Saturday, August 17, 2013 7:40 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/17/2013 Date In : 8/17/2013
Time Out : 06:31 Time In : 07:30

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1722

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Lockout to - found A phs faults on -
Energized TR2 and closed at 0730 // Patrolling

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/17/13 - Mankato, North Mankato & South Bend - POWER RESTORED

Power outage - Mankato, North Mankato & South Bend - power restored.

Wendy

From: Vorachek, Kelly
Sent: Saturday, August 17, 2013 8:07 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/17/2013 Date In : 8/17/2013
Time Out : 06:31 Time In : 07:57

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 3572

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN; SOUTH BEND, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Lockout on - Crew found blown A phase Porcelain
Arrester at the S Tie SW cleared and closed Breakers by Remote at 07:57 restoring all customers.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 12:16 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/28/2013- POWER OUTAGE - Mankato
8/28/2013 - Power Outage Mankato

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Wednesday, August 28, 2013 08:31
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In :
Time Out : 08:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1628

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Sub and Trouble en-route

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 12:17 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 8/28/2013 UPDATE Mankato
8/28/2013 - Update Mankato

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Wednesday, August 28, 2013 09:19
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In :
Time Out : 08:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1628

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : None

Cause : Crew found Jumpers on
Crew making repairs at this time.

Overhead Switch burned open and flashed.

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, August 28, 2013 12:18 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/28/2013 POWER RESTORED Mankato
8/28/2013- POWER RESTORED Mankato

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Wednesday, August 28, 2013 10:35
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/28/2013 Date In : 8/28/2013

Time Out : 08:27 Time In : 10:30

Time Zone : CST

Duration : 2 hours, 3 mins

Number of Customers Affected : 1628

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Crew replaced two jumpers that burnt open on switch

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 3:45 PM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/29/2013 POWER OUTAGE GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN
8/29/2013- POWER OUTAGE GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Thursday, August 29, 2013 15:01
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In :
Time Out : 13:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 190

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers :

Cause : Wires wrapped on , Non SCADA sub

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, August 30, 2013 7:23 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/29/2013- POWER RESTORED GOODHUE, MN;
LAKE CITY, MN; MOUNT PLEASANT, MN
8/29/2013- POWER RESTORED GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT,
MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Mark S
Sent: Thursday, August 29, 2013 17:17
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/29/2013 Date In : 8/29/2013
Time Out : 13:36 Time In : 17:10

Time Zone : CST

Duration : 3 hours, 34 mins

Number of Customers Affected : 190

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT,
MN

State : MN - Minnesota

Major Customers : none

Cause : wires wrapped on down road. due to oversized load moving

Follow-Up : isolated load thru c bypasses. breaker due to oil spitting out of OCR. Carried

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Tuesday, August 27, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013 POWER OUTAGE EDINA, MN;
MINNEAPOLIS, MN; SAINT LOUIS PARK, MN
8/26/2013 POWER OUTAGE EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Monday, August 26, 2013 18:46
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 8/26/2013 Date In :
Time Out : 18:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2808

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : B PHASE JUMPER BURNED OPEN BY THE 8 SW OPENED BREAKER AT THE
SUB TO DO REPAIRS

Follow-Up : B PHASE JUMPER WAS BLOWING IN THE WIND AND TOUCHING C PHASE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 12:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice *** Momentary Outage *** - 8/26/13 - Edina, Minneapolis & Saint Louis Park - POWER RESTORED
Power outage - Edina, Minneapolis & Saint Louis Park - power restored.

Wendy

From: Lund, Lisa M
Sent: Tuesday, September 03, 2013 12:45
To: Jaede, Wendy L; Lund, Lisa M
Subject: First Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013
Time Out : 18:42 Time In : 18:47

Time Zone : CST

Duration : 0 hours, 5 mins

Number of Customers Affected : 2810

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional outage to repair B phase jumber

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, August 29, 2013 8:22 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/28/2013- POWER OUTAGE MINNETONKA, MN; PLYMOUTH, MN
8/28/2013- Power Outage MINNETONKA, MN; PLYMOUTH, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, August 28, 2013 15:29
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/28/2013	Date In : 8/28/2013
Time Out : 14:46	Time In : 15:23

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 1236

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT WIRES AT

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, August 26, 2013 3:55 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 8/26/2013 POWER OUTAGE Hopkins,
Minnetonka, Plymouth, Wayzata
8/26/2013 POWER OUTAGE Hopkins, Minnetonka, Plymouth, Wayzata

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Monday, August 26, 2013 14:46
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In :
Time Out : 14:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 933

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : WILL PATROL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 12:09 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/26/13 - Hopkins, Minnetonka, Plymouth & Wayzata - POWER RESTORED

Sorry for the delay.

Power outage - Hopkins, Minnetonka, Plymouth & Wayzata - power restored.

Wendy

From: Lund, Lisa M
Sent: Tuesday, September 03, 2013 12:05 PM
To: Jaede, Wendy L; Lund, Lisa M
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/26/2013 Date In : 8/26/2013
Time Out : 14:42 Time In : 15:33

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 934

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable between 2 & 3 switch. 19 customers restored at 1514; final 915 restored at 1533.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 1:41 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/19/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Monday, August 19, 2013 1:07 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/19/2013 Date In :
Time Out : 13:01 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1920

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 2:06 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 8/19/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Monday, August 19, 2013 2:05 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/19/2013 Date In : 8/19/2013
Time Out : 13:01 Time In : 13:51

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 1920

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : head end cable

Follow-Up : switch out under

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, August 19, 2013 2:28 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/19/13 - Saint Paul - POWER RESTORED/UPDATE
Power outage - Saint Paul - power restored/update.

Wendy

From: Chial, Terry L
Sent: Monday, August 19, 2013 2:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/19/2013 Date In : 8/19/2013
Time Out : 13:01 Time In : 13:51

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 1920

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bad head cable

Follow-Up : referred to area for repair

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 10, 2013 8:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/10/13 - Maplewood & Saint Paul
Power outage - Maplewood & Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Tuesday, September 10, 2013 8:22 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/10/2013 Date In :
Time Out : 08:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1946

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS TIME. TROUBLE TO RESPOND

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 10, 2013 8:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/10/13 - Maplewood & Saint Paul -
UPDATE

Power outage - Maplewood & Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Tuesday, September 10, 2013 8:54 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/10/2013 Date In :
Time Out : 08:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1946

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TROUBLE PATROLLING

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 10, 2013 9:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/10/13 - Maplewood & Saint Paul - POWER RESTORED

Power outage - Maplewood & Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, September 10, 2013 9:09 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/10/2013 Date In : 9/10/2013
Time Out : 08:17 Time In : 09:03

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1946

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : AT
TROUBLEMAN FOUND OVER HEAD ARRESSTERS BLOWN ON 3 PHASE BANK.
CLEARED ARRESSTERS AND FEEDER BACK IN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/15/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul
Power Outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, September 15, 2013 5:36 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In :
Time Out : 05:15 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3527

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : .

Cause : unknown at this time

Follow-Up : patrolling

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/15/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Sunday, September 15, 2013 6:55 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In : 9/15/2013
Time Out : 05:15 Time In : 06:47

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 3527

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : fault downstream of swich,picked up 50 %

Follow-Up : will restore rest as we can .

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/15/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED/UPDATE
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored/update.

Wendy

From: Chial, Terry L
Sent: Sunday, September 15, 2013 8:50 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In : 9/15/2013
Time Out : 05:15 Time In : 06:47

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 3527

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bell on feeder failed ,

Follow-Up : 100 % restored 0845

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:27 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/15/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul
Power outages - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul.

Wendy

From: Chial, Terry L
Sent: Sunday, September 15, 2013 6:27 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In : 9/15/2013
Time Out : 06:13 Time In : 06:19

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 1793

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : switch bad

Follow-Up : will repair

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/15/13 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED

Power outages - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Sunday, September 15, 2013 6:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In : 9/15/2013
Time Out : 06:13 Time In : 06:19

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 1793

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : fault on feeder, when picking up load with took
out bkr

Follow-Up : will refere as needed

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/15/13 - Maplewood & Saint Paul
Power outage - Maplewood & Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Sunday, September 15, 2013 8:19 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In :
Time Out : 19:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2918

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS TIME- PART OF IS BEING
FEED BY

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/15/13 - Maplewood & Saint Paul - UPDATE
Power outage - Maplewood & Saint Paul - update.

Wendy

From: Abbott, Edward J
Sent: Sunday, September 15, 2013 8:40 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In :
Time Out : 19:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2918

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : C PHASE ON FEEDER BURNT DOWN AT
GOING TO THE NORTH, TROUBLE WILL CUT IN CLEAR AND FIELD SWITCH TO
BRING EVERYONE BACK IN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 8:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/15/13 - Maplewood & Saint Paul - POWER RESTORED

Power outage - Maplewood & Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Sunday, September 15, 2013 9:10 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/15/2013 Date In : 9/15/2013
Time Out : 19:57 Time In : 21:08

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2918

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : CUT C PHASE FEEDER IN THE CLEAR. PUT
BACK TO NORMAL(IT WAS SWITCHED FOR LOAD RELIEF) AND FIELD SWITCHED
TO BRING BACK ALL CUSTOMERS

Follow-Up : REFERRED FOR WBL O.H. TO PUT C PHASE FEEDER
BACK UP ASAP MONDAY MORNING.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 12:10 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/16/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Chial, Terry L
Sent: Monday, September 16, 2013 12:06 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/16/2013 Date In :
Time Out : 12:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 997

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : TRUCK HIT POLE

Follow-Up : ON ROUTE

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 16, 2013 12:31 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/16/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Monday, September 16, 2013 12:27 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/16/2013 Date In : 9/16/2013
Time Out : 12:00 Time In : 12:25

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 997

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : TRUCK HIT GUY WIRE CAUSING PHASE TO BURN
DOWN.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:08 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice 9/18/2013 OAK PARK HEIGHTS, MN; STILLWATER, MN
Power Outage OAK PARK HEIGHTS, MN; STILLWATER, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Wednesday, September 18, 2013 07:41
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/18/2013 Date In :
Time Out : 07:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2266

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:09 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice 9/18/2013 UPDATE OAK PARK HEIGHTS, MN;
STILLWATER, MN
Outage Update - OAK PARK HEIGHTS, MN; STILLWATER, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Wednesday, September 18, 2013 08:11
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/18/2013 Date In : 9/18/2013
Time Out : 07:19 Time In : 07:49

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 1651

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up : problem past . Open and close bkr at 7:49. 615
cust's still out until cause found

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Third Outage Notice 9/18/2013 Update OAK PARK HEIGHTS, MN;
STILLWATER, MN
Outage Update OAK PARK HEIGHTS, MN; STILLWATER, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Wednesday, September 18, 2013 09:03
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 9/18/2013 Date In : 9/18/2013
Time Out : 07:19 Time In : 08:50

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 483

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up : On , 132 cust's remain out of power and is being patrolled,
95% of fdr restored

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:11 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Fourth Outage Notice Power Restored 9/18/2013 OAK PARK HEIGHTS, MN; STILLWATER, MN
Power Restored- OAK PARK HEIGHTS, MN; STILLWATER, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Wednesday, September 18, 2013 09:10
To: dl Electric Outage ME Notification
Subject: Fourth Outage Notice

Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 9/18/2013 Date In : 9/18/2013
Time Out : 07:19 Time In : 09:07

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 132

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : none

Cause : no cause found for fdr lock

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 10:33 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/4/13 - Golden Valley, Minnetonka & Saint Louis Park
Power outage - Golden Valley, Minnetonka & Saint Louis Park.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 9:57 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In :
Time Out : 09:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1048

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME.

Follow-Up : WILL PATROL.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 11:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/4/13 - Golden Valley, Minnetonka, Plymouth & Saint Louis Park - UPDATE
Power outage - Golden Valley, Minnetonka, Plymouth & Saint Louis Park - update.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 10:40 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In :
Time Out : 09:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1837

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; PLYMOUTH, MN;
SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : BURNT UP LOAD CENTER.

Follow-Up : WILL ISOLATE.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 11:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/4/13 - Golden Valley, Minnetonka & Saint Louis Park - POWER RESTORED

Power outage - Golden Valley, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 11:09 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In : 9/4/2013
Time Out : 09:40 Time In : 11:05

Time Zone : CST

Duration : 1 hours, 25 mins

Number of Customers Affected : 1048

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers :

Cause : BURNT UP LOAD CENTER, L02.

Follow-Up : ISOLATED FOR REPAIR.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 10:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/4/13 - Golden Valley, Plymouth & Saint Louis Park
Power outage - Golden Valley, Plymouth & Saint Louis Park

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 9:58 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In :
Time Out : 09:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 789

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; PLYMOUTH, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME.

Follow-Up : WILL PATROL.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 11:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/4/13 - Golden Valley, Minnetonka, Plymouth & Saint Louis Park - UPDATE
Power outage - Golden Valley, Minnetonka, Plymouth & Saint Louis Park - update.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 10:40 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In :
Time Out : 09:40 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1837

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; PLYMOUTH, MN;
SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : BURNT UP LOAD CENTER.

Follow-Up : WILL ISOLATE.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 11:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/4/13 - Golden Valley, Plymouth & Saint Louis Park - POWER RESTORED

Power outage - Golden Valley, Plymouth & Saint Louis Park - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 04, 2013 11:44 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In : 9/4/2013
Time Out : 09:40 Time In : 11:41

Time Zone : CST

Duration : 2 hours, 1 mins

Number of Customers Affected : 789

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; PLYMOUTH, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : BURNT UP LOAD CENTER L02.

Follow-Up : ISOLATED FOR REPAIR.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 06, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/5/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Knutson, David A
Sent: Thursday, September 05, 2013 3:07 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/5/2013 Date In :
Time Out : 15:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 77

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 06, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/5/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Thursday, September 05, 2013 4:25 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 9/5/2013	Date In : 9/5/2013
Time Out : 15:04	Time In : 16:18

Time Zone : CST
Duration : 1 hours, 14 mins
Number of Customers Affected : 76
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369
Communities Affected : MINNEAPOLIS, MN
State : MN - Minnesota
Major Customers :
Cause : Faulted cable
Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/6/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata.

Wendy

From: Hills, Thomas L
Sent: Friday, September 06, 2013 5:53 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/6/2013 Date In :
Time Out : 16:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2083

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/6/13 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, September 06, 2013 7:53 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/6/2013 Date In : 9/6/2013
Time Out : 16:43 Time In : 19:50

Time Zone : CST

Duration : 3 hours, 7 mins

Number of Customers Affected : 2083

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : sectionalized. restored part of and then
R 1630 VRC opened for unknown reason. Patrolled ok.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/6/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria.

Wendy

From: Anderson, Timothy K
Sent: Friday, September 06, 2013 5:10 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/6/2013 Date In :
Time Out : 16:26 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 6349

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN;
EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN,POSSIBLE MULTIPLE PROBLEMS

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/6/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - UPDATE
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - update.

Wendy

From: Hills, Thomas L
Sent: Friday, September 06, 2013 7:25 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/6/2013 Date In :
Time Out : 16:26 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 6349

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN;
EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : None

Cause : Broken crossarm at

Follow-Up : Crew called in to repair crossarm. 854 customers out until repairs are made.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/6/13 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - POWER RESTORED
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - power restored.

Wendy

From: Hills, Thomas L
Sent: Saturday, September 07, 2013 12:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/6/2013 Date In : 9/7/2013
Time Out : 16:26 Time In : 00:22

Time Zone : CST

Duration : 7 hours, 56 mins

Number of Customers Affected : 854

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN;
EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : None

Cause : Broken crossarm at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/8/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Sunday, September 08, 2013 8:46 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In :
Time Out : 08:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1598

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Load center faulted.

Follow-Up : Isolating LDCR to restore.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/8/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Sunday, September 08, 2013 8:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In : 9/8/2013
Time Out : 08:24 Time In : 08:54

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 1598

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Load center faulted.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/11/13 - Minnetonka
Power outage - Minnetonka.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, September 11, 2013 10:27 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/11/2013 Date In :
Time Out : 22:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1001

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/11/13 - Minnetonka - POWER RESTORED
Power outage - Minnetonka - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, September 11, 2013 11:11 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/11/2013 Date In : 9/11/2013
Time Out : 22:23 Time In : 22:45

Time Zone : CST

Duration : 0 hours, 22 mins

Number of Customers Affected : 1001

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Head end cable

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 11:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/12/13 -
Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park

Power outage - Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, September 12, 2013 11:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/12/2013 Date In :
Time Out : 11:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 12514

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLAINE, MN; COLUMBIA HEIGHTS, MN; COON RAPIDS, MN;
FRIDLEY, MN; MINNEAPOLIS, MN; MOUNDS VIEW, MN; NEW BRIGHTON, MN; SPRING LAKE
PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time. Buss 2 lockout

Follow-Up : feeder also lockout at same time.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 12:57 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/12/13 - Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park - POWER RESTORED

Power outage - Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, September 12, 2013 12:45 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/12/2013 Date In : 9/12/2013
Time Out : 11:10 Time In : 12:12

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 10488

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLAINE, MN; COLUMBIA HEIGHTS, MN; COON RAPIDS, MN; FRIDLEY, MN; MINNEAPOLIS, MN; MOUNDS VIEW, MN; NEW BRIGHTON, MN; SPRING LAKE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Possible equipment failure. Still under investigation

Follow-Up : Relay on site. to be energized shortly

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 11:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/12/13 -
Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park

Power outage - Blaine, Columbia Heights, Coon Rapids, Fridley, Minneapolis, Mounds View, New Brighton & Spring Lake Park.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, September 12, 2013 11:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/12/2013 Date In :
Time Out : 11:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 12514

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLAINE, MN; COLUMBIA HEIGHTS, MN; COON RAPIDS, MN;
FRIDLEY, MN; MINNEAPOLIS, MN; MOUNDS VIEW, MN; NEW BRIGHTON, MN; SPRING LAKE
PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time. Buss 2 lockout

Follow-Up : feeder also lockout at same time.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 12, 2013 12:59 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: 'staff, cao (PUC)'
Subject: FW: Final Outage Notice - Fridley, Minneapolis & Spring Lake Park -
POWER RESTORED
Power outage - Fridley, Minneapolis & Spring Lake Park - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, September 12, 2013 12:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 9/12/2013	Date In : 9/12/2013
Time Out : 11:10	Time In : 12:43

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 2026

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN; SPRING LAKE PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Possible equipment failure

Follow-Up : investigation on going. This restores eveyone

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice OUTAGE 9/18/2013 EDEN PRAIRIE, MN
Power Outage EDEN PRAIRIE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, September 18, 2013 09:54
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/18/2013

Date In :

Time Out : 09:49

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 589

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, September 19, 2013 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Final Outage Notice Power Restored 9/18/2013 EDEN PRAIRIE, MN
Power Restored- EDEN PRAIRIE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Wednesday, September 18, 2013 12:03
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/18/2013 Date In : 9/18/2013
Time Out : 09:49 Time In : 10:49

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 589

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT CABLE BETWEEN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/19/13 - Hopkins & Minnetonka
Power outage - Hopkins & Minnetonka.

Wendy

From: Babb, Randall J
Sent: Thursday, September 19, 2013 10:18 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 10:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown at this time.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/19/13 - Hopkins & Minnetonka - UPDATE
Power outage - Hopkins & Minnetonka - update.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 10:56 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 10:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE LAYING ACROSS FEEDER AT
,TROUBLEMAN TO REMOVE TREE OFF FEEDER.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 11:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9-19-13 - Hopkins & Minnetonka - POWER RESTORED

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 11:30 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 10:14 Time In : 11:27

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 1554

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE ON FEEDER,TREE REMOVED,FEEDER PATROLLED,BKR CLOSED RC.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 3:47 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 9/19/13
Attachments: IMG_0360.JPG

Non-preventable

Silver maple lead broke during storm due to internal decay. No visible outward signs of decay.
All debris removed on arrival.
Last worked 3/2011

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 11:30 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013

Date In : 9/19/2013

Time Out : 10:14

Time In : 11:27

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 1554

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

3/25/2014

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE ON FEEDER, TREE REMOVED, FEEDER
PATROLLED, BKR CLOSED RC.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/19/13 -
Brooklyn Center, Brooklyn Park, Crystal, Minneapolis, New Hope & Robbinsdale
Power outage - Brooklyn Center, Brooklyn Park, Crystal, Minneapolis, New Hope & Robbinsdale.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 10:31 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 10:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 16759

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN;
CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : BUSS LOCK- LOCKOUT ON BUSS
.UNKNOWN AT TIME

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 12:27 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/19/13 -
Brooklyn Center, Brooklyn Park, Crystal, Minneapolis, New Hope & Robbinsdale - POWER
RESTORED

Power outage - Brooklyn Center, Brooklyn Park, Crystal, Minneapolis, New Hope & Robbinsdale - power restored.

Wendy

From: Cedar, Daren A
Sent: Thursday, September 19, 2013 11:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 10:25 Time In : 11:44

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 16759

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN; CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers :

Cause : will need to portol all feeders yet dont know what happened

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 11:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/19/13 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata
Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 11:09 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 11:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1959

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN;
MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING
PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 12:30 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/19/13 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - UPDATE
Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - update.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:28 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 11:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1959

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN;
MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING
PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER, TROUBLEMAN TO REMOVE TREE
AND BRANCH.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 12:34 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9-19-13 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - POWER RESTORED
Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - power restored.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:32 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 11:06 Time In : 12:29

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1959

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN;
MINNETONKA BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING
PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCH ON FEEDER AT
.TROUBLEMAN REMOVED BRANCH AND PATROLLED
FEEDER.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 3:14 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 9/19/13
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Thursday, September 19, 2013 3:12 PM
To: Ayers, Patrick S; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-preventable
Broken limb based on Troubleman's comments. Found small charred piece of a maple branch on site. All other debris was removed on arrival.
Feeder last worked 2/2013 and tree at location given was pruned to the full extent.

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:32 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 11:06 Time In : 12:29

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1959

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA
BCH, MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCH ON FEEDER AT
.TROUBLEMAN REMOVED BRANCH AND PATROLLED
FEEDER.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:48 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/1913 - Bloomington, Eden Prairie & Edina
Power outage - Bloomington, Eden Prairie & Edina.

Wendy

From: Babb, Randall J
Sent: Thursday, September 19, 2013 10:38 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 10:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 773

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown at this time.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 1:33 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/19/13 - Bloomington, Eden Prairie & Edina - POWER RESTORED

Power outage - Bloomington, Eden Prairie & Edina - power restored.

Wendy

From: Babb, Randall J
Sent: Thursday, September 19, 2013 1:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 10:22 Time In : 11:54

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 773

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch on overhead line.

Follow-Up : Breaker would not operate. Field switched for restoration. Relay on site for breaker repair.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 23, 2013 11:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 9/19/13

Preventable

Inspected entire mainline and unable to locate limb

Based on Troubleman's comments it was a broken limb form within the maintenance zone

Work last completed in October 2010 as part of VM Maintenance Map

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Babb, Randall J
Sent: Thursday, September 19, 2013 1:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 10:22 Time In : 11:54

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 773

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

3/25/2014

Major Customers : None

Cause : Branch on overhead line.

Follow-Up : Breaker would not operate. Field switched for restoration. Relay on site for breaker repair.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 11:49 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9-19-13 - Coon Rapids & Fridley
Power outage - Coon Rapids & Fridley.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 11:46 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 11:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN AT TIME

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 1:35 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/19/13 - Coon Rapids & Fridley - UPDATE
Power outage - Coon Rapids & Fridley - update.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:27 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 11:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE BRANCH ON FEEDER AT
TROUBLEMAN TO CLEAR BRANCH

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 12:46 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 9/19/13 - Coon Rapids & Fridley - UPDATE
Power outage - Coon Rapids & Fridley - update.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:43 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 11:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCH ON FEEDER, TROUBLEMAN
REMOVED BRANCH PATROLLED FEEDER. BKR WOULD NOT CLOSE
RC, NEED OPERATOR AT SUB.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 20, 2013 8:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/19/13 - Coon Rapids & Fridley - POWER RESTORED

Power outage - Coon Rapids & Fridley - power restored.

Wendy

From: Ayers, Patrick S
Sent: Friday, September 20, 2013 8:31 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 11:43 Time In : 13:30

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 1062

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : none

Cause : large tree branch on feeder, troubleman removed branch. patrolled feeder. this feeder outage had longer outage duration due to the fact that the bkr at the sub would not close rc. needed operator to close bkr.

Follow-Up : bkr issue referred to em@p, relay depts.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 3:24 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 9/19/13
Attachments: IMG_0364.JPG; IMG_0362.JPG

Preventable

Dead silver maple limb broke during storm and fell into conductors.
Last worked 11/2009 as part of VM maintenance map

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Ayers, Patrick S
Sent: Thursday, September 19, 2013 12:27 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/19/2013

Date In :

Time Out : 11:43

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1062

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COON RAPIDS, MN; FRIDLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE BRANCH ON FEEDER AT
.TROUBLEMAN TO CLEAR BRANCH

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 23, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/21/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 21, 2013 7:04 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/21/2013 Date In :
Time Out : 07:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 517

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown at time

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 23, 2013 8:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/21/13 - Minneapolis - UPDATE
Power outage - Minneapolis - update.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 21, 2013 7:37 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/21/2013 Date In :
Time Out : 07:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 517

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : contractor drove stake into feeder at ,need to
isolate feeder

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 23, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/21/13 - Minneapolis - POWER
RESTORED

Power outage - Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 21, 2013 7:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/21/2013 Date In : 9/21/2013
Time Out : 07:00 Time In : 07:37

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 517

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : contractor hit feeder cable .isolated hit feeder cable,

Follow-Up : feeder cable is only about 18 inches deep at this location
will need to be lowered for about 150-to -200 feet

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 24, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/24/13 - Minnetrista, Mound, Shorewood & Spring Park
Power outage - Minnetrista, Mound, Shorewood & Spring Park.

Wendy

From: Babb, Randall J
Sent: Tuesday, September 24, 2013 1:46 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/24/2013 Date In :
Time Out : 01:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2347

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING
PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Unknown.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 24, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/24/13 - Minnetrista, Mound, Shorewood & Spring Park - POWER RESTORED

Power outage - Minnetrista, Mound, Shorewood & Spring Park - power restored.

Wendy

From: Babb, Randall J
Sent: Tuesday, September 24, 2013 2:58 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/24/2013 Date In : 9/24/2013
Time Out : 01:37 Time In : 02:48

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2347

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree contact with the switch causing lightning arrester to fail.

Follow-Up : Refer for complete feeder line for tree trimming.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 24, 2013 3:44 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0367.JPG; IMG_0366.JPG

Preventable

Oak tree with side growth next to
Last worked 12/2008

On 2013 schedule, maintenance worked started on Monday 9/23/2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Babb, Randall J
Sent: Tuesday, September 24, 2013 2:58 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/24/2013 Date In : 9/24/2013
Time Out : 01:37 Time In : 02:48

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2347

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : MINNETRISTA, MN; MOUND, MN; SHOREWOOD, MN; SPRING PARK,

State : MN - Minnesota

Major Customers : None

Cause : Tree contact with the switch causing lightning arrester to fail.

Follow-Up : Refer for complete feeder line for tree trimming.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 26, 2013 2:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/26/13 - Edina, Hopkins, Minnetonka & Saint Louis Park
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park.

Wendy

From: Ayers, Patrick S
Sent: Thursday, September 26, 2013 2:48 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/26/2013 Date In :
Time Out : 14:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN;
SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT TIME

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 26, 2013 4:05 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/26/13 - Edina, Hopkins, Minnetonka & Saint Louis Park - UPDATE
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park - update.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, September 26, 2013 3:07 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/26/2013 Date In :
Time Out : 14:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2391

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell on oh wire at / automatic burned open
at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 26, 2013 4:06 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 9/26/13 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, September 26, 2013 3:57 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 9/26/2013 Date In : 9/26/2013
Time Out : 14:44 Time In : 15:50

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 2391

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS
PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell on oh wire and caused a automatic splice to fail

Follow-Up : Picked up 1485 customers to the new 17 switch

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 27, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/26/13 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED/UPDATE
Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park - power restored/update.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, September 26, 2013 4:42 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 9/26/2013	Date In : 9/26/2013
Time Out : 14:44	Time In : 16:24

Time Zone : CST

Duration : 1 hours, 40 mins

Number of Customers Affected : 2391

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell on oh wire and caused a automatic splice to fail

Follow-Up : picked up final 906 customers

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 27, 2013 1:05 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0376.JPG; IMG_0375.JPG

Non-preventable

Silver maple, from outside maintenance zone, had dead limb break from within its canopy and fall across conductors
Feeder last worked 1/2013

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Peterson, Kenneth W
Sent: Thursday, September 26, 2013 4:42 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/26/2013 Date In : 9/26/2013

Time Out : 14:44 Time In : 16:24

Time Zone : CST

Duration : 1 hours, 40 mins

Number of Customers Affected : 2391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS

3/25/2014

PARK, MN

State : MN - Minnesota

Major Customers :

Cause : Tree fell on oh wire and caused a automatic splice to fail

Follow-Up : picked up final 906 customers

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 27, 2013 2:06 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/27/13 - Bloomington & Burnsville
Power outage - Bloomington & Burnsville

Wendy

From: Cedar, Daren A
Sent: Friday, September 27, 2013 2:00 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/27/2013 Date In :
Time Out : 13:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 410

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, September 27, 2013 3:55 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/27/13 - Bloomington & Burnsville - POWER RESTORED

Power outage - Bloomington & Burnsville - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, September 27, 2013 3:19 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/27/2013 Date In : 9/27/2013
Time Out : 13:53 Time In : 15:10

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 410

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; BURNSVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/28/13 - Brooklyn Park, Maple Grove & Osseo
Power outage - Brooklyn Park, Maple Grove & Osseo.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, September 28, 2013 12:43 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In :
Time Out : 12:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 172

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : Car hit double deck pole at

Follow-Up : opened feeder for trouble to clear fire at pole

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/28/13 - Brooklyn Park, Maple Grove & Osseo -
UPDATE

Power outage - Brooklyn Park, Maple Grove & Osseo - update.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, September 28, 2013 1:09 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In :
Time Out : 12:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 172

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : car hit pole

Follow-Up : picked up 137 customers breaker to / picked up 15 customers
 / 20 customers out

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:26 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/28/13 - Brooklyn Park, Maple Grove & Osseo -
POWER RESTORED

Power outage - Brooklyn Park, Maple Grove & Osseo - power restored.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 28, 2013 6:28 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In : 9/28/2013
Time Out : 12:44 Time In : 18:23

Time Zone : CST

Duration : 5 hours, 39 mins

Number of Customers Affected : 172

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN;
OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : burned up pole, broken xarms , wire down

Follow-Up : final 20 cust. on returned as of 1823.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/27/13- Brooklyn Park, Crystal, Maple Grove & New Hope
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope.

Wendy

From: Hills, Thomas L
Sent: Saturday, September 28, 2013 12:05 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In :
Time Out : 11:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1593

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:18 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/28/13 - Brooklyn Park, Crystal, Maple Grove & New Hope - UPDATE
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope - update.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, September 28, 2013 12:39 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In :
Time Out : 11:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1593

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Car hit double decked pole at

Follow-Up : Crews and troublemen on site

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:22 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 9/28/13 - Brooklyn Park, Crystal, Maple Grove & New Hope - UPDATE
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope - update.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, September 28, 2013 1:55 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In :
Time Out : 11:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1593

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit double deck pole

Follow-Up : picked up 1559 customers at
customers out

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:23 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/28/13 - Brooklyn Park, Crystal, Maple Grove & New Hope - POWER RESTORED

Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope - power restored.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 28, 2013 9:45 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/28/2013 Date In : 9/28/2013
Time Out : 11:53 Time In : 21:35

Time Zone : CST

Duration : 9 hours, 42 mins

Number of Customers Affected : 1593

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BURN UP POLE ,WIRE DOWN,X ARM BROKEN.

Follow-Up : THIS FINAL OUTAGE NOTIFICATION IS FOR 168 CUST.
ON FEEDER.THERE WAS 168 CUST OUT UNTIL RESTORED AS OF 2135

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 12:53 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/30/13 - Brooklyn Park, Crystal, Maple Grove, New Hope
Power outage - Brooklyn Park, Crystal, Maple Grove, New Hope.

Wendy

From: Hills, Thomas L
Sent: Monday, September 30, 2013 12:51 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/30/2013 Date In :
Time Out : 12:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear emergency pole change out.

Follow-Up : Crew on site.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 2:07 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/30/13 - Brooklyn Park, Crystal, Maple Grove & New Hope - POWER RESTORED
Power outage - Brooklyn Park, Crystal, Maple Grove & New Hope - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, September 30, 2013 1:29 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/30/2013 Date In : 9/30/2013
Time Out : 12:49 Time In : 13:24

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 7

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MAPLE GROVE, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear emergency pole change out.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 12:42 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/30/13 - Brooklyn Park, Maple Grove & Osseo
Power outage - Brooklyn Park, Maple Grove & Osseo.

Wendy

From: Hills, Thomas L
Sent: Monday, September 30, 2013 12:22 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/30/2013 Date In :
Time Out : 12:15 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 20

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear emergency pole change out.

Follow-Up : Crew on site.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 2:03 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/30/13 - Brooklyn Park, Maple Grove & Osseo -
POWER RESTORED

Power outage - Brooklyn Park, Maple Grove & Osseo - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, September 30, 2013 1:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/30/2013 Date In : 9/30/2013
Time Out : 12:15 Time In : 13:46

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 20

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : MEDTRONIC -

Cause : Intentional to clear emergency pole change out.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 12:04 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/4/13 - Big Lake & Monticello
Power outage - Big Lake & Monticello.

Wendy

From: Peterson, Mark S
Sent: Wednesday, September 04, 2013 12:02 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In :
Time Out : 11:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CREW IN ROUTE. BREAKER WAS ON MANUAL FOR
HOTLINE CLEARANCE, BUT CREW WAS NO INVOLVED IN LOCK.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 04, 2013 1:02 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/4/13 - Big Lake & Monticello - POWER RESTORED

Power outage - Big Lake & Monticello - power restored.

Wendy

From: Peterson, Mark S
Sent: Wednesday, September 04, 2013 12:39 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/4/2013 Date In : 9/4/2013
Time Out : 11:50 Time In : 12:30

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNDERGROUND FAULT ON 1/0 LOOP DID NOT CLEAR
CAUSING FEEDER TO LOCK OPEN AT

Follow-Up : BREAKER WAS ON MANUAL FOR ONE SHOT HOT LINE
CLEARANCE.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice -9/19/13 - Sacred Heart
Power outage - Sacred Heart.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, September 19, 2013 9:33 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 09:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 333

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SACRED HEART, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional outage to cut open feeder where tree has knocked down the lines. Location is on .

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/19/13 - Sacred Heart - POWER RESTORED
Power outage - Sacred Heart - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, September 19, 2013 9:58 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 9/19/2013	Date In : 9/19/2013
Time Out : 09:23	Time In : 09:36

Time Zone : CST
Duration : 0 hours, 13 mins
Number of Customers Affected : 306
For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SACRED HEART, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional outage to clear down lines. Crew to install fuses on the lines
going

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 23, 2013 1:02 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Tree Report
Attachments: photo.jpg

Non preventable outage caused by top of maple breaking off in high winds. Tree trunk approx. 8 feet from phase and portion that broke was 8 to 10 feet from conductor, tree height 75 feet. Feeder had just undergone maintenance prune. Numerous trees were damaged in the area.

Rod Puhmann

Xcel Energy

Supervisor, Vegetation Management

210 Lime Street, PO Box 1090, Mankato, MN 56001

P: 507.387.9621 C: 507.676.2228 F: 507.387.9604

E: rodney.d.puhmann@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this e-mail.

From: Reinschmidt, Brad A
Sent: Thursday, September 19, 2013 9:58 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013

Date In : 9/19/2013

Time Out : 09:23

Time In : 09:36

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 306

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SACRED HEART, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional outage to clear down lines. Crew to install fuses on the lines

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 10:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/19/13 - Saint Joseph
Power outage - Saint Joseph

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, September 19, 2013 10:36 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In :
Time Out : 10:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 747

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers : None

Cause : found broken pole at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, September 19, 2013 11:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9-19-13 - Saint Joseph - POWER RESTORED
Power outage - Saint Joseph - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, September 19, 2013 11:17 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2013 Date In : 9/19/2013
Time Out : 10:13 Time In : 10:28

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 747

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers : None

Cause : Found broken pole, cut line open to make repairs

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 11:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/3/13 - Mankato
Power outage - Mankato.

Wendy

From: Peterson, Mark S
Sent: Tuesday, September 03, 2013 9:02 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/3/2013 Date In :
Time Out : 08:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1627

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 11:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/3/13 - Mankato - POWER RESTORED
Power outage - Mankato - power restored.

Wendy

From: Peterson, Mark S
Sent: Tuesday, September 03, 2013 9:36 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/3/2013 Date In : 9/3/2013
Time Out : 08:57 Time In : 09:31

Time Zone : CST

Duration : 0 hours, 34 mins

Number of Customers Affected : 1627

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT GUY WIRE FLIPPING IT INTO FEEDER AT
. CREW CUT JUMPERS OPEN AND RE-ENERGIZED

FEEDER

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/8/13 - Mankato & North Mankato
Power outage - Mankato & North Mankato.

Wendy

From: Peterson, Mark S
Sent: Sunday, September 08, 2013 4:56 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In :
Time Out : 16:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1151

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/8/13 - Mankato & North Mankato -
UPDATE

Power outage - Mankato & North Mankato - update.

Wendy

From: Peterson, Mark S
Sent: Sunday, September 08, 2013 5:59 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In : 9/8/2013
Time Out : 16:43 Time In : 17:40

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 773

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : homeowner cutting down tree behind dropped
tree into primary. This was behind a recloser but recloser failed to open
before feeder breaker.

Follow-Up : 378 customers will be out behind recloser until wire can be
put back up.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/8/13 - Mankato & North Mankato - POWER RESTORED

Power outage - Mankato & North Mankato - power restored.

Wendy

From: Peterson, Mark S
Sent: Sunday, September 08, 2013 9:58 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In : 9/8/2013
Time Out : 16:43 Time In : 21:29

Time Zone : CST

Duration : 4 hours, 46 mins

Number of Customers Affected : 378

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : Final 378 customers energized @ 21:29

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 09, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/8/13 - Mankato & North Mankato - POWER RESTORED/UPDATE

Power outage - Mankato & North Mankato - power restored/update.

Wendy

From: Peterson, Mark S
Sent: Sunday, September 08, 2013 9:59 PM
To: Peterson, Mark S; dl Electric Outage SE Notification
Subject: RE: Final Outage Notice

[Actual time back in was 2100 hours, not 2129..](#)

From: Peterson, Mark S
Sent: Sunday, September 08, 2013 21:58
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/8/2013 Date In : 9/8/2013
Time Out : 16:43 Time In : 21:29

Time Zone : CST

Duration : 4 hours, 46 mins

Number of Customers Affected : 378

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : none

Cause : Final 378 customers energized @ 21:29

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 17, 2013 9:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/17/13 - Goodhue, Lake City & Mount Pleasant
Power outage - Goodhue, Lake City & Mount Pleasant.

Wendy

From: Vorachek, Kelly
Sent: Tuesday, September 17, 2013 8:45 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/17/2013 Date In :
Time Out : 08:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 190

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Squirrel got on to and flashed over causing
and 86 Lockout to Inst per Randy the

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 17, 2013 10:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/17/13 - Goodhue, Lake City & Mount Pleasant -
POWER RESTORED

Power outage - Goodhue, Lake City & Mount Pleasant - power restored.

Wendy

From: Vorachek, Kelly
Sent: Tuesday, September 17, 2013 10:01 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/17/2013 Date In : 9/17/2013
Time Out : 08:27 Time In : 09:27

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 190

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : GOODHUE, MN; LAKE CITY, MN; MOUNT PLEASANT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - 86 Lockout on Isolated on for testing.
Restored customers by closing tie with Feeder

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, September 25, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/24/13 - Kenyon & Wanamingo - POWER RESTORED

Power outage - Kenyon & Wanamingo - power restored.

Wendy

From: Medellin, Victor J
Sent: Wednesday, September 25, 2013 5:16 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/24/2013 Date In : 9/25/2013
Time Out : 22:21 Time In : 04:11

Time Zone : CST

Duration : 5 hours, 50 mins

Number of Customers Affected : 63

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : KENYON, MN; WANAMINGO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Semi tore down 3 spans of feeder line
non rtu sub. repairs complete.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, September 30, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/27/13 - Courtland - POWER RESTORED
Power outage - Courtland - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, September 27, 2013 10:43 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/27/2013 Date In : 9/27/2013
Time Out : 16:41 Time In : 22:39

Time Zone : CST

Duration : 5 hours, 58 mins

Number of Customers Affected : 382

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COURTLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : INTENTIONAL TO REPLACE BROKEN FEEDER POLE
AND PUT PRIMARY BACK UP. POLE ROTTED OFF

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 11:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 9/1/13 - Edina & Richfield
Power outage - Edina & Richfield.

Wendy

From: Kittock, Joseph C
Sent: Sunday, September 01, 2013 12:41 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 9/1/2013 Date In :
Time Out : 00:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3470

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 11:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/1/13 - Edina & Richfield - UPDATE
Power outage - Edina & Richfield - update.

Wendy

From: Kittock, Joseph C
Sent: Sunday, September 01, 2013 1:42 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/1/2013 Date In :
Time Out : 00:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3560

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : non

Cause : New # count due to existing model error.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, September 03, 2013 11:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/1/13 - Edina & Richfield - POWER RESTORED
Power outage - Edina & Richfield - power restored.

Wendy

From: Kittock, Joseph C
Sent: Sunday, September 01, 2013 2:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/1/2013 Date In : 9/1/2013
Time Out : 00:29 Time In : 02:29

Time Zone : CST

Duration : 2 hours, 0 mins

Number of Customers Affected : 3560

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : non

Cause : Nothing found.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/5/13 - Falcon Heights, Maplewood & Saint Paul
Power outage - Falcon Heights, Maplewood & Saint Paul.

Wendy

From: Driscoll, Paul M
Sent: Saturday, October 05, 2013 1:23 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/5/2013 Date In :
Time Out : 01:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2328

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/a

Cause : Storm..

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/5/13 - Falcon Heights, Maplewood & Saint Paul -
POWER RESTORED

Power outage - Falcon Heights, Maplewood & Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, October 05, 2013 4:26 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2013 Date In : 10/5/2013
Time Out : 01:05 Time In : 04:19

Time Zone : CST

Duration : 3 hours, 14 mins

Number of Customers Affected : 2328

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Our troubleman took a tree off this feeder at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 22, 2013 4:08 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice
Attachments: IMG_0151.jpg
FYI...tree report.

Wendy

From: Weidenfeller, Bradley M
Sent: Tuesday, October 22, 2013 2:36 PM
To: dl Electric Outage ME Notification
Cc: Johnson, Fletcher L
Subject: FW: Final Outage Notice

Non-preventable
5" diameter silver maple limb broke out of top of the tree and fell onto line during storm.
No signs of decay, LTD 12-19-09, next maintenance cycle 2014
[Investigated 10-8-13](#)

From: Driscoll, Paul M
Sent: Saturday, October 05, 2013 3:26 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2013 Date In : 10/5/2013
Time Out : 01:05 Time In : 04:19

Time Zone : CST

Duration : 3 hours, 14 mins

Number of Customers Affected : 2328

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Our troubleman took a tree off this feeder at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 3:48 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/14/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Chial, Terry L
Sent: Monday, October 14, 2013 3:36 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/14/2013 Date In :
Time Out : 15:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1116

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : unknown/ not

Follow-Up : feeder lock

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 3:48 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/14/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Chial, Terry L
Sent: Monday, October 14, 2013 3:41 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/14/2013 Date In :
Time Out : 15:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1116

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : underground boring hit feeder .will isolate and reenergize.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 15, 2013 7:31 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/14/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Monday, October 14, 2013 4:12 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/14/2013 Date In : 10/14/2013
Time Out : 15:17 Time In : 16:08

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 1116

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : pd urd boring hit feeder

Follow-Up : will repair

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 15, 2013 11:29 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/15/13 - Forest Lake & Wyoming
Power outage - Forest Lake & Wyoming.

Wendy

From: Abbott, Edward J
Sent: Tuesday, October 15, 2013 11:27 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/15/2013 Date In :
Time Out : 11:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1380

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOW

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 15, 2013 12:38 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/15/13 - Forest Lake & Wyoming - UPDATE
Power outage - Forest Lake & Wyoming - update.

Wendy

From: Abbott, Edward J
Sent: Tuesday, October 15, 2013 11:40 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/15/2013 Date In :
Time Out : 11:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1380

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : POLICE CALLED AND WIRE DOWN AT
TROUBLEMEN HEADING THERE

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 15, 2013 12:39 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/15/13 - Forest Lake & Wyoming - POWER RESTORED

Power outage - Forest Lake & Wyoming - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, October 15, 2013 12:14 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/15/2013 Date In : 10/15/2013
Time Out : 11:22 Time In : 12:05

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 1380

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : C PHASE AUTO SLEVE ON FEEDER FAILED, TROUBLE CUT OPEN JUMPERS AND WERE ABLE TO FIELD SWITCH AND EVERYONE BACK ON

Follow-Up : CREW ON WAY TO PUT UP FEEDER WIRE

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/2/13 - Bloomington & Minneapolis
Power outage - Bloomington & Minneapolis.

Wendy

From: Kittock, Joseph C
Sent: Wednesday, October 02, 2013 10:12 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In :
Time Out : 22:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3665

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/2/13 - Bloomington & Minneapolis -
POWER RESTORED

Power outage - Bloomington & Minneapolis - power restored.

Wendy

From: Cedar, Daren A
Sent: Thursday, October 03, 2013 12:10 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In : 10/3/2013
Time Out : 22:09 Time In : 00:02

Time Zone : CST

Duration : 1 hours, 53 mins

Number of Customers Affected : 3665

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON FEEDER BLOWN FUSE ON CAP

BANK AT

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 1:49 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0454.jpg

Non-Preventable

Live willow limb, 5ft long, broke from within the canopy due to strong winds. No signs of decay.
Last worked 4/2009

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Cedar, Daren A
Sent: Thursday, October 03, 2013 12:10 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In : 10/3/2013

Time Out : 22:09 Time In : 00:02

Time Zone : CST

Duration : 1 hours, 53 mins

Number of Customers Affected : 3665

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN

3/25/2014

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON FEEDER

BLOWN FUSE ON CAP BANK AT

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/6/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Knutson, David A
Sent: Sunday, October 06, 2013 5:14 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/6/2013 Date In :
Time Out : 04:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1359

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLE ON THE WAY

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/6/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Kittock, Joseph C
Sent: Sunday, October 06, 2013 8:10 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/6/2013 Date In : 10/6/2013
Time Out : 04:59 Time In : 05:38

Time Zone : CST

Duration : 0 hours, 39 mins

Number of Customers Affected : 1359

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : non

Cause : Failed head end cable.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 9:15 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/7/13 - Eden Prairie & Minnetonka
Power outage - Eden Prairie & Minnetonka.

Wendy

From: Peterson, Kenneth W
Sent: Monday, October 07, 2013 8:21 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/7/2013 Date In :
Time Out : 08:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 07, 2013 9:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/7/13 - Eden Prairie & Minnetonka - POWER RESTORED

Power outage - Eden Prairie & Minnetonka - power restored.

Wendy

From: Schwarz, John W
Sent: Monday, October 07, 2013 9:45 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/7/2013 Date In : 10/7/2013
Time Out : 08:18 Time In : 09:11

Time Zone : CST

Duration : 0 hours, 53 mins

Number of Customers Affected : 2313

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PATROLED FEEDER NOTHING FOUND.. CONTRACTORS ARE WORKING IN THE SUB ON

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 09, 2013 3:58 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 10/9/13 - Golden Valley
Power outage - Golden Valley.

Wendy

From: Cedar, Daren A
Sent: Wednesday, October 09, 2013 3:56 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/9/2013 Date In :
Time Out : 15:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 665

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : TROUBLE ON THE WAY

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 09, 2013 5:00 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/9/13 - Golden Valley - POWER
RESTORED

Power outage - Golden Valley - power restored.

Wendy

From: Cedar, Daren A
Sent: Wednesday, October 09, 2013 4:43 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/9/2013 Date In : 10/9/2013
Time Out : 15:52 Time In : 16:38

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 665

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers :

Cause : SQUIRREL BLEW ASRTOR AT THE FEED TO

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/11/13 - Columbia Heights & Minneapolis
Power outage - Columbia Heights & Minneapolis.

Wendy

From: Peterson, Kenneth W
Sent: Friday, October 11, 2013 9:46 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 09:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1271

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/11/13 - Columbia Heights & Minneapolis -
UPDATE

Power outage - Columbia Heights & Minneapolis - update.

Wendy

From: Peterson, Kenneth W
Sent: Friday, October 11, 2013 10:44 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 09:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1271

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Feeder Wire down

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:55 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/11/13 - Columbia Heights & Minneapolis -
POWER RESTORED

Power outage - Columbia Heights & Minneapolis - power restored.

Wendy

From: Anderson, Timothy K
Sent: Friday, October 11, 2013 10:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In : 10/11/2013
Time Out : 9:44 Time In : 10:46

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 1271

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN UNFUSED TAP OFF OF MAINLINE

Follow-Up : PATROL,TAP REFERRED

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 10/11/13 - Eden Prairie & Edina
Power outage - Eden Prairie & Edina.

Wendy

From: Kittock, Joseph C
Sent: Friday, October 11, 2013 10:42 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 22:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 215

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/11/13 - Eden Prairie & Edina - POWER RESTORED
Power outage - Eden Prairie & Edina - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 12:40 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In : 10/12/2013
Time Out : 22:21 Time In : 00:17

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 215

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : tree branch fell across recloser.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 16, 2013 1:25 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 10/11/13 - Eden Prairie & Edina
Attachments: IMG_0396.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, October 16, 2013 1:18 PM
To: Kittock, Joseph C; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-Preventable

Unable to locate limb, no debris found at time of investigation
Based on Troubleman's comments it was a broken limb
Tree pruned to full extent 12/2012

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 12:40 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/11/2013

Date In : 10/12/2013

Time Out : 22:21

Time In : 00:17

Time Zone : CST

Duration : 1 hours, 56 mins

3/25/2014

Number of Customers Affected : 215

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers :

Cause : tree branch fell across recloser.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:52 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Buffalo, Greenfield, Loretto & Rockford
Power outage - Buffalo, Greenfield, Loretto & Rockford.

Wendy

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 12:47 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 22:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BUFFALO, MN; GREENFIELD, MN; LORETTO, MN; ROCKFORD,
MN

State : MN - Minnesota

Major Customers : non

Cause : A / phase burnt down west of station, breaker opened all 3 phases.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/11/13 - Buffalo, Greenfield, Loretto & Rockford
- POWER RESTORED

Power outage - Buffalo, Greenfield, Loretto & Rockford - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 2:52 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In : 10/12/2013
Time Out : 22:09 Time In : 02:38

Time Zone : CST

Duration : 4 hours, 29 mins

Number of Customers Affected : 1095

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BUFFALO, MN; GREENFIELD, MN; LORETTO, MN; ROCKFORD,

MN

State : MN - Minnesota

Major Customers : non

Cause : A / phase burnt down west of station, breaker opened all 3 phases.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/12/13 - Plymouth
Power outage - Plymouth.

Wendy

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 6:42 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/12/2013 Date In :
Time Out : 18:37 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1636

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice -10/12/13 - Plymouth - POWER RESTORED
Power outage - Plymouth - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, October 12, 2013 7:10 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/12/2013 Date In : 10/12/2013
Time Out : 18:37 Time In : 19:07

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 1636

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : non

Cause : Head end cable fault.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 16, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/15/13 - Golden Valley & Minneapolis
Power outage - Golden Valley & Minneapolis.

Wendy

From: Kittock, Joseph C
Sent: Tuesday, October 15, 2013 8:23 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/15/2013 Date In :
Time Out : 20:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2075

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 16, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/15/13 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Tuesday, October 15, 2013 10:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/15/2013 Date In : 10/15/2013
Time Out : 20:14 Time In : 21:58

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 2075

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Tree fell across feeder north of the

Follow-Up : removed tree

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, October 16, 2013 1:15 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report - 10/15/13 - Golden Valley & Minneapolis
Attachments: IMG_0400.JPG; IMG_0399.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Wednesday, October 16, 2013 1:08 PM
To: Kittock, Joseph C; dl Electric Outage MW Notification
Subject: RE: Tree Report

Preventable

Dead tree uprooted
Last worked 10/2009

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Kittock, Joseph C
Sent: Tuesday, October 15, 2013 10:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/15/2013

Date In : 10/15/2013

Time Out : 20:14

Time In : 21:58

Time Zone : CST

Duration : 1 hours, 44 mins

3/25/2014

Number of Customers Affected : 2075

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Tree fell across feeder north of the

Follow-Up : removed tree

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:56 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/18/13 - Golden Valley, Minneapolis & Saint Louis Park
Power outage - Golden Valley, Minneapolis & Saint Louis Park.

Wendy

From: Hills, Thomas L
Sent: Friday, October 18, 2013 10:18 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/18/2013 Date In :
Time Out : 22:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 569

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to put up B phase feeder line.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/18/13 - Golden Valley, Minneapolis & Saint Louis Park - POWER RESTORED

Power outage - Golden Valley, Minneapolis & Saint Louis Park - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, October 18, 2013 10:44 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/18/2013 Date In : 10/18/2013
Time Out : 22:14 Time In : 22:42

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 569

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to put up B phase feeder line.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:57 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/18/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Hills, Thomas L
Sent: Friday, October 18, 2013 11:58 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/18/2013 Date In :
Time Out : 23:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 77

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/18/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Saturday, October 19, 2013 1:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 10/18/2013	Date In : 10/19/2013
Time Out : 23:48	Time In : 01:04

Time Zone : CST
Duration : 1 hours, 16 mins
Number of Customers Affected : 77
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369
Communities Affected : MINNEAPOLIS, MN
State : MN - Minnesota
Major Customers :
Cause : Failed cable.
Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/20/13 - Bloomington & Richfield
Power outage - Bloomington & Richfield.

Wendy

From: Knutson, David A
Sent: Sunday, October 20, 2013 12:39 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/20/2013 Date In :
Time Out : 12:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2764

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLE ON THE WAY

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/20/13 - Bloomington & Richfield - UPDATE
Power outage - Bloomington & Richfield - update.

Wendy

From: Knutson, David A
Sent: Sunday, October 20, 2013 1:13 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/20/2013 Date In :
Time Out : 12:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2764

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LD CTR D4 BURNED UP

Follow-Up : IN THE PROCESS OF SW OUT

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/20/13 - Bloomington & Richfield - POWER RESTORED

Power outage - Bloomington & Richfield - power restored.

Wendy

From: Knutson, David A
Sent: Sunday, October 20, 2013 1:58 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/20/2013 Date In : 10/20/2013
Time Out : 12:32 Time In : 13:26

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 2764

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LD CTR D4 BURNED UP

Follow-Up : ALL BACK ON AS OF 1354

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 2:06 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10-21-13 - Minneapolis & Saint Louis Park
Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Peterson, Kenneth W
Sent: Monday, October 21, 2013 2:02 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/21/2013 Date In :
Time Out : 13:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2998

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 21, 2013 3:28 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/21/13 - Minneapolis & Saint Louis Park - POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, October 21, 2013 3:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/21/2013 Date In : 10/21/2013
Time Out : 13:59 Time In : 15:18

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 2998

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : tree branch West of on phases

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 22, 2013 1:08 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0404.JPG; IMG_0402.JPG
FYI...TREE REPORT.

WENDY

From: Loiselle, Christopher D
Sent: Tuesday, October 22, 2013 10:43 AM
To: Peterson, Kenneth W; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-Preventable

Live Cottonwood limb broke and fell into conductor
Tree pruned to full extent
Feeder last worked 3/2010

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Peterson, Kenneth W
Sent: Monday, October 21, 2013 3:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/21/2013 Date In : 10/21/2013
Time Out : 13:59 Time In : 15:18

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 2998

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : tree branch West of on phases

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 25, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/24/13 - Golden Valley
Power outage - Golden Valley.

Wendy

From: Babb, Randall J
Sent: Friday, October 25, 2013 7:09 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/24/2013 Date In : 10/24/2013
Time Out : 18:33 Time In : 18:56

Time Zone : CST

Duration : 0 hours, 23 mins

Number of Customers Affected : 176

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : None

Cause : switch found open while performing feeder level restoration
switching.

Follow-Up : Investigating how and why switch was open and not involved in
the switching request.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 25, 2013 1:20 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/25/13 - Brooklyn Park, Crystal, Minneapolis & New Hope
Power outage - Brooklyn Park, Crystal, Minneapolis & New Hope.

Wendy

From: Knutson, David A
Sent: Friday, October 25, 2013 11:52 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/25/2013 Date In :
Time Out : 11:43 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2896

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLEMAN ON THE WAY

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 25, 2013 1:20 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/25/13 - Brooklyn Park, Crystal, Minneapolis & New Hope - POWER RESTORED
Power outage - Brooklyn Park, Crystal, Minneapolis & New Hope - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, October 25, 2013 12:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/25/2013 Date In : 11/25/2013
Time Out : 11:43 Time In : 12:26

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 2896

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 29, 2013 11:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/29/13 - Minnetonka
Power outage - Minnetonka.

Wendy

From: Cedar, Daren A
Sent: Tuesday, October 29, 2013 10:39 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/29/2013 Date In :
Time Out : 10:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 921

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN ON THE WAY

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 29, 2013 11:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/29/13 - Minnetonka - POWER RESTORED
Power outage - Minnetonka - power restored.

Wendy

From: Cedar, Daren A
Sent: Tuesday, October 29, 2013 11:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/29/2013 Date In : 10/29/2013
Time Out : 10:36 Time In : 11:12

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 921

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : ARRESTOR AT PHASE BLEW

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 7:49 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/30/13 - Burnsville & Savage
Power outage - Burnsville & Savage.

Wendy

From: Babb, Randall J
Sent: Wednesday, October 30, 2013 3:46 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/30/2013 Date In :
Time Out : 15:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 21

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 7:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/30/13 - Burnsville & Savage - Update
Power outage - Burnsville & Savage - update.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, October 30, 2013 4:26 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/30/2013 Date In :
Time Out : 15:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 21

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : WIRE DOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 7:51 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/30/13 - Burnsville & Savage - POWER RESTORED
Power outage - Burnsville & Savage - power restored.

Wendy

From: Babb, Randall J
Sent: Wednesday, October 30, 2013 6:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/30/2013 Date In : 10/30/2013
Time Out : 15:42 Time In : 18:19

Time Zone : CST

Duration : 2 hours, 37 mins

Number of Customers Affected : 21

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; SAVAGE, MN

State : MN - Minnesota

Major Customers :

Cause : Wires put back up and all customers restored.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/31/13 - Minneapolis
Power outage - Minneapolis.

Wendy

From: Ayers, Patrick S
Sent: Thursday, October 31, 2013 7:57 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/31/2013 Date In :
Time Out : 07:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2784

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LOCK,UNKNOWN AT TIME

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 9:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/31/13 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Thursday, October 31, 2013 8:39 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/31/2013 Date In : 10/31/2013
Time Out : 07:55 Time In : 08:36

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 2784

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Head end Cable

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/2/13 - Clements, Cobden, Evan,
Morgan, Morton, Redwood Falls & Sleepy Eye
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 7:10 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In :
Time Out : 18:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1121

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN;
MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Transmission Level Event, Trouble en-route.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/2/13 - Clements, Cobden, Evan,
Morgan, Morton, Redwood Falls & Sleepy Eye - POWER RESTORED
Power outage - Clements, Cobden, Evan, Morgan, Morton, Redwood Falls & Sleepy Eye - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 7:43 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In : 10/2/2013
Time Out : 18:51 Time In : 19:37

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1121

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLEMENTS, MN; COBDEN, MN; EVAN, MN; MORGAN, MN;
MORTON, MN; REDWOOD FALLS, MN; SLEEPY EYE, MN

State : MN - Minnesota

Major Customers : None

Cause : 100% Restored at 19:37, Transmission Level Event.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 04, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/4/13 - Becker, Clear Lake & Monticello
Power outage - Becker, Clear Lake & Monticello.

Wendy

From: Reinschmidt, Brad A
Sent: Friday, October 04, 2013 4:12 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/4/2013 Date In :
Time Out : 02:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 242

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; CLEAR LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : None

Cause : unknown crew patrolling feeder

Follow-Up : non RTU sub

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 04, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/4/13 - Becker, Clear Lake & Monticello - POWER RESTORED

Power outage - Becker, Clear Lake & Monticello - power restored.

Wendy

From: Medellin, Victor J
Sent: Friday, October 04, 2013 6:52 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2013 Date In : 10/4/2013
Time Out : 02:28 Time In : 06:45

Time Zone : CST

Duration : 4 hours, 17 mins

Number of Customers Affected : 242

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

MN Communities Affected : BECKER, MN; CLEAR LAKE, MN; MONTICELLO,

State : MN - Minnesota

Major Customers : N/A

Cause : POLE BURNT OFF AT OUT ON
BREAKER AT SUB WOULD NOT CLOSE

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:20 AM
To: Jaede, Wendy L; 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: RE: First Outage Notice 10/11/13 - Clara City, Maynard & Sacred Heart
Spelling correction -

Power outage - Clara City, Maynard & Sacred Heart

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:20 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 10/11/13 - Clara City, Maybard & Sacred Heart

Power outage - Clara City, Maybard & Sacred Heart.

Wendy

From: Chase, Julie B
Sent: Friday, October 11, 2013 10:09 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 08:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 806

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers :

Cause : 2 Poles down on train at grain elevator.

Follow-Up : Non SCADA sub

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 10:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/11/13 - Clara City, Maynard & Sacred Heart - UPDATE
Power outage - Clara City, Maynard & Sacred Heart - Update.

Wendy

From: Chase, Julie B
Sent: Friday, October 11, 2013 10:25 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 08:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 806

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers :

Cause : 2 poles lying on train at the grain elevator

Follow-Up : Jumpers opened to isolate line for repair. Breaker closed at 1018 picking up 258 customers. The remaining 548 will be out until the 2 poles are replaced.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, October 11, 2013 1:09 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 10/11/13 - Clara City, Maynard & Sacred Heart - UPDATE
Power outage - Clara City, Maynard & Sacred Heart - update.

Wendy

From: Chase, Julie B
Sent: Friday, October 11, 2013 11:11 AM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In :
Time Out : 08:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 806

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers :

Cause : 2 broken poles

Follow-Up : 258 customers restored at 1018, anticipate that the remaining 548 will be restored around 1700

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 14, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/11/13 - Clara City, Maynard & Sacred Heart -
POWER RESTORED

Power outage - Clara City, Maynard & Sacred Heart - power restored.

Wendy

From: Chase, Julie B
Sent: Friday, October 11, 2013 5:36 PM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/11/2013 Date In : 10/11/2013
Time Out : 08:55 Time In : 17:04

Time Zone : CST

Duration : 8 hours, 9 mins

Number of Customers Affected : 806

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers :

Cause : - 2 broken poles

Follow-Up : 258 customers in at 1018, the remaining 548 at 1704

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 28, 2013 9:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/26/13 - Chandler & Lake Wilson
Power outage - Chandler & Lake Wilson.

Wendy

From: Kaveny, Michael J
Sent: Saturday, October 26, 2013 1:05 PM
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/26/2013 Date In :
Time Out : 12:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 173

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : None

failed on Cause : Report of Fire at Sub, Non-RTU Sub, Trouble just found C Phase Regulator
. Verifying Hi-side Fuses in at this time, and planning isolation of Regulator.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 28, 2013 9:07 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/26/13 - Chandler & Lake Wilson - UPDATE
Power outage - Chandler & Lake Wilson - update.

Wendy

From: Kaveny, Michael J
Sent: Saturday, October 26, 2013 1:36 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/26/2013 Date In :
Time Out : 12:21 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 173

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : None

good on Cause : Failed C Phase regulator on . Damage isolated to , voltage
Trouble isolating Regulator and will close Tie when help arrives.

Follow-Up : ERAD Notified.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, October 28, 2013 9:08 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/26/13 - Chandler & Lake Wilson - POWER RESTORED

Power outage - Chandler & Lake Wilson - power restored.

Wendy

From: Kaveny, Michael J
Sent: Saturday, October 26, 2013 2:26 PM
To: dl Electric Outage SD Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/26/2013 Date In : 10/26/2013
Time Out : 12:21 Time In : 14:18

Time Zone : CST

Duration : 1 hours, 57 mins

Number of Customers Affected : 173

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; LAKE WILSON, MN

State : SD - South Dakota

Major Customers : None

Cause : Regulator isolated on . Tie Sw closed and 100% restored at
14:18.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:34 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/2/13 - Essig & New Ulm
Power outage - Essig & New Ulm.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 7:09 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In :
Time Out : 18:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 33

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ESSIG, MN; NEW ULM, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Transmission Level Event. Trouble en-route.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/2/13 - Essig & New Ulm - POWER
RESTORED

Power outage - Essig & New Ulm - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 8:42 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In : 10/2/2013
Time Out : 18:51 Time In : 20:36

Time Zone : CST

Duration : 1 hours, 45 mins

Number of Customers Affected : 33

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ESSIG, MN; NEW ULM, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event. 100% Restored.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 10/2/13 - Faribault, Medford,
Morristown, Warsaw, Waseca & Waterville
Power outage - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 9:42 PM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In :
Time Out : 21:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1218

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown, Transmission Level Event, Trouble en-route.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/2/13 - Faribault, Medford, Morrystown, Warsaw, Waseca & Waterville - POWER RESTORED
Power outage - Faribault, Medford, Morrystown, Warsaw, Waseca & Waterville - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, October 02, 2013 10:30 PM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/2/2013 Date In : 10/2/2013
Time Out : 21:33 Time In : 22:28

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1218

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Transmission Level Event, 100% Restored.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice -
10/3/13 - Byron, Dodge Center, Kasson, Mantorville, Pine Island, Wasioja, West Concord & Zumbrota
Power outage - Byron, Dodge Center, Kasson, Mantorville, Pine Island, Wasioja, West Concord & Zumbrota.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, October 03, 2013 3:27 AM
To: dl Electric Outage SE Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 10/3/2013 Date In :
Time Out : 03:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5467

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BYRON, MN; DODGE CENTER, MN; KASSON, MN;
MANTORVILLE, MN; PINE ISLAND, MN; WASIOJA, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers :

Cause : weather in area

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 7:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: 2nd Outage Notice-
10/3/13-Austin, Brownsdale, Byron, Claremont, Concord, Dodge Ctr, Hayfied, Kasson, Mantorville, Old
Concord, Pine Islnd, Waltham, Wasioja, Wst Concord & Zumbrota-UPDATE
Power outage - Austin, Brownsdale, Byron, Claremont, Concord, Dodge Ctr, Hayfied, Kasson,
Mantorville, Old Concord, Pine Islnd, Waltham, Wasioja, West Concord & Zumbrota - Update.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, October 03, 2013 4:04 AM
To: dl Electric Outage SE Notification
Subject:
Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/3/2013 Date In :
Time Out : 03:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 8867

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : AUSTIN, MN; BROWNSDALE, MN; BYRON, MN; CLAREMONT,
MN; CONCORD, MN; DODGE CENTER, MN; HAYFIELD, MN; KASSON, MN; MANTORVILLE, MN;
OLD CONCORD, MN; PINE ISLAND, MN; WALTHAM, MN; WASIOJA, MN; WEST CONCORD, MN;
ZUMBROTA, MN

State : MN - Minnesota

Major Customers :

Cause : weather in area

Follow-Up : all customers restored via switching except for 2041 customers at
sub.

3/25/2014

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 03, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: -10/3/13-Final Notice-
Austin, Brownsdale, Byron, Claremont, Concord, Dodge Ctr, Hayfield, Kasson, Mantorville, Old Concord, Pine
Islnd, Waltham, Wasioja, Wst Concord & Zumbrota-POWER RESTORED

Power outage - Austin, Brownsdale, Byron, Claremont, Concord, Dodge Center, Hayfield, Kasson,
Mantorville, Old Concord, Pine Island, Waltham, Wasioja, West Concord & Zumbrota - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, October 03, 2013 6:33 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/3/2013 Date In : 10/3/2013
Time Out : 03:08 Time In : 06:18

Time Zone : CST

Duration : 3 hours, 10 mins

Number of Customers Affected : 6891

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : AUSTIN, MN; BROWNSDALE, MN; BYRON, MN;
CLAREMONT, MN; CONCORD, MN; DODGE CENTER, MN; HAYFIELD, MN;
KASSON, MN; MANTORVILLE, MN; OLD CONCORD, MN; PINE ISLAND, MN;
WALTHAM, MN; WASIOJA, MN; WEST CONCORD, MN

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION EVENT LAST 2041 CUSTOMERS
RESTORED VIA SWITCHING

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, October 31, 2013 12:45 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/31/13 - Albert Lea, Clarks Grove, Ellendale & Hartland - POWER RESTORED
Power outage - Albert Lea, Clarks Grove, Ellendale & Hartland - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, October 31, 2013 11:56 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

041

Date Out : 10/31/2013 Date In : 10/31/2013
Time Out : 11:29 Time In : 11:51

Time Zone : CST

Duration : 0 hours, 22 mins

Number of Customers Affected : 470

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ALBERT LEA, MN; CLARKS GROVE, MN;
ELLENDALE, MN; HARTLAND, MN

State : MN - Minnesota

Major Customers : N/A

Cause : INTENTIONAL TO CLEAR DEFECTIVE C PHASE FIELD
REGULATOR STUCK @ 16 RAISE

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, October 08, 2013 7:35 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/8/13 - Bloomington & Minneapolis -
POWER RESTORED

Power outage - Bloomington & Minneapolis - power restored.

Wendy

From: Cedar, Daren A
Sent: Tuesday, October 08, 2013 6:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/8/2013 Date In : 10/9/2013
Time Out : 22:09 Time In : 00:02

Time Zone : CST

Duration : 1 hours, 53 mins

Number of Customers Affected : 3665

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BRANCH ON FEEDER

Follow-Up : FORGOT TO PUT IN FINAL NOTICE ON 10/3/2013

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:38 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview
Power outage - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview.

Wendy

From: Gilland, William P
Sent: Sunday, November 03, 2013 2:34 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In :
Time Out : 14:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1786

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/3/13 - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - POWER RESTORED
Power outage - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, November 03, 2013 3:37 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In : 11/3/2013
Time Out : 14:25 Time In : 15:07

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 1786

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : tree on fdr at /trbl cleared problem

Follow-Up : opened and fdr bkr closed at 15:07-1340 custs back in.
closed at 15:35 -remaining 446 custs back in

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 12:15 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0412.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Monday, November 04, 2013 11:38 AM
To: Gilland, William P; dl Electric Outage ME Notification
Subject: RE: Tree Report

Non-Preventable

Oak tree from outside maintenance zone had trunk break due to internal decay
Tree had live full canopy
Strong winds
Feeder last worked 8/2010

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Gilland, William P
Sent: Sunday, November 03, 2013 3:37 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/3/2013

Date In : 11/3/2013

Time Out : 14:25

Time In : 15:07

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 1786

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : tree on fdr at /trbl cleared problem

Follow-Up : opened and fdr bkr closed at 15:07-1340 custs back in.
closed at 15:35 -remaining 446 custs back in

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 05, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/4/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Monday, November 04, 2013 10:24 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/4/2013 Date In :
Time Out : 22:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3571

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 05, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/4/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, November 04, 2013 10:59 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/4/2013 Date In : 11/4/2013
Time Out : 22:19 Time In : 22:58

Time Zone : CST

Duration : 0 hours, 39 mins

Number of Customers Affected : 3571

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FAULTED HEAD END CABLE, SWITCHED OUT AND FIELDDED
SWITCHED TO BRING EVERYONE BACK IN

Follow-Up : REFERRED FOR BIDDLE AND REPAIR

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 05, 2013 8:50 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Saint Paul
Power outage - Saint Paul.

Wendy

From: Driscoll, Paul M
Sent: Tuesday, November 05, 2013 8:38 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/5/2013 Date In :
Time Out : 07:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3332

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : We had "A"phase line burn down at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 05, 2013 10:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/5/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Driscoll, Paul M
Sent: Tuesday, November 05, 2013 10:39 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/5/2013 Date In :
Time Out : 07:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3332

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : We have "A"phase line down at ,"A"phase line
down & "A"phase jumper burned open at .We will
have "A"phase cust.out for some time.

Follow-Up : Crews are working on this now..

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 05, 2013 10:59 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 11/5/13 - Saint Paul - UPDATE
Power outage - Saint Paul - update.

Wendy

From: Driscoll, Paul M
Sent: Tuesday, November 05, 2013 10:46 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 11/5/2013 Date In :
Time Out : 07:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 160

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : As of 08:40 we have all but 160 customers in with our feeder..

Follow-Up : Crews are working on this..

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 06, 2013 7:19 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/5/13 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Tuesday, November 05, 2013 4:01 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/5/2013 Date In : 11/5/2013
Time Out : 07:50 Time In : 15:40

Time Zone : CST

Duration : 7 hours, 50 mins

Number of Customers Affected : 3332

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : wire down and burned up trans

Follow-Up : 100% of the customers are back on at 15:40

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 11, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/10/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul.

Wendy

From: Gilland, William P
Sent: Sunday, November 10, 2013 7:37 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/10/2013 Date In :
Time Out : 07:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2629

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : tbd

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 11, 2013 7:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/10/13 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, November 10, 2013 7:56 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/10/2013 Date In : 11/10/2013
Time Out : 07:24 Time In : 07:50

Time Zone : CST

Duration : 0 hours, 26 mins

Number of Customers Affected : 2629

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN;
MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : squirrel at

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 12:19 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/13/13 - Eagan
Power outage - Eagan.

Wendy

From: Elden, Thomas L
Sent: Wednesday, November 13, 2013 12:16 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In :
Time Out : 12:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 288

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 2:00 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/13/13 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, November 13, 2013 1:56 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In : 11/13/2013
Time Out : 12:10 Time In : 13:21

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 288

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : Cable failed from ..

Follow-Up : Biddle & repair..

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 15, 2013 8:28 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: MOL-MOORE LAKE (064) First Outage Notice - 11/15/13 - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul
Power outage - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul.

Wendy

From: Abbott, Edward J
Sent: Friday, November 15, 2013 8:25 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/15/2013 Date In :
Time Out : 08:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1643

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; FRIDLEY, MN; MOUNDS VIEW, MN;
NEW BRIGHTON, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN, TROUBLE IN ROUTE

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 15, 2013 9:41 AM
To: 'staff, cao (PUC)'; Doughty, Kathryn L
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/15/13 - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul - POWER RESTORED
Power outage - Arden Hills, Fridley, Mounds View, New Brighton & Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Friday, November 15, 2013 8:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/15/2013 Date In : 11/15/2013
Time Out : 08:20 Time In : 08:53

Time Zone : CST

Duration : 0 hours, 33 mins

Number of Customers Affected : 1643

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; FRIDLEY, MN; MOUNDS VIEW, MN;
NEW BRIGHTON, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TRUCK HIT FEEDER POLE AT WAS ABLE TO
BRING FEEDER BACK IN AND TO REPLACE BROKEN FEEDER POLE ASAP

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 18, 2013 8:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/17/13 - Blaine, Circle Pines, Lexington & Shoreview
Power outage - Blaine, Circle Pines, Lexington & Shoreview.

Wendy

From: Driscoll, Paul M
Sent: Sunday, November 17, 2013 4:36 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/17/2013 Date In :
Time Out : 04:14 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1845

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BLAINE, MN; CIRCLE PINES, MN; LEXINGTON, MN;
SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Unknown..

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 18, 2013 8:37 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/17/13 - Blaine, Circle Pines, Lexington & Shoreview - POWER RESTORED

Power outage - Blaine, Circle Pines, Lexington & Shoreview - power restored.

Wendy

From: Abbott, Edward J
Sent: Sunday, November 17, 2013 5:33 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/17/2013 Date In : 11/17/2013
Time Out : 04:41 Time In : 05:22

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 1845

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : BLAINE, MN; CIRCLE PINES, MN; LEXINGTON, MN;
SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : 2 LARGE TREES ON FEEDER AT
TROUBLEMAN CLEARED TREES AND FEEDER BACK IN

Follow-Up : WILL NEED TO PUT BACK TO PREFERRED
FEEDER

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 26, 2013 7:39 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/25/13 - Newport
Power outage - Newport.

Wendy

From: Elden, Thomas L
Sent: Monday, November 25, 2013 8:50 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/25/2013 Date In :
Time Out : 20:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 52

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers : mn

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 26, 2013 7:40 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/25/13 - Newport - POWER RESTORED
Power outage - Newport - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, November 25, 2013 10:39 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/25/2013 Date In : 11/25/2013
Time Out : 20:46 Time In : 22:28

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 52

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers : ASHLAND

Cause : BAD URD FDR CABLE BETWN . FUALT
INDICATERS ON 3 SWITCHES ARE NOT WORKING

Follow-Up : REFFERED TO NEWPORT AND RELAY TO BIDDLE AND
REPAIR CABLE

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, November 26, 2013 11:03 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/25/13 - Newport - FINAL/UPDATE
Power outage - Newport - final/update (date is 11/25 & not 11/26).

Wendy

From: Chial, Terry L
Sent: Tuesday, November 26, 2013 8:23 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/26/2013 Date In : 11/26/2013
Time Out : 20:46 Time In : 22:33

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 52

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : NEWPORT, MN

State : MN - Minnesota

Major Customers : REFINERY

Cause : FAULT ON FEEDER CABLE

Follow-Up : REFERED TO BE REPAIRED

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:41 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/3/13 - Minnetrista & Mound
Power outage - Minnetrista & Mound.

Wendy

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 3:01 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1193

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/3/13 - Minnetrista & Mound - POWER RESTORED
Power outage - Minnetrista & Mound - power restored.

Wendy

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 3:29 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In : 11/3/2013
Time Out : 14:56 Time In : 15:25

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 1193

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIND

Follow-Up : PATROL FEEDER NOTHING FOUND.

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/3/13 - Bloomington
Power outage - Bloomington.

Wendy

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 3:23 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In :
Time Out : 15:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1428

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/3/13 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 4:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In : 11/3/2013
Time Out : 15:13 Time In : 16:01

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 1428

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH ON FDR.

Follow-Up : PATROL, REMOVE BRANCH

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 12:15 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report
Attachments: IMG_0416.JPG; IMG_0415.JPG
FYI...Tree report.

Wendy

From: Loiselle, Christopher D
Sent: Monday, November 04, 2013 11:46 AM
To: Anderson, Timothy K; dl Electric Outage MW Notification
Subject: RE: Tree Report

Non-Preventable

Elm limb failed, no signs of decay
Strong winds
Last worked 8/2010

Christopher Loiselle

Xcel Energy

Vegetation Management Supervisor I

5309 West 70th St, Edina, MN, 55439

O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 4:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/3/2013

Date In : 11/3/2013

Time Out : 15:13

Time In : 16:01

Time Zone : CST

3/21/2014

Duration : 0 hours, 48 mins

Number of Customers Affected : 1428

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH ON FDR.

Follow-Up : PATROL, REMOVE BRANCH

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 12:16 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Tree Report correction
Tree report - correction.

Wendy

From: Loiselle, Christopher D
Sent: Monday, November 04, 2013 11:47 AM
To: Anderson, Timothy K; dl Electric Outage MW Notification
Subject: RE: Tree Report correction

Last worked date 5/2009

Christopher Loiselle
Xcel Energy
Vegetation Management Supervisor I
5309 West 70th St, Edina, MN, 55439
O: 952.829.4577 C: 612.418.5225 F: 952.829.14509 Christopher.D.Loiselle@xcelenergy.com

XCELENERGY.COM

F7^\$3bW7

From: Anderson, Timothy K
Sent: Sunday, November 03, 2013 4:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In : 11/3/2013
Time Out : 15:13 Time In : 16:01

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 1428

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH ON FDR.

Follow-Up : PATROL, REMOVE BRANCH

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:46 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/4/13 - Minneapolis & Saint Louis Park
Power outage - Minneapolis & Saint Louis Park.

Wendy

From: Knutson, David A
Sent: Monday, November 04, 2013 7:34 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/4/2013 Date In :
Time Out : 07:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3008

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : trouble on the way

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:47 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/4/13 - Minneapolis & Saint Louis Park - UPDATE
Power outage - Minneapolis & Saint Louis Park - update.

Wendy

From: Babb, Randall J
Sent: Monday, November 04, 2013 8:37 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/4/2013 Date In :
Time Out : 07:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3008

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Patrolling feeder at this time.

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 9:53 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/4/13 - Minneapolis & Saint Louis Park - POWER RESTORED

Power outage - Minneapolis & Saint Louis Park - power restored.

Wendy

From: Knutson, David A
Sent: Monday, November 04, 2013 9:43 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/4/2013 Date In : 11/4/2013
Time Out : 07:29 Time In : 09:36

Time Zone : CST

Duration : 2 hours, 7 mins

Number of Customers Affected : 3008

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown nothing found on the patrol raining at the time

Follow-Up : hard to patrol feeder is along the tracks and bike path heavy traffic area

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 2:52 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/8/13 - Burnsville
Power outage - Burnsville.

Wendy

From: Cedar, Daren A
Sent: Friday, November 08, 2013 2:02 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In :
Time Out : 13:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 3:38 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/8/13 - Burnsville - UPDATE
Power outage - Burnsville - update.

Wendy

From: Karolevitz, Paul W
Sent: Friday, November 08, 2013 3:16 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In :
Time Out : 13:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : 2 broken poles found. Will isolated and restore.

Follow-Up : traffic very heavy while enroute

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 3:38 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/8/13 - Burnsville - UPDATE
Power outage - Burnsville - update.

Wendy

From: Anderson, Timothy K
Sent: Friday, November 08, 2013 3:21 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In :
Time Out : 13:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 2 FEEDER POLES DOWN & OTHER FDR POLE)

Follow-Up : ISOLATE,REFER

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 3:54 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 11/8/13 - Burnsville - UPDATE
Power outage - Burnsville - update.

Wendy

From: Anderson, Timothy K
Sent: Friday, November 08, 2013 3:51 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In :
Time Out : 13:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1048

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 2 FDR POLES DOWN

Follow-Up : ISOLATE, SWITCH AROUND

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 4:44 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 11/8/13 - Burnsville - POWER RESTORED
Power outage - Burnsville - power restored.

Wendy

From: Cedar, Daren A
Sent: Friday, November 08, 2013 4:39 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In : 11/8/2013
Time Out : 13:58 Time In : 15:24

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SWITCHING IN THE REST OF CUSTOMER BY 1/0 GOT 1048 CUSTOMERS
IN AT 1524

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, November 08, 2013 5:12 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/8/13 - Burnsville - POWER RESTORED
Power outage - Burnsville - power restored.

Wendy

From: Anderson, Timothy K
Sent: Friday, November 08, 2013 4:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/8/2013 Date In : 11/8/2013
Time Out : 13:58 Time In : 16:39

Time Zone : CST

Duration : 2 hours, 41 mins

Number of Customers Affected : 1095

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 2 BROKEN FDR POLES

Follow-Up : REFER

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 1:14 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/13/13 - Cologne, Green Isle,
Hamburg, Lake Wilson, Mayer, Nya & Plato
Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato.

Wendy

From: Schwarz, John W
Sent: Wednesday, November 13, 2013 1:10 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In :
Time Out : 12:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2203

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN;
MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT FEEDER CABLE BETWEEN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 1:24 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/13/13 - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato - POWER RESTORED
Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, November 13, 2013 1:22 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In : 11/13/2013
Time Out : 12:09 Time In : 13:09

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 2203

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN;
MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT FEEDER CABLE BETWEEN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 1:14 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/13/13 - Cologne, Green Isle,
Hamburg, Lake Wilson, Mayer, Nya & Plato
Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato.

Wendy

From: Schwarz, John W
Sent: Wednesday, November 13, 2013 1:10 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In :
Time Out : 12:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2203

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN;
MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT FEEDER CABLE BETWEEN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 13, 2013 1:24 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/13/13 - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato - POWER RESTORED
Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, Nya & Plato - power restored.

Wendy

From: Schwarz, John W
Sent: Wednesday, November 13, 2013 1:22 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/13/2013 Date In : 11/13/2013
Time Out : 12:09 Time In : 13:09

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 2203

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN; MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT FEEDER CABLE BETWEEN

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 18, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/17/13 - Minneapolis & Saint Paul
Power outage - Minneapolis & Saint Paul.

Wendy

From: Hills, Thomas L
Sent: Sunday, November 17, 2013 5:49 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/17/2013 Date In :
Time Out : 17:44 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3898

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 18, 2013 8:43 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/17/13 - Minneapolis & Saint Paul - POWER RESTORED

Power outage - Minneapolis & Saint Paul - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, November 17, 2013 7:18 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/17/2013 Date In : 11/17/2013
Time Out : 17:44 Time In : 18:57

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 3898

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown/ Patroled feeder

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, November 27, 2013 1:40 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice- 11/27/2013 -COLOGNE,MAYER,NEW GERMANY,
NYA, WACONIA
Power Outage - COLOGNE,MAYER,NEW GERMANY, NYA, WACONIA

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Kenneth W
Sent: Wednesday, November 27, 2013 10:43
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/27/2013 Date In :
Time Out : 08:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 298

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;

WACONIA, MN

State : MN - Minnesota

Major Customers : none

Cause : Feeder wire down

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, November 27, 2013 1:41 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: Second Outage Notice- 11/27/2013 -COLOGNE,MAYER,NEW GERMANY, NYA, WACONIA
Update -COLOGNE,MAYER,NEW GERMANY, NYA, WACONIA

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Kenneth W
Sent: Wednesday, November 27, 2013 10:47
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/27/2013 Date In :
Time Out : 08:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 298

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;

WACONIA, MN

State : MN - Minnesota

Major Customers : None

Cause : Feeder wire down at

Follow-Up : Cut Bph clear and closed tie / picked up 293 customers / 5 customers out on one tap to the west at this time

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, November 27, 2013 1:44 PM
To: 'staff, cao (PUC)'
Cc: 'doug.renier@state.mn.us'; dl Customer Advocate Team
Subject: FW: Final Outage Notice- 11/27/2013 -COLOGNE,MAYER,NEW GERMANY, NYA, WACONIA
Update- - 11/27/2013 -COLOGNE,MAYER,NEW GERMANY, NYA, WACONIA

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Peterson, Kenneth W
Sent: Wednesday, November 27, 2013 13:13
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/27/2013 Date In : 11/27/2013
Time Out : 08:42 Time In : 12:50

Time Zone : CST

Duration : 4 hours, 8 mins

Number of Customers Affected : 5

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;

WACONIA, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire down at

Follow-Up : Put wire up and picked up tap

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Wednesday, November 06, 2013 11:44 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/6/13 - Annandale - POWER RESTORED
Power outage - Annandale - power restored.

Wendy

From: Kaveny, Michael J
Sent: Wednesday, November 06, 2013 11:40 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/6/2013 Date In : 11/6/2013
Time Out : 11:22 Time In : 11:36

Time Zone : CST

Duration : 0 hours, 14 mins

Number of Customers Affected : 2246

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ANNANDALE, MN

State : MN - Minnesota

Major Customers : None

Cause : Jumper came loose while crews were doing construction work, Feeder was on Manua. No injuries and Feeder 100% restored at 11:36

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:30 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/3/13 - Chandler, Hadley, Iona, Lake Wilson & Slayton
Power outage - Chandler, Hadley, Iona, Lake Wilson & Slayton.

Wendy

From: Peterson, Mark S
Sent: Sunday, November 03, 2013 11:58 AM
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In :
Time Out : 10:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 372

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN; SLAYTON, MN

State : SD - South Dakota

Major Customers : none

Cause : FDR LOCK ON NON RTU SUB. ALL OF IS
BEING CARRIED BY . CREW PATROLLING LINE. VERY WINDY

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:32 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Chandler, Hadley, Iona, Lake Wilson & Slayton - UPDATE

Power outage - Chandler, Hadley, Iona, Lake Wilson & Slayton - update.

Wendy

From: Peterson, Mark S
Sent: Sunday, November 03, 2013 1:11 PM
To: dl Electric Outage SD Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In :
Time Out : 10:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 372

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN; SLAYTON, MN

State : SD - South Dakota

Major Customers : none

Cause : troubleman found phase down 1 1/2 miles west of Sub on
Also found another problem 1 mile further down with the static neutral down. All of this is
on . TRBLMN in process of opening TIE SW to energize .

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 04, 2013 8:36 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/3/13 - Chandler, Hadley, Iona, Lake Wilson & Slayton - POWER RESTORED

Power outage - Chandler, Hadley, Iona, Lake Wilson & Slayton - power restored.

Wendy

From: Vorachek, Kelly
Sent: Sunday, November 03, 2013 4:51 PM
To: dl Electric Outage SD Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/3/2013 Date In : 11/3/2013
Time Out : 10:30 Time In : 16:36

Time Zone : CST

Duration : 6 hours, 6 mins

Number of Customers Affected : 372

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHANDLER, MN; HADLEY, MN; IONA, MN; LAKE WILSON, MN; SLAYTON, MN

State : SD - South Dakota

Major Customers : N/A

Cause : - Crew had phases down on Feeder, in multiple locations from
wind. Feeders abnormal carried , crew opened Tie sw @1311 and restored load at 13:15.
Wire back up and load restored on @ 16:36

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 11, 2013 7:42 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 11/11/13 - Pipestone
Power outage - Pipestone.

Wendy

From: Peterson, Mark S
Sent: Monday, November 11, 2013 6:53 AM
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/11/2013 Date In :
Time Out : 06:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 705

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PIPESTONE, MN

State : SD - South Dakota

Major Customers : none

Cause : Intentional to fix broken jumper on feeder @

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, November 11, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 11/11/13 - Pipestone - POWER RESTORED
Power outage - Pipestone - power restored.

Wendy

From: Peterson, Mark S
Sent: Monday, November 11, 2013 7:23 AM
To: dl Electric Outage SD Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/11/2013 Date In : 11/11/2013
Time Out : 06:47 Time In : 07:15

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 705

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PIPESTONE, MN

State : SD - South Dakota

Major Customers : none

Cause : Intentional to fix jumper @

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Monday, December 02, 2013 3:56 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/2/13 - Cottage Grove & Hastings
Power outage - Cottage Grove & Hastings.

Wendy

From: Chial, Terry L
Sent: Monday, December 02, 2013 3:41 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/2/2013 Date In :
Time Out : 15:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2496

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : NO

Cause : UNKNOWN AT THIS TIME

Follow-Up : WILL PATROL

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, December 03, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 12/2/13 - Cottage Grove & Hastings - Update
Power outage - Cottage Grove & Hastings - update.

Wendy

From: Chial, Terry L
Sent: Monday, December 02, 2013 4:12 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/2/2013 Date In :
Time Out : 15:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2496

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : NO

Cause : POLE AND WIRES DOWN

Follow-Up : WORKING ON ISOLATING FEEDER NOW

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Tuesday, December 03, 2013 8:00 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/2/13 - Cottage Grove & Hastings - POWER RESTORED

Power outage - Cottage Grove & Hastings - power restored.

Wendy

From: Chial, Terry L
Sent: Monday, December 02, 2013 6:02 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/2/2013 Date In : 12/2/2013
Time Out : 15:34 Time In : 16:43

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 2496

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : NO

Cause : ,3 PHASE POLE FLASHED
OVER TAKING OUT FEEDER AND CUTOUPS AND ARRESTERS.

Follow-Up : NO CUSTOMERS VACANT BUILDING REFERED TO

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:39 AM
To: staff, cao (PUC); doug.renier@state.mn.us
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Power Outage - 12/14/2013 - Saint Paul
Power Outage- Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Elden, Thomas L
Sent: Saturday, December 14, 2013 16:24
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/14/2013 Date In :
Time Out : 16:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 865

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Power Restored - 12/14/2013- Saint Paul
Power Restored - Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Elden, Thomas L
Sent: Saturday, December 14, 2013 16:47
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/14/2013 Date In : 12/14/2013
Time Out : 16:16 Time In : 16:36

Time Zone : CST

Duration : 0 hours, 20 mins

Number of Customers Affected : 865

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bald eagle got between phases and took out line

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:41 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Power Restored 12/14/2013- Saint Paul
Power Restored- Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Elden, Thomas L
Sent: Saturday, December 14, 2013 17:07
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/14/2013 Date In : 12/14/2013
Time Out : 16:16 Time In : 16:36

Time Zone : CST

Duration : 0 hours, 20 mins

Number of Customers Affected : 865

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bald eagle got between phases and took out line at
bald eagle is dead and reported to chris stewart

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Friday, December 20, 2013 3:36 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/20/13 - Saint Paul
Power outage - Saint Paul.

Wendy

From: Gilland, William P
Sent: Friday, December 20, 2013 3:21 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/20/2013 Date In :
Time Out : 15:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 167

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : tbd

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 23, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 12/20/2013- Power Restored- Saint Paul
Power Restored- Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Friday, December 20, 2013 16:16
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/20/2013

Date In : 12/20/2013

Time Out : 15:13

Time In : 15:49

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 167

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : def fdr cable past

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 7:55 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice- Power Outage- 12/28/2013 - Falcon Heights, Maplewood, Saint Paul
Power Outage - Falcon Heights, Maplewood, Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Saturday, December 28, 2013 12:01
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/28/2013 Date In : 12/28/2013
Time Out : 11:03 Time In : 11:54

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 2302

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT

PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : vehicle hit pole

Follow-Up : a portion of feeder will be out until pole replaced

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 7:58 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 12/28/2013 Power Outage - Falcon Heights, Maplewood, Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

Power Outage - Falcon Heights, Maplewood, Saint Paul

From: Gilland, William P
Sent: Saturday, December 28, 2013 13:02
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/28/2013

Date In : 12/28/2013

Time Out : 11:00

Time In : 12:42

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 2302

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : vehicle broke feeder pole

Follow-Up : 1240 cust's restored at 11:54, another 214 custs restored at 12:42. 136 cust's to remain out until pole repaired

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 12/28/2013- Outage Update - Falcon Heights, Maplewood, Saint Paul
Outage Update - Falcon Heights, Maplewood, Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Browen, Troy A
Sent: Saturday, December 28, 2013 20:54
To: Gilland, William P
Cc: dl Electric Outage ME Notification
Subject: Re: Second Outage Notice

Just touched base with ME trouble Foreman. Construction crews have approximately three hours left on this pole change out. This pole is a double-deck feeder pole with a switch, the switching and opening of feeder jumpers in five spots is adding to this lengthy outage. Additional FTE's would not expedite at this time.

Dave Madigan,
Please piece together all details before 0700 on Monday.

Thanks
Troy

Troy Browen
Director, Control Center and Trouble Operations
612-202-4795

On Dec 28, 2013, at 13:02, "Gilland, William P" <William.P.Gilland@xcelenergy.com> wrote:

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/28/2013 Date In : 12/28/2013
Time Out : 11:00 Time In : 12:42

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 2302

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-
2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : vehicle broke feeder pole

Follow-Up : 1240 cust's restored at 11:54, another 214 custs
restored at 12:42. 136 cust's to remain out until pole repaired

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice 12/28/2013 - Power Restored - Falcon Heights, Maplewood, Saint Paul
Power Restored - Falcon Heights, Maplewood, Saint Paul

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Gilland, William P
Sent: Saturday, December 28, 2013 23:09
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 12/28/2013 Date In : 12/28/2013
Time Out : 11:00 Time In : 12:42

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 2302

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT

PAUL, MN

State : MN - Minnesota

Major Customers : none

normal. Cause : final 136 cust's were restored at 15:00. now back to

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 09, 2013 8:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team; 'doug.renier@state.mn.us'
Subject: FW: First Outage Notice- Power Outage 12/7/2013 - Bloomington
Power Outage- Bloomington

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Saturday, December 07, 2013 06:18
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/7/2013 Date In :
Time Out : 03:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 796

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : A phase burned down one span west of 5 switch.

Follow-Up : Trouble to temp. and restore. 246 cust. restored at 0609.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 09, 2013 8:42 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Power Restored - 12/7/2013 - Bloomington
Power Restored - Bloomington

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Hills, Thomas L
Sent: Saturday, December 07, 2013 07:00
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/7/2013 Date In : 12/7/2013

Time Out : 03:31 Time In : 06:27

Time Zone : CST

Duration : 2 hours, 56 mins

Number of Customers Affected : 796

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : A phase burned down one span west of switch.

Follow-Up : All restored. Temp jumper west of .

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/10/2013 Power Outage- Coon Rapids
Power Outage- Coon Rapids

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, December 10, 2013 18:53
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/10/2013 Date In :
Time Out : 18:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3373

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : is carrying all of 7 and part of .

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:06 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice -Update - 12/10/2013- Coon Rapids
Outage Update- Coon Rapids

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Tuesday, December 10, 2013 20:07
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/10/2013 Date In : 12/10/2013

Time Out : 18:24 Time In : 19:55

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 1442

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers :

SUB Cause : BAD HEAD CABLE ON DUE TO CONSTRUCTION AT
WAS BEING CARRIED BY WE SPLIT THAT AND PUT ON .

Follow-Up : STILL WORKING ON RESTORING REST OF CUSTOMERS

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/10/2013 Power Outage- Coon Rapids
Power Outage- Coon Rapids

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Tuesday, December 10, 2013 18:53
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/10/2013 Date In :
Time Out : 18:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3373

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up : is carrying all of and part of .

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/10/2013- Power Restored- Coon Rapids
Power Restored- Coon Rapids

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Tuesday, December 10, 2013 21:08
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/10/2013 Date In : 12/10/2013

Time Out : 18:24 Time In : 20:53

Time Zone : CST

Duration : 2 hours, 29 mins

Number of Customers Affected : 1355

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD HEAD END CABLE ON . ALL OF BACK ON AT 2053.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, December 12, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Power Outage- 12/11/2013 - Eden Prairie
Power Outage- Eden Prairie

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Babb, Randall J
Sent: Wednesday, December 11, 2013 17:40
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

Feeder/Bus : First Outage Notice

Date Out : 12/11/2013 Date In :
Time Out : 17:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 237

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, December 12, 2013 8:08 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Power Restored - 12/11/2013- Eden Prairie
Power Restored- Eden Prairie

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Wednesday, December 11, 2013 18:52
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/11/2013 Date In : 12/11/2013
Time Out : 17:34 Time In : 18:28

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 240

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : Head end cable fault.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:43 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - Power Outage - 12/14/2013- CRYSTAL,
GOLDEN VALLEY, MINNEAPOLIS,NEW HOPE,
Power Outage - CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Saturday, December 14, 2013 20:41
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/14/2013 Date In :

Time Out : 10:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2150

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW
HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : possible pole fire trbl men on the way

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice- Outage Update - 12/14/2013 -
CRYSTAL,GOLDEN VALLEY, MINNEAPOLIS, NEW HOPE
Outage Update - CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Saturday, December 14, 2013 21:01
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/14/2013

Date In :

Time Out : 20:35

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2150

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE,

MN

State : MN - Minnesota

Major Customers :

Cause : c phase wire is down at the going to the north auto let loose

Follow-Up : will do field switching to get everybody back on

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice -Outage Update - 12/14/2013 - CRYSTAL,
GOLDEN VALLEY, MINNEAPOLIS, NEW HOPE,
Outage Update - CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Saturday, December 14, 2013 21:34
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 12/14/2013

Date In :

Time Out : 20:35

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2150

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW
HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : C PHASE WIRE BURNED DOWN AT THE

Follow-Up : OPENED CLOSED TIE SW SOUTH END IS BACK ON INCLUDING

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 16, 2013 7:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - POWER RESTORED - 12/14/2013-
CRYSTAL, GOLDEN VALLEY, MINNEAPOLIS, NEW HOPE,
Power Restored - CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Saturday, December 14, 2013 21:52
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/14/2013 Date In : 12/14/2013
Time Out : 20:35 Time In : 21:48

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 2150

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE,

MN

State : MN - Minnesota

Major Customers :

Cause : C PHASE WIRE BURNED DOWN AUTO LET LOOSE AT THE

Follow-Up : EVERYBODY BACK ON INCLUDING

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 23, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/22/2013- Power Outage - Columbia Heights, Fridley, Minneapolis
Power Outage - Columbia Heights, Fridley, Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

Power Outage- Columbia Heights, Fridley, Minneapolis

From: Kittock, Joseph C
Sent: Sunday, December 22, 2013 23:20
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :
Date Out : 12/22/2013 Date In :
Time Out : 23:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1622

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 23, 2013 8:11 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/22/2013 Power Restored - Columbia Heights, Fridley, Minneapolis
Power Restored - Columbia Heights, Fridley, Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Monday, December 23, 2013 00:37
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/22/2013 Date In : 12/23/2013
Time Out : 23:07 Time In : 00:29

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1622

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : car hit pole

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, December 26, 2013 3:06 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/24/2013- Power Outage - Minneapolis
Power Outage- Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Schwarz, John W
Sent: Tuesday, December 24, 2013 19:46
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/24/2013 Date In :
Time Out : 19:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 78

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Thursday, December 26, 2013 3:06 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/24/2013- Power Restored - Minneapolis
Power Restored- Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Schwarz, John W
Sent: Tuesday, December 24, 2013 20:42
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/24/2013 Date In : 12/24/2013

Time Out : 19:42 Time In : 20:33

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 78

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : BAD FEEDER CABLE,

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 12:46 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/27/2013 -Power Outage Golden Valley and Saint Louis Park
Power Outage - Golden Valley and Saint Louis Park

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Friday, December 27, 2013 10:11
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 12/27/2013 Date In :
Time Out : 09:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 291

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN TRBL ON THE WAY

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 12:47 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/27/2013 - Power Restored - Golden Valley
and Saint Louis Park
Power Restored - Golden Valley and Saint Louis Park

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Friday, December 27, 2013 10:43
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/27/2013 Date In : 12/27/2013
Time Out : 09:59 Time In : 10:37

Time Zone : CST

Duration : 0 hours, 38 mins

Number of Customers Affected : 291

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : ASSTORERS AT

SWITCH CAUSE OUTAGE

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 8:33 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/27/2013 - Power Outage - Minneapolis
Power Outage - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Friday, December 27, 2013 06:03
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/27/2013

Date In :

Time Out : 06:00

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 614

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : unknown at this time

Follow-Up : trouble on the way

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 8:34 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 12/27/2013 - Power Outage - Minneapolis
Power Outage - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Friday, December 27, 2013 06:54
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/27/2013

Date In :

Time Out : 06:00

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 614

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

TIME

Cause : LD

IS SMOKED POSSIBLE BAD 1/0'S SWITCHING LD CTR OUT AT THIS

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 8:35 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice 12/27/2013 -Power Outage - Minneapolis
Power Outage - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Friday, December 27, 2013 07:53
To: dl Electric Outage MW Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice
Feeder/Bus :

Date Out : 12/27/2013 Date In :
Time Out : 06:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 614

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : LD IS SMOKED 55 CUSTOMERS PICKED UP WITH BKR AT THE SUB
AT 706 544 CUSTOMERS PICKED UP WITH TIE AT 0745 15 CUSTOMERS STILL OUT
TESTING CABLE AT THIS TIME TO BRING THEM BACK ON

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Friday, December 27, 2013 12:44 PM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/27/2013 - Power Restored - Minneapolis
Power Restored - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Cedar, Daren A
Sent: Friday, December 27, 2013 11:25
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/27/2013 Date In : 12/27/2013
Time Out : 06:00 Time In : 11:15

Time Zone : CST

Duration : 5 hours, 15 mins

Number of Customers Affected : 614

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : LD IS SMOKED

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/28/2013 - Power Outage - Minnetrista
Power Outage - Minnetrista

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Saturday, December 28, 2013 19:58
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/28/2013

Date In :

Time Out : 19:53

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 283

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN

State : MN - Minnesota

Major Customers : non

sw. Cause : Intentional outage to clear up a hazzard between tie

Follow-Up : Verticle feeder pole has a 7 ft. jumper dangling near open delta tap.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:03 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/28/2013- Power Restored - Minnetrista
Power Restored - Minnetrista

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Saturday, December 28, 2013 20:28
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/28/2013

Date In : 12/28/2013

Time Out : 19:53

Time In : 20:23

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 283

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : Minnetrista

State : MN - Minnesota

Major Customers : non

sw. Cause : Intentional outage to clear up a hazzard between tie

Follow-Up : Verticle feeder pole has a 7 ft. jumper dangling near open delta tap.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:07 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/29/2013 - Power Outage - Minneapolis
Power Outage - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Sunday, December 29, 2013 20:56
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/29/2013

Date In :

Time Out : 20:14

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2150

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : C phase feeder fell down at

Follow-Up : C phase count only.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:16 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/29/2013 - Power Restored - Minneapolis
Power Restored - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Sunday, December 29, 2013 21:04
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/29/2013 Date In : 12/29/2013

Time Out : 20:14 Time In : 20:45

Time Zone : CST

Duration : 0 hours, 31 mins

Number of Customers Affected : 2150

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : C phase burnt down...closed this and created feeder outage at 2045 on

Follow-Up : C phase time out now under feeder outage in order to clear hazzard.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:08 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/29/2013 - Power Outage - Minneapolis
Outage Update - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Sunday, December 29, 2013 20:58
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 12/29/2013 Date In :
Time Out : 20:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4589

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Opened to clear hazzard.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 12/29/2013 Outage Update - Minneapolis
Outage Update- Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Sunday, December 29, 2013 23:01
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/29/2013 Date In : 12/29/2013
Time Out : 20:45 Time In : 22:32

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 2438

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : C phase fell down across light rail.

Follow-Up : Cleared wire and closed

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:17 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/29/2013- Power Restored - Minneapolis
Power Restored - Minneapolis

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kittock, Joseph C
Sent: Sunday, December 29, 2013 23:20
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/29/2013

Date In : 12/29/2013

Time Out : 20:45

Time In : 22:33

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 2151

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : C phase fell down across

Follow-Up : Closed
tap fuses were open due to back feed from

. to back feed C phase...Reported that 90% of C phase
. These remain open at this time.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 31, 2013 8:08 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/30/2013 - Power Outage - Eden Prairie,
Minnetonka
Power Outage - Eden Prairie, Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Monday, December 30, 2013 22:26
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/30/2013 Date In :
Time Out : 22:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2311

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 31, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 12/30 12/31 - Outage Update - Eden Prairie, Minnetonka
Outage Update - Eden Prairie and Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Tuesday, December 31, 2013 00:03
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification
Second Outage Notice
Feeder/Bus :
Date Out : 12/31/2013 Date In :
Time Out : 22:08 Time In :
Time Zone : CST
Duration :
Number of Customers Affected : 2311
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369
Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

BUILT) Cause : PHASE FELL DOWN FROM 69 KV LN ON TO (UNDER

Follow-Up : WORKING TO CLEAR DOWN PHASE

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 31, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/30 Power Restored - Eden Prairie, Minnetonka
Power Restored- Eden Prairie, Minnetonka

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Anderson, Timothy K
Sent: Tuesday, December 31, 2013 02:11
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

E Final Outage Notice

Feeder/Bus :

Date Out : 12/30/2013 Date In : 12/31/2013
Time Out : 22:08 Time In : 1:37

Time Zone : CST

Duration : 3 hours, 29 mins

Number of Customers Affected : 2311

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PHASE FROM 69 KV LN FELL ON

Follow-Up : PATROL,DAMMAGE TO HEAD IN CABLE & POLE) REFER BIDDLE
& REPAIR

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, December 05, 2013 7:21 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/5/13 - Brooten,
Glenwood, Lowry, Sedan & Starbuck
Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck.

Wendy

From: Peterson, Mark S
Sent: Thursday, December 05, 2013 5:26 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/5/2013 Date In :
Time Out : 03:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1229

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN,
MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, December 05, 2013 7:24 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/5/13 - Brooten,
Glenwood, Lowry, Sedan & Starbuck - UPDATE
UPDATE - SEE BELOW....

From: Peterson, Mark S
Sent: Thursday, December 05, 2013 5:31 AM
To: Peterson, Mark S; dl Electric Outage NT Notification
Subject: RE: First Outage Notice

[Disregard this notification! Wrong time out. New alert sent!](#)

From: Peterson, Mark S
Sent: Thursday, December 05, 2013 05:26
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/5/2013 Date In :
Time Out : 03:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1229

Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN;
SEDAN, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, December 05, 2013 7:25 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 12/5/13 - Brooten,
Glenwood, Lowry, Sedan & Starbuck
Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck.

Wendy

From: Peterson, Mark S
Sent: Thursday, December 05, 2013 5:29 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/5/2013 Date In :
Time Out : 04:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1229

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN,
MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : none

Cause : Crew in Route

Follow-Up :

Hedlund, Amber R

From: Jaede, Wendy L
Sent: Thursday, December 05, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/5/13 - Brooten,
Glenwood, Lowry, Sedan & Starbuck - POWER RESTORED
Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck - power restored.

Wendy

From: Peterson, Mark S
Sent: Thursday, December 05, 2013 8:03 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/5/2013 Date In : 12/5/2013
Time Out : 04:55 Time In : 07:40

Time Zone : CST

Duration : 2 hours, 45 mins

Number of Customers Affected : 1229

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN,
MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : none

Cause : transmission level event.

Follow-Up : 1161 customers back in @ 0720 ; 68 @ 0740

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:04 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice- Power Outage- 12/9/2013- BELVIEW +
5 others

Power Outage- BELVIEW, COTTONWOOD, ECHO, GRANITE FALLS, HANLEY FALLS,
HAZEL RUN, WOOD LAKE, WOODLAKE

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Monday, December 09, 2013 20:24
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus : 211, 212

Date Out : 12/9/2013 Date In :

Time Out : 19:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1330

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

State : MN - Minnesota

Major Customers : na

Cause : Transmission outage

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice- 12/9/2013- BELVIEW, + 5 others
Power Outage Update- BELVIEW, COTTONWOOD, ECHO, GRANITE FALLS, HANLEY FALLS, HAZEL RUN, WOOD LAKE, WOODLAKE

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Monday, December 09, 2013 20:48
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/9/2013 Date In :
Time Out : 19:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1330

Communities Affected : BELVIEW, MN; COTTONWOOD, MN; ECHO, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN; WOOD LAKE, MN; WOODLAKE, MN

State : MN - Minnesota

Major Customers : NA

Cause : Transmission has been galloping dur to high winds and ice. Off & on multiple times / crew is isolating and hope the wind will die down or change direction.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:05 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice- POWER RESTORED
12/9/2013 - BELVIEW, + 5 others

Power Restored - BELVIEW, COTTONWOOD, ECHO, GRANITE FALLS, HANLEY FALLS, HAZEL RUN, WOOD LAKE, WOODLAKE

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Monday, December 09, 2013 21:42
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/9/2013 Date In : 12/9/2013
Time Out : 19:53 Time In : 21:07

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1330

Communities Affected : BELVIEW, MN; COTTONWOOD, MN; ECHO, MN; GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN; WOOD LAKE, MN; WOODLAKE, MN

State : MN - Minnesota

Major Customers : NA

Cause : Transmission Level Event due to galoping conductors in high winds and ice.
Multiple breaker operations and switching to isolate line.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:09 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 12/11/2013- Power Outage - Montevideo
Power Outage- Montevideo

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Wednesday, December 11, 2013 03:08
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/11/2013 Date In :
Time Out : 02:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 385

Communities Affected : MONTEVIDEO, MN

State : MN - Minnesota

Major Customers :

Cause :
operator called in.

Non RTU Sub / found breaker open on arrival. Patrolling feeder and

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:10 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice- Power Restored- 12/11/2013- Montevideo
Power Restored- Montevideo

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Goulet, Terry W
Sent: Wednesday, December 11, 2013 04:04
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 12/11/2013	Date In : 12/11/2013
Time Out : 02:05	Time In : 03:38

Time Zone : CST
Duration : 1 hours, 33 mins
Number of Customers Affected : 385
Communities Affected : MONTEVIDEO, MN
State : MN - Minnesota
Major Customers :

Cause : Crew found automatic splice pulled apart in jumper
Repairs made and breaker closed @ 0338

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice Power Outage - Power Outage - 12/28/2013- Champlin, Dayton, Maple Grove, Osseo, Rogers
Power Outage - Champlin, Dayton, Maple Grove, Osseo, Rogers

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Medellin, Victor J
Sent: Saturday, December 28, 2013 16:55
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/28/2013 Date In :
Time Out : 16:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1272

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN;

OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause : INTENTIONAL TO CLEAR POLE OFF OF CAR

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 30, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/28/2013- Power Restored - Champlin, Dayton, Maple Grove, Osseo, Rogers
Power Restored - Champlin, Dayton, Maple Grove, Osseo, Rogers

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Chase, Julie B
Sent: Saturday, December 28, 2013 17:10
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/28/2013 Date In : 12/28/2013
Time Out : 16:50 Time In : 17:05

Time Zone : CST

Duration : 0 hours, 15 mins

Number of Customers Affected : 1272

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CHAMPLIN, MN; DAYTON, MN; MAPLE GROVE, MN; OSSEO, MN;

ROGERS, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : car broke pole at

intentional to remove pole from top of vehicle

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:01 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice Power Outage - 12/9/2013-
CURRIE, MN; GARVIN, MN; TRACY, MN
Power Outage- CURRIE, MN; GARVIN, MN; TRACY, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Monday, December 09, 2013 20:21
To: dl Electric Outage SD Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/9/2013 Date In :
Time Out : 19:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1607

Communities Affected : CURRIE, MN; GARVIN, MN; TRACY, MN

State : SD - South Dakota

Major Customers : None

Cause : Transmission Level Event, wind and ice.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - Update
12/9/2013- CURRIE, MN; GARVIN, MN; TRACY, MN
Power Outage -CURRIE, MN; GARVIN, MN; TRACY, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Monday, December 09, 2013 21:20
To: dl Electric Outage SD Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/9/2013 Date In :

Time Out : 19:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1607

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CURRIE, MN; GARVIN, MN; TRACY, MN

State : SD - South Dakota

Major Customers : None

Cause : Transmission Level Event, Galloping conductors with wind and ice. Constant Trip and Reclosing. Troublemaker on scene.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Tuesday, December 10, 2013 8:02 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/9/2013- POWER
RESTORED
Power Restored- CURRIE, MN; GARVIN, MN; TRACY, MN

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Kaveny, Michael J
Sent: Monday, December 09, 2013 21:41
To: dl Electric Outage SD Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/9/2013 Date In : 12/9/2013
Time Out : 19:53 Time In : 21:30

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 1607

Communities Affected : CURRIE, MN; GARVIN, MN; TRACY, MN

State : SD - South Dakota

Major Customers : None

restored at 2130. Cause : Transmission Level Event, Tripping and Reclosing. Customers should be 100%

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 09, 2013 8:44 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice Power Outage - 12/8/2013 - Brooklyn Park, Crystal, Minneapolis and New Hope
Power Outage - Brooklyn Park, Crystal, Minneapolis and New Hope

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Ayers, Patrick S
Sent: Sunday, December 08, 2013 01:01
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 12/8/2013

Date In :

Time Out : 00:56

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2919

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN;
MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 1/0 ACSR TAP OFF OF FEEDER LAYING DOWN ACROSS
LOCATION IS ABOUT .POLICE ON SCENE.NEEDED
TO OPEN FEEDER BKR.

Follow-Up :

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 09, 2013 8:45 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice Power Outage - 12/8/2013 - Brooklyn Park, Crystal, Minneapolis and New Hope
Power Outage Update - Brooklyn Park, Crystal, Minneapolis and New Hope

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Ayers, Patrick S
Sent: Sunday, December 08, 2013 01:15
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/8/2013 Date In : 12/8/2013
Time Out : 00:56 Time In : 01:06

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 2919

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN;
MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : A PHASE 1/0 ACSR TAP OFF FEEDER DOWN ACROSS
,ALL BUT 658 CUST. BACK IN AS OF 0106.

Follow-Up : TROUBLEMAN ON SCENE TO CLEAR UP WIRE,PUT WIRE
BACK UP AND RESTORE POWER.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Monday, December 09, 2013 8:46 AM
To: 'doug.renier@state.mn.us'; 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Power Restored - 12/8/2013 - Brooklyn Park, Crystal, Minneapolis and New Hope
Power Restored - Brooklyn Park, Crystal, Minneapolis and New Hope

Allyson Guttormson

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (612) 329-2982
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Ayers, Patrick S
Sent: Sunday, December 08, 2013 02:56
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/8/2013 Date In : 12/8/2013
Time Out : 00:31 Time In : 02:40

Time Zone : CST

Duration : 2 hours, 9 mins

Number of Customers Affected : 2919

Communities Affected : BROOKLYN PARK, MN; CRYSTAL, MN;
MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN ACROSS
APPEARS TO HAVE PULLED OUT OF SLEEVE.

WIRE

Follow-Up : TROUBLEMAN CLEARED UP WIRE,SPLICED WIRE
TOGETHER,PUT PHASE BACK UP,PATROLLED TAP,CLOSED IN R-56-140D
RECLOSURE.FINAL CUST.RESTORED AS OF 0240.

Hedlund, Amber R

From: Guttormson, Allyson E
Sent: Wednesday, December 11, 2013 8:08 AM
To: 'staff, cao (PUC)'; 'doug.renier@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice- Outage Update -12/13/2013- Coon Rapids

Outage Update- Coon Rapids

Allyson Guttormson

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Dr, Roseville, MN 55113

P: (651) 639-4526 F: (612) 329-2982

E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

From: Knutson, David A
Sent: Tuesday, December 10, 2013 21:02
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 12/10/2013

Date In : 12/10/2013

Time Out : 18:24

Time In : 20:25

Time Zone : CST

Duration : 2 hours, 1 mins

Number of Customers Affected : 576

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PART OF WAS BEING CARRIED BY 1. WE OPENED TIE SW
AND CLOSED THE .

Follow-Up : GOING TO CLOSE 1 TO PICK UP PART OF