

Rebuttal Testimony  
Gregory L. Ford

Before the Minnesota Public Utilities Commission  
State of North Dakota

In the Matter of the Petition of Northern States Power Company d/b/a  
Xcel Energy for Approval of Competitive Resource Acquisition Proposal and  
Certificate of Need

Docket No. E002/CN-12-1240  
Exhibit\_\_\_(GLF-2)

**CT Generation Response and Selective Catalytic Reduction Testimony**

October 18, 2013

## Table of Contents

I.	Introduction	1
II.	CT Generation Response Time	1
III.	Selective Catalytic Reduction	3

1 **I. INTRODUCTION**

2  
3 Q. PLEASE STATE YOUR NAME AND TITLE.

4 A. My name is Gregory L. Ford. I am Director of Engineering, Design, and  
5 Document Services in the Energy Supply Engineering and Construction  
6 Department.

7  
8 Q. HAVE YOU PREVIOUSLY PROVIDED TESTIMONY IN THIS PROCEEDING?

9 A. Yes, I filed direct testimony discussing the design, operation and maintenance,  
10 and construction costs and schedules for the Company's proposed addition of  
11 three 215 MW natural gas-fired, simple-cycle, combustion turbine generators  
12 to its system at its Black Dog location in Burnsville, Minnesota, and a new  
13 generating plant to be located near the Red River Valley by Hankinson, North  
14 Dakota.

15  
16 Q. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?

17 A. I address the testimony of Calpine witness Paul Hibbard regarding the  
18 responsiveness of combustion turbine (CT) generation versus combined cycle  
19 (CC) generation with respect to load-following. In addition, I address Mr.  
20 Hibbard's testimony about the purported need for Selective Catalytic  
21 Reduction (SCR) for the Company's three proposed CT generators.

22  
23 **II. CT GENERATION RESPONSE**

24  
25 Q. WHAT WAS MR. HIBBARD'S TESTIMONY WITH RESPECT TO CT GENERATION  
26 AND LOAD FOLLOWING?

27 A. In his direct testimony, at pages 27-28, Mr. Hibbard provided testimony on

1 the ability of both CT and CC generation to address expected variation in load  
2 that occurs over several hours or more, and sudden system events for which  
3 recovery is needed in tens of minutes or hours. For purposes of load  
4 following, however, Mr. Hibbard testified that CC generation could address  
5 net load variation in a matter of minutes and tens of minutes, while the CT  
6 generation proposed in this proceeding by Invenergy and the Company may  
7 require more advance notice time.

8

9 Q. WHAT DOES LOAD FOLLOWING REFER TO?

10 A. Load following refers to the adjustment of the generation levels of the  
11 system's coal and gas fired units to match the variations in the system's load  
12 that occur on a minute-by-minute basis. Many of these units are equipped  
13 with automatic generation controls (AGC) to facilitate the quickest response  
14 by generation units to meet system load shifts.

15

16 Q. DO YOU AGREE WITH MR. HIBBARD REGARDING THE ABILITY OF  
17 CC GENERATION TO MORE QUICKLY RESPOND THAN CT GENERATION FOR  
18 PURPOSES OF LOAD FOLLOWING?

19 A. If the CC unit is already on line and at operating load, it would generally have  
20 a wider operating range and a potentially faster ramp rate available than a large  
21 frame CT. However, the current F Class CT technology being considered for  
22 Black Dog Unit 6 and Red River Valley Units 1 and 2 – the GE 7FA Series 5  
23 and the Siemens 5000F.05 – has a 50 to 100 percent load operating range with  
24 a high ramp rate, and an 8 to 10 minute cold start to minimum load capability.  
25 Older F Class models, on the other hand, have a 30-minute start time from  
26 cold, have a smaller operating range while meeting emissions limits, and have  
27 slower ramp rates within the operating range. All of these traits make older

1 models less capable of supporting system changes in load.

2  
3 A CC facility such as proposed by Calpine will have a significantly slower start  
4 time than the current F Class CTs proposed for Black Dog 6 and Red River  
5 Valley 1 and 2. The combustion turbine start time for Calpine will be on the  
6 order of 30 minutes, based on CT cold start criteria, but will be slowed in  
7 achieving operational levels by the requirements to bring the Heat Recovery  
8 Steam Generator (HRSG) up to temperature and pressure, and to match the  
9 steam temperatures and pressures with the other unit, assuming the other unit  
10 is already on line.

11  
12 **III. SELECTIVE CATALYTIC REDUCTION**

13  
14 Q. WHAT IS YOUR RESPONSE TO MR. HIBBARD'S ADJUSTMENT OF THE COSTS OF  
15 THE CT GENERATION PROPOSALS IN THIS PROCEEDING TO INCLUDE  
16 SELECTIVE CATALYTIC REDUCTION?

17 A. The addition of SCR to our proposed CTs is wholly unnecessary because  
18 these units will meet all applicable environmental standards. As proposed,  
19 Black Dog 6 and Red River Valley 1 and 2 meet the current NOx Best  
20 Available Control Technology (BACT) emission requirements for peaking or  
21 CT units of 9 ppm under normal operating conditions, not including startup,  
22 shutdown, or upset conditions. We have also completed a permitting analysis  
23 that demonstrates Black Dog 6 and Red River Valley 1 and 2 will comply with  
24 the more recent rules of the National Ambient Air Quality Standards  
25 (NAAQS) that place restrictions on emissions from a plant site on an hourly  
26 basis. These rules apply to all modes of operation, including the start up/shut  
27 down period when CT and CC emissions are significantly higher than during

1 normal operation. Adding Unit 6 to the Black Dog plant upon the retirement  
2 of Units 3 and 4 will result in an overall reduction of plant site emissions from  
3 historical levels.

4  
5 Q. WHAT IS YOUR RESPONSE TO MR. HIBBARD'S CONTENTION AT PAGES 29-30 OF  
6 HIS DIRECT TESTIMONY THAT THE \$15 MILLION OF SCR TECHNOLOGY COSTS  
7 NEED TO BE ADDED TO EACH CT PROPOSAL SO THAT CALPINE IS NOT  
8 PUNISHED FOR BEING A MORE EXPENSIVE GENERATION PROPOSAL THAT  
9 RESULTS IN LOWER EMISSIONS?

10 A. As Mr. Wishart explains in his rebuttal testimony addressing this proposed  
11 adjustment, the relative value of a unit that costs more to build and maintain  
12 but results in less emissions is fully captured by Strategist's analysis of the  
13 avoided costs associated with the unit's lower emissions. What concerns me  
14 about Mr. Hibbard's contention is the implication that the operation of  
15 Calpine's CC facility will necessarily result in significantly lower emissions over  
16 time than the operation of a CT. This is not the case.

17  
18 As I noted, current permitting criteria for a CT in Minnesota and North  
19 Dakota under BACT is 9 ppm for NO<sub>x</sub>, while it is 4.5 ppm or even lower for  
20 a CC unit. But with CCs commonly operating at a capacity factor that is four  
21 times higher than the capacity factor for CTs (20 percent versus 5 percent), a  
22 CC unit will emit double the NO<sub>x</sub> emissions on an annual basis than a CT.

23  
24 In addition, all CTs – whether operating alone or in a CC configuration – have  
25 significantly higher NO<sub>x</sub> and CO emissions during the startup period, and to a  
26 smaller extent during shut down. The quick start CTs that we are proposing  
27 have a shorter time period from first fire to minimum environmental

1 compliance than the older models of F Class CTs, and thus will have less total  
2 emissions for each start. The CT emissions for a CC plant during startup are  
3 also high because SCR cannot be put into service until the gas temperature in  
4 the Heat Recovery Steam Generator gets high enough for the ammonia and  
5 catalyst to work effectively. Startup emissions are a significant portion of the  
6 annual totals for a CT even in CC mode.

7

8 Q. DOES THIS CONCLUDE YOUR TESTIMONY?

9 A. Yes, it does.