

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 07, 2015 3:18 PM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: FW: [REDACTED] First Outage Notice - 1/7/15 - Eagle Lake, Janesville, Madison Lake, Mankato, Saint Clair & Smiths Mill

Power outage - Eagle Lake, Janesville, Madison Lake, Mankato, Saint Clair & Smiths Mill.

Wendy

From: Chase, Julie B
Sent: Wednesday, January 07, 2015 2:51 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/7/2015 Date In :
Time Out : 14:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1262

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EAGLE LAKE, MN; JANESVILLE, MN; MADISON LAKE, MN; MANKATO, MN; SAINT CLAIR, MN; SMITHS MILL, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission event, troubleman enroute

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, January 07, 2015 3:58 PM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Notice - 1/7/15 - Eagle Lk, Janesville, Madison Lk, Mankato, Saint Clair & Smiths Mill - POWER RESTORED

Power outage - Eagle Lake, Janesville, Madison Lake, Mankato, Saint Clair & Smiths Mill – power restored.

Wendy

From: Chase, Julie B
Sent: Wednesday, January 07, 2015 3:52 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/7/2015 Date In : 1/7/2015
Time Out : 14:38 Time In : 15:48

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1262

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EAGLE LAKE, MN; JANESVILLE, MN; MADISON LAKE, MN; MANKATO, MN; SAINT CLAIR, MN; SMITHS MILL, MN

State : MN - Minnesota

Major Customers :

Cause : transmission event

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 12, 2015 8:01 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice-1/10/15-Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, St. Paul, Sunfish Lk, W St. Paul

Power outage - Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake, West Saint Paul.

Wendy

From: Streine, Richard P
Sent: Saturday, January 10, 2015 9:33 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/10/2015 Date In :
Time Out : 19:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1898

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : car accident-trbl on site

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 12, 2015 8:02 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Notice-1/10/15 - Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, St. Paul, Sunfish Lk, W St. Paul-POWER RESTORED

Power outage - Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake, West Saint Paul – power restored.

Wendy

From: Streine, Richard P
Sent: Saturday, January 10, 2015 10:35 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/10/2015 Date In : 1/10/2015
Time Out : 19:57 Time In : 22:22

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 1898

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause: car hit pole at [REDACTED] causing wire to burn down at [REDACTED]

Follow-Up : temp repairs made 100% restored @22:22

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 12, 2015 8:03 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/11/15 - Chanhassen & Eden Prairie

Power outage - Chanhassen & Eden Prairie.

Wendy

From: Cedar, Daren A
Sent: Sunday, January 11, 2015 12:40 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/11/2015 Date In :
Time Out : 00:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 917

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 12, 2015 8:04 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/11/15 - Chanhassen & Eden Prairie
- POWER RESTORED

Power outage - Chanhassen & Eden Prairie – power restored.

Wendy

From: Cedar, Daren A
Sent: Sunday, January 11, 2015 1:52 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/11/2015 Date In : 1/11/2015
Time Out : 00:33 Time In : 01:48

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 917

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE FAULT BETWEEN [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 12, 2015 8:05 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/11/15 - Chanhassen & Eden Prairie
- POWER RESTORED/UPDATE

Power outage - Chanhassen & Eden Prairie – power restored/update.

Wendy

From: Cedar, Daren A
Sent: Sunday, January 11, 2015 2:00 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/11/2015 Date In : 1/11/2015
Time Out : 00:33 Time In : 01:54

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 917

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CABLE FAULT [REDACTED] TIME CORRECTION

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 8:24 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/13/15 - Lake Elmo, Maplewood & Oakdale

Power outage - Lake Elmo, Maplewood & Oakdale.

Wendy

From: Abbott, Edward J
Sent: Tuesday, January 13, 2015 5:56 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In :
Time Out : 05:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 8:24 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 1/13/15 - Lake Elmo, Maplewood & Oakdale - UPDATE

Power outage - Lake Elmo, Maplewood & Oakdale – update.

Wendy

From: Stewart, Christopher D
Sent: Tuesday, January 13, 2015 7:43 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Second Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In :
Time Out : 05:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : We have one 336 auto sleeve burned down at this time, 2 Troublemakers are on site and 1 more is on the way. We are still patrolling for the primary cause.

~~Follow-Up: Currently patrolling the feeder and sectionalizing.~~

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 8:25 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 1/13/15 - Lake Elmo, Maplewood & Oakdale - UPDATE

Power outage - Lake Elmo, Maplewood & Oakdale – update.

Wendy

From: Stewart, Christopher D
Sent: Tuesday, January 13, 2015 8:18 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Third Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In :
Time Out : 05:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : N\A

Cause : Still under investigation. We have the [REDACTED] open for the burned down wire and the [REDACTED] open into [REDACTED].

Follow-Up [REDACTED] *Breaker closed @ 07:52. 312 customers remain out behind the* [REDACTED] *until we clear the downed wire.*

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 9:21 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/13/15 - Lake Elmo, Maplewood & Oakdale - POWER RESTORED

Power outage - Lake Elmo, Maplewood & Oakdale – power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, January 13, 2015 9:00 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In : 1/13/2015
Time Out : 05:47 Time In : 08:54

Time Zone : CST

Duration : 3 hours, 7 mins

Number of Customers Affected : 2313

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : ALL CUSTOMERS BACK ON AND CONSTUCTION ON SITE PUTTING UP A PHASE ON

FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 10:01 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/13/15 - Mankato

Power outage – Mankato.

Wendy

From: Johnson, Michael A
Sent: Tuesday, January 13, 2015 10:00 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In :
Time Out : 09:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 552

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : FEEDER HAD THREE OPERATIONS AND STAYED IN, NO LOAD ON ONE PHASE
AFTER; SUB OPERATOR AND TROUBLESMAN ENROUTE TO INVESTIGATE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, January 13, 2015 11:22 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/13/15 - Mankato - POWER RESTORED

Power outage – Mankato – power restored.

Wendy

From: Johnson, Michael A
Sent: Tuesday, January 13, 2015 11:12 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/13/2015 Date In : 1/13/2015
Time Out : 09:51 Time In : 11:09

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 552

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : FAULTED B PHASE HEAD END CABLE; ALL CUSTOMERS RESTORED BY SWITCHING

AT 11:09

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 15, 2015 12:18 PM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/15/15 - Champlin, Maple Grove & Osseo

Power outage - Champlin, Maple Grove & Osseo.

Wendy

From: Babb, Randall J
Sent: Thursday, January 15, 2015 12:11 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/15/2015 Date In :
Time Out : 11:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2305

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHAMPLIN, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Unknown

Follow-Up : Troublemens enroute.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 15, 2015 12:49 PM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 1/15/15 - Champlin, Maple Grove & Osseo - UPDATE

Power outage - Champlin, Maple Grove & Osseo – update.

Wendy

From: Anderson, Timothy K
Sent: Thursday, January 15, 2015 12:47 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/15/2015 Date In :
Time Out : 11:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2305

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHAMPLIN, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : FEEDER WIRE DOWN C PHASE, [REDACTED]

Follow-Up : ISO REFER FOR OH TO PUT UP WIRE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 15, 2015 2:44 PM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 1/15/15 - Champlin, Maple Grove & Osseo - UPDATE

Power outage - Champlin, Maple Grove & Osseo – update.

Wendy

From: Babb, Randall J
Sent: Thursday, January 15, 2015 2:11 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/15/2015 Date In :
Time Out : 11:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2305

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHAMPLIN, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Automatic sleeve failure causing mainline wire down at [REDACTED]

Follow-Up: 1276 customers restored at 13:32, 724 at 13:39, 273 at 13:38. Crew on site making repairs to restore remaining 32 customers.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, January 16, 2015 8:22 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/15/15 - Champlin, Maple Grove & Osseo - POWER RESTORED

Power outage - Champlin, Maple Grove & Osseo – power restored.

Wendy

From: Babb, Randall J
Sent: Thursday, January 15, 2015 4:09 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/15/2015 Date In : 1/15/2015
Time Out : 11:58 Time In : 15:32

Time Zone : CST

Duration : 3 hours, 34 mins

Number of Customers Affected : 2305

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHAMPLIN, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Automatic sleeve failure causing mainline wire down at [REDACTED].

Follow-Up : Repairs made by crew, remaining 32 customers restored.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 19, 2015 8:47 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/16/15 - Edina, Minneapolis & Saint Louis Park

Power outage - Edina, Minneapolis & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Friday, January 16, 2015 11:58 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 1/16/2015

Date In :

Time Out : 23:39

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Major Communities Affected Noted: EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down [REDACTED]. Garage fire.

Follow-Up : Momentaried at 23:39. Opened [REDACTED] Breaker at 23:50.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, January 19, 2015 8:49 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/16/15 - Edina, Minneapolis & Saint Louis Park - POWER RESTORED

Power outage - Edina, Minneapolis & Saint Louis Park – power restored.

Wendy

From: Hills, Thomas L
Sent: Saturday, January 17, 2015 1:21 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/16/2015 Date In : 1/17/2015
Time Out : 23:39 Time In : 01:17

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 2608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : A phase wire down at [REDACTED]. Garage fire.

Follow Up Momentaries at 23:39. Opened [REDACTED] Breaker at 23:50.
Momentaries at 23:39. Opened [REDACTED] Breaker at 23:50. 234 customers in at 0102. 2374 customers in at

0117.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 22, 2015 9:31 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/22/15 - Lakeville

Power outage – Lakeville.

Wendy

From: Elden, Thomas L
Sent: Thursday, January 22, 2015 9:02 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/22/2015 Date In :
Time Out : 08:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1938

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : mn

Cause : [REDACTED] burned up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 22, 2015 9:43 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/22/15 - Lakeville - POWER RESTORED

Power outage – Lakeville – power restored.

Wendy

From: Elden, Thomas L
Sent: Thursday, January 22, 2015 9:34 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/22/2015 Date In : 1/22/2015
Time Out : 08:13 Time In : 09:27

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1938

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : mn

Cause : [REDACTED] burned up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 22, 2015 10:02 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/22/15 - Lakeville - POWER RESTORED/UPDATE

Power outage – Lakeville – power restored/update.

Wendy

From: Stewart, Christopher D
Sent: Thursday, January 22, 2015 9:49 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Final Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 1/22/2015 Date In : 1/22/2015
Time Out : 08:13 Time In : 09:27

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1938

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Switching error/[REDACTED] switch failure

Follow-Up : Currently replacing the [REDACTED]

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 22, 2015 10:32 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice UPDATED CUSTOMER COUNT - 1/22/15 - Lakeville - POWER RESTORED/UPDATE-CUSTOMER

Power outage – Lakeville – power restored/update – updated customer count.

Wendy

From: Stewart, Christopher D
Sent: Thursday, January 22, 2015 10:23 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice UPDATED CUSTOMER COUNT

Distribution System Status Outage Notification

[REDACTED] *Final Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 1/22/2015 Date In : 1/22/2015
Time Out : 08:13 Time In : 09:27

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 3399

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : None

Cause : Switching error/[REDACTED] switch failure

Follow-Up: Currently replacing the [REDACTED] switch. THIS HAS THE UPDATED CUSTOMER COUNT.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 29, 2015 8:39 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 1/28/15 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria

Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria.

Wendy

From: Hills, Thomas L
Sent: Wednesday, January 28, 2015 3:25 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/28/2015 Date In :
Time Out : 14:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3007

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : None

Cause : Broken pole on [REDACTED] and 1.5 mi. west of [REDACTED]

Follow-Up Intel team operated. 3 switch opened and [REDACTED] breaker closed back in restoring up to the 3 switch.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 29, 2015 8:40 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 1/28/15 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - UPDATE

Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria – update.

Wendy

From: Kubes, Kenneth B
Sent: Wednesday, January 28, 2015 4:54 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/28/2015 Date In :
Time Out : 14:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3007

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : NONE

WEST OF SWITCH AT [REDACTED] & [REDACTED].
Cause: CAR HIT POLE WEST OF SWITCH. FAULT CURRENT BURNED DOWN WIRE WEST

Follow-Up : IN PROCESS OF ISOLATING DOWN WIRE. CONSTRUCTION CREW ENROUTE TO PUT UP WIRE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, January 29, 2015 8:41 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 1/28/15 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - POWER RESTORED

Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria – power restored.

Wendy

From: Knutson, David A
Sent: Wednesday, January 28, 2015 8:02 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 1/28/2015 Date In : 1/28/2015
Time Out : 14:57 Time In : 18:18

Time Zone : CST

Duration : 3 hours, 21 mins

Number of Customers Affected : 6402

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN; EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit pole

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 03, 2015 11:22 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 2/3/15 - Saint Paul

Power outage – Saint Paul.

Wendy

From: Wolf, Terry K
Sent: Tuesday, February 03, 2015 10:17 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/3/2015 Date In :
Time Out : 10:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1462

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : L01 smoking

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 03, 2015 11:23 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 2/3/15 - Saint Paul - UPDATE

Power outage – Saint Paul – update.

Wendy

From: Wolf, Terry K
Sent: Tuesday, February 03, 2015 11:14 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/3/2015 Date In :
Time Out : 10:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : fault on [REDACTED] switch gear

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 03, 2015 11:49 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 2/3/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy

From: Stewart, Christopher D
Sent: Tuesday, February 03, 2015 11:45 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Final Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 2/3/2015 *Date In : 2/3/2015*
Time Out : 10:00 *Time In : 11:24*

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1462

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Fault on [REDACTED] equipment

Follow-Up: Need to replace potheads in switchgear. 1461 customers restored @ 11:09, final customer restored @ 11:24.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 04, 2015 7:45 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 2/4/15 - Cold Springs, Rockville, Saint Cloud, Saint Joseph, Sartell & Waite Park

Power outage - Cold Springs, Rockville, Saint Cloud, Saint Joseph, Sartell & Waite Park.

Wendy

From: Goulet, Terry W
Sent: Wednesday, February 04, 2015 7:31 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/4/2015 Date In :
Time Out : 06:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2489

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLD SPRING, MN; ROCKVILLE, MN; SAINT CLOUD, MN; SAINT JOSEPH, MN; SARTELL, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] LOCKOUT / CREW IN PROCESS OF FIELD SWITCHING FEEDERS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 04, 2015 9:26 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - - Cold Springs, Rockville, Saint Cloud, Saint Joseph, Sartell & Waite Park - POWER RESTORED

Power outage - - Cold Springs, Rockville, Saint Cloud, Saint Joseph, Sartell & Waite Park – power restored.

Wendy

From: Goulet, Terry W
Sent: Wednesday, February 04, 2015 8:05 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/4/2015 Date In : 2/4/2015
Time Out : 06:09 Time In : 07:42

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 2489

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLD SPRING, MN; ROCKVILLE, MN; SAINT CLOUD, MN; SAINT JOSEPH, MN; SARTELL, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

86 LOCKOUT / ISOLATED TRANSFORMER ON
FIELD SWITCHED FEEDERS

AND CREW

Follow-Up : EM&P REPORT SENT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 09, 2015 9:02 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 2/8/15 - Mankato & South Bend

Power outage - Mankato & South Bend.

Wendy

From: Medellin, Victor J
Sent: Monday, February 09, 2015 8:40 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/8/2015 Date In :
Time Out : 11:45 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1614

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN; SOUTH BEND, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-up. This is a follow up notification sent due to the one sent yesterday was in the wrong format

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, February 09, 2015 9:02 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 2/8/15 - Mankato & South Bend - POWER RESTORED

Power outage - Mankato & South Bend – power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Sunday, February 08, 2015 1:02 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/8/2015 Date In : 2/8/2015
Time Out : 11:45 Time In : 12:59

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1614

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN; SOUTH BEND, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Transmission line let loose from sleeve and fell into the [REDACTED] feeder btw the sub and [REDACTED] Switch

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 10, 2015 7:55 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 2/10/15 - Blomkest, Clara City, Prinsburg & Raymond

Power outage - Blomkest, Clara City, Prinsburg & Raymond.

Wendy

From: Ankoviak, Robert S
Sent: Tuesday, February 10, 2015 7:51 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In :
Time Out : 07:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 905

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOMKEST, MN; CLARA CITY, MN; PRINSBURG, MN; RAYMOND, MN

State : MN - Minnesota

Major Customers :

Cause : REPORT OF WIRE DOWN, INCLEMENT WEATHER IN AREA, CREWS ENROUTE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 10, 2015 9:32 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 2/10/15 - Blomkest, Clara City, Prinsburg & Raymond - UPDATE

Power outage - Blomkest, Clara City, Prinsburg & Raymond – update.

Wendy

From: Ankoviak, Robert S
Sent: Tuesday, February 10, 2015 9:02 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In :
Time Out : 07:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 905

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOMKEST, MN; CLARA CITY, MN; PRINSBURG, MN; RAYMOND, MN

State : MN - Minnesota

Major Customers :

Cause : WIRE DOWN JUST OUTSIDE OF SUB, CREWS ON SITE FOR RESTORATION

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, February 10, 2015 10:51 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 2/10/15 - Blomkest, Clara City, Prinsburg & Raymond - POWER RESTORED

Power outage - Blomkest, Clara City, Prinsburg & Raymond – power restored.

Wendy

From: Chase, Julie B
Sent: Tuesday, February 10, 2015 10:41 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In : 2/10/2015
Time Out : 07:16 Time In : 10:17

Time Zone : CST

Duration : 3 hours, 1 mins

Number of Customers Affected : 905

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOMKEST, MN; CLARA CITY, MN; PRINSBURG, MN; RAYMOND, MN

State : MN - Minnesota

Major Customers :

Cause : wires down 4 spans outside sub

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 11, 2015 7:56 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 2/10/15 - Faribault

Power outage - Faribault.

Wendy

From: Peterson, Mark S
Sent: Tuesday, February 10, 2015 5:55 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In :
Time Out : 17:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1090

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : none

Cause : crew being called out.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 11, 2015 7:57 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 2/10/15 - Faribault - UPDATE

Power outage - Faribault – update.

Wendy

From: Peterson, Mark S
Sent: Tuesday, February 10, 2015 6:50 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In :
Time Out : 17:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1090

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : none

Cause : operator found 150 ft of 336 down in private right of way. [REDACTED]. Crew to isolate feeder and restore power before repairs.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 11, 2015 7:58 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 2/10/15 - Faribault - UPDATE

Power outage - Faribault – update.

Wendy

From: Peterson, Mark S
Sent: Tuesday, February 10, 2015 7:59 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In :
Time Out : 17:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1090

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : none

Cause : 839 customers picked up via switching. crew to cut jumpers open on east end close breaker at sub to pick up all but 2 transformers

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, February 11, 2015 7:59 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 2/10/15 - Faribault - POWER RESTORED

Power outage - Faribault – power restored.

Wendy

From: Peterson, Mark S
Sent: Tuesday, February 10, 2015 10:13 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 2/10/2015 Date In : 2/10/2015
Time Out : 17:51 Time In : 21:43

Time Zone : CST

Duration : 3 hours, 52 mins

Number of Customers Affected : 1090

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN

State : MN - Minnesota

Major Customers : none

Cause : sleeve pulled apart 839 customers on @ 19:43, 125 cust back on @ 20:16 and final 26 cust back on @ 22:43

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 10, 2015 9:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/10/15 - Saint Paul

Power outage - 3/10/15 - Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, March 10, 2015 6:45 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/10/2015 Date In :
Time Out : 06:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 792

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

Major Customers : na

Cause : car hit pole

Follow-Up : trouble in route

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 10, 2015 9:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/10/15 - Saint Paul - UPDATE

Power outage - Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Stewart, Christopher D
Sent: Tuesday, March 10, 2015 7:14 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Second Outage Notice*
Feeder/Bus: [REDACTED]

Date Out : 3/10/2015 *Date In :*
Time Out : 06:35 *Time In :*

Time Zone : CST

Duration :

Number of Customers Affected : 792

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : N/A

Cause : Vehicle hit our pole at [REDACTED].

Follow-Up : Trouble is in the process of switching and construction is on the way to hold/replace the pole.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, March 10, 2015 9:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/10/15 - Saint Paul - POWER RESTORED

Power outage - Saint Paul – power restored.

Wendy

From: Wolf, Terry K
Sent: Tuesday, March 10, 2015 8:19 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/10/2015 Date In : 3/10/2015
Time Out : 06:35 Time In : 08:03

Time Zone : CST

Duration : 1 hours, 28 mins

Number of Customers Affected : 792

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : na

Cause : car hit pole

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 8:32 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/15/15 - Hamel, Medina, Minneapolis, Plymouth & Wayzata

Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Sunday, March 15, 2015 6:26 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/15/2015 Date In :

Time Out : 18:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3468

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown ; Momentary on [REDACTED] prior to no load at [REDACTED]. Reports of wire down at [REDACTED] and [REDACTED].

Follow-Up : Operators and Troubleman in route.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 8:33 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/15/15 - Hamel, Medina, Minneapolis, Plymouth & Wayzata - UPDATE

Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata – update.

Wendy

From: Babb, Randall J
Sent: Sunday, March 15, 2015 7:09 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/15/2015 Date In :
Time Out : 18:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3468

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

patrolling [REDACTED]. Cause: False report of wire down and grass fire at [REDACTED] and [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 8:34 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 3/15/15 - Hamel, Medina, Minneapolis, Plymouth & Wayzata - UPDATE

Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Stewart, Christopher D
Sent: Sunday, March 15, 2015 8:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Third Outage Notice*

Feeder/Bus : [REDACTED]

Date Out : 3/15/2015 Date In :

Time Out : 18:02 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3468

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : Blown arrestor at [REDACTED] and [REDACTED]

Follow-Up : Trouble is clearing the arrestor and checking the [REDACTED] switch, it may have opened when it saw the fault. Also, the batteries at the HOL sub may be dead which will require us to field switch the HOL feeders.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 8:38 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/15/15 - Hamel, Medina, Minneapolis, Plymouth & Wayzata - POWER RESTORED

Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Stewart, Christopher D
Sent: Sunday, March 15, 2015 9:23 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] *Final Outage Notice*

Feeder/Bus : [REDACTED]

Date Out : 3/15/2015

Date In : 3/15/2015

Time Out : 18:02

Time In : 20:57

Time Zone : CST

Duration : 2 hours, 55 mins

Number of Customers Affected : 3468

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : Blown arrestor and down neutral

Follow-Up : Arrestor failed causing the [REDACTED] to open. Trouble cleared the arrestor and neutral, closed the [REDACTED] on site. Need to check on communication issues with [REDACTED]

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 8:40 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/16/15 -
La Crescent & Winona

Power outage - La Crescent & Winona.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Monday, March 16, 2015 7:43 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/16/2015 Date In :

Time Out : 07:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5941

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Unknown cause at this time. Operator headed to Sub / 86 lockout on [REDACTED] & [REDACTED].

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 16, 2015 11:22 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - La Crescent & Winona - POWER RESTORED

Power outage - La Crescent & Winona – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Johnson, Michael A
Sent: Monday, March 16, 2015 10:16 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/16/2015 Date In : 3/16/2015

Time Out : 07:31 Time In : 10:06

Time Zone : CST

Duration : 2 hours, 35 mins


Number of Customers Affected : 5941

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : 

Cause : TRANSMISSION EVENT; 2656 CUSTOMERS RESTORED @ 09:21; REMAINING
CUSTOMERS RESTORED @10:06

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 23, 2015 8:14 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/22/15 - Fridley & Minneapolis

From: Cedar, Daren A
Sent: Sunday, March 22, 2015 2:08 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/22/2015 Date In :
Time Out : 01:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 933

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HAD TO OPEN FEEDER WIRE DOWN AND BURNING ABOUT [REDACTED] AND [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 23, 2015 8:16 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/22/15 - Fridley & Minneapolis - UPDATE

Power outage - Fridley & Minneapolis – update.

Wendy

From: Cedar, Daren A
Sent: Sunday, March 22, 2015 2:39 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/22/2015 Date In : 3/22/2015
Time Out : 01:58 Time In : 02:27

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 933

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE GOT 849 CUSTOMERS BACK IN STILL HAVE 84 OUT NEED TO CALL IN CREW FOR REPAIRS

Cause : WIRES DOWN ABOUT [REDACTED] AND [REDACTED]

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 23, 2015 8:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - Fridley & Minneapolis - POWER RESTORED

Power outage - Fridley & Minneapolis – power restored.

Wendy

From: Schwarz, John W
Sent: Sunday, March 22, 2015 9:04 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/22/2015 Date In : 3/22/2015
Time Out : 01:58 Time In : 09:00

Time Zone : CST

Duration : 7 hours, 2 mins

Number of Customers Affected : 934

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : .

Cause : FINAL 84 CUSTOMERS RESTORED @ 09:00

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:05 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - Power Outage 3/25/2015 Multiple

Categories: Green Category

Power Outage- CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

From: Hofer, Kory G
Sent: Wednesday, March 25, 2015 5:08 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 04:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4054

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

State : MN - Minnesota

Major Customers :

Cause : reports of pole down

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:06 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Update 3/25/2015- Multiple

Categories: Green Category

Update- CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

From: Hofer, Kory G
Sent: Wednesday, March 25, 2015 6:10 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 04:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4054

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

State : MN - Minnesota

Major Customers :

Cause : report of pole down

Follow-up DAS switching picked up 2130 customers, 1924 customers still out

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:07 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice Update 3/25/2015- Multiple

Categories: Green Category

Update - CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

From: Hofer, Kory G
Sent: Wednesday, March 25, 2015 7:23 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 04:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4054

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

State : MN - Minnesota

Major Customers :

Cause : pole fire

Follow-up field switching completed. 9 customers out for pole replacement.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 1:02 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice POWER RESTORED 3/25/2015 - Multiple

Categories: Green Category

Power Restored - CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

From: Johnson, Michael A
Sent: Wednesday, March 25, 2015 12:46 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 04:49 Time In : 12:34

Time Zone : CST

Duration : 7 hours, 45 mins

Number of Customers Affected : 4054

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; GREENFIELD, MN; HANOVER, MN; HASSAN, MN; LORETTO, MN; MAPLE GROVE, MN; ROGERS, MN; SAINT MICHAEL, MN

State : MN - Minnesota

Major Customers : NA

Cause : POLE FIRE; FINAL 9 CUSTOMERS RESTORED AT 12:34

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:09 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage - 3/25/2015
MENDOTA, MN; WOODBURY, MN

Categories: Green Category

Power Outage - MENDOTA, MN; WOODBURY, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 6:14 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 06:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1960

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:09 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restore 3/25/2015 MENDOTA, MN; WOODBURY, MN

Categories: Green Category

Power Restored - MENDOTA, MN; WOODBURY, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 8:04 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 06:08 Time In : 07:28

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 1959

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] switch burned up

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:14 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/25/2015 Power Outage - Multiple

Categories: Green Category

Power Outage - EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 8:01 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 07:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1905

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : unkown

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, March 26, 2015 7:44 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice POWER RESTORED - 3/25/2015 Multiple

Power Restored - EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

From: Wolf, Terry K
Sent: Wednesday, March 25, 2015 5:20 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 07:49 Time In : 13:30

Time Zone : CST

Duration : 5 hours, 41 mins

Number of Customers Affected : 1905

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up : REPAIRED

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:17 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice 3/25/2015- Power Outage - MINNETONKA, MN; PLYMOUTH, MN

Categories: Green Category

Power Outage - MINNETONKA, MN; PLYMOUTH, MN

From: Mcmoore, Stephen G
Sent: Wednesday, March 25, 2015 8:15 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 08:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1245

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:17 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Update - 3/25/2015
MINNETONKA, MN; PLYMOUTH, MN

Categories: Green Category

Update - MINNETONKA, MN; PLYMOUTH, MN

From: Anderson, Timothy K
Sent: Wednesday, March 25, 2015 9:25 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 08:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1245

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : POLE FIRE, POLE TOP & X-ARMS NEED TO BE REPLACED [REDACTED]

Follow-Up FEEDER PARTIAL RESTO. ISOLATED BTWN JIMPERS CUT OPEN

TO [REDACTED]

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:18 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice POWER RESTORED - 3/25/2015
MINNETONKA, MN; PLYMOUTH, MN

Categories: Green Category

Power Restored - MINNETONKA, MN; PLYMOUTH, MN

From: Anderson, Timothy K
Sent: Wednesday, March 25, 2015 9:53 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 08:09 Time In : 09:03

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 1245

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : POLE FIRE

Follow-Up: 178 OUTAGE COUNT UNTIL REPAIRS MADE, REFERRED TO

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 11:23 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice POWER OUTAGE 3/25/2015 ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN

Categories: Green Category

Power Outage *ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN*

From: Stewart, Christopher D
Sent: Wednesday, March 25, 2015 11:13 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] *First Outage Notice*
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 10:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1278

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Follow-Up : Troubleman and Operator in route.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 12:35 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 3/25/2015 ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN

Categories: Green Category

Power Restored - ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 12:23 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 10:52 Time In : 12:10

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1278

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down [REDACTED]

Follow-up: Isolated section of feeder, 3 transformers remain out (Street lights and signal light controls)

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 12:36 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 3/25/2015 INVER GROVE HEIGHTS, MN; INVER GROVE, MN

Categories: Green Category

Power Outage- INVER GROVE HEIGHTS, MN; INVER GROVE, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 12:18 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In :
Time Out : 11:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3647

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder @ [REDACTED]

Follow-up: Trouble is removing the tree, 1596 customers picked up with SCADA switches @ 11:33, 2051 still out.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Wednesday, March 25, 2015 1:01 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice POWER RESTORED 3/25/2015 INVER GROVE HEIGHTS, MN; INVER GROVE, MN

Categories: Green Category

Power Restored INVER GROVE HEIGHTS, MN; INVER GROVE, MN

From: Elden, Thomas L
Sent: Wednesday, March 25, 2015 12:42 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/25/2015 Date In : 3/25/2015
Time Out : 11:32 Time In : 12:32

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 3647

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder.

Follow-up: Troublemaker removed tree.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:41 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/29/15 -
Brooten, Glenwood, Lowry, Sedan & Starbuck

Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 4:57 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :

Time Out : 04:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN, MN; STARBUCK,

State : MN - Minnesota

Major Customers : N/A

Cause : Transmission event

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:42 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/29/15
- Brooten, Glenwood, Lowry, Sedan & Starbuck - UPDATE

Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 6:26 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 04:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN, MN; STARBUCK,

State : MN - Minnesota

Major Customers : N/A

Cause : Transmission event 68 customers restored @ 06:17

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:42 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 3/29/15 -
Brooten, Glenwood, Lowry, Sedan & Starbuck - UPDATE

Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 7:27 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :

Time Out : 04:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN, MN; STARBUCK,

State : MN - Minnesota

Major Customers : N/A

Cause : UPDATE: CREW PATROLLING PRIVATE RIGHT OF WAY

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:31 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Fourth Outage Notice - 3/29/15 - Glenwood, Lowry & Starbuck - UPDATE

Power outage – Glenwood, Lowry & Starbuck – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Karolevitz, Paul W
Sent: Sunday, March 29, 2015 10:50 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Fourth Outage Notice

Distribution System Status Outage Notification

[REDACTED] Fourth Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :

Time Out : 04:46 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1179

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : None

Cause : transmission line down on private right a way

Follow-Up : crews making temporary repairs. ert is 14:00 today

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:43 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/29/15 -
Brooten, Glenwood, Lowry, Sedan & Starbuck - POWER RESTORED

Power outage - Brooten, Glenwood, Lowry, Sedan & Starbuck – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 1:10 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/29/2015

Time Out : 04:46 Time In : 12:54

Time Zone : CST

Duration : 8 hours, 8 mins

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

MN Communities Affected : BROOTEN, MN; GLENWOOD, MN; LOWRY, MN; SEDAN, MN; STARBUCK,

State : MN - Minnesota

Major Customers : N/A

Cause : Transmission event remaining 1179 customers restored

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:15 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Momentary Outage *** Momentary Outage *** - 3/29/15
- Lake Elmo, Oakdale & Woodbury

Power outage - Lake Elmo, Oakdale & Woodbury.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Sunday, March 29, 2015 6:51 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Momentary Outage *** Momentary Outage ***

Distribution System Status Outage Notification

[REDACTED] Momentary Outage

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/29/2015

Time Out : 06:32 Time In : 06:32

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 3155

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOW

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:16 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/29/15 - Lake Elmo, Oakdale & Woodbury - UPDATE

Power outage - Lake Elmo, Oakdale & Woodbury – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Sunday, March 29, 2015 10:25 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 06:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3155

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : n/a

Cause : BREAKER IN AT SUB, INTELLA TEAM OPERATED EFFECTING HALF OF FEEDER,
TROUBLE PATROLLING TO FIND PROBLEM

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/29/15 - Lake Elmo, Oakdale & Woodbury - POWER RESTORED

Power outage - Lake Elmo, Oakdale & Woodbury – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Sunday, March 29, 2015 12:23 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/29/2015

Time Out : 06:32 Time In : 12:22

Time Zone : CST

Duration : 5 hours, 50 mins

Number of Customers Affected : 3155

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : [REDACTED] SWITCH BURNT UP, ALSO [REDACTED] SWITCH MAY NEED TO BE
CHANGED OUT. SWITCHED ON FEEDER AND EVERYONE BACK IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:35 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/29/15 - La Crescent & Winona

Power outage - La Crescent & Winona.

Wendy Jaede
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM
Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 6:41 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 06:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1598

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : N/A

Cause : CAUSE UNKNOWN CREW BEING CALLED IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:36 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/29/15 - La Crescent & Winona - UPDATE

Power outage - La Crescent & Winona – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 8:21 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :

Time Out : 06:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1598

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UPDATE Crew patrolling feeder fault indicators indicate fault on overhead section of line. Storm went through area

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:37 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/29/15 - La Crescent & Winona - POWER RESTORED

Power outage - La Crescent & Winona – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Sunday, March 29, 2015 9:01 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/29/2015

Time Out : 06:38 Time In : 08:57

Time Zone : CST

Duration : 2 hours, 19 mins

Number of Customers Affected : 1598

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : N/A

Cause : [REDACTED] failed @ [REDACTED] not mapped on feeder map

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:46 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/29/15 - Burnsville

Power outage – Burnsville

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Sunday, March 29, 2015 1:18 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 13:10 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1103

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:47 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/29/15 - Burnsville - POWER RESTORED

Power outage – Burnsville – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Sunday, March 29, 2015 2:39 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/29/2015

Time Out : 13:10 Time In : 14:33

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1103

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 1/0 NEUTRAL BURNT DOWN @ [REDACTED], AND C PHASE ARRESTER BLOWN @ [REDACTED]

Follow-Up : VERY WINDY

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:54 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/29/15 - Bloomington

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Sunday, March 29, 2015 6:49 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 18:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 799

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear burned feeder pole at [REDACTED].

Follow-Up : 799 cust. out until switching is completed. 247 will remain out until pole is fixed

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:56 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/29/15 - Bloomington - UPDATE

Power outage – Bloomington - update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Sunday, March 29, 2015 7:01 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In :
Time Out : 18:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 799

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : : Intentional to clear burned feeder pole at [REDACTED]

Follow-Up : 552 restored at 18:53. 247 will be out until repairs are made.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 9:56 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/29/15 - Bloomington - POWER RESTORED

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Monday, March 30, 2015 3:33 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/29/2015 Date In : 3/30/2015

Time Out : 18:42 Time In : 03:28

Time Zone : CST

Duration : 8 hours, 46 mins

Number of Customers Affected : 247

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : : Intentional to clear burned feeder pole at [REDACTED].

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:22 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 3/30/15 - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, NYA & Plato

Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, NYA & Plato.

From: Peterson, Kenneth W
Sent: Monday, March 30, 2015 9:30 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/30/2015 Date In :
Time Out : 07:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2217

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN; MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : Nonje

Cause : Fuses open at Sub

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 10:23 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 3/30/15 - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, NYA & Plato - UPDATE

Power outage - Cologne, Green Isle, Hamburg, Lake Wilson, Mayer, NYA & Plato – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Monday, March 30, 2015 9:59 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/30/2015

Date In :

Time Out : 07:53

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2217

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN; MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : none

Cause : Squirrels burned up [REDACTED] and blew A & C ph 69kv on [REDACTED]

Follow-Up : refusing Highside of [REDACTED] to pickup [REDACTED] and field switch [REDACTED] to restore outage

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 1:05 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/30/15 - Cologne, Green Isle, Hamburg, NYA & Plato - POWER RESTORED

Power outage - Cologne, Green Isle, Hamburg, NYA & Plato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Monday, March 30, 2015 12:49 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 3/30/2015 Date In : 3/30/2015

Time Out : 07:53 Time In : 12:17

Time Zone : CST

Duration : 4 hours, 24 mins

Number of Customers Affected : 1032

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : None

Cause : Squirrels knocked out [REDACTED] HIGHSIDE FUSES a & c PH

Follow-Up : pickedup 120 cust back half of feeder 1156 / Front half 912 cust 1217

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, March 30, 2015 1:06 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 3/30/15 - Lake Wilson, Mayer & NYA - POWER RESTORED

Power outage - Lake Wilson, Mayer & NYA – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Monday, March 30, 2015 12:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 3/30/2015 Date In : 3/30/2015
Time Out : 08:58 Time In : 12:21

Time Zone : CST

Duration : 3 hours, 23 mins

Number of Customers Affected : 1185

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LAKE WILSON, MN; MAYER, MN; NYA, MN

State : MN - Minnesota

Major Customers : none

Cause : squirrels knocked out [REDACTED] highside fuses A & c ph

Follow-Up : had to isolate [REDACTED] to x-out fuses

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 01, 2015 5:02 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/1/15 - Minneapolis

Categories: Green Category

Power outage – Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Wednesday, April 01, 2015 5:00 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/1/2015

Date In :

Time Out : 16:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1801

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:45 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015- Mpls

Categories: Green Category

Power Restored - Mpls

From: Peterson, Kenneth W
Sent: Wednesday, April 01, 2015 6:24 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/1/2015
Time Out : 16:45 Time In : 17:50

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 1801

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : [REDACTED] was with [REDACTED] on double deck pole C ph on [REDACTED] burned down taking out
[REDACTED]

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:42 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/1/2015- MPLS

Categories: Green Category

Power Outage - MPLS

From: Peterson, Kenneth W
Sent: Wednesday, April 01, 2015 5:23 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In :
Time Out : 17:11 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1140

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Intentional to clear wire down on [REDACTED] and [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:43 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015 - MPLS

Categories: Green Category

Power Restored - MPLS

From: Peterson, Kenneth W
Sent: Wednesday, April 01, 2015 6:29 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/1/2015
Time Out : 17:11 Time In : 18:13

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 1140

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : [REDACTED] was with [REDACTED] on double deck pole C ph on [REDACTED] burned down taking out
[REDACTED]

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 10:08 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice *** Momentary Outage *** 4/1/2015
ArdHills, NwBrighton, Rsville, St Paul

Categories: Green Category

Power Outage - 4/1/2015 ArdHills, NwBrighton, Rsville, St Paul

From: Wolf, Terry K
Sent: Wednesday, April 01, 2015 8:24 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/1/2015
Time Out : 20:18 Time In : 20:18

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 1786

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 10:09 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Update - 4/1/2015 ArdHills, NwBrighton, Rsville, St Paul

Categories: Green Category

Update - 4/1/2015 ArdHills, NwBrighton, Rsville, St Paul

From: Wolf, Terry K
Sent: Wednesday, April 01, 2015 8:58 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/1/2015
Time Out : 20:18 Time In : 20:50

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 1338

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-Up: PATROLING FEEDER 1338 PICKED UP

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 10:09 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015 ArdHills, NwBrighton, Rsville, St Paul

Categories: Green Category

Power Restored - ArdHills, NwBrighton, Rsville, St Paul

From: Abbott, Edward J
Sent: Wednesday, April 01, 2015 9:37 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/1/2015
Time Out : 20:18 Time In : 21:32

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1786

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : N/A

Cause : PATROLLED WHOLE FEEDER AND FOUND NOTHING. FEEDER BACK IN

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:47 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/1/2015 Farmington

Categories: Green Category

Power Outage - Farmington

From: Abbott, Edward J
Sent: Wednesday, April 01, 2015 9:59 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In :
Time Out : 21:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 645

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:48 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015-
Farmington

Categories: Green Category

Power Restored - Farmington

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 12:06 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/2/2015
Time Out : 21:53 Time In : 00:02

Time Zone : CST

Duration : 2 hours, 9 mins

Number of Customers Affected : 645

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause: a phase insulator on transmission pole broke, troubleman temp. repaired same and feeder back in. It took long because no troublemen in area when feeder locked and then he had to patroll and repair

Follow-Up : referred to newport const. to make perm. repairs

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:49 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/1/2015 Hamel, Medina, Plymouth, Wayzata

Categories: Green Category

Power Outage - Hamel, Medina, Plymouth, Wayzata

From: Hills, Thomas L
Sent: Wednesday, April 01, 2015 10:52 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In :
Time Out : 22:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1615

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:50 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015 Hamel, Medina, Plymouth, Wayzata

Categories: Green Category

Power Restored - Hamel, Medina, Plymouth, Wayzata

From: Kubes, Kenneth B
Sent: Thursday, April 02, 2015 12:08 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/2/2015
Time Out : 22:48 Time In : 00:03

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 1615

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-up patrolled feeder, found no problems, energized to restore all customers

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 10:11 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/1/2015- Mpls

Categories: Green Category

Power Outage - Mpls

From: Hills, Thomas L
Sent: Wednesday, April 01, 2015 11:02 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In :
Time Out : 22:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1993

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 10:12 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Update 4/1/2015 -Mpls

Categories: Green Category

Update - Mpls

From: Hills, Thomas L
Sent: Thursday, April 02, 2015 12:35 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In :
Time Out : 22:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1990

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Burned pole.

Follow-Up: 1988 customers restored at 0025. Need crew to make repairs and restore remaining two customers.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Friday, April 03, 2015 10:13 AM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015-Mpls

Categories: Green Category

From: Karolevitz, Paul W
Sent: Friday, April 03, 2015 8:44 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/1/2015 Date In : 4/2/2015
Time Out : 22:56 Time In : 01:13

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 1990

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : pole fire

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:53 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage - 4/1/2015 St Paul

Categories: Green Category

Power Outage – St Paul

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 12:29 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In :
Time Out : 00:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : HAD MOMENTARY EARLIER, NUMEROUS OUTAGES CAME IN AFTER MOMENTARY,
HAD TROUBLE PATROLL AND FOUND A PHASE ON FEEDER BURNT DOWN, TROUBLE FEILD SWITCHED TO
ISOLATE AND CREW IN ROUTE TO REPAIR

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:54 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/1/2015- St Paul

Categories: Green Category

Power Restored – St Paul

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 12:54 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In : 4/2/2015
Time Out : 00:20 Time In : 00:45

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 1247

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : SWITCHED TO ISOLATE DOWNED A PHASE AND GOT EVERYONE BACK IN EXCEPT
SMALL PORTION

Follow-Up: CREW ON SITE AND WILL REPAIR

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:56 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/2/2015 MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

Categories: Green Category

Power Outage - MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 2:08 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In :
Time Out : 01:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1797

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BURNING POWER POLE

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:56 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: ██████████ Second Outage Notice Update 4/2/2015 MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

Categories: Green Category

Update - MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 2:21 AM
To: dl Electric Outage ME Notification
Subject: ██████████ Second Outage Notice

Distribution System Status Outage Notification

██████████ Second Outage Notice
Feeder/Bus : ██████████

Date Out : 4/2/2015 Date In :
Time Out : 01:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1797

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Major Service Cause: TOP BURN OFF FEEDER POLE [REDACTED], FEILD SWITCHED TO GET MOST OF FEEDER BACK IN AT 02:10

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 9:57 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice Power Restored 4/2/2015 MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

Categories: Green Category

Power Restored MENDOTA HTS, SAINT PAUL, WEST SAINT PAUL,

From: Abbott, Edward J
Sent: Thursday, April 02, 2015 3:20 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In : 4/2/2015
Time Out : 01:56 Time In : 03:08

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 1797

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

ON EXCEPT ON TAP. REFERRED TO [REDACTED] TO REPLACE POLE

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 2:22 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice 4/2/2015- Power Outage Bloomington

Categories: Green Category

Power Outage - Bloomington

From: Peterson, Kenneth W
Sent: Thursday, April 02, 2015 2:12 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In :
Time Out : 14:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1453

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 5:16 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice UPDATE 4/2/2015 Bloomington

Categories: Green Category

Update - Bloomington

From: Peterson, Kenneth W
Sent: Thursday, April 02, 2015 2:54 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In :
Time Out : 14:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1453

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up : opened [REDACTED] closed [REDACTED] at Sub to pickup 530 customers patoling [REDACTED]

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Thursday, April 02, 2015 5:17 PM
To: 'staff, cao (PUC)'; 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice 4/2/2015 Power Restored Bloomington

Categories: Green Category

Power Restored - Bloomington

From: Peterson, Kenneth W
Sent: Thursday, April 02, 2015 3:34 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/2/2015 Date In : 4/2/2015
Time Out : 14:07 Time In : 15:29

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1453

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown patrolled [REDACTED] feeder and found nothing

Follow-Up : restored 530 customers at 1441 / remaining 923 customers restored 1529

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 8:16 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/3/15 - Cokato

Power outage – Cokato.

Wendy

From: Johnson, Michael A
Sent: Friday, April 03, 2015 4:41 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/3/2015 Date In :
Time Out : 4:24PM Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1306

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNDER INVESTIGATION; CALLOUT CREATED

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 8:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/3/15 - Cokato - POWER RESTORED

Power outage – Cokato – power restored.

Wendy

From: Johnson, Michael A
Sent: Friday, April 03, 2015 6:52 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/3/2015 Date In : 4/3/2015
Time Out : 4:24PM Time In : 6:45PM

Time Zone : CST

Duration : 2 hours, 21 mins

Number of Customers Affected : 1306

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : BROKEN GUY WIRE CONTACTING PHASES

Follow-Up : ALL CUSTOMERS RESTORED AT 6:45 PM

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 10:15 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/6/15 - Golden Valley

Power outage – Golden Valley.

Wendy

From: Anderson, Timothy K
Sent: Monday, April 06, 2015 10:01 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In :
Time Out : 09:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 642

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : POLE FIRE [REDACTED]

Follow-Up : ISOLATE & REFER TO DIVISION

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 11:06 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 4/6/15 - Golden Valley - POWER RESTORED/PARTIAL

Power outage – power restored/partial.

From: Kittock, Joseph C
Sent: Monday, April 06, 2015 10:49 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In : 4/6/2015
Time Out : 09:53 Time In : 10:30

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 619

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : non

Cause : Partial restoration. [REDACTED] out until [REDACTED] repairs pole damage by fire.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 2:42 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/6/15 - Golden Valley - POWER RESTORED/FINAL

Power outage – Golden Valley – power restored/final.

Wendy

From: Anderson, Timothy K
Sent: Monday, April 06, 2015 2:17 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In : 4/6/2015
Time Out : 09:53 Time In : 14:12

Time Zone : CST

Duration : 4 hours, 19 mins

Number of Customers Affected : 642

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : POLE FIRE 7 & C PHASE CONDUCTOR DOWN

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 10:27 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/6/15 - Saint Paul

Power outage – Saint Paul.

Wendy

From: Elden, Thomas L
Sent: Monday, April 06, 2015 10:23 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In :
Time Out : 10:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 506

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : wire down at [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 12:11 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 4/6/15 - Saint Paul - UPDATE

Power outage – Saint Paul – update.

Wendy

From: Elden, Thomas L
Sent: Monday, April 06, 2015 12:08 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In :
Time Out : 10:08 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 506

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : 30 more customers are back on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 12:20 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/6/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy

From: Elden, Thomas L
Sent: Monday, April 06, 2015 12:12 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In : 4/6/2015
Time Out : 10:08 Time In : 11:50

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 506

For information about this alert, contact :
For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : every one is back on at 11:50 cause was wire down at [REDACTED]

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 06, 2015 4:04 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/6/15 - Mankato

Power outage – Mankato.

Wendy

From: Ankoviak, Robert S
Sent: Monday, April 06, 2015 3:39 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/6/2015 Date In :
Time Out : 3:32 pm Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1919

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Follow-Up : CALL OUT UNDERWAY

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 07, 2015 8:43 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/6/15 - Mankato - POWER RESTORED

Power outage – Mankato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Johnson, Michael A
Sent: Monday, April 06, 2015 5:24 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/6/2015

Date In : 4/6/2015

Time Out : 3:32PM

Time In : 5:10PM

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 1919

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : 

Cause : FAULTED HEAD END CABLE

Follow-Up : ALL CUSTOMERS RESTORED BY SWITCHING AT 17:10

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 13, 2015 9:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/13/15 - Mazeppa & Zumbro Falls

Power outage - Mazeppa & Zumbro Falls.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Monday, April 13, 2015 8:16 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/13/2015 Date In :
Time Out : 07:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 657

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : none

Cause : crew in route. Report of 2 high side fuses blown on [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 13, 2015 9:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 4/13/15 - Mazeppa & Zumbro Falls
- Update

Power outage - Mazeppa & Zumbro Falls – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Monday, April 13, 2015 8:47 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/13/2015 Date In :
Time Out : 07:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 657

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAZEPPA, MN; ZUMBRO FALLS, MN

State : MN - Minnesota

Major Customers : none

Cause : Squirrel got on jumper on a phase regulator, damaging top side of A disc. Customers will be out until repairs made. No way to carry load in field.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 13, 2015 10:19 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 4/13/15 - Mazeppa & Zumbro Falls - UPDATE

Power outage – Mazeppa & Zumbro Falls – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Monday, April 13, 2015 10:05 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/13/2015 Date In :

Time Out : 07:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 657

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAZEPPA, MN; ZUMBRO FALLS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CREW HAS TAKEN CLEARANCE ON [REDACTED] WITH A TARGET RESTORATION TIME OF 1200 IF ALL GOES RIGHT.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 13, 2015 11:24 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/13/15 - Mazeppa & Zumbro Falls - POWER RESTORED

Power outage – Mazeppa & Zumbro Falls – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Monday, April 13, 2015 11:15 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/13/2015 Date In : 4/13/2015

Time Out : 07:19 Time In : 11:10

Time Zone : CST

Duration : 3 hours, 51 mins

Number of Customers Affected : 657

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAZEPPA, MN; ZUMBRO FALLS, MN

State : MN - Minnesota

Major Customers : none

Cause : REPAIRS MADE PERMANENT AND POWER RESTORED.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 14, 2015 2:30 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/14/15 - Golden Valley

Power outage – Golden Valley.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, April 14, 2015 2:22 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/14/2015 Date In :
Time Out : 14:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 647

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : HONEYWELL - GOLDEN VALLEY

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, April 14, 2015 3:34 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 4/14/15 - Golden Valley -
POWER RESTORED

Power outage – Golden Valley – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, April 14, 2015 2:58 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/14/2015 Date In : 4/14/2015
Time Out : 14:16 Time In : 14:50

Time Zone : CST

Duration : 0 hours, 34 mins

Number of Customers Affected : 646

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Primary customer [REDACTED], C phase pot head faulted. They will be out until repaired.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 15, 2015 7:46 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/14/15 - Golden Valley - POWER RESTORED/UPDATE

Power outage – Golden Valley – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, April 14, 2015 8:26 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/14/2015 Date In : 4/14/2015

Time Out : 14:16 Time In : 20:18

Time Zone : CST

Duration : 6 hours, 2 mins

Number of Customers Affected : 1

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : 

Cause : Squirrel contact on C phase pot head.

Follow-Up : Repaires complete.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 7:51 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - Power Outage - Hutch, Lstr Prairie, Slvr Lk, Winsted

Categories: Green Category

Power Outage - HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

From: Knutson, David A
Sent: Sunday, April 19, 2015 1:03 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 01:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 692

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Pole fire. Pole needs to be replaced. Total feeder out for now. Will look to see if anyone can be restored after problem is isolated. Crews are being called in at this time.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 7:52 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Power Outage 4/19/2015 -
Hutch, Lstr Prairie, Slvr Lk, Winsted

Categories: Green Category

Update - HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

From: Knutson, David A
Sent: Sunday, April 19, 2015 5:56 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 01:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 692

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

State : MN - Minnesota

Major Customers : NONE

Cause : POLE FIRE

Follow-up Crew are estimating being done at about 0630. Should be able to pick up all customers at that time. Kicked out ERT till 0700.

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 7:54 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - Power Restored 4/19 Hutch, Lstr
Prairie, Slvr Lk, Winsted

Categories: Green Category

Power Restored - HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

From: Cedar, Daren A
Sent: Sunday, April 19, 2015 6:57 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In : 4/19/2015
Time Out : 01:00 Time In : 06:53

Time Zone : CST

Duration : 5 hours, 53 mins

Number of Customers Affected : 692

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HUTCHINSON, MN; LESTER PRAIRIE, MN; SILVER LAKE, MN; WINSTED, MN

State : MN - Minnesota

Major Customers : none

Cause : pole fire

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 7:55 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage
Notice Power Outage 4/19/2015- Multiple

Categories: Green Category

Power Outage - BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN; COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN; VESELI, MN; WEBSTER, MN

From: Peterson, Mark S
Sent: Sunday, April 19, 2015 1:42 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 01:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 6393

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN; COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN; VESELI, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : none

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 7:55 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage
Notice Power Restored 4/19 Multiple

Categories: Green Category

Power Restored - BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN; COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN; VESELI, MN; WEBSTER, MN

From: Peterson, Mark S
Sent: Sunday, April 19, 2015 4:19 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In : 4/19/2015
Time Out : 01:18 Time In : 03:50

Time Zone : CST

Duration : 2 hours, 32 mins

Number of Customers Affected : 6393

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BELLE PLAINE, MN; BELLE PLAINE, MN; CARVER, MN; COLOGNE, MN; JORDAN, MN; LONSDALE, MN; NEW PRAGUE, MN; SHAKOPEE, MN; VESELI, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : none

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 8:01 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/19/2015- Renville

Categories: Green Category

Power Outage - Renville

From: Ankoviak, Robert S
Sent: Sunday, April 19, 2015 6:43 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 05:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 693

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RENVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN, CALLOUT ACCEPTED

Follow-Up : OPENED RNV021 BKR IN MODEL AT 06:28

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 8:02 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Update 4/19 - Renville

Categories: Green Category

Update - Renville

From: Ankoviak, Robert S
Sent: Sunday, April 19, 2015 7:32 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 05:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 693

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RENVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : POLE FIRE REPORTED, CREW IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 8:03 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - Power Restored 4/19/2015 Renville

Categories: Green Category

Power Restored - Renville

From: Ankoviak, Robert S
Sent: Sunday, April 19, 2015 9:30 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In : 4/19/2015
Time Out : 05:58 Time In : 07:46

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 693

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RENVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : POLE TOP FIRE, CREW CLEARED AND MAKING REPAIRS

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 8:05 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - Power Outage 4/19 La Crescent, Winona

Categories: Green Category

Power Outage – La Crescent, Winona

From: Johnson, Michael A
Sent: Sunday, April 19, 2015 9:39 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In :
Time Out : 07:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2662

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : BUS SECTION [REDACTED] LOCKOUT; CAUSE UNDER INVESTIGATION; CREW ON SCENE

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 8:06 AM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - Power Restored - la Crescent, Winona

Categories: Green Category

Power Restored – La Crescent, Winona

From: Ankoviak, Robert S
Sent: Sunday, April 19, 2015 9:49 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/19/2015 Date In : 4/19/2015
Time Out : 07:51 Time In : 09:42

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 2662

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LA CRESCENT, MN; WINONA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : SQUIRREL GOT INTO BUS SECTION [REDACTED]

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 4:50 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice Power Outage 4/20/2015 Edina

Power Outage - Edina

From: Cedar, Daren A
Sent: Monday, April 20, 2015 3:01 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/20/2015 Date In :
Time Out : 14:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1446

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKOWN AT THIS TIME

Follow-Up :

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 4:51 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice Outage Update 4/20/2015 - Edina

Update - Edina

From: Kittock, Joseph C
Sent: Monday, April 20, 2015 4:21 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/20/2015 Date In :
Time Out : 15:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1438

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : non

Cause : [REDACTED] phase cutout broke affecting all 3 phases at [REDACTED]. Also,
Faulted feeder cable between the [REDACTED].

Follow-Up : 8 customers at [REDACTED].

Eilers, Rebecca D

From: Guttormson, Allyson E
Sent: Monday, April 20, 2015 4:51 PM
To: staff, cao (PUC); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice 4/20/2015- POWER RESTORED - Edina

Power Restored - Edina

From: Kittock, Joseph C
Sent: Monday, April 20, 2015 4:41 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/20/2015 Date In : 4/20/2015
Time Out : 14:56 Time In : 16:20

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 8

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : non

Cause : Cable fault [REDACTED] to tie [REDACTED]. Also, cable fault "A" phase [REDACTED]. (FCO broke on A phase).

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 22, 2015 8:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/21/15 - Rosemount

Power outage – Rosemount.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, April 21, 2015 3:44 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 4/21/2015 Date In : 4/21/2015
Time Out : 14:05 Time In : 15:20

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 898

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected: ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : NO

Cause : SUB STATION DOWN//WILL NEED WORK .FEED FROM ALT FEEDER

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 22, 2015 8:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/21/15 - Rosemount - POWER RESTORED

Power outage – Rosemount – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, April 21, 2015 3:53 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/21/2015 Date In : 4/21/2015

Time Out : 14:05 Time In : 15:20

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 898

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : NO

Cause : SUBSTATION FAILURE

Follow-Up : WILL REFERE TO HAVE REPAIRED

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 22, 2015 12:46 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED]
First Outage Notice - 4/22/15

Sorry for the duplication....

Power outage – Arden Hills, Columbia Heights, Fridley, Hilltop, Mendota Heights, Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, April 22, 2015 12:23 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/22/2015

Date In :

Time Out : 12:17

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 23043

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ARDEN HILLS, MN; COLUMBIA HEIGHTS, MN; FRIDLEY, MN; HILLTOP, MN; MENDOTA HEIGHTS, MN; MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] lockout Substation is dark

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 22, 2015 2:37 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED]
Second Outage Notice - 4/22/15 - UPDATE

Power outage -- Arden Hills, Columbia Heights, Fridley, Hilltop, Mendota Heights, Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, April 22, 2015 2:19 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/22/2015 Date In :

Time Out : 12:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 23043

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ARDEN HILLS, MN; COLUMBIA HEIGHTS, MN; FRIDLEY, MN; HILLTOP, MN; MENDOTA HEIGHTS, MN; MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] lockout B ph differential

Follow-Up : in process of switching in [REDACTED] / 30 - 45 Min

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, April 22, 2015 3:56 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED]
Final Outage Notice - 4/22/15 - POWER RESTORED

Power outage -- Arden Hills, Columbia Heights, Fridley, Hilltop, Mendota Heights, Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, April 22, 2015 3:54 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/22/2015 Date In : 4/22/2015

Time Out : 12:17 Time In : 15:34

Time Zone : CST

Duration : 3 hours, 17 mins

Number of Customers Affected : 23043

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ARDEN HILLS, MN; COLUMBIA HEIGHTS, MN; FRIDLEY, MN; HILLTOP, MN; MENDOTA HEIGHTS, MN; MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] lockout

Follow-Up : MW Energized 13554 customers between 1511 to 1534

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 27, 2015 9:06 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 4/25/15 - Crystal, Golden Valley & Robbinsdale

Power outage – Crystal, Golden Valley & Robbinsdale.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Saturday, April 25, 2015 8:19 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/25/2015 Date In :

Time Out : 7:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2017

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : B PHASE CONDUCTOR DOWN & JUMPER BURNT OPEN AT 

Follow-Up : ISOLATE, CALL IN CREW FOR REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 27, 2015 9:07 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 4/25/15 - Crystal, Golden Valley & Robbinsdale - UPDATE

Power outage - Crystal, Golden Valley & Robbinsdale – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Saturday, April 25, 2015 9:04 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/25/2015 Date In :

Time Out : 7:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 647

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : B PHASE CONDUCTOR DOWN & JUMPER BURNT OPEN 

Follow-Up : ISOLATED,CREW CALLED IN FOR REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, April 27, 2015 9:08 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 4/25/15 - Crystal, Golden Valley & Robbinsdale - POWER RESTORED

Power outage - Crystal, Golden Valley & Robbinsdale – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Saturday, April 25, 2015 11:54 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 4/25/2015 Date In : 4/25/2015

Time Out : 7:31 Time In : 11:20

Time Zone : CST

Duration : 3 hours, 49 mins

Number of Customers Affected : 2017

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : None

Cause : B Phase conductor down,jumper burnt open caused by squirrel

Follow-Up : repair permanant

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 04, 2015 8:26 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/2/15 - Saint Paul

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Saturday, May 02, 2015 3:35 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/2/2015

Date In :

Time Out : 15:28

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1635

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 04, 2015 8:27 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/2/15 - Saint Paul - UPDATE

Power outage – Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Saturday, May 02, 2015 4:55 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/2/2015 Date In :
Time Out : 15:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1635

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : [REDACTED] 1624 customers were picked up at 16:21

Cause : cable burned up at [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 04, 2015 8:27 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/2/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Saturday, May 02, 2015 5:03 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/2/2015

Date In : 5/2/2015

Time Out : 15:28

Time In : 16:39

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1635

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : All customers were picked up at 1639

Cause : [REDACTED] urd cable burned up

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 04, 2015 8:29 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice-5/2/15-Chanhassen, Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata

Power outage - Chanhassen, Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, May 02, 2015 5:20 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/2/2015

Date In :

Time Out : 17:08

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2740

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 04, 2015 8:30 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice-5/2/15-Chanhassen, Excelsior, Mtka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata-POWER RESTORED

Power outage - Chanhassen, Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, May 02, 2015 6:15 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/2/2015

Date In : 5/2/2015

Time Out : 17:08

Time In : 18:10

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 2740

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed arrestor on transmission bus.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 05, 2015 8:37 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/5/15 - Saint Paul

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, May 05, 2015 12:52 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/5/2015

Date In :

Time Out : 00:34

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 571

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Follow-Up : PART OF [REDACTED] TIED TO THIS FEEDER

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 05, 2015 8:38 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/5/15 - 5/5/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, May 05, 2015 2:13 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/5/2015

Date In : 5/5/2015

Time Out : 00:34

Time In : 02:09

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 571

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : FUALTED FEEDER CABLE BETWEEN [REDACTED] AND [REDACTED], FEILD SWITCHED TO
BRING EVERYONE BACK IN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 05, 2015 8:38 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/5/15 - Saint Paul

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, May 05, 2015 1:52 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/5/2015

Date In :

Time Out : 01:34

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 527

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 05, 2015 8:39 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/5/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, May 05, 2015 3:07 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/5/2015

Date In : 5/5/2015

Time Out : 01:34

Time In : 03:01

Time Zone : CST

Duration : 1 hours, 27 mins

Number of Customers Affected : 527

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FUALTED FEEDER CABLE BETWEEN [REDACTED] AND [REDACTED], FEILD SWITCHED TO
BRING EVERYONE BACK ON

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 07, 2015 8:00 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/6/15 - Crystal, New Hope & Plymouth

Power outage – Crystal, New Hope & Plymouth.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, May 06, 2015 5:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/6/2015 Date In :

Time Out : 17:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 603

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 07, 2015 8:01 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/6/15 - Crystal, New Hope & Plymouth - UPDATE

Power outage - Crystal, New Hope & Plymouth – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, May 06, 2015 6:52 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/6/2015

Date In :

Time Out : 17:47

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 83

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Large tree across all three phases [REDACTED] private right-a-way

Follow-Up : opened the [REDACTED] picked up 520
customers 18:35 / 83 are out until tree removed

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 07, 2015 8:01 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/6/15 - Crystal, New Hope & Plymouth - POWER RESTORED

Power outage - Crystal, New Hope & Plymouth – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, May 06, 2015 8:55 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/6/2015

Date In : 5/6/2015

Time Out : 17:47

Time In : 20:50

Time Zone : CST

Duration : 3 hours, 3 mins

Number of Customers Affected : 83

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on Feeder [REDACTED]

Follow-Up : Removed tree / private right-a way / restored 520 at 18:35

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 08, 2015 7:57 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/7/15 - Maplewood, Roseville & Saint Paul

Power outage - Maplewood, Roseville & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, May 07, 2015 6:02 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/7/2015 Date In :

Time Out : 17:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2335

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : na

Cause : unknown

Follow-Up : to be patrolled

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 08, 2015 7:59 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/7/15 - Maplewood, Roseville & Saint Paul - POWER RESTORED

Power outage - Maplewood, Roseville & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, May 07, 2015 7:18 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/7/2015 Date In : 5/7/2015

Time Out : 17:52 Time In : 19:11

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 2335


For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : lighting hit x arm @ 

Follow-Up : crew to make repairs 100% restored

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 11, 2015 8:46 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/10/15 - Minneapolis

Power outage – Minneapolis

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Sunday, May 10, 2015 11:24 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/10/2015 Date In :
Time Out : 23:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2569

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Major Communities Affected: MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TROUBLE MEN ON THE WAY

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 11, 2015 8:47 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/10/15 - Minneapolis - UPDATE

Power outage – Minneapolis – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Sunday, May 10, 2015 11:50 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/10/2015 Date In :

Time Out : 23:09 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2569

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : Transformer on fire took fuse out possible cause of feeder lock. Feeder being patrolled as of now. Transformer location [REDACTED].

Follow-Up : Cutout blown to pieces.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 11, 2015 8:48 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/10/15 - Minneapolis - POWER RESTORED

Power outage – Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Monday, May 11, 2015 1:04 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/10/2015 Date In : 5/11/2015

Time Out : 23:09 Time In : 00:21

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 2569

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : transformer fire fuse didn't clear locked out feeder

Follow-Up : transformer still out with 23 cust0mers crew has been called in to change out transformer.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 11, 2015 8:52 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/10/15 - Saint Paul

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Sunday, May 10, 2015 11:55 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/10/2015 Date In :
Time Out : 23:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1367

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : na

Cause : unknown

Follow-Up : to be patrolled

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 11, 2015 8:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/10/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, May 11, 2015 1:23 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/10/2015 Date In : 5/11/2015

Time Out : 23:42 Time In : 01:04

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1367

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : na

Cause : faulted cable

Follow-Up : biddle repr

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:50 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/17/15 - Roseville & Saint Paul

Power outage - Roseville & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Sunday, May 17, 2015 9:00 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In :
Time Out : 20:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3231

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : NO

Cause : UNKNOWN

Follow-Up : IN ROUTE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:52 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 5/17/15 - Roseville & Saint Paul - POWER RESTORED - UPDATE

Power outage - Roseville & Saint Paul – power restored – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, May 17, 2015 10:57 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In :

Time Out : 20:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3231

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

back on Cause : 21:23 there were 1964 customers back on at 22:04 there were 2722 customers
cause tree on line

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Fourth Outage Notice - 5/17/15 - Roseville & Saint Paul - POWER RESTORED/UPDATE

Power outage - Roseville & Saint Paul – power restored – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, May 17, 2015 11:23 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Fourth Outage Notice

Distribution System Status Outage Notification

[REDACTED] Fourth Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In :

Time Out : 20:51 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3231

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : tree on line at alta vista and roma 21:23 1964 customers are back on 22:04 2722
are back on feeders is back in at 22:04 tap is cut open at alta vista and roma to remove tree 509
customers are still out until tree is removed

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:55 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/17/15 - Roseville & Saint Paul - POWER RESTORED - FINAL

Power outage - Roseville & Saint Paul – power restored – final.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Monday, May 18, 2015 2:55 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In : 5/18/2015

Time Out : 20:23 Time In : 02:46

Time Zone : CST

Duration : 6 hours, 23 mins

Number of Customers Affected : 3231

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : tree on line alta vista and roma everyone is back on 509 more customers came
back on 3231 total customers are all on

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:56 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/17/15 - Minnetonka

Power outage – Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Sunday, May 17, 2015 10:52 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In :
Time Out : 22:41 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2682

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLEMAN ARE ENROUTE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 8:57 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/17/15 - Minnetonka - POWER RESTORED

Power outage – Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Sunday, May 17, 2015 11:57 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/17/2015 Date In : 5/17/2015

Time Out : 22:41 Time In : 23:44

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2682

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STREET LIGHT POLE BROKE AND FELL INTO FEEDER AND BURNED DOWN


Follow-Up : ISOLATED, RESTORED ALL CUSTOMERS, CREW IS ENROUTE TO PUT UP WIRE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 9:29 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/18/15 - Mendota Heights, Saint Paul & West Saint Paul

Power outage - Mendota Heights, Saint Paul & West Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, May 18, 2015 9:24 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/18/2015 Date In :

Time Out : 09:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1804

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, May 18, 2015 10:29 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/18/15 - Mendota Heights, Saint Paul & West Saint Paul - POWER RESTORED

Power outage - Mendota Heights, Saint Paul & West Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, May 18, 2015 10:19 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/18/2015 Date In : 5/18/2015

Time Out : 09:07 Time In : 10:16

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 1804

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : tree fell into feeder at [REDACTED] - trbl cleared tree

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 26, 2015 3:11 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/26/15 - Minnetonka, Plymouth, Wayzata & Woodland

Power outage - Minnetonka, Plymouth, Wayzata & Woodland.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, May 26, 2015 3:02 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/26/2015 Date In :
Time Out : 14:50 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1278

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 26, 2015 4:11 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/26/15 - Minnetonka, Plymouth, Wayzata & Woodland - REVISION

Power outage - Minnetonka, Plymouth, Wayzata & Woodland – REVISION (see below).

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, May 26, 2015 3:50 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/26/2015

Date In :

Time Out : 14:50

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 669

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up : Correction to the 1st notification count due to feeder being abnormal.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, May 26, 2015 4:12 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/26/15 - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED

Power outage - Minnetonka, Plymouth, Wayzata & Woodland – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, May 26, 2015 3:53 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/26/2015 Date In : 5/26/2015
Time Out : 14:50 Time In : 15:46

Time Zone : CST

Duration : 0 hours, 56 mins

Number of Customers Affected : 631

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : non

Cause : Tree fell on wire south of the [REDACTED].

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 8:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/26/15 - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED/REVISED

Power outage - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED/REVISED

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Tuesday, May 26, 2015 4:29 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/26/2015 Date In : 5/26/2015

Time Out : 14:50 Time In : 16:20

Time Zone : CST

Duration : 1 hours, 30 mins

Number of Customers Affected : 669

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch at [REDACTED].

Follow-Up : 631 customers restored at 1546 and 38 at 1620. Heavy tree trimming needed from [REDACTED]. to the [REDACTED].

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 3:13 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/27/15 - Saint Louis Park

Power outage – Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Wednesday, May 27, 2015 3:03 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1872

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : non

Cause : unknow

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 4:04 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/27/15 - Saint Louis Park - UPDATE

Power outage – Saint Louis Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 3:58 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1872

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down on [REDACTED] and got into [REDACTED].

Follow-Up : 1871 customers restored at 15:43. Crew on the way to make repairs to restore remaining 1 cust.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 9:59 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice 5/27/15 - Saint Louis Park - POWER RESTORED

Power outage – Saint Louis Park – power restored

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 6:20 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In : 5/27/2015

Time Out : 14:48 Time In : 18:02

Time Zone : CST

Duration : 3 hours, 14 mins

Number of Customers Affected : 1872

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable on [REDACTED]. [REDACTED]. and [REDACTED]

Follow-Up : 1871 customers restored at 15:43 and 1 at 1802.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 3:14 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/27/15 - Saint Louis Park

Power outage – Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Wednesday, May 27, 2015 3:07 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 4:04 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/27/15 - Saint Louis Park - UPDATE

Power outage – Saint Louis Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 3:42 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire down on [REDACTED] and got into [REDACTED].

Follow-Up : Crew on the way to repair perm. Isolating work site and will restore 99% very soon.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, May 27, 2015 4:10 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 5/27/15 - Saint Louis Park - UPDATE

Power outage – Saint Louis Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 4:05 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :

Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Wire down on [REDACTED] and got into [REDACTED].

Follow-Up : Crew on the way to repair perm. Second wire down when closing tie switch. Auto splice let loose. Will restore about 70% soon.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 9:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Fourth Outage Notice-5/27/15-Minneapolis & Saint Louis Park-UPDATE

Power outage – Minneapolis & Saint Louis Park – UPDATE

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 5:03 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Fourth Outage Notice

Distribution System Status Outage Notification

[REDACTED] Fourth Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable at [REDACTED].

Follow-Up : Working to restore.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 9:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Fifth Outage Notice-5/27/15-Minneapolis & Saint Louis Park - UPDATE

Power outage – Minneapolis & Saint Louis Park – Update

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 5:18 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Fifth Outage Notice

Distribution System Status Outage Notification

[REDACTED] Fifth Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable.

Follow-Up : 85% of customers restored at 1712. Crew to put wire up to restore remainder.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 9:50 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/27/15 - Minneapolis & Saint Louis Park - POWER RESTORED

Power outage – Minneapolis & Saint Louis Park – POWER RESTORED

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 8:06 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In : 5/27/2015

Time Out : 14:48 Time In : 19:52

Time Zone : CST

Duration : 5 hours, 4 mins

Number of Customers Affected : 2537

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable. [REDACTED].

Follow-Up : 2482 cust. restored at 1712, 27 at 1757, 25 at 1944, and 1 at 1952. Repaired perm.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 10:34 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/27/15 - Edina, Hopkins, Minnetonka & Saint Louis Park

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 8:35 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :

Time Out : 20:25 Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 2388

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 10:35 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/27/15 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, May 27, 2015 10:47 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In : 5/27/2015

Time Out : 20:25 Time In : 22:42

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 2388

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Blown lightning arresters on [REDACTED] causing flash into [REDACTED] (double deck). [REDACTED]
[REDACTED] Breaker failed to close.

Follow-Up : All restored as of 2242.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 10:39 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/27/15 - Saint Paul

Power outage – Saint Paul

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Wednesday, May 27, 2015 10:15 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/27/2015 Date In :
Time Out : 22:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2404

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : na

Cause : unknown

Follow-Up : to be patrolled

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, May 28, 2015 10:40 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/27/15 - Saint Paul - POWER RESTORED

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, May 28, 2015 12:04 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/28/2015 Date In : 5/29/2015

Time Out : 22:04 Time In : 00:00

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 2404

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : na

Cause : blown arestor @ [REDACTED]

Follow-Up : repl blown arrestors

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:10 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/29/15 - Edina & Richfield-DATE CORRECTION

Date Correction

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:08 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/28/15 - Edina & Richfield

Power outage - Edina & Richfield.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Friday, May 29, 2015 4:33 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/29/2015 Date In :
Time Out : 04:22 Time In :

Time Zone : CST

Number of Customers Affected : 2916

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:11 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 5/29/15 - Edina & Richfield - UPDATE

Power outage - Edina & Richfield – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Friday, May 29, 2015 5:02 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 5/29/2015 Date In :
Time Out : 04:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2916

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed pothead at [REDACTED].

Follow-Up : Isolating [REDACTED] to restore.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:16 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/29/15 - Edina & Richfield - POWER RESTORED

Corrected distribution list.

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:12 AM
To: MN PUC (consumer.puc@state.mn.us); 'Renier, Doug (COMM)'
Cc: MN PUC (consumer.puc@state.mn.us)
Subject: FW: [REDACTED] Final Outage Notice - 5/29/15 - Edina & Richfield - POWER RESTORED

Power outage - Edina & Richfield – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Friday, May 29, 2015 5:33 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/29/2015

Date In : 5/29/2015

Time Out : 04:22

Time In : 05:22

Time Zone : CST

Number of Customers Affected : 2916

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed Pothead at [REDACTED]

Follow-Up : 612 customers restored at 0516 and 2297 at 0522.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 8:18 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 5/29/15 - Edina, Hopkins, Minnetonka & Saint Louis Park

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Friday, May 29, 2015 7:15 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/29/2015 Date In :
Time Out : 07:12 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2386

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : SUPERVALU INC

Cause : Clear for emergency / guy wire wrapped around pothead at 3 SLP 321

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, May 29, 2015 9:12 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 5/29/15 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Friday, May 29, 2015 9:03 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 5/29/2015 Date In : 5/29/2015

Time Out : 07:12 Time In : 08:14

Time Zone : CST

Duration : 1 hours, 2 mins


Number of Customers Affected : 2386

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : TRUCK HIT GUY WIRE

Follow-Up : ISOLATED,RESTORED ALL CUSTOMERS, REFERRED FOR REPAIRS

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 9:57 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/5/15 - Golden Valley & Minneapolis

Power outage - Golden Valley & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, June 05, 2015 3:46 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/5/2015 Date In :
Time Out : 15:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1551

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up : Troublemen in route.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 9:58 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/5/15 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, June 05, 2015 4:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/5/2015 Date In : 6/5/2015

Time Out : 15:42 Time In : 16:44

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 1551

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable.

Follow-Up : Isolation and repair of failed cable in process.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 9:59 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/6/15 - Mankato - POWER RESTORED

Power outage – Mankato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Saturday, June 06, 2015 4:55 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In : 6/6/2015

Time Out : 02:37 Time In : 04:43

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 1627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : Bad crossarm at [REDACTED]

Follow-Up : 581 customers remain out on tap outage

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 9:59 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/6/15 - Mankato - POWER RESTORED

Power outage – Mankato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Saturday, June 06, 2015 4:55 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In : 6/6/2015

Time Out : 02:37 Time In : 04:43

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 1627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : Bad crossarm at [REDACTED]

Follow-Up : 581 customers remain out on tap outage

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:00 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/6/15 - Lakeville

Power outage – Lakeville.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Saturday, June 06, 2015 3:51 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015

Date In :

Time Out : 03:19

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2108

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN/ [REDACTED] LOCKOUT. CAN NOT GET OPERATOR TO COME IN. WILL HAVE TO GET TROUBLEMAN TO FIELD SWITCH FOR NOW.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:01 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/6/15 - Lakeville - POWER RESTORED

Power outage – Lakeville – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Saturday, June 06, 2015 5:02 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015

Date In : 6/6/2015

Time Out : 03:19

Time In : 05:00

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 2108

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN, WILL NOT KNOW UNTIL WE CAN GET OPERATOR TO SUB, FIELD SWITCHED FEEDERS TO GET EVERYONE BACK IN. [REDACTED] HAS [REDACTED] LOCKOUT AND NEED OPERATOR AT SUB TO GET [REDACTED] BACK IN SERVICE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:02 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/6/15 - Lakeville - POWER RESTORED/UPDATE

Power outage – Lakeville – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Saturday, June 06, 2015 7:59 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015

Date In : 6/6/2015

Time Out : 03:19

Time In : 05:00

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 2108

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : RACCOON GOT INTO [REDACTED] IN SUBSTATION .

Follow-Up : FIELD SWITCHED FEEDERS IN FIELD UNTIL WE COULD INSPECT TX ,RESTORED TO

NORMAL

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/6/15 - Eden Prairie

Power outage – Eden Prairie.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, June 06, 2015 10:41 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In :
Time Out : 10:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up : Troublemens in route.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/6/15 - Eden Prairie - UPDATE

Power outage - Eden Prairie – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, June 06, 2015 11:30 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In :
Time Out : 10:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up : All underground feeder; Testing cable at this time.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 6/6/15 - Eden Prairie - UPDATE

Power outage - Eden Prairie – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, June 06, 2015 11:40 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In :
Time Out : 10:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : None

Cause : Contractor hit feeder cable at [REDACTED] and [REDACTED].

Follow-Up : Isolation of damaged cable and restoration in progress.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 08, 2015 10:05 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/6/15 - Eden Prairie - POWER RESTORED

Power outage - Eden Prairie – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, June 06, 2015 12:05 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/6/2015 Date In : 6/6/2015

Time Out : 10:34 Time In : 11:51

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 608

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : None

Cause : Contractor hit feeder cable at [REDACTED] and [REDACTED].

Follow-Up : Crew has been dispatched to repair damaged cable. Restoration complete via switching.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:07 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/9/15 - Saint Paul

Power outage - Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, June 09, 2015 5:42 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015

Date In :

Time Out : 17:06

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3026

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:08 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/9/15 - Saint Paul - POWER RESTORED

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, June 09, 2015 6:56 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015 Date In : 6/9/2105

Time Out : 17:06 Time In : 18:00

Time Zone : CST

Duration : 788928 hours, 54 mins


Number of Customers Affected : 3026

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : BLOWN CABLE HEAD NOT LOCATED YET 90%ON 100%ON AT 18:55 HAVE 1 TX OFF
LINE DO TO FAILED SWITCH.

Follow-Up : WILL BE SWITCHING AND LOCATING FURTHER .MANY PEICES OFF EQUIPMENT TO
GO THROUGH.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:09 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/9/15 - Saint Paul - POWER RESTORED/UPDATE

Power outage - Saint Paul – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, June 09, 2015 7:32 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015

Date In : 6/9/2015

Time Out : 17:06

Time In : 18:24

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 3026

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : BLOWN CABLE AND [REDACTED]

Follow-Up : SWITCHGEAR MAY ALSO BE BAD RELAY WILL PROOF BOTH SIDE TO SEE HOW BAD

IT IS .

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:12 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/9/15 - Minneapolis

Power outage – Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Tuesday, June 09, 2015 7:22 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015 Date In :

Time Out : 19:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1802

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : troublemen & operator are enroute

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:13 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/9/15 - Minneapolis - Update

Power outage –Minneapolis – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Tuesday, June 09, 2015 8:16 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015

Date In :

Time Out : 19:13

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1802

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected: MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : wire is down at [REDACTED].

Follow-Up : Troublemens are in the process of putting wire back up.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:14 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/9/15 - Minneapolis - POWER RESTORED

Power outage – Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Tuesday, June 09, 2015 9:00 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015 Date In : 6/9/2015

Time Out : 19:13 Time In : 20:54

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 1802

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire burned down at [REDACTED].

Follow-Up : Put up wire, patrolled, restored all customers

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:19 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/9/15 - Inver Grove Heights, Inver Grove, Mendota Heights, St Paul, So St Paul & W St Paul

Power outage - - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, June 09, 2015 8:24 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015 Date In :
Time Out : 19:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2641

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : ON ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:19 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice-6/9/15- Inver Grove Heights, Inver Grove, Mendota Heights, St Paul, S St Paul & W St Paul-POWER RESTORED

From: Abbott, Edward J
Sent: Tuesday, June 09, 2015 9:39 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/9/2015 Date In : 6/9/2015
Time Out : 19:57 Time In : 21:11

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 2641

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BLOWN ARRESTERS ON TIE SWITCH [REDACTED]

Follow-Up : REFERRRED FOR REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/9/15 - Inver Grove Heights, Inver Grove, Minneapolis & South Saint Paul

Power outage - Inver Grove Heights, Inver Grove, Minneapolis & South Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Tuesday, June 09, 2015 8:23 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015

Date In :

Time Out : 19:57

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2496

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MINNEAPOLIS,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : UNKNOWN IN ROUTE

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 8:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/9/15 - Inver Grove Heights, Inver Grove, Minneapolis & South Saint Paul - POWER RESTORED

Power outage - Inver Grove Heights, Inver Grove, Minneapolis & South Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, June 09, 2015 9:41 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/9/2015

Date In : 6/9/2015

Time Out : 19:57

Time In : 21:11

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 2496

For information about this alert, contact :

For follow-up information or questions, contact : Chris Stewart: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MINNEAPOLIS,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BLOWN ARRESTERS ON 

Follow-Up : REFERRED FOR REPAIR

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 1:45 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/10/15 - Mayer, Waconia & Watertown

Power outage - Mayer, Waconia & Watertown.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, June 10, 2015 1:44 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/10/2015 Date In :

Time Out : 13:20 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1447

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Wednesday, June 10, 2015 3:09 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/10/15 - - Mayer, Waconia & Watertown - POWER RESTORED

Power outage - - Mayer, Waconia & Watertown – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, June 10, 2015 3:04 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/10/2015 Date In : 6/10/2015

Time Out : 13:20 Time In : 14:55

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 1447

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : None

Cause : Cut cable between [REDACTED] and [REDACTED]

Follow-Up : restored 623 Cust at 1410 / 699 Cust at 1443 /125 Cust at 1455

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 15, 2015 11:15 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/14/15 - Chanhassen, Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata

Power outage - Chanhassen, Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 14, 2015 9:53 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/14/2015 Date In :

Time Out : 9:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2734

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : EXC BUS [REDACTED] LOCKOUT

Follow-Up : OPER. ON WAY TO STATION

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 15, 2015 11:16 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/14/15 - Chanhassen, Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata - UPDATE

Power outage - Chanhassen, Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 14, 2015 10:23 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/14/2015 Date In :

Time Out : 9:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2734

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : [REDACTED] PHASE REG. FAILURE

Follow-Up : ISOLATE AT STATION, FIELD SWITCH FEEDERS.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 15, 2015 11:17 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/14/15 - Chanhassen, Excelsior & Shorewood - POWER RESTORED

Power outage - Chanhassen, Excelsior & Shorewood – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 14, 2015 12:14 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/14/2015 Date In : 6/14/2015

Time Out : 9:38 Time In : 11:17

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 1138

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; SHOREWOOD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : [REDACTED] PASE REG. FAILURE

Follow-Up : ISOLATE,RESTORE BY FIELD TIE

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 15, 2015 11:19 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/14/15 - Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata-POWER RESTORED

Power outage - Excelsior, Mtka Beach, Navarre, Orono, Shorewood, Tonka Bay & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 14, 2015 12:18 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/14/2015 Date In : 6/14/2015

Time Out : 9:38 Time In : 12:07

Time Zone : CST

Duration : 2 hours, 29 mins

Number of Customers Affected : 1596

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : [REDACTED] C PHASE REG. FAILURE

Follow-Up : ISOLATE,RESTORE BY FIELD TIE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 18, 2015 7:58 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/18/15 - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park

Power outage - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, June 18, 2015 12:02 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/18/2015 Date In :

Time Out : 23:31 Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 2797

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 18, 2015 8:04 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/17/15 - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park - UPDATE

Power outage - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, June 18, 2015 12:53 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/17/2015 Date In :
Time Out : 23:28 Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 2797

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : PATROLLING FDR.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Thursday, June 18, 2015 8:05 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/17/15 - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park - POWER RESTORED

Power outage - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, June 18, 2015 2:59 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/17/2015 Date In : 6/18/2015

Time Out : 23:31 Time In : 02:39

Time Zone : CST

Duration : 3 hours, 8 mins

Number of Customers Affected : 2797

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : LOAD CENTER [REDACTED] FLASHED OVER [REDACTED]

Follow-Up : ISOLATE,REFERRED

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:52 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/21/15 - Corcoran, Hamel, Media, Minneapolis & Plymouth - FIRST NOTICE REC'D/MOMENTARIES NOTED BELOW

Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 21, 2015 10:29 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/21/2015 Date In :
Time Out : 22:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2905

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 3 MOMENTARY OPS. OF [REDACTED] BKR. REPORTS OF PRIORITY CALL & OUTAGES
DOWN STREAM FROM [REDACTED]. TRBL FOUND PHASE OF FEEDER DOWN 1 SPAN WEST OF [REDACTED]. OPEN 4
SWITCH TO CLEAR WIRE & PATROL

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 6/21/15 - Corcoran, Hamel, Media, Minneapolis & Plymouth - UPDATE

Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, June 21, 2015 11:36 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/21/2015 Date In :
Time Out : 22:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2905

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PHASE DOWN, ARRESTORS BLOWN 2 DIFFERENT LOCATIONS SO FAR

Follow-Up : TRBL IN PROCESS OF CLEARING, PREPARING TO RE-ENERGIZE BY FIELD TIE. CALL IN
CREW TO PUT UP PHASE.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:54 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/21/15 - Corcoran, Hamel, Media, Minneapolis & Plymouth - POWER RESTORED

Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, June 22, 2015 12:12 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/21/2015 Date In : 6/22/2016

Time Out : 22:00 Time In : 23:58

Time Zone : CST

Duration : 8809 hours, 58 mins

Number of Customers Affected : 2905

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : B PHASE DOWN IN FEEDER [REDACTED] . & [REDACTED] ARRESTOR FAILURE AT 3
DIFFERENT LOCATIONS

Follow-Up : CLEAR CONDUCTOR & ARRESTORS, RESTORE BY FIELD TIE. CALL OUT CREW TO
PUT UP CONDUCTOR PERM.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:55 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/21/15 - Corcoran, Hamel, Media, Minneapolis & Plymouth - POWER RESTORED/UPDATE

Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, June 22, 2015 3:36 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/21/2015 Date In : 6/21/2015

Time Out : 22:00 Time In : 23:58

Time Zone : CST

Duration : 1 hours, 58 mins

Number of Customers Affected : 1253

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUNDUCTOR DOWN & ARRESSTOR FAILURE

Follow-Up : NOTE; CORRECTION OF CUSTOMER COUNT

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:56 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/22/15 - Bloomington

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, June 22, 2015 5:09 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In :
Time Out : 04:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2152

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:56 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/22/15 - Bloomington - UPDATE

Power outage – Bloomington – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Monday, June 22, 2015 5:55 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In :

Time Out : 04:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2152

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable [REDACTED]

Follow-Up : Isolating to restore.

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 8:57 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/22/15 - Bloomington - POWER RESTORED

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Monday, June 22, 2015 6:09 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In : 6/22/2015

Time Out : 04:59 Time In : 06:08

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 2152

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable [REDACTED]

Follow-Up : All restored

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 12:32 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/22/15 - Delavan, Good Thunder, Mapleton & Minnesota Lake - POWER RESTORED

Power outage - Delavan, Good Thunder, Mapleton & Minnesota Lake – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Monday, June 22, 2015 12:19 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In : 6/22/2015

Time Out : 08:19 Time In : 11:42

Time Zone : CST

Duration : 3 hours, 23 mins

Number of Customers Affected : 1014

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DELAVAN, MN; GOOD THUNDER, MN; MAPLETON, MN; MINNESOTA LAKE, MN

State : MN - Minnesota

Major Customers :

Cause : branches down from storm in multiple locations. sparking jumper in sub at A Phase regulator.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 10:00 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/22/15 - Various

Power outage - Almelund, Center City, E Bethel, Harris, Henderson, Lindstrom, N Branch, Stacy, Sunrise, Taylors Falls & Wyoming.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, June 22, 2015 9:55 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015

Date In :

Time Out : 09:20

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 960

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : ALMELUND, MN; CENTER CITY, MN; EAST BETHEL, MN; HARRIS, MN; HENDERSON, MN; LINDSTROM, MN; NORTH BRANCH, MN; STACY, MN; SUNRISE, MN; TAYLORS FALLS, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : na

Cause : [REDACTED] auto sectionalized

Follow-Up : to be patrolled

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 12:25 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/22/15 - Various - POWER RESTORED

Power outage - Almelund, Center City, E Bethel, Harris, Henderson, Lindstrom, N Branch, Stacy, Sunrise, Taylors Falls & Wyoming – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, June 22, 2015 12:13 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In : 6/22/2015

Time Out : 09:20 Time In : 12:05

Time Zone : CST

Duration : 2 hours, 45 mins

Number of Customers Affected : 960

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : ALMELUND, MN; CENTER CITY, MN; EAST BETHEL, MN; HARRIS, MN; HENDERSON, MN; LINDSTROM, MN; NORTH BRANCH, MN; STACY, MN; SUNRISE, MN; TAYLORS FALLS, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : na

Cause : wire down

Follow-Up : crew to make repairs 100% restored via switching

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 1:27 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/22/15 - Eagan

Power outage – Eagan.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, June 22, 2015 12:42 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In :
Time Out : 12:33 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 286

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected: EAGAN, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Follow-Up : trouble in route

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 22, 2015 4:10 PM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/22/15 - Eagan, Inver Grove Heights & Inver Grove - POWER RESTORED

Power outage - Eagan, Inver Grove Heights & Inver Grove – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, June 22, 2015 2:15 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/22/2015 Date In : 6/22/2015

Time Out : 12:33 Time In : 13:55

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 3265

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] carrying [REDACTED] on [REDACTED] - backhoe cut into feeder cable
btwn [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 26, 2015 8:48 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/25/15 - Hastings

Power outage – Hastings.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, June 25, 2015 5:33 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/25/2015 Date In :
Time Out : 17:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1389

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

State : MN - Minnesota

Major Customers : MN.

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 26, 2015 8:49 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Second Outage Notice - 6/25/15 - Hastings - UPDATE

Power outage – Hastings – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, June 25, 2015 6:35 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/25/2015 Date In :
Time Out : 17:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1389

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected: HASTINGS, MN

State : MN - Minnesota

Major Customers : MN

Cause : [REDACTED] hotline clamp burned up and went phase to phase

Follow-Up : 1323 customers are back on and 66 customers are still out

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 26, 2015 8:50 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Third Outage Notice - 6/25/15 - Hastings - UPDATE

Power outage – Hastings – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, June 25, 2015 6:40 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/25/2015 Date In :
Time Out : 17:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1389

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] hotline burned up and went phase to phase

Follow-Up : 1323 customers are back on at 18:18 and 66 customers are still out

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Friday, June 26, 2015 8:50 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/25/15 - Hastings - POWER RESTORED

Power outage – Hastings – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, June 25, 2015 7:27 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/25/2015 Date In : 6/25/2015
Time Out : 17:24 Time In : 19:21

Time Zone : CST

Duration : 1 hours, 57 mins

Number of Customers Affected : 1389

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : HASTINGS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : hotline clamp burned up at [REDACTED] and went phase to phase

Follow-Up : the last 66 customers are back on at 19:21

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 27, 2015 10:52 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/27/15 - Falcon Heights, Roseville & Saint Paul

Power outage - Falcon Heights, Roseville & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, June 27, 2015 8:56 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/27/2015 Date In :

Time Out : 08:47 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 857

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Saturday, June 27, 2015 10:53 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/27/15 - Falcon Heights, Roseville & Saint Paul - POWER RESTORED

Power outage - Falcon Heights, Roseville & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, June 27, 2015 10:06 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/27/2015 Date In : 6/27/2015

Time Out : 08:47 Time In : 09:49

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 857

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : burnt up switch gear [REDACTED] with [REDACTED] in it - restored on [REDACTED]

Follow-Up : referred for repair

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 8:45 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/28/15 - Burnsville, Prior Lake, Savage & Shakopee

Power outage - Burnsville, Prior Lake, Savage & Shakopee.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Sunday, June 28, 2015 1:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/28/2015 Date In :

Time Out : 13:38 Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 1952

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; PRIOR LAKE, MN; SAVAGE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 8:45 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/28/15 - Burnsville, Prior Lake, Savage & Shakopee - POWER RESTORED

Power outage - Burnsville, Prior Lake, Savage & Shakopee – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Sunday, June 28, 2015 3:36 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/28/2015 Date In : 6/28/2015

Time Out : 13:38 Time In : 15:19

Time Zone : CST

Duration : 1 hours, 41 mins


Number of Customers Affected : 1952

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN; PRIOR LAKE, MN; SAVAGE, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : 

Cause : Nothing found.

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 8:46 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/28/15 - Plymouth

Power outage – Plymouth.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Sunday, June 28, 2015 4:21 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/28/2015 Date In :
Time Out : 19:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1905

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 8:47 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/28/15 - Plymouth - POWER RESTORED

Power outage – Plymouth – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Sunday, June 28, 2015 5:41 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/28/2015 Date In : 6/28/2015

Time Out : 16:08 Time In : 17:37

Time Zone : CST

Duration : 1 hours, 29 mins

Number of Customers Affected : 1905

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PATROL DID NOT FIND ANY THING

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 8:49 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/29/15 - Cologne, Green Isle, Hamburg, Lk Wilson, Mayer, NYA & Plato

Power outage - Cologne, Green Isle, Hamburg, Lk Wilson, Mayer, NYA & Plato.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Monday, June 29, 2015 8:00 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/29/2015

Date In :

Time Out : 07:07

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2212

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; LAKE WILSON, MN; MAYER, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : SQUIRREL GOT ON BUE TIE IN SUB WORKING ON RESTORE OUTAGE WE HAVE DAMAGE ON BUS TIE MAY NEED TO FIELED SWITCH YAM [REDACTED] AFTER REFUSEING [REDACTED] SIDE OF TR [REDACTED] AND TR [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 9:48 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/29/15 - Lk Wilson, Mayer & NYA - POWER RESTORED

Power outage - Lk Wilson, Mayer & NYA – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Monday, June 29, 2015 9:33 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/29/2015 Date In : 6/29/2015
Time Out : 07:07 Time In : 09:21

Time Zone : CST

Duration : 2 hours, 14 mins

Number of Customers Affected : 1181

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LAKE WILSON, MN; MAYER, MN; NYA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : : SQUIRREL GOT ON BUE TIE IN SUB WORKING ON RESTORE OUTAGE WE HAVE
DAMAGE ON BUS [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Monday, June 29, 2015 9:47 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/29/15 - Cologne, Green Isle, Hamburg, NYA & Plato - POWER RESTORED

Power outage - Cologne, Green Isle, Hamburg, NYA & Plato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Monday, June 29, 2015 9:29 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/29/2015 Date In : 6/29/2015
Time Out : 07:07 Time In : 08:54

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 1031

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; NYA, MN; PLATO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : : SQUIRREL GOT ON BUE TIE IN SUB WORKING ON RESTORE OUTAGE WE HAVE
DAMAGE ON BUS [REDACTED]

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 30, 2015 7:33 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] First Outage Notice - 6/30/15 - Forest Lake & Wyoming

Power outage - Forest Lake & Wyoming.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Tuesday, June 30, 2015 5:58 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 6/30/2015 Date In :
Time Out : 05:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2306

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected: FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown- trbl dispatched

Follow-Up :

Eilers, Rebecca D

From: Jaede, Wendy L
Sent: Tuesday, June 30, 2015 7:34 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: [REDACTED] Final Outage Notice - 6/30/15 - Forest Lake & Wyoming - POWER RESTORED

Power outage - Forest Lake & Wyoming – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Tuesday, June 30, 2015 7:28 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 6/30/2015 Date In : 6/30/2015

Time Out : 05:39 Time In : 07:02

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 2306

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FOREST LAKE, MN; WYOMING, MN

State : MN - Minnesota

Major Customers : n/a

Cause : wire burnt down at [REDACTED]

Follow-Up : crew dispatched to make repairs

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/1/15 - Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Date: Wednesday, July 01, 2015 4:15:50 PM

Power outage - Saint Paul, South Saint Paul & West Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Wednesday, July 01, 2015 2:20 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/1/2015

Date In : 7/1/2015

Time Out : 12:24

Time In : 14:06

Time Zone : CST

Duration : 1 hours, 42 mins

Number of Customers Affected : 657

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : na

Cause : contractor hit cable

Follow-Up : crew to make repairs

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/5/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids
Date: Monday, July 06, 2015 8:16:18 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Ankoviak, Robert S
Sent: Sunday, July 05, 2015 11:39 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/5/2015

Date In :

Time Out : 23:32

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,

MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN, STORMS PASSING THROUGH AREA

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN PUC \(consumer.puc@state.mn.us\)](mailto:consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/6/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids - UPDATE
Date: Monday, July 06, 2015 8:17:05 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Ankoviak, Robert S
Sent: Monday, July 06, 2015 1:00 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015 Date In :

Time Out : 23:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,
MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : STORMS IN AREA, CREWS PATROLLING

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 7/6/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids - UPDATE
Date: Monday, July 06, 2015 8:22:05 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Ankoviak, Robert S
Sent: Monday, July 06, 2015 2:51 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015 Date In :

Time Out : 23:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3245

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,
MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : CLOSED BREAKER AT 01:37, 2473 CUSTOMERS RESTORED

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/5/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids - POWER RESTORED
Date: Monday, July 06, 2015 8:23:29 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Ankoviak, Robert S
Sent: Monday, July 06, 2015 3:27 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/5/2015

Date In : 7/6/2015

Time Out : 23:32

Time In : 02:53

Time Zone : CST

Duration : 3 hours, 21 mins

Number of Customers Affected : 3245


For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,
MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : LIGHTNING STRIKE ON SOURCE SIDE OF 
RECLOSER

Follow-Up : FINAL 772 CUSTOMERS RESTORED AT 02:53

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/6/15 - Cottage Grove, Newport & Saint Paul Park
Date: Monday, July 06, 2015 8:29:57 AM

Power outage - Cottage Grove, Newport & Saint Paul Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, July 06, 2015 3:10 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In :

Time Out : 02:52

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2496

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN; NEWPORT, MN; SAINT PAUL

PARK, MN

State : MN - Minnesota

Major Customers :



Cause : unknown - trbl dispatched

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/6/15 - Cottage Grove, Newport & Saint Paul Park - UPDATE
Date: Monday, July 06, 2015 8:32:23 AM

Power outage - Cottage Grove, Newport & Saint Paul Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, July 06, 2015 4:17 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In :

Time Out : 02:52

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2496

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN; NEWPORT, MN; SAINT PAUL
PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : hot up to [REDACTED] @ 03:41 picked up 786 customers

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/6/15 - Cottage Grove, Newport & Saint Paul Park - POWER RESTORED
Date: Monday, July 06, 2015 8:35:30 AM

Power outage - Cottage Grove, Newport & Saint Paul Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Monday, July 06, 2015 4:33 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In : 7/6/2015

Time Out : 02:52

Time In : 04:27

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 2496

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN; NEWPORT, MN; SAINT PAUL
PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : NO PROBLEMS FOUND AFTER THE [REDACTED] PICKED UP THE
REMAINING 1711 CUSTOMERS @ 04:27

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/6/15 - VARIOUS CITIES
Date: Monday, July 06, 2015 8:39:07 AM

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Monday, July 06, 2015 5:09 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In :

Time Out : 03:18

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 698

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

**Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN;
EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT
BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN
TWP, MN; WATERTOWN, MN; WAYZATA, MN**

State : MN - Minnesota

Major Customers : non

Cause : Tree on the line between [REDACTED].

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - Various Cities - POWER RESTORED
Date: Monday, July 06, 2015 8:39:50 AM

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Monday, July 06, 2015 5:25 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In : 7/6/2015

Time Out : 03:18

Time In : 05:17

Time Zone : CST

Duration : 1 hours, 59 mins

Number of Customers Affected : 698

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN;
EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT
BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN
TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : Tree on the line - [REDACTED].

Follow-Up : Intelliteam correctly operated.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/6/15 - Brooklyn Center & Minneapolis
Date: Monday, July 06, 2015 12:12:32 PM

Power outage - Brooklyn Center & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Monday, July 06, 2015 12:08 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In :

Time Out : 11:59

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1188

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLEMEN ARE ENROUTE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/6/15 - Brooklyn Center & Minneapolis - POWER RESTORED
Date: Monday, July 06, 2015 1:24:01 PM

Power outage – Brooklyn Center & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Monday, July 06, 2015 1:20 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/6/2015

Date In : 7/6/2015

Time Out : 11:59

Time In : 13:13

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1188

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 2 ARRESTORS BLEW AT [REDACTED] SWITCH

Follow-Up : CLEARED UP ARRESTORS , RESTORED ALL CUSTOMERS

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/12/15 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights
Date: Monday, July 13, 2015 8:20:03 AM

Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, July 12, 2015 5:08 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015 Date In :

Time Out : 16:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 5190

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN;
SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : 

Cause : pole down rice and owasso

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/12/15 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights
Date: Monday, July 13, 2015 8:20:42 AM

Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, July 12, 2015 5:44 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015 Date In :

Time Out : 16:52 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2049

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN;
SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : car hit pole by [REDACTED]

Follow-Up : 102 customers are back on at 17:36

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 7/12/15 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - UPDATE/POWER RESTORED
Date: Monday, July 13, 2015 8:22:29 AM

Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights – update/power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Sunday, July 12, 2015 6:34 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In : 7/12/2015

Time Out : 16:52

Time In : 17:58

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 5

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN;
SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : na

Cause : car hit pole

Follow-Up : need to replace pole 5 customers to remain out untill repairs
are made

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/12/15 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - UPDATE/POWER RESTORED-FINAL
Date: Monday, July 13, 2015 8:32:34 AM

Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights – update/power restored/final.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, July 13, 2015 5:37 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In : 7/13/2015

Time Out : 16:52

Time In : 04:00

Time Zone : CST

Duration : 11 hours, 8 mins

Number of Customers Affected : 5

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN;
SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : NA

Cause : CAR HIT POLE

Follow-Up : LAST 5 RESTORED 04:00

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/12/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids
Date: Monday, July 13, 2015 8:23:23 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Sunday, July 12, 2015 8:45 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In :

Time Out : 20:40

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3246

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,

MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/12/15 - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids
- POWER RESTORED
Date: Monday, July 13, 2015 8:24:08 AM

Power outage - Foley, Rice, Saint Cloud, Sartell & Sauk Rapids – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Sunday, July 12, 2015 10:58 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In : 7/12/2015

Time Out : 20:40

Time In : 22:51

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 3246

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FOLEY, MN; RICE, MN; SAINT CLOUD, MN; SARTELL,
MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : none

Cause : crew found 2 spans of wire down. opened jumpers to isolate
and closed breaker.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/12/15 - Saint Paul
Date: Monday, July 13, 2015 8:24:39 AM

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Sunday, July 12, 2015 11:51 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In :

Time Out : 23:37

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2393

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : STORM IN AREA

Follow-Up : TROUBLE TO PATROL

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/12/15 - Saint Paul - POWER RESTORED
Date: Monday, July 13, 2015 8:25:22 AM

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, July 13, 2015 1:31 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/12/2015

Date In : 7/13/2015

Time Out : 23:37

Time In : 01:26

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 2393

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/13/15 - Gem Lake, White Bear Lake & White Bear Lk
Date: Monday, July 13, 2015 8:28:22 AM

Power outage - Gem Lake, White Bear Lake & White Bear Lk

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, July 13, 2015 3:11 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In :

Time Out : 02:46

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1344

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR

LK, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up : TROUBLE TO PATROL

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/13/15 - Gem Lake, White Bear Lake & White Bear Lk - UPDATE
Date: Monday, July 13, 2015 8:34:30 AM

Power outage - Gem Lake, White Bear Lake & White Bear Lk – update

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Monday, July 13, 2015 8:05 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/13/2015 Date In :

Time Out : 07:22 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1344

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR
LK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] switch burned up 299 customers were picked up at
07:57

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/13/15 - Gem Lake, White Bear Lake & White Bear Lk - POWER RESTORED
Date: Monday, July 13, 2015 8:28:57 AM

Power outage - Gem Lake, White Bear Lake & White Bear Lk – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Monday, July 13, 2015 3:51 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In : 7/13/2015

Time Out : 02:46

Time In : 03:48

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 1344

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE BEAR
LK, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/13/15 - Deephaven, Excelsior, Minnetonka, Wayzata & Woodland
Date: Tuesday, July 14, 2015 9:32:12 AM

Power outage - Deephaven, Excelsior, Minnetonka, Wayzata & Woodland.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Monday, July 13, 2015 5:39 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/13/2015 Date In :

Time Out : 17:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1670

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN;
WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/13/15 - Deephaven, Excelsior, Minnetonka, Wayzata & Woodland - UPDATE
Date: Tuesday, July 14, 2015 9:33:38 AM

Power outage - Deephaven, Excelsior, Minnetonka, Wayzata & Woodland – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Monday, July 13, 2015 6:43 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015 Date In :

Time Out : 17:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1670

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN;

WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FEEDER WAS ABNORMAL ON [REDACTED], FOUND WIRE DOWN
AT [REDACTED], TROUBLEMAN IS ONSITE AND CREW IS ENROUTE TO PUT WIRE UP

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/13/15- Deephaven, Excelsior, Minnetonka, Wayzata & Woodland - POWER RESTORED
Date: Tuesday, July 14, 2015 9:35:53 AM

Power outage - Deephaven, Excelsior, Minnetonka, Wayzata & Woodland – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Monday, July 13, 2015 8:12 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In : 7/13/2015

Time Out : 17:35

Time In : 20:05

Time Zone : CST

Duration : 2 hours, 30 mins

Number of Customers Affected : 1670

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN;
WAYZATA, MN; WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE WAS BURNED DOWN AT THE [REDACTED]. FEEDER WAS
ABNORMAL ON [REDACTED]

Follow-Up : PUT UP WIRE, RESTORED ALL CUSTOMERS

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/13/15 - Bloomington, Edina, Richfield & Waite Park
Date: Tuesday, July 14, 2015 9:37:16 AM

Power outage - Bloomington, Edina, Richfield & Waite Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, July 13, 2015 6:40 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In :

Time Out : 18:31

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 900

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; RICHFIELD, MN;

WAITE PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/13/15 - Bloomington, Edina, Richfield & Waite Park - UPDATE
Date: Tuesday, July 14, 2015 9:38:13 AM

Power outage - Bloomington, Edina, Richfield & Waite Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, July 13, 2015 7:54 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015 Date In :

Time Out : 18:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 900

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; RICHFIELD, MN;
WAITE PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up : REPORT OF POSSIBLE HIT FDR CABLE, PATROLLING

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/13/15 - Bloomington, Edina, Richfield & Waite Park - POWER RESTORED
Date: Tuesday, July 14, 2015 9:39:37 AM

Power outage - Bloomington, Edina, Richfield & Waite Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, July 13, 2015 8:30 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In : 7/13/2015

Time Out : 18:31

Time In : 20:08

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 900

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; RICHFIELD, MN;
WAITE PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : HIT CABLE [REDACTED]
[REDACTED]

Follow-Up : ISOLATE REFER FOR BIDDLE & REPAIR

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/13/15 - Saint Cloud & Sauk Rapids
Date: Tuesday, July 14, 2015 9:40:56 AM

Power outage - Saint Cloud & Sauk Rapids.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Johnson, Michael A
Sent: Monday, July 13, 2015 7:33 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In :

Time Out : 19:28

Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 2478

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN; TROUBLMAN ENROUTE

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice- 7/13/15 - Saint Cloud & Sauk Rapids - POWER RESTORED
Date: Tuesday, July 14, 2015 9:42:00 AM

Power outage - Saint Cloud & Sauk Rapids – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Monday, July 13, 2015 9:17 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/13/2015

Date In : 7/13/2015

Time Out : 19:28

Time In : 20:44

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 2478

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : faulted feeder cable between [REDACTED] and [REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/15/15 - Saint Paul
Date: Thursday, July 16, 2015 7:53:50 AM

Power outage – Saint Paul

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Wednesday, July 15, 2015 6:36 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/15/2015

Date In :

Time Out : 18:18

Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 1455

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/15/15 - Saint Paul - POWER RESTORED
Date: Thursday, July 16, 2015 7:54:43 AM

Power outage – Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Wednesday, July 15, 2015 7:26 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/15/2015

Date In : 7/15/2015

Time Out : 18:18

Time In : 19:24

Time Zone : CST

Duration : 1 hours, 6 mins


Number of Customers Affected : 1455

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : SWICHGEAR WITH THE 1,2 AND 3-DBL SWITCHES BURNT UP,
TROUBLE CLEARED AND FIELD SWITCHED, EVERYONE BACK ON

Follow-Up : REFERRED TO ST PAUL UNDERGROUND

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - Crystal Bay, Long Lake, Orono & Wayzata
Date: Monday, July 20, 2015 9:51:19 AM

Power outage - Crystal Bay, Long Lake, Orono & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:06 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:27

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1310

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;

WAYZATA, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Crystal Bay, Long Lake, Orono & Wayzata - POWER RESTORED
Date: Thursday, July 23, 2015 8:31:55 AM

This should be 7/18/15

Power outage – Crystal Bay, Long Lake, Orono & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:42 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/21/2015

Date In : 7/21/2015

Time Out : 00:27

Time In : 10:01

Time Zone : CST

Duration : 9 hours, 34 mins

Number of Customers Affected : 1309

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Plymouth
Date: Monday, July 20, 2015 9:52:04 AM

Power outage – Plymouth.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:07 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:31

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1907

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Plymouth - POWER RESTORED
Date: Thursday, July 23, 2015 8:35:09 AM

Power outage – Plymouth – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:45 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:31

Time In : 09:37

Time Zone : CST

Duration : 9 hours, 6 mins

Number of Customers Affected : 1906

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington
Date: Monday, July 20, 2015 9:52:42 AM

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:09 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:37

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 656

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington - POWER RESTORED
Date: Thursday, July 23, 2015 8:38:07 AM

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:47 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:37

Time In : 13:17

Time Zone : CST

Duration : 12 hours, 40 mins

Number of Customers Affected : 656

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington
Date: Monday, July 20, 2015 9:53:29 AM

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:10 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:38

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 701

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington - POWER RESTORED
Date: Thursday, July 23, 2015 8:42:46 AM

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:50 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:38

Time In : 11:41

Time Zone : CST

Duration : 11 hours, 3 mins

Number of Customers Affected : 701

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington, Minneapolis & Richfield
Date: Monday, July 20, 2015 9:55:12 AM

Power outage - Bloomington, Minneapolis & Richfield.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:13 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:39

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1316

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN; RICHFIELD,

MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington, Minneapolis & Richfield - POWER RESTORED
Date: Thursday, July 23, 2015 8:47:56 AM

Power outage – Bloomington, Minneapolis & Richfield – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:56 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 00:39 Time In : 19:55

Time Zone : CST

Duration : 19 hours, 16 mins

Number of Customers Affected : 1316

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; MINNEAPOLIS, MN; RICHFIELD,

MN

State : MN - Minnesota

Major Customers : NONE

Cause : HAD 42 IN AT 1036 AM HAD 729 IN AT 1106 AM ALL AT 755

PM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington
Date: Monday, July 20, 2015 9:54:20 AM

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:12 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:39

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1444

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington - POWER RESTORED
Date: Thursday, July 23, 2015 8:45:08 AM

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 9:51 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:39

Time In : 09:08

Time Zone : CST

Duration : 8 hours, 29 mins

Number of Customers Affected : 1445

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Minneapolis
Date: Monday, July 20, 2015 9:56:02 AM

Power outage – Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:15 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:44

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 618

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Minneapolis - POWER RESTORED
Date: Thursday, July 23, 2015 8:51:08 AM

Power outage – Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:02 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:44

Time In : 12:10

Time Zone : CST

Duration : 11 hours, 26 mins

Number of Customers Affected : 619

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice -- 7/18/15 - Minneapolis & Saint Paul
Date: Monday, July 20, 2015 8:48:34 AM

Power outage - Minneapolis & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, July 18, 2015 12:52 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1375

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : trbl dispatched

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Minneapolis & Saint Paul - POWER RESTORED
Date: Monday, July 20, 2015 8:49:09 AM

Power outage - Minneapolis & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, July 18, 2015 5:26 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:45

Time In : 02:51

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 1375

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : wire burnt down south of [REDACTED] - feeder restored on
[REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington
Date: Monday, July 20, 2015 9:56:47 AM

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:17 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:46

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2700

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington - POWER RESTORED
Date: Tuesday, July 21, 2015 10:13:33 AM

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:04 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:46

Time In : 10:05

Time Zone : CST

Duration : 9 hours, 19 mins

Number of Customers Affected : 2701

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Columbia Heights, Fridley, Hilltop, Minneapolis & New Brighton
Date: Monday, July 20, 2015 9:57:58 AM

Power outage - Columbia Heights, Fridley, Hilltop, Minneapolis & New Brighton.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:24 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 00:49 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1563

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; HILLTOP, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Columbia Heights, Fridley, Hilltop, Minneapolis & New Brighton
Date: Friday, July 24, 2015 8:22:09 AM

Power outage - Columbia Heights, Fridley, Hilltop, Minneapolis & New Brighton – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Friday, July 24, 2015 7:13 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:49

Time In : 12:50

Time Zone : CST

Duration : 12 hours, 1 mins

Number of Customers Affected : 1564

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; HILLTOP, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HAD 655 CUST IN AT 0840 HAD 787 CUST IN AT 0854 ALL IN
AT 1250 

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Arden Hills, New Brighton & Saint Paul
Date: Monday, July 20, 2015 9:15:17 AM

Power outage - Arden Hills, New Brighton & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:41 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:53

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 938

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; SAINT PAUL,

MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees at various locations on the feeder.

Follow-Up : Storm in area.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Arden Hills, New Brighton & Saint Paul - POWER RESTORED
Date: Monday, July 20, 2015 9:16:11 AM

Power outage - Arden Hills, New Brighton & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:43 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:53

Time In : 10:12

Time Zone : CST

Duration : 9 hours, 19 mins

Number of Customers Affected : 938

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees at various locations on the feeder.

Follow-Up : Storm in area. No partial restorations.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul
Date: Monday, July 20, 2015 9:23:14 AM

Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:48 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:54

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1711

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree branch @ [REDACTED].

Follow-Up : Storm in area.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice-7/18/15-Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul-POWER RESTORED
Date: Monday, July 20, 2015 9:24:05 AM

Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:49 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:54

Time In : 07:36

Time Zone : CST

Duration : 6 hours, 42 mins

Number of Customers Affected : 1711


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree branch @ 

Follow-Up : No partial restoration.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - 00:57 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata
Date: Monday, July 20, 2015 10:00:42 AM

Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:36 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 00:57

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1983

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH,
MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice-7/18/15-00:57 Crystal Bay, Excelsior, Mtka Bch, Mound, Navarre, Orono, Spring Pk & Wayzata-POWER RESTORED
Date: Thursday, July 23, 2015 10:02:41 AM

Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:16 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:57

Time In : 09:52

Time Zone : CST

Duration : 8 hours, 55 mins

Number of Customers Affected : 1984

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH,
MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice -- 7/18/15 - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk
Date: Monday, July 20, 2015 9:07:17 AM

Power outage - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Rubedor, Mark W
Sent: Saturday, July 18, 2015 5:20 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 00:58 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 752

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; SAINT PAUL, MN; VADNAIS HEIGHTS,
MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : patrol

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/18/15 - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk - Update
Date: Monday, July 20, 2015 9:08:54 AM

Power outage - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Rubedor, Mark W
Sent: Saturday, July 18, 2015 5:22 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 00:59 Time In : 03:35

Time Zone : CST

Duration : 2 hours, 36 mins

Number of Customers Affected : 752

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; SAINT PAUL, MN; VADNAIS HEIGHTS,
MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk - POWER RESTORED
Date: Monday, July 20, 2015 9:10:54 AM

Power outage - Gem Lake, Saint Paul, Vadnais Heights, White Bear Lake & White Bear Lk – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:40 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 00:58

Time In : 03:35

Time Zone : CST

Duration : 2 hours, 37 mins

Number of Customers Affected : 752

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : GEM LAKE, MN; SAINT PAUL, MN; VADNAIS HEIGHTS,
MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None.

Cause : Trees at multiple locations on feeder.

Follow-Up : Storm in area.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Dellwood, Grant, Hugo, Saint Paul, White Bear Lake & White Bear Lk
Date: Monday, July 20, 2015 9:02:35 AM

Power outage - Dellwood, Grant, Hugo, Saint Paul, White Bear Lake & White Bear Lk.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:34 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 01:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2737


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : DELLWOOD, MN; GRANT, MN; HUGO, MN; SAINT
PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on Feeder @ 

Follow-Up : Storm in area

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Dellwood, Grant, Hugo, Saint Paul, White Bear Lake & White Bear Lk - POWER RESTORED
Date: Monday, July 20, 2015 9:04:40 AM

Power outage - Dellwood, Grant, Hugo, Saint Paul, White Bear Lake & White Bear Lk – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:35 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:05

Time In : 05:55

Time Zone : CST

Duration : 4 hours, 50 mins

Number of Customers Affected : 2737


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : DELLWOOD, MN; GRANT, MN; HUGO, MN; SAINT
PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on Feeder @ 

Follow-Up : No partial restorations.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Deephaven, Excelsior, Greenwood & Shorewood
Date: Monday, July 20, 2015 10:02:56 AM

Power outage - Deephaven, Excelsior, Greenwood & Shorewood.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:48 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:06

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1679

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN;

SHOREWOOD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Deephaven, Excelsior, Greenwood & Shorewood - POWER RESTORED
Date: Thursday, July 23, 2015 9:13:04 AM

Power outage – Deephaven, Excelsior, Greenwood & Shorewood – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:29 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 01:06 Time In : 11:12

Time Zone : CST

Duration : 10 hours, 6 mins

Number of Customers Affected : 1679

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN;
SHOREWOOD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Crystal, Golden Valley & New Hope
Date: Monday, July 20, 2015 10:01:54 AM

Power outage - Crystal, Golden Valley & New Hope.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:47 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:06

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2052

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Crystal, Golden Valley & New Hope - POWER RESTORED
Date: Thursday, July 23, 2015 9:09:48 AM

Power outage – Crystal, Golden Valley & New Hope – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:26 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:06

Time In : 09:05

Time Zone : CST

Duration : 7 hours, 59 mins

Number of Customers Affected : 2052

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : 

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Minnetrista & Mound
Date: Monday, July 20, 2015 10:03:36 AM

Power outage - Minnetrista & Mound.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 5:49 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:07

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1197

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Minnetrista & Mound - POWER RESTORED
Date: Thursday, July 23, 2015 9:17:28 AM

Power outage – Minnetrista & Mound – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:31 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:07

Time In : 11:24

Time Zone : CST

Duration : 10 hours, 17 mins

Number of Customers Affected : 1198

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Golden Valley & Saint Louis Park
Date: Monday, July 20, 2015 10:05:36 AM

Power outage - Golden Valley & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 6:24 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:09

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 497

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Golden Valley & Saint Louis Park - POWER RESTORED
Date: Thursday, July 23, 2015 9:21:18 AM

Power outage – Golden Valley & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:59 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:09

Time In : 16:35

Time Zone : CST

Duration : 15 hours, 26 mins

Number of Customers Affected : 497

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : 315 IN AT 1435 ALL IN AT 1635

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Minnetonka, Plymouth, Wayzata & Woodland
Date: Monday, July 20, 2015 10:06:43 AM

Power outage - Minnetonka, Plymouth, Wayzata & Woodland.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 6:25 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:09

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1274

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN;

WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED
Date: Thursday, July 23, 2015 9:23:49 AM

Power outage – Minnetonka, Plymouth, Wayzata & Woodland – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 11:03 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:09

Time In : 10:59

Time Zone : CST

Duration : 9 hours, 50 mins

Number of Customers Affected : 1272

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN;
WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Eden Prairie, Hopkins & Minnetonka
Date: Monday, July 20, 2015 10:04:44 AM

Power outage - Eden Prairie, Hopkins & Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 6:17 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:08

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2085

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Eden Prairie, Hopkins & Minnetonka - POWER RESTORED
Date: Tuesday, July 21, 2015 10:50:05 AM

Power outage - Eden Prairie, Hopkins & Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 10:34 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 01:08 Time In : 10:15

Time Zone : CST

Duration : 9 hours, 7 mins

Number of Customers Affected : 2084

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Eden Prairie & Minnetonka
Date: Monday, July 20, 2015 10:09:12 AM

Power outage - Eden Prairie & Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 7:23 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:11

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2313

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Eden Prairie & Minnetonka - POWER RESTORED
Date: Thursday, July 23, 2015 9:32:08 AM

Power outage – Eden Prairie & Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 11:30 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:11

Time In : 14:09

Time Zone : CST

Duration : 12 hours, 58 mins

Number of Customers Affected : 2313

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HAD 1460 CUST IN AT 0851 ALL IN AT 1409



Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Edina & Richfield
Date: Monday, July 20, 2015 10:10:15 AM

Power outage – Edina & Richfield.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 7:26 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:12

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 994

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Edina & Richfield - POWER RESTORED
Date: Thursday, July 23, 2015 9:38:54 AM

Power outage – Edina & Richfield – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 11:40 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:11

Time In : 11:44

Time Zone : CST

Duration : 10 hours, 33 mins

Number of Customers Affected : 994

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : 

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Hopkins, Minnetonka & Saint Louis Park
Date: Monday, July 20, 2015 9:37:28 AM

Power outage - Hopkins, Minnetonka & Saint Louis Park - Hopkins, Minnetonka & Saint Louis Park

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:17 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:13

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1332

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Hopkins, Minnetonka & Saint Louis Park -
POWER RESTORED
Date: Tuesday, July 21, 2015 12:02:33 PM

Power outage - Hopkins, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 11:47 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 01:13 Time In : 13:20

Time Zone : CST

Duration : 12 hours, 7 mins

Number of Customers Affected : 1332

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Mayer, Waconia & Watertown - POWER RESTORED
Date: Monday, July 20, 2015 9:30:04 AM

Power outage – Mayer, Waconia & Watertown – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Sunday, July 19, 2015 1:50 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/19/2015

Time Out : 01:15

Time In : 19:55

Time Zone : CST

Duration : 42 hours, 40 mins

Number of Customers Affected : 1454

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD CABLE [REDACTED]

Follow-Up : ISOLATE RESTORE BY FIELD TIES,REFER FOR BIDDLE & REPAIR

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park
Date: Monday, July 20, 2015 9:40:51 AM

Power outage - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:27 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 01:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2046

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

**Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN;
MINNETONKA, MN; SAINT LOUIS PARK, MN**

State : MN - Minnesota

Major Customers : NONE

Cause : STROM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park - POWER RESTORED
Date: Thursday, July 23, 2015 8:07:16 AM

Power outage - Golden Valley, Minneapolis, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 1:31 PM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 01:17 Time In : 11:04

Time Zone : CST

Duration : 9 hours, 47 mins

Number of Customers Affected : 2046

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

**Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN;
MINNETONKA, MN; SAINT LOUIS PARK, MN**

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Hopkins, Minnetonka & Saint Louis Park
Date: Monday, July 20, 2015 9:39:52 AM

Power outage - Hopkins, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:24 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:17

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2372

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers : NONE

Cause : STROM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Hopkins, Minnetonka & Saint Louis Park -
POWER RESTORED
Date: Thursday, July 23, 2015 8:02:11 AM

Power outage - Hopkins, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 1:29 PM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:17

Time In : 10:43

Time Zone : CST

Duration : 9 hours, 26 mins

Number of Customers Affected : 2371

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN; SAINT LOUIS PARK,
MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Edina, Hopkins, Minnetonka & Saint Louis Park
Date: Monday, July 20, 2015 9:39:10 AM

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:20 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:17

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2390


For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT

LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Edina, Hopkins, Minnetonka & Saint Louis Park - POWER RESTORED
Date: Tuesday, July 21, 2015 12:59:54 PM

Power outage - Edina, Hopkins, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, July 21, 2015 12:54 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:17

Time In : 10:40

Time Zone : CST

Duration : 9 hours, 23 mins

Number of Customers Affected : 2391

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNETONKA, MN; SAINT
LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Columbia Heights, Minneapolis, Saint Louis Park & Saint Paul Park
Date: Monday, July 20, 2015 9:44:45 AM

Power outage - Columbia Heights, Minneapolis, Saint Louis Park & Saint Paul Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:32 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 01:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3007

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN; SAINT
LOUIS PARK, MN; SAINT PAUL PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STROM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Columbia Heights, Minneapolis, Saint Louis Park & Saint Paul Park - POWER RESTORED
Date: Thursday, July 23, 2015 8:13:48 AM

Power outage - Columbia Heights, Minneapolis, Saint Louis Park & Saint Paul Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Wednesday, July 22, 2015 6:32 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:19

Time In : 13:47

Time Zone : CST

Duration : 12 hours, 28 mins

Number of Customers Affected : 3008

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN; SAINT
LOUIS PARK, MN; SAINT PAUL PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HAD 217 IN AT 0814 ALL IN AT 1347



Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Edina, Minneapolis & Saint Louis Park
Date: Monday, July 20, 2015 9:46:31 AM

Power outage - Edina, Minneapolis & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:35 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:20

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2811

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STROM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Edina, Minneapolis & Saint Louis Park - POWER RESTORED
Date: Thursday, July 23, 2015 8:18:45 AM

Power outage - Edina, Minneapolis & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Wednesday, July 22, 2015 6:37 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In : 7/18/2015

Time Out : 01:20 Time In : 09:27

Time Zone : CST

Duration : 8 hours, 7 mins

Number of Customers Affected : 2813

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Edina
Date: Monday, July 20, 2015 9:47:06 AM

Power outage – Edina.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:37 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:22

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2054

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STROM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Edina - POWER RESTORED
Date: Thursday, July 23, 2015 8:20:56 AM

Power outage – Edina – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Wednesday, July 22, 2015 6:42 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:22

Time In : 09:57

Time Zone : CST

Duration : 8 hours, 35 mins

Number of Customers Affected : 2053

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Bloomington, Edina & Minneapolis
Date: Monday, July 20, 2015 9:47:50 AM

Power outage - Bloomington, Edina & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 3:38 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:23

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 769

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Bloomington, Edina & Minneapolis - POWER RESTORED
Date: Thursday, July 23, 2015 8:25:28 AM

Power outage - Bloomington, Edina & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Wednesday, July 22, 2015 6:51 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:23

Time In : 10:37

Time Zone : CST

Duration : 9 hours, 14 mins

Number of Customers Affected : 769

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Red Wing
Date: Monday, July 20, 2015 8:41:40 AM

Power outage - Red Wing.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Saturday, July 18, 2015 1:31 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:25

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 999

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : thunderstorm in area

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Red Wing - POWER RESTORED
Date: Monday, July 20, 2015 8:42:46 AM

Power outage - Red Wing – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Saturday, July 18, 2015 4:07 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:25

Time In : 03:50

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 999

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers :

Cause : Tree down by 

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Edina, Minneapolis & Saint Louis Park
Date: Monday, July 20, 2015 9:50:28 AM

Power outage - Edina, Minneapolis & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 4:10 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:26

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1287

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Edina, Minneapolis & Saint Louis Park - POWER RESTORED
Date: Thursday, July 23, 2015 9:56:59 AM

Power outage - Edina, Minneapolis & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Wednesday, July 22, 2015 7:07 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:26

Time In : 11:47

Time Zone : CST

Duration : 10 hours, 21 mins

Number of Customers Affected : 1285

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : STORM

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Saint Paul
Date: Monday, July 20, 2015 8:50:04 AM

Power outage - Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 3:10 PM
To: Abbott, Edward J; Abbott, Jennifer; Ahmedic, Emir; Ainscough, John P; Amundson, Brian D; Andrews, Arlie A; Asmussen, Michael J; Auth, Edward T; Bagley, Shawn D; Beach, Neil B; Beaulieu, Erich; Bellinghausen, Alan L; Bennett, Gregory G; Benson, Aaron B; Berger, Alicia E; Berklund, David J; Berzins, John U; Bickford, Timothy J; Bigge, Brian N; Billett, David L; Blaschka, Luke N; Bloch, Kelly A; Bocovich, Michael; Bodine, Eric M; Boland, Mike; Borgerson, Jenny L; Borglum, Cynthia M; Brandes, Steven J; Browen, Troy A; Byron, Jeff; Carney, Brian J; Cascalenda, Thomas J; Chial, Terry L; Clarke, Gregg P; Cline, Patrick V; Conrad, Christopher W; Coppock, Betsy; Corrigan, Barbara J; Cottrell, Dana; Crosby, Larry R; Cummings, Bethlyn K; Custer, Jeffrey O; Dalton, Patrick L; Dammel, Andrew G; DeFeyter, Shane M; Dice, Mitchell J; Dickey, Kevin C; Dickey, Ryan P; dl CIC Advisors; dl CIC All; dl Customer Advocate Team; dl Customer Care Communications; dl Sales BSC WI; dl SC MCT Emergency Response; dl STED MN SPE; dl System Protection Engineering-NSP; dl Vegetation Mgmt-MN-ND-SD-WI; Dogubo, Oyekan K; Donelan, John R; Drill, Lisa A; Duellman, Lance R; Edwards, Michelle S; Elden, Thomas L; Fedor, Debra J; Fedor, Vincent; Felcyn, Thomas M; Figueroa Valeyre, Carlos D; Foss, Stephen R; Gamble, Alyson A; Ganz, Steven P; Garrels, Michael A; Grasso, Kenneth F; Grimm, John N; Gubash Jr, Joseph M; Guck, Timothy J; Guenther, Larry T; Gunderzik, Michael R; Gustafson, Barry F; Hansen, William L; Hargreaves, Roger D; Harmon, Todd A; Harvey, Brian D; Hawkins, Ronald L; Hayes, Brian J; Heidorn-Anderson, Garrett W; Henke, Brian M; Hillestad, Paul; Hinde, Scott A; Hinz, Jeremy T; Hoen, Thomas M; Horejsi, David M; Horsman, Jason W; Hui, Ming-Wa; Huynh, Thanh; Impola, Morgan B; Jerhoff, Barb; Jerhoff, Patrick D; Joe, Albert G; Johnson, David G; Johnson, Roxanne M; Johnson, William D; Joseph, Jennifer R; Jurek, Colette C; Juvland, Harlan K; Karolevitz, Paul W; Karp, Heather M; Kelm, Brent A; Kiemele, Cory F; King, Ian M; Kinne, Charles P; Klemz, Keith R; Kluver, Holly A; Kogler Sr, Christian J; Kosak, Jeffery P; Koski, Steven; Kraemer, Michael A; Kreidler, Romyana T; Kurtz, Scott; LaCasse, Joseph S; Lakkaraju, Talpasai; Larson, Justin J; Lee, John D; Limoges, Joel H; Long, Brian D; Lorentz, Brian R; Lucas, Lisa; Lysaker, Daniel D; Madigan, David A; Marinac, Kim J; Marshall, John I; McCollum, Michael L; Meagher, Justin R; Miller, Jake I; Molde, Robert E; Monson, Brian T; Monteith, Curtis G; Mulawarman, Adi; Nash, James M; Naswood, Evangelita; Nordell, Daniel E; NSP MN Feeder Alerts; Nystuen, Patti J; Oberle, Luke E; Olsen, David S; Olsen, Ryan J; Palmer, Kyle G; Petersen, Kennon; Pfothenauer, John F; Pinewski, David A; Punt, Chris J; Rauckman, William J; Reyzer, Adam J; Richert, Samuel L; Ries, Patrick R; Ring, Judy L; Rollin, Steven P; Rubedor, Mark W; Sandok, Mary R; Santori, Mary S; Sarkinen, Todd K; Scharmer, Ward M; Schire, Lorraine B; Schuh, Steven J; Sedlacek, Jake; Shannon, Edmund G; Shapiro, Ami M; Sipple, Karl A; Snow, Wayne C; Snyder, Scott W; Spaulding, Philip J; Srock, Alan E; Stewart, Christopher D; Storrar, Scott R; Streine, Richard P; Sutliff,

Erik M; Sylliaasen, Brad L; Szykalski, David C; TARIFF1; Tegg, Barry C; Terrell, Sara A; Thompson, Jeremy J; Tiemeier, Mark A; Tisdell, Meghan E; Urban, Alan M; Vance, Matthew A; Verhulst, Ryan J; Virant, Tim J; Visser, Brent A; Walker, Sean D; Waltz, Jean A; Wilson, Robert G; Wishard, Anthony J; Wolf, Terry K; Wood, Jennifer; Wood, Michelle (MN Trans Eng) A; Yalew, Tirsit; Yohn, Thomas J; Zenner, Michael A; Zima, Scott B

Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015 Date In :

Time Out : 01:28 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1466

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Tree on feeder @ [REDACTED].

Follow-Up : Storm in area.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Saint Paul - POWER RESTORED
Date: Monday, July 20, 2015 8:51:30 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 3:11 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:28

Time In : 08:02

Time Zone : CST

Duration : 6 hours, 34 mins

Number of Customers Affected : 1466


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder @ 

Follow-Up : No partial restorations.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Saint Paul
Date: Monday, July 20, 2015 8:52:11 AM

Power outage - Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:28 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 01:29

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3569

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None.

Cause : Broken Pole @ [REDACTED]

Wire down @ [REDACTED]

Follow-Up : Storm in area.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Saint Paul - POWER RESTORED
Date: Monday, July 20, 2015 8:52:44 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: LaCasse, Joseph S
Sent: Saturday, July 18, 2015 2:32 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 01:29

Time In : 10:21

Time Zone : CST

Duration : 8 hours, 52 mins

Number of Customers Affected : 3569

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Broken Pole @ [REDACTED]

Wire Down @ [REDACTED]

Follow-Up : Partial restore - 3203 @ 06:17. Remaining 366 customers
restored @ 10:21

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Minnetonka
Date: Monday, July 20, 2015 10:12:27 AM

Power outage – Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Saturday, July 18, 2015 7:29 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 06:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2681

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : OPEN TO CLEAR LIVE WIRE DOWN.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15 - Minnetonka
Date: Friday, July 24, 2015 9:16:03 AM

Power outage – Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Friday, July 24, 2015 8:31 AM
To: Karolevitz, Paul W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 06:45

Time In : 11:07

Time Zone : CST

Duration : 4 hours, 22 mins

Number of Customers Affected : 2676

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : storm

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/18/15 - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata
Date: Monday, July 20, 2015 8:56:34 AM

Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 7:07 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In :

Time Out : 18:33

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1984

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH,
MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/18/15- Crystal Bay, Excelsior, Mtka Bch, Mound, Navarre, Orono, Spring Pk & Wayzata-POWER RESTORED
Date: Monday, July 20, 2015 8:57:19 AM

Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Saturday, July 18, 2015 8:35 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/18/2015

Date In : 7/18/2015

Time Out : 18:33

Time In : 20:29

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 1984

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH,
MN; MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER AT [REDACTED] REMOVED TREE

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/21/15 - Saint Paul
Date: Tuesday, July 21, 2015 8:16:30 AM

Power outage - Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, July 21, 2015 1:07 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/21/2015

Date In :

Time Out : 00:48

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1455

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up : TROUBLE IN ROUTE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/21/15 - Saint Paul - UPDATE
Date: Tuesday, July 21, 2015 8:17:06 AM

Power outage - Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, July 21, 2015 1:45 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/21/2015

Date In :

Time Out : 00:48

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up : BIDDLE RPER [REDACTED]

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/21/15 - Saint Paul - POWER RESTORED
Date: Tuesday, July 21, 2015 8:17:47 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, July 21, 2015 2:02 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/21/2015

Date In : 7/21/2015

Time Out : 00:48

Time In : 01:52

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1455

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NA

Cause : CABLE FAULT

Follow-Up : BIDDLE REPR

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/24/15 - Brooklyn Center & Minneapolis
Date: Friday, July 24, 2015 8:18:13 AM

Power outage - Brooklyn Center & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Friday, July 24, 2015 2:51 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/24/2015

Date In :

Time Out : 02:39

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1187

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER TROUBLEMAN IS ON THE WAY

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/24/15 - Brooklyn Center & Minneapolis - POWER RESTORED
Date: Friday, July 24, 2015 8:18:55 AM

Power outage - Brooklyn Center & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Friday, July 24, 2015 4:21 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/24/2015

Date In : 7/24/2015

Time Out : 02:39

Time In : 04:16

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 1187

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

**Cause : NOTHING FOUND ON THE PATROL. LOTS OF LIGHTNING. ALL
SHOULD BE BACK ON.**

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/24/15 - Farmington - POWER RESTORED
Date: Friday, July 24, 2015 10:17:20 AM

Power outage – Farmington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Friday, July 24, 2015 10:12 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/24/2015

Date In : 7/24/2015

Time Out : 07:33

Time In : 09:56

Time Zone : CST

Duration : 2 hours, 23 mins

Number of Customers Affected : 922

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : top of pole burnt off at [REDACTED] - crew made
repairs

Follow-Up : 446 custs restored @ 08:06 the remaining 476 custs restored
@ 09:56

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/24/15 - Farmington
Date: Friday, July 24, 2015 8:27:11 AM

Power outage – Farmington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Friday, July 24, 2015 7:47 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/24/2015

Date In :

Time Out : 07:33

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 922

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : top of pole burnt off at [REDACTED] - trbl onsite

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/27/15 - Golden Valley
Date: Monday, July 27, 2015 9:09:59 AM

Power outage – Golden Valley.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Monday, July 27, 2015 9:03 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/27/2015

Date In :

Time Out : 09:00

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 644

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : Trbl on the way

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/27/15 - Golden Valley - POWER RESTORED
Date: Monday, July 27, 2015 10:26:40 AM

Power outage – Golden Valley – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Knutson, David A
Sent: Monday, July 27, 2015 10:11 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/27/2015

Date In : 7/27/2015

Time Out : 09:00

Time In : 10:02

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 644

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN

State : MN - Minnesota

Major Customers : 

Cause : Nothing found on the patrol. Energized feeder and all should be
back on

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/28/15 - Minneapolis & Saint Paul
Date: Tuesday, July 28, 2015 9:17:25 AM

Power outage – Minneapolis & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Tuesday, July 28, 2015 9:13 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/28/2015

Date In :

Time Out : 9:05

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1374

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : XXX

Cause : UNKNOWN

Follow-Up : EN-ROUTE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 7/28/15 - Minneapolis & Saint Paul - UPDATE
Date: Tuesday, July 28, 2015 9:38:14 AM

Power outage – Minneapolis & Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Tuesday, July 28, 2015 9:33 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/28/2015

Date In :

Time Out : 09:05

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1374

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : ■

Cause : UNKNOWN

Follow-Up : OPENED ■ SWITCH-PATROLING

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 7/28/15 - Minneapolis & Saint Paul - POWER RESTORED
Date: Tuesday, July 28, 2015 11:10:49 AM

Power outage – Minneapolis & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Tuesday, July 28, 2015 10:30 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/28/2015

Date In : 7/28/2015

Time Out : 09:05

Time In : 10:24

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1374

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : FIRST PIECE OF CABLE

Follow-Up : CLOSED MPK [REDACTED] MPK [REDACTED] @ 10:24

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 7/28/15 - Crystal, Minneapolis & New Hope
Date: Wednesday, July 29, 2015 7:51:41 AM

Power outage - Crystal, Minneapolis & New Hope.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Tuesday, July 28, 2015 8:25 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/28/2015

Date In :

Time Out : 19:25

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 806


For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : non

Cause : A/ phase jumper burned open on 

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 7/28/15 - Crystal, Minneapolis & New Hope - POWER RESTORED
Date: Wednesday, July 29, 2015 7:52:29 AM

Power outage - Crystal, Minneapolis & New Hope – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Tuesday, July 28, 2015 9:03 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 7/28/2015

Date In : 7/28/2015

Time Out : 19:25

Time In : 20:52

Time Zone : CST

Duration : 1 hours, 27 mins

Number of Customers Affected : 806


For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : non

Cause : A/ Phase jumper burned open on 

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/1/15 - Saint Paul
Date: Monday, August 03, 2015 8:58:26 AM

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 01, 2015 1:19 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/1/2015

Date In :

Time Out : 01:04

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2230

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : patrol feeder

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/1/15 - Saint Paul - POWER RESTORED
Date: Monday, August 03, 2015 8:59:04 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 01, 2015 2:19 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/1/2015

Date In : 8/1/2015

Time Out : 01:04

Time In : 02:11

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 2230

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : ARRESTER

Follow-Up : arrester @ [REDACTED] A PATROL - TAKE ARRESTER OFF
LINE AND REFER TO REPLACE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/2/15 - Falcon Heights, Maplewood & Saint Paul
Date: Monday, August 03, 2015 9:04:47 AM

Power outage - Falcon Heights, Maplewood & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Sunday, August 02, 2015 3:18 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/2/2015

Date In :

Time Out : 03:08

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2380

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT PAUL,

MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : patrolling

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/2/15 - Falcon Heights, Maplewood & Saint Paul -
POWER RESTORED
Date: Monday, August 03, 2015 9:06:26 AM

Power outage - Falcon Heights, Maplewood & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Sunday, August 02, 2015 8:13 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/2/2015

Date In : 8/2/2015

Time Out : 03:58

Time In : 05:48

Time Zone : CST

Duration : 1 hours, 50 mins

Number of Customers Affected : 4443


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : no

Cause : car hit pole 

Follow-Up : crew was called in to make perm repairs

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Momentary Outage - 8/2/15 - Maplewood & Saint Paul
Date: Monday, August 03, 2015 9:05:45 AM

Power outage - Maplewood & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Sunday, August 02, 2015 4:31 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Momentary Outage

Distribution System Status Outage Notification

[REDACTED] Momentary Outage

Feeder/Bus : [REDACTED]

Date Out : 8/2/2015

Date In :

Time Out : 04:08

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2064

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : broken pole

Follow-Up : xxx

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/2/15 - Falcon Heights, Maplewood & Saint Paul -
POWER RESTORED
Date: Monday, August 03, 2015 9:06:26 AM

Power outage - Falcon Heights, Maplewood & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Sunday, August 02, 2015 8:13 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/2/2015

Date In : 8/2/2015

Time Out : 03:58

Time In : 05:48

Time Zone : CST

Duration : 1 hours, 50 mins

Number of Customers Affected : 4443


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN; SAINT PAUL,
MN

State : MN - Minnesota

Major Customers : no

Cause : car hit pole 

Follow-Up : crew was called in to make perm repairs

From: [Rubedor, Mark W](#)
To: [Jaede, Wendy L](#)
Subject: [REDACTED] First Outage Notice - QUESTION FOR YOU....
Date: Monday, August 03, 2015 1:44:19 PM

Yes the 1st notification was a typo it should have read [REDACTED]

From: Jaede, Wendy L
Sent: Monday, August 03, 2015 9:16 AM
To: Rubedor, Mark W
Subject: FW: [REDACTED] First Outage Notice - QUESTION FOR YOU....
Importance: High

Hi Mark:

Just have a question for you.....

Listed below is a outage notification for [REDACTED]. I also received individual notifications for [REDACTED] and then final notifications for [REDACTED]. Is the first notification a typo – DBL [REDACTED] [REDACTED] since I never received a final for [REDACTED]?

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Monday, August 03, 2015 12:37 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/3/2015

Date In :

Time Out : 00:19

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1461

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : ■

Cause : unknown

Follow-Up : patrolling

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - Saint Paul - POWER RESTORED
Date: Monday, August 03, 2015 9:10:16 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Monday, August 03, 2015 1:24 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/3/2015

Date In : 8/3/2015

Time Out : 00:19

Time In : 01:19

Time Zone : CST

Duration : 1 hours, 0 mins


Number of Customers Affected : 1455

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : ARRESTERS FAILED IN 

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/4/15 - Brooklyn Center & Minneapolis
Date: Tuesday, August 04, 2015 11:15:17 AM

Power outage - Brooklyn Center & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, August 04, 2015 8:54 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/4/2015

Date In :

Time Out : 08:47

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2363

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/4/15 - Brooklyn Center & Minneapolis - POWER RESTORED
Date: Tuesday, August 04, 2015 11:17:26 AM

Power outage - Brooklyn Center & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cuno, Dean M
Sent: Tuesday, August 04, 2015 10:35 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/4/2015

Date In : 8/4/2015

Time Out : 08:47

Time In : 10:02

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 3450

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] HIT HEAD END CABLE ON BOTH
[REDACTED] AND [REDACTED] WITH BORING RIG

Follow-Up : INFORMATION WAS OBTAINED AFTER FINAL NOTICE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/4/15 - Brooklyn Center & Minneapolis
Date: Tuesday, August 04, 2015 11:15:52 AM

Power outage - Brooklyn Center & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Tuesday, August 04, 2015 8:56 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/4/2015

Date In :

Time Out : 08:47

Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 1087

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/4/15 - Brooklyn Center & Minneapolis - POWER RESTORED
Date: Tuesday, August 04, 2015 11:16:45 AM

Power outage - Brooklyn Center & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cuno, Dean M
Sent: Tuesday, August 04, 2015 10:19 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/4/2015

Date In : 8/4/2015

Time Out : 08:47

Time In : 10:02

Time Zone : CST

Duration : 1 hours, 15 mins


Number of Customers Affected : 1087

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : 

Cause : HEAD END CABLE FAULT

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - Power Outage 8/9/2015
Date: Monday, August 10, 2015 7:57:12 AM

Power Outage – 8/9/2015 BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN; HAMEL, MN; INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN; ROCKFORD, MN

From: Cedar, Daren A
Sent: Sunday, August 09, 2015 4:24 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/9/2015 Date In :

Time Out : 04:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1813

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN;
HAMEL, MN; INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN;
ROCKFORD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMSSION EVENT

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice 8/9/215 Update
Date: Monday, August 10, 2015 7:58:01 AM

Outage Update - BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN; HAMEL, MN;
INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN; ROCKFORD, MN

From: Cedar, Daren A
Sent: Sunday, August 09, 2015 5:19 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/9/2015 Date In :

Time Out : 04:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1813

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN;
HAMEL, MN; INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN;
ROCKFORD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMSSSION EVENT REPORTS ARE CAR HIT POLE AT [REDACTED]
[REDACTED] TROUBLE IN ROUTE AND OPERATOR

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice POWER RESTORED 8/9/2015
Date: Monday, August 10, 2015 7:58:49 AM

Power Restored - BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN; HAMEL, MN;
INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN; ROCKFORD, MN

From: Hills, Thomas L
Sent: Sunday, August 09, 2015 6:12 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/9/2015

Date In : 8/9/2015

Time Out : 04:03

Time In : 05:59

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 1813

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BUFFALO, MN; CORCORAN, MN; GREENFIELD, MN;
HAMEL, MN; INDEPENDENCE, MN; LORETTO, MN; MAPLE PLAIN, MN; MEDINA, MN;
ROCKFORD, MN

State : MN - Minnesota

Major Customers : None

Cause : Car hit pole.

Follow-Up : All restored

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/12/15 - Brooklyn Center
Date: Wednesday, August 12, 2015 2:58:45 PM

Power outage – Brooklyn Center.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Wednesday, August 12, 2015 2:39 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/12/2015

Date In :

Time Out : 14:22

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1490

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Follow-Up : troubleman en route, carrying portion of [REDACTED]

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/12/15 - Brooklyn Center - POWER RESTORED
Date: Thursday, August 13, 2015 7:37:11 AM

Power outage - Brooklyn Center – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, August 12, 2015 3:40 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/12/2015

Date In : 8/12/2015

Time Out : 14:22

Time In : 15:26

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1490

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Failed cable [REDACTED] to [REDACTED]

Follow-Up : 1222 restored at 1525, 267 restored at 1526, 1 at 1523.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/12/15 - Minneapolis
Date: Thursday, August 13, 2015 7:38:03 AM

Power outage – Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Kenneth W
Sent: Wednesday, August 12, 2015 8:36 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/12/2015

Date In :

Time Out : 20:33

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3377

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 8/12/15 - Minneapolis - UPDATE
Date: Thursday, August 13, 2015 7:38:48 AM

Power outage – Minneapolis – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, August 12, 2015 9:27 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/12/2015

Date In :

Time Out : 20:33

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3377

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed head end cable

Follow-Up : Working to isolate and restore.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/12/15 - Minneapolis - POWER RESTORED
Date: Thursday, August 13, 2015 7:39:32 AM

Power outage – Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, August 12, 2015 9:50 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/12/2015

Date In : 8/12/2015

Time Out : 20:33

Time In : 21:41

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 3377

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed head end cable

Follow-Up : 2224 customers restored at 2129, 1153 at 2141.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/14/15 - Plymouth
Date: Monday, August 17, 2015 8:06:52 AM

Power outage - Plymouth.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Friday, August 14, 2015 10:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/14/2015

Date In :

Time Out : 22:47

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1630

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/15/15 - Plymouth - POWER RESTORED
Date: Monday, August 17, 2015 8:07:31 AM

Power outage - Plymouth – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Saturday, August 15, 2015 12:07 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/15/2015

Date In : 8/15/2015

Time Out : 22:47

Time In : 23:55

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 1630

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed head end cable.

Follow-Up : 561 customers restored at 2344 and 1069 at 2355.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/16/16 - Oak Park Heights & Stillwater
Date: Monday, August 17, 2015 8:24:48 AM

Power outage - Oak Park Heights & Stillwater.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, August 16, 2015 7:49 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/16/2015

Date In :

Time Out : 07:34

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 625

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/16/15 - Oak Park Heights & Stillwater - POWER RESTORED
Date: Monday, August 17, 2015 8:25:29 AM

Power outage - Oak Park Heights & Stillwater – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, August 16, 2015 9:01 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/16/2015

Date In : 8/16/2015

Time Out : 07:34

Time In : 08:42

Time Zone : CST

Duration : 1 hours, 8 mins


Number of Customers Affected : 625

For information about this alert, contact :


For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : fault indicators did not work right have new ones installed at


From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/16/15 - Apple Valley, Farmington, Lakeville & Rosemount
Date: Monday, August 17, 2015 8:26:46 AM

Power outage - Apple Valley, Farmington, Lakeville & Rosemount.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Sunday, August 16, 2015 11:11 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/16/2015

Date In :

Time Out : 22:42

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4013

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : APPLE VALLEY, MN; FARMINGTON, MN; LAKEVILLE,

MN; ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : patrol

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 8/17/15 -Apple Valley, Farmington, Lakeville & Rosemount - UPDATE
Date: Monday, August 17, 2015 8:27:22 AM

Power outage - Apple Valley, Farmington, Lakeville & Rosemount – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Monday, August 17, 2015 1:30 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/17/2015 Date In :

Time Out : 22:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4013

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : APPLE VALLEY, MN; FARMINGTON, MN; LAKEVILLE,
MN; ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : 

Cause : wire down

Follow-Up : crew on site

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 8/16/15 - Apple Valley, Farmington, Lakeville & Rosemount - UPDATE
Date: Monday, August 17, 2015 8:28:01 AM

Power outage - Apple Valley, Farmington, Lakeville & Rosemount – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Monday, August 17, 2015 2:07 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 8/16/2015 Date In :

Time Out : 22:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 4013

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : APPLE VALLEY, MN; FARMINGTON, MN; LAKEVILLE,
MN; ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : 

Cause : phase down

Follow-Up : crew in the process of putting wire back up

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/16/15 - Apple Valley, Farmington, Lakeville & Rosemount
- POWER RESTORED
Date: Monday, August 17, 2015 8:28:37 AM

Power outage - Apple Valley, Farmington, Lakeville & Rosemount – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Monday, August 17, 2015 4:51 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/16/2015

Date In : 8/17/2015

Time Out : 22:42

Time In : 04:42

Time Zone : CST

Duration : 6 hours, 0 mins

Number of Customers Affected : 4013

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : APPLE VALLEY, MN; FARMINGTON, MN; LAKEVILLE,
MN; ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : 

Cause : auto sleeve

Follow-Up : CREW PUT PHASE BACK UP BTN 8/17/15 @ 0442

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/18/15 - Oak Park Heights & Stillwater
Date: Tuesday, August 18, 2015 8:16:42 AM

Power outage - Oak Park Heights & Stillwater.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, August 18, 2015 4:30 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/18/2015

Date In :

Time Out : 04:18

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2132

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : na

Cause : tree on wires

Follow-Up : trouble in route

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/18/15 - Oak Park Heights & Stillwater - POWER RESTORED
Date: Tuesday, August 18, 2015 8:17:41 AM

Power outage - Oak Park Heights & Stillwater – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Tuesday, August 18, 2015 5:24 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/18/2015

Date In : 8/18/2015

Time Out : 04:18

Time In : 05:20

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 2132

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : OAK PARK HEIGHTS, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : na

Cause : tree on wires

Follow-Up : tre crew to trim

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/18/15 - Golden Valley, Minnetonka & Saint Louis Park
Date: Tuesday, August 18, 2015 10:22:47 AM

Power outage - Golden Valley, Minnetonka & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Tuesday, August 18, 2015 9:38 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/18/2015

Date In :

Time Out : 09:31

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1074

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS

PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/18/15 - Golden Valley, Minnetonka & Saint Louis Park - POWER RESTORED
Date: Tuesday, August 18, 2015 10:50:35 AM

Power outage - Golden Valley, Minnetonka & Saint Louis Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Tuesday, August 18, 2015 10:39 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/18/2015

Date In : 8/18/2015

Time Out : 09:30

Time In : 10:35

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 1074

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNETONKA, MN; SAINT LOUIS
PARK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : CABLE DIG IN BETWEEN [REDACTED] TO [REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Saint Paul & White Bear Lake & White Bear Lk
Date: Monday, August 24, 2015 8:29:59 AM

Power outage - Saint Paul & White Bear Lake & White Bear Lk.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 12:05 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] E First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 11:53

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1550

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR

LK, MN

State : MN - Minnesota

Major Customers : 

Cause : per fire dept tree

Follow-Up : trb in route

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 8/22/15 - Saint Paul & White Bear Lake & White Bear Lk }
POWER RESTORED
Date: Monday, August 24, 2015 8:30:52 AM

Power outage - Saint Paul & White Bear Lake & White Bear Lk – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 1:28 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 11:53

Time In : 13:15

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 55

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR
LK, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : TREE

Follow-Up : OPENED [REDACTED] & [REDACTED] CLOSED [REDACTED] PICKED
UP 85% OF CUSTOMERS

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Saint Paul & White Bear Lake & White Bear Lk - POWER RESTORED/UPDATE
Date: Monday, August 24, 2015 8:31:44 AM

Power outage - Saint Paul & White Bear Lake & White Bear Lk – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 4:55 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 11:53

Time In : 16:07

Time Zone : CST

Duration : 4 hours, 14 mins

Number of Customers Affected : 1550

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR
LK, MN

State : MN - Minnesota

Major Customers : 

Cause : TREE IN PRI

Follow-Up : TRIMMED IN CLEAR

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Minneapolis & Saint Paul
Date: Monday, August 24, 2015 8:34:18 AM

Power outage - Minneapolis & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 12:34 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 12:26

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1381

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up : TECH ON THE WAY

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Minneapolis & Saint Paul - POWER RESTORED
Date: Monday, August 24, 2015 8:34:58 AM

Power outage - Minneapolis & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 2:06 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 12:26

Time In : 13:55

Time Zone : CST

Duration : 1 hours, 29 mins

Number of Customers Affected : 1381

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : 

Cause : TREE 

Follow-Up : BTN

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Becker, Big Lake & Monticello
Date: Monday, August 24, 2015 8:37:01 AM

Power outage - Becker, Big Lake & Monticello.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Saturday, August 22, 2015 2:46 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 14:26

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 885

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BECKER, MN; BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : NON RTU SUB / Reports of wire down on feeder @ [REDACTED]

[REDACTED] - Crew enroute

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Becker, Big Lake & Monticello - POWER RESTORED
Date: Monday, August 24, 2015 8:39:17 AM

Power outage - Becker, Big Lake & Monticello – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Saturday, August 22, 2015 3:55 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 14:26

Time In : 15:50

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 885

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BECKER, MN; BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Outage caused by branch of elm tree falling through feeder [REDACTED]

[REDACTED]
Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Cottage Grove & Hastings
Date: Monday, August 24, 2015 9:11:21 AM

Power outage - Cottage Grove & Hastings.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 4:03 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 14:59

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1103

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : 

Cause : CAR HIT POLE IN THE PARKING LOT OF 

Follow-Up : CREW IN ON THE WAY TO GET POLE OFF GROUND

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Cottage Grove & Hastings - POWER RESTORED
Date: Monday, August 24, 2015 9:12:06 AM

Power outage - Cottage Grove & Hastings – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Saturday, August 22, 2015 5:19 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 14:59

Time In : 17:15

Time Zone : CST

Duration : 2 hours, 16 mins

Number of Customers Affected : 1103

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN; HASTINGS, MN

State : MN - Minnesota

Major Customers : 

Cause : CAR HIT POLE

Follow-Up :  HOLDING POLE OFF GRD TO RE ENERGIZE FEEDER

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Little Canada, Maplewood, Saint Paul & Vadnais Heights
Date: Monday, August 24, 2015 9:16:46 AM

Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, August 22, 2015 9:04 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 20:53

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2040

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL,
MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up : trbl dispatched

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 8/22/15 - Little Canada, Maplewood, Saint Paul & Vadnais Heights - POWER RESTORED
Date: Monday, August 24, 2015 9:17:31 AM

Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, August 22, 2015 9:57 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/22/2015

Time Out : 20:53

Time In : 21:45

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 2040

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL,
MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up : picked up 287 cust - fdr hot up to [REDACTED]=trl still patrolling

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 8/22/15 - Little Canada, Maplewood, Saint Paul & Vadnais Heights - POWER RESTORED/UPDATE
Date: Monday, August 24, 2015 9:18:55 AM

Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Saturday, August 22, 2015 11:59 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 8/22/2015 Date In : 8/22/2015

Time Out : 20:53 Time In : 23:21

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 2040

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL,
MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : tree on fdr @ [REDACTED] - tree crew clearing tree

Follow-Up : all but 69 cust back on at 23:21

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Little Canada, Maplewood, Saint Paul & Vadnais Heights - POWER RESTORED/FINAL/UPDATE
Date: Monday, August 24, 2015 9:21:20 AM

Power outage - Little Canada, Maplewood, Saint Paul & Vadnais Heights – power restored/final/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Streine, Richard P
Sent: Sunday, August 23, 2015 2:47 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/23/2015

Time Out : 20:53

Time In : 02:40

Time Zone : CST

Duration : 5 hours, 47 mins

Number of Customers Affected : 2040

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL,
MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : tree on fdr @ [REDACTED] -tree crew cleared tree and
const crew replaced brkn x-arm

Follow-Up : remaining 69 cust back on @ 02:40

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/22/15 - Cannon Falls & Pipestone
Date: Monday, August 24, 2015 9:22:54 AM

Power outage - Cannon Falls & Pipestone.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Sunday, August 23, 2015 12:03 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In :

Time Out : 21:52

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1280

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CANNON FALLS, MN; PIPESTONE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : [REDACTED] FDR BREAKER OPEN AND 2 69KV FUSES ON [REDACTED]
WERE BLOWN. NON RTU'D SUBSTATION

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/22/15 - Cannon Falls & Pipestone - POWER RESTORED
Date: Monday, August 24, 2015 9:23:36 AM

Power outage - Cannon Falls & Pipestone – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Sunday, August 23, 2015 1:18 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/22/2015

Date In : 8/23/2015

Time Out : 21:52

Time In : 01:12

Time Zone : CST

Duration : 3 hours, 20 mins

Number of Customers Affected : 1280

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CANNON FALLS, MN; PIPESTONE, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : TREE ON LINE CAUSE [REDACTED] TO OPEN BUT [REDACTED] DID NOT
CAUSING C PHASE 69KV FUSE TO BLOW ON [REDACTED]

Follow-Up : CREW CLEARED UP TREE AND RE-ENERGIZED.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/23/15 - Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs & White Bear Lake
Date: Monday, August 24, 2015 9:35:05 AM

Power outage - Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs & White Bear Lake.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Sunday, August 23, 2015 8:21 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/23/2015

Date In :

Time Out : 08:02

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2038

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAHTOMEDI, MN; MAPLEWOOD,
MN; OAKDALE, MN; PINE SPRINGS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up : trbl to patrol feeder

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/23/15 - Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs & White Bear Lake - POWER RESTORED
Date: Monday, August 24, 2015 9:35:51 AM

Power outage - Lake Elmo, Mahtomedi, Maplewood, Oakdale, Pine Springs & White Bear Lake – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Sunday, August 23, 2015 9:27 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/23/2015

Date In : 8/23/2015

Time Out : 08:02

Time In : 09:18

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 2038

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; MAHTOMEDI, MN; MAPLEWOOD,
MN; OAKDALE, MN; PINE SPRINGS, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : limb + blown lgt arrester B,C PHASE AT [REDACTED]

Follow-Up : CLEARED LIMB + ARRESTER OFF LINE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 8/28/15 - Various Communities
Date: Friday, August 28, 2015 8:00:25 AM

Power outage - Belview, Cottonwood, Echo, Granite Falls, Hanley Falls, Hazel Run, Wood Lake & Woodlake.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Friday, August 28, 2015 2:17 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/28/2015 Date In :

Time Out : 00:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1329

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BELVIEW, MN; COTTONWOOD, MN; ECHO, MN;
GRANITE FALLS, MN; HANLEY FALLS, MN; HAZEL RUN, MN; WOOD LAKE, MN;
WOODLAKE, MN

State : MN - Minnesota

Major Customers : NA

Cause : NON RTU SUB / Operator found high side transformer fuse
blown in sub.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 8/28/15 - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - POWER RESTORED
Date: Friday, August 28, 2015 8:02:09 AM

Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Friday, August 28, 2015 2:40 AM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 8/28/2015

Date In : 8/28/2015

Time Out : 00:29

Time In : 02:12

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 852

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY
FALLS, MN; HAZEL RUN, MN

State : MN - Minnesota

Major Customers : NA

Cause : Operator found A phase transformer high side fuse blown in
SUB. Refused and reenergized feeder @ 0212.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/1/15 - Lake Elmo, Oakdale & Woodbury
Date: Tuesday, September 01, 2015 4:15:11 PM

Power outage - Lake Elmo, Oakdale & Woodbury.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Tuesday, September 01, 2015 3:57 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/1/2015

Date In :

Time Out : 15:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3148

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : nn

Cause : UNKNOWN

Follow-Up : TECH ON THE -INTELTEAM OPENED AT [REDACTED] & [REDACTED]

[REDACTED]

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/1/15 - Lake Elmo, Oakdale & Woodbury - UPDATE
Date: Tuesday, September 01, 2015 4:15:54 PM

Power outage - Lake Elmo, Oakdale & Woodbury – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Tuesday, September 01, 2015 4:11 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/1/2015

Date In :

Time Out : 15:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3148

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : NN

Cause : UNKNOWN

Follow-Up : PICKED UP 1460 CUSTOMERS BY TELETEAM OPERATING

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Third Outage Notice - 9/1/15 - Lake Elmo, Oakdale & Woodbury - UPDATE
Date: Tuesday, September 01, 2015 4:51:33 PM

Power outage – Lake Elmo, Oakdale & Woodbury – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Abbott, Edward J
Sent: Tuesday, September 01, 2015 4:42 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/1/2015

Date In :

Time Out : 15:45

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3148

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : PHASE OF 336 FEEDER DOWN AT [REDACTED], 200FT OF
[REDACTED]. CREW IN ROUTE AND THIS PORTION OF FEEDER WILL BE OUT TILL CREW CAN PUT UP
THIS PHASE OF THE FEEDER

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/1/15 - Lake Elmo, Oakdale & Woodbury - POWER RESTORED
Date: Thursday, September 03, 2015 9:34:53 AM

Power outage - Lake Elmo, Oakdale & Woodbury – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Rubedor, Mark W
Sent: Thursday, September 03, 2015 9:30 AM
To: Rubedor, Mark W; Jaede, Wendy L
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/1/2015

Date In : 9/1/2015

Time Out : 15:45

Time In : 18:39

Time Zone : CST

Duration : 2 hours, 54 mins

Number of Customers Affected : 3153

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKE ELMO, MN; OAKDALE, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down between the [REDACTED] and the [REDACTED]
switches

Follow-Up : 1680 customers out while crew put wire up

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/2/15 - Saint Paul
Date: Thursday, September 03, 2015 7:45:34 AM

Power outage – Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Wednesday, September 02, 2015 4:49 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/2/2015

Date In :

Time Out : 16:32

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 791

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : ■

Cause : unknown

Follow-Up : ■

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 9/2/15 - Saint Paul - UPDATE
Date: Thursday, September 03, 2015 7:46:06 AM

Power outage - Saint Paul – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Wednesday, September 02, 2015 5:47 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/2/2015

Date In : 9/2/2015

Time Out : 16:32

Time In : 17:26

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 791

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] CABLE FAUL WAS TIED TO [REDACTED] FEEDER

Follow-Up : PART OF [REDACTED] STILL OUT

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/2/15 - Saint Paul - POWER RESTORED
Date: Thursday, September 03, 2015 7:47:24 AM

Power outage - Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Wednesday, September 02, 2015 6:45 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/2/2015

Date In : 9/2/2015

Time Out : 16:32

Time In : 17:26

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 791

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Bad urd cable

Follow-Up : [REDACTED] was back in at 17:26 and was close to part of [REDACTED]
everyone was back on at 18:16

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/2/15 - Saint Paul - POWER RESTORED/UPDATE
Date: Thursday, September 03, 2015 7:48:12 AM

Power outage - Saint Paul – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Wednesday, September 02, 2015 6:27 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/2/2015

Date In : 9/2/2015

Time Out : 16:32

Time In : 18:16

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 791

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : bad cable from [REDACTED] to [REDACTED]

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/4/2015 - Ellendale, Medford, meriden, Owatonna, Waseca
Date: Tuesday, September 08, 2015 7:45:03 AM

Power Outage - Ellendale, Medford, meriden, Owatonna, Waseca

From: Jerhoff, Patrick D
Sent: Friday, September 04, 2015 1:47 PM
To: dl Electric Outage SE Notification
Subject: MRN-MERIDEN (021) First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/4/2015 Date In :

Time Out : 13:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 618

For information about this alert, contact :

Communities Affected : ELLENDALE, MN; MEDFORD, MN; MERIDEN, MN;
OWATONNA, MN; WASECA, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown

Follow-Up : Troubleman is patrolling

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice 9/4/2015- Ellendale, Medford, meriden, Owatonna, Waseca
Date: Tuesday, September 08, 2015 7:45:42 AM

Outage Update- Ellendale, Medford, meriden, Owatonna, Waseca

From: Jerhoff, Patrick D
Sent: Friday, September 04, 2015 2:12 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/4/2015 Date In :

Time Out : 13:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 618

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ELLENDALE, MN; MEDFORD, MN; MERIDEN, MN;
OWATONNA, MN; WASECA, MN

State : MN - Minnesota

Major Customers :

Cause : Wire down at [REDACTED] [REDACTED].

Follow-Up : Crew is on the way

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice 9/4/2015 Ellendale, Medford, meriden, Owatonna, Waseca
Date: Tuesday, September 08, 2015 7:46:20 AM

Power Restored - Ellendale, Medford, Meriden, Owatonna, Waseca

From: Jerhoff, Patrick D
Sent: Friday, September 04, 2015 2:55 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/4/2015 Date In : 9/4/2015

Time Out : 13:03 Time In : 14:49

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 618

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ELLENDALE, MN; MEDFORD, MN; MERIDEN, MN;
OWATONNA, MN; WASECA, MN

State : MN - Minnesota

Major Customers :

Cause : Wire down at [REDACTED].

Follow-Up : Repaired permanent

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice 9/6/2015- Farmington, Randolph, St Joseph,
Date: Tuesday, September 08, 2015 7:49:24 AM

Power Outage - Farmington, Randolph, St Joseph,

From: Streine, Richard P
Sent: Sunday, September 06, 2015 2:28 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/6/2015 Date In :

Time Out : 14:19 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2066

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FARMINGTON, MN; RANDOLPH, MN; SAINT JOSEPH,

MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : n/a

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice -Power Restored- Farmington, Randolph, St Joseph,
Date: Tuesday, September 08, 2015 7:49:54 AM

Power Restored - Farmington, Randolph, St Joseph,

From: Streine, Richard P
Sent: Sunday, September 06, 2015 3:44 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/6/2015 Date In : 9/6/2015

Time Out : 14:19 Time In : 15:39

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 2066

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : FARMINGTON, MN; RANDOLPH, MN; SAINT JOSEPH,

MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : BROKEN FDR POLE @ [REDACTED] - TRBL TIED

UP TEMP

Follow-Up :

From: [Guttormson, Allyson E](#)
To: ["staff_cao \(PUC\)"; "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/8/2015 Maplewood Oakdale
Date: Tuesday, September 08, 2015 12:20:46 PM

Power Outage – Maplewood, Oakdale

From: Streine, Richard P
Sent: Tuesday, September 08, 2015 12:16 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/8/2015 Date In :

Time Out : 11:56 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2382

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : n/a

Cause : reports car hit pole @ [REDACTED]

Follow-Up :

From: [Guttormson, Allyson E](#)
To: ["staff_cao \(PUC\)"; "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice POWER RESTORED 9/8 Maplewood, Oakdale
Date: Tuesday, September 08, 2015 3:16:17 PM

Power Restored – Maplewood, Oakdale

From: Streine, Richard P
Sent: Tuesday, September 08, 2015 1:41 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/8/2015

Date In : 9/8/2015

Time Out : 11:56

Time In : 13:06

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 2382

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MAPLEWOOD, MN; OAKDALE, MN

State : MN - Minnesota

Major Customers : n/a

Cause : broken frd pole at [REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/11/15 - Brooklyn Park, Maple Grove & Osseo
Date: Friday, September 11, 2015 2:56:11 PM

Power outage – Brooklyn Park, Maple Grove & Osseo.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Friday, September 11, 2015 2:32 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/11/2015

Date In :

Time Out : 14:19

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2008

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 9/11/15 - Brooklyn Park, Maple Grove & Osseo - UPDATE
Date: Friday, September 11, 2015 3:25:01 PM

Power outage - Brooklyn Park, Maple Grove & Osseo – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Friday, September 11, 2015 3:12 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/11/2015

Date In :

Time Out : 14:19

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2008

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : Load Center X is bad

Follow-Up : Troubleman isolating Load Center to restore all customers

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/11/15 - Brooklyn Park, Maple Grove & Osseo - POWER RESTORED
Date: Friday, September 11, 2015 4:14:26 PM

Power outage - Brooklyn Park, Maple Grove & Osseo – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wieskus, Gregg J
Sent: Friday, September 11, 2015 4:01 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/11/2015

Date In : 9/11/2015

Time Out : 14:19

Time In : 15:28

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 2008

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : Bad Load Center X

Follow-Up : Load Center X isolated by troubleman

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/18/15 - Minneapolis & Richfield
Date: Friday, September 18, 2015 10:07:42 AM

Power outage - Minneapolis & Richfield.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Friday, September 18, 2015 8:47 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/18/2015

Date In :

Time Out : 08:42

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2048

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 9/18/15 - Minneapolis & Richfield - UPDATE
Date: Friday, September 18, 2015 10:08:24 AM

Power outage - Minneapolis & Richfield – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Friday, September 18, 2015 9:38 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/18/2015

Date In :

Time Out : 08:42

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2048

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : REPORT OF POSSIBLE HIT FDR. CABLE

Follow-Up : TROUBLE ON SITE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/18/15 - Minneapolis & Richfield - POWER RESTORED
Date: Friday, September 18, 2015 11:13:18 AM

Power outage – Minneapolis & Richfield – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Friday, September 18, 2015 10:22 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/18/2015

Date In : 9/18/2015

Time Out : 08:42

Time In : 09:53

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2048

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FDR CABLE IT 

Follow-Up : ISOLATE RESTORE BY FIELD TIE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 9/27/15 - Eden Prairie, Hopkins & Minnetonka
Date: Monday, September 28, 2015 7:53:58 AM

Power outage - Eden Prairie, Hopkins & Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cuno, Dean M
Sent: Sunday, September 27, 2015 10:07 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/27/2015

Date In :

Time Out : 21:44

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2315

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : unknown

Follow-Up : [REDACTED] BKR OPEN CLOSED [REDACTED] OPENED TROUBLE IN

ROUTE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 9/27/15 - Eden Prairie, Hopkins & Minnetonka - UPDATE
Date: Monday, September 28, 2015 7:54:31 AM

Power outage - Eden Prairie, Hopkins & Minnetonka – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cuno, Dean M
Sent: Sunday, September 27, 2015 10:58 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 9/27/2015

Date In :

Time Out : 21:44

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2315

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] FEEDER BURNT DOWN ON [REDACTED]

[REDACTED]

Follow-Up : TROUBLE WORKING ON ISO FEEDER

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 9/27/15 - Eden Prairie, Hopkins & Minnetonka - POWER RESOTRED
Date: Monday, September 28, 2015 7:55:11 AM

Power outage - Eden Prairie, Hopkins & Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cuno, Dean M
Sent: Sunday, September 27, 2015 11:35 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 9/27/2015 Date In : 9/27/2015

Time Out : 21:44 Time In : 23:20

Time Zone : CST

Duration : 1 hours, 36 mins

Number of Customers Affected : 2315

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : FEEDER BURNT DOWN [REDACTED]

Follow-Up : FEEDER CUT IN CLEAR PROBLEM ISOLATED

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/6/15 - Lakeville
Date: Wednesday, October 07, 2015 8:54:55 AM

Power outage – Lakeville.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Tuesday, October 06, 2015 8:19 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/6/2015

Date In :

Time Out : 20:13

Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 73

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 10/6/15 - Lakeville - UPDATE
Date: Wednesday, October 07, 2015 8:56:06 AM

Power outage - Lakeville – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Tuesday, October 06, 2015 8:40 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/6/2015

Date In :

Time Out : 20:13

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 73

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : [REDACTED]

[REDACTED] Cause : unknown also part of [REDACTED] is out because [REDACTED]
[REDACTED] 1974 customers are out

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/6/15 - Lakeville - POWER RESTORED
Date: Wednesday, October 07, 2015 8:57:04 AM

Power outage – Lakeville – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Tuesday, October 06, 2015 10:22 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/6/2015

Date In : 10/6/2015

Time Out : 20:13

Time In : 21:27

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 73

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : bad urd cable from sub to [REDACTED] because of req 718551 all
1974 customers are back on at 21:27 new req 719940

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/7/15 - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver
Date: Wednesday, October 07, 2015 8:59:18 AM

Power outage - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Wednesday, October 07, 2015 2:47 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/7/2015 Date In :

Time Out : 01:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1014

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ALTURA, MN; ELBA, MN; MINNEISKA, MN; MINNESOTA
CITY, MN; ROLLINGSTONE, MN; WEAVER, MN

State : MN - Minnesota

Major Customers :

Cause : report of broken pole, crew and operator enroute, Non SCADA
sub

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 10/7/15 - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver - UPDATE
Date: Wednesday, October 07, 2015 9:02:12 AM

Power outage - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Wednesday, October 07, 2015 7:03 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/7/2015 Date In :

Time Out : 01:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 250

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ALTURA, MN; ELBA, MN; MINNEISKA, MN; MINNESOTA
CITY, MN; ROLLINGSTONE, MN; WEAVER, MN

State : MN - Minnesota

Major Customers :

Cause : Broken pole

Follow-Up : 763 customers restored at 04:48, 250 will be out until pole is
replaced.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/7/15 - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver - POWER RESTORED
Date: Wednesday, October 07, 2015 10:47:21 AM

Power outage - Altura, Elba, Minneiska, Minnesota City, Rollingstone & Weaver – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Wednesday, October 07, 2015 10:42 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/7/2015

Date In : 10/7/2015

Time Out : 01:59

Time In : 09:11

Time Zone : CST

Duration : 7 hours, 12 mins

Number of Customers Affected : 250

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : ALTURA, MN; ELBA, MN; MINNEISKA, MN; MINNESOTA
CITY, MN; ROLLINGSTONE, MN; WEAVER, MN

State : MN - Minnesota

Major Customers :

Cause : Broken pole

Follow-Up : all customers restored

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/10/15 - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville
Date: Monday, October 12, 2015 10:06:02 AM

Power outage - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Saturday, October 10, 2015 7:39 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/10/2015 Date In :

Time Out : 07:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1225

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : crew in route

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 10/10/15 - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville - UPDATE
Date: Monday, October 12, 2015 10:06:46 AM

Power outage - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Saturday, October 10, 2015 8:43 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/10/2015 Date In :

Time Out : 07:42 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1225

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : Crew found burned off jumper and high side fuse blown on
transformer. Crew to make repairs.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/10/15 - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville - POWER RESTORED
Date: Monday, October 12, 2015 10:08:08 AM

Power outage - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Saturday, October 10, 2015 9:26 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/10/2015

Date In : 10/10/2015

Time Out : 07:24

Time In : 09:13

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 1225

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : REPAIRS MADE TO 69 KV JUMPERS AND ALL CUSTOMERS BACK

ON

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/10/15 - Faribault, Medford, Morristown, Warsaw |
Waseca & Waterville - POWER RESTORED/UPATE
Date: Monday, October 12, 2015 10:09:07 AM

Power outage - Faribault, Medford, Morristown, Warsaw, Waseca & Waterville – power restored/update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Peterson, Mark S
Sent: Saturday, October 10, 2015 9:48 AM
To: dl Electric Outage SE Notification
Subject: RE: [REDACTED] Final Outage Notice

Update on cause of outage. Squirrel got onto the regulator , causing high side fuse to blow and burned open 12.5kv jumper. Squirrel guards were installed but did not stop the contact.

From: Peterson, Mark S
Sent: Saturday, October 10, 2015 9:26 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/10/2015

Date In : 10/10/2015

Time Out : 07:24

Time In : 09:13

Time Zone : CST

Duration : 1 hours, 49 mins

Number of Customers Affected : 1225

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FARIBAULT, MN; MEDFORD, MN; MORRISTOWN, MN;
WARSAW, MN; WASECA, MN; WATERVILLE, MN

State : MN - Minnesota

Major Customers : none

Cause : REPAIRS MADE TO 69 KV JUMPERS AND ALL CUSTOMERS BACK

ON

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/14/15 - Brooklyn Center
Date: Wednesday, October 14, 2015 2:38:04 PM

Power outage – Brooklyn Center

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kubes, Kenneth B
Sent: Wednesday, October 14, 2015 2:29 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/14/2015 Date In :

Time Out : 14:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1262

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up : TROUBLEMEN ARE ENROUTE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice- 10/14/15 - Brooklyn Center - POWER RESTORED
Date: Wednesday, October 14, 2015 3:39:58 PM

Power outage – Brooklyn Center – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Wednesday, October 14, 2015 3:36 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/14/2015

Date In : 10/14/2015

Time Out : 14:24

Time In : 15:28

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1262

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Failed cable [REDACTED] to [REDACTED]

Follow-Up : 1224 restored at 1524 and 38 restored at 1528.

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/22/15 - Columbia Heights & Minneapolis
Date: Thursday, October 22, 2015 9:51:01 AM

Power outage – Columbia Heights & Minneapolis.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Thursday, October 22, 2015 9:39 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/22/2015 Date In :

Time Out : 09:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1234

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Second Outage Notice - 10/22/15 - Columbia Heights & Minneapolis - UPDATE
Date: Thursday, October 22, 2015 11:48:44 AM

Power outage - Columbia Heights & Minneapolis – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Thursday, October 22, 2015 10:45 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/22/2015

Date In : 10/22/2015

Time Out : 09:34

Time In : 10:35

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 989

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : non

Cause : Arrestor & insulator blown on pri. customer feed - Mpls. elec.
steel co.

Follow-Up : #245 out until repaired.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/22/15 - Columbia Heights & Minneapolis - POWER RESTORED
Date: Thursday, October 22, 2015 11:49:29 AM

Power outage - Columbia Heights & Minneapolis – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Thursday, October 22, 2015 11:15 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/22/2015

Date In : 10/22/2015

Time Out : 09:34

Time In : 11:08

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 1234

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

**Cause : Failed equipment has been replaced and repaired. Remaining
245 customers have been restored.**

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/25/15 - Bloomington
Date: Monday, October 26, 2015 8:19:40 AM

Power outage – Bloomington.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Sunday, October 25, 2015 4:41 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/25/2015 Date In :

Time Out : 04:27 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 647

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/25/15 - Bloomington - POWER RESTORED
Date: Monday, October 26, 2015 8:20:18 AM

Power outage – Bloomington – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Sunday, October 25, 2015 5:51 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/25/2015

Date In : 10/25/2015

Time Out : 04:27

Time In : 05:38

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 647

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : None

Cause : Failed cable [REDACTED] to [REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: dl [REDACTED] [Advocate Team](#)
Subject: [REDACTED] First Outage Notice - 10/29/15 - Brooklyn Center, Brooklyn Park, Crystal, [REDACTED] New Hope
Date: Thursday, October 29, 2015 8:55:15 AM

Power outage - Brooklyn Center, Brooklyn Park, Crystal, Minneapolis & New Hope.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Thursday, October 29, 2015 1:15 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 10/29/2015 Date In :

Time Out : 00:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1654

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

**Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN;
CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN**

State : MN - Minnesota

Major Customers : None

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: [REDACTED] Final Outage Notice - 10/29/15 - Brooklyn Center, Brooklyn Park, Crystal, Minneapolis & New Hope - POWER RESTORED
Date: Thursday, October 29, 2015 8:57:56 AM

Power outage - Brooklyn Center, Brooklyn Park, Crystal, Minneapolis & New Hope – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Thursday, October 29, 2015 3:03 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 10/29/2015

Date In : 10/29/2015

Time Out : 00:57

Time In : 02:45

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 1654

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN;
CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : [REDACTED] flashed over at [REDACTED]. B phase feeder line
down at [REDACTED].

Follow-Up : Isolated [REDACTED] and B phase feeder line.

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\)](#)
Cc: [dl Customer Advocate Team; "Renier, Doug \(COMM\)"](#)
Subject: FW: [REDACTED] First Outage Notice- 11/2/2015- Brooklyn Park, Osseo
Date: Monday, November 02, 2015 7:37:49 AM

Power Outage – Brooklyn Park, Osseo

From: Schwarz, John W
Sent: Monday, November 02, 2015 12:13 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/2/2015 Date In :
Time Out : 00:05 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1108

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\)](#)
Cc: [dl Customer Advocate Team: "Renier, Doug \(COMM\)"](#)
Subject: FW: [REDACTED] Second Outage Notice 11/2/2015- Brooklyn Park, Osseo
Date: Monday, November 02, 2015 7:38:59 AM

Update – Brooklyn Park, Osseo

From: Schwarz, John W
Sent: Monday, November 02, 2015 1:42 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/2/2015 Date In : 11/2/2015

Time Out : 00:05 Time In : 01:29

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1108

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BROKEN POLE @ [REDACTED] . CREW STILL CLEARING
THE AREA. 52 CUSTOMERS RESTORED @ 01:29

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\)](#)
Cc: [dl Customer Advocate Team; "Renier, Doug \(COMM\)"](#)
Subject: FW: [REDACTED] Third Outage Notice- Update 11/2 Brooklyn Park, Osseo
Date: Monday, November 02, 2015 7:40:09 AM

Update – Brooklyn Park, Osseo

From: Schwarz, John W
Sent: Monday, November 02, 2015 2:22 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/2/2015 Date In : 12/2/2015

Time Out : 00:05 Time In : 02:14

Time Zone : CST

Duration : 722 hours, 9 mins

Number of Customers Affected : 1108

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BROKEN POLE ,, [REDACTED] ,, 949 CUSTOMERS
RESTORED @ 02:14,,, TROUBLE STILL WORKING TO RESTORE REMAINING 107 CUSTOMERS

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\)](#)
Cc: [dl Customer Advocate Team; "Renier, Doug \(COMM\)"](#)
Subject: FW [REDACTED] Final Outage Notice 11/2/2015 Brooklyn Park, Osseo
Date: Monday, November 02, 2015 7:41:04 AM

Power Restored – Brooklyn Park, Osseo

From: Schwarz, John W
Sent: Monday, November 02, 2015 3:31 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/2/2015

Date In : 11/2/2015

Time Out : 00:05

Time In : 03:14

Time Zone : CST

Duration : 3 hours, 9 mins

Number of Customers Affected : 1108

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BROKEN POLE.. REMAINING 107 CUSTOMERS RESTORED @

03:14

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/3/15 - New Brighton
Date: Tuesday, November 03, 2015 8:30:33 AM

Power outage – New Brighton.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Donelan, John R
Sent: Tuesday, November 03, 2015 3:10 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/3/2015

Date In :

Time Out : 02:59

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2053

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : NEW BRIGHTON, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up : trouble dispatched

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/3/15 - New Brighton - POWER RESTORED
Date: Tuesday, November 03, 2015 8:31:17 AM

Power outage - New Brighton – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Tuesday, November 03, 2015 4:15 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/3/2015

Date In : 11/3/2015

Time Out : 02:59

Time In : 04:02

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2053

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : NEW BRIGHTON, MN

State : MN - Minnesota

Major Customers : MN

Cause : [REDACTED] was carried by [REDACTED] on sw pl # [REDACTED] ...ANIMAL
@ 1 [REDACTED] CAUSED OUTAGE

Follow-Up : BACK IN @ 0402

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/3/15 - Minneapolis, New Brighton, Roseville, St Anthony & Saint Paul
Date: Tuesday, November 03, 2015 8:33:44 AM

Power outage - Minneapolis, New Brighton, Roseville, St Anthony & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Donelan, John R
Sent: Tuesday, November 03, 2015 3:46 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/3/2015 Date In :

Time Out : 02:59 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1554

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE,
MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : n/a

Cause : [REDACTED] is being carried by [REDACTED] via tb disc in sub

Follow-Up : trouble patrolling

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/3/15 - Minneapolis, New Brighton, Roseville, St Anthony & Saint Paul - POWER RESTORED
Date: Tuesday, November 03, 2015 8:34:54 AM

Power outage - Minneapolis, New Brighton, Roseville, St Anthony & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Gubash Jr, Joseph M
Sent: Tuesday, November 03, 2015 4:09 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/3/2015

Date In : 11/3/2015

Time Out : 02:59

Time In : 04:02

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 1554

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE,
MN; SAINT ANTHONY, MN; SAINT PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : MN

Cause : ANIMAL @ 1 [REDACTED]

Follow-Up : BACK IN [REDACTED] + [REDACTED]

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/5/15 - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & West Lakeland
Date: Friday, November 06, 2015 7:57:08 AM

Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & West Lakeland.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, November 05, 2015 3:07 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/5/2015 Date In :

Time Out : 14:56 Time In :

Time Zone : CST

Duration :


Number of Customers Affected : 1899

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN; WEST LAKELAND, MN

State : MN - Minnesota

Major Customers : 

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/5/15 - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & West Lakeland - Update
Date: Friday, November 06, 2015 7:58:20 AM

Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & West Lakeland
– Update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, November 05, 2015 4:00 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/5/2015

Date In :

Time Out : 14:56

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1899

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN; WEST LAKELAND, MN

State : MN - Minnesota

Major Customers :



Cause : 15:52 1281 customers are back on

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/5/15 - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & W Lakeland - POWER RESTORED
Date: Friday, November 06, 2015 7:58:57 AM

Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater, W Lakeland Twp & West Lakeland – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Thursday, November 05, 2015 5:16 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/5/2015

Date In : 11/5/2015

Time Out : 14:56

Time In : 16:28

Time Zone : CST

Duration : 1 hours, 32 mins


Number of Customers Affected : `

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS,
MN; STILLWATER, MN; W LAKELAND TWP, MN; WEST LAKELAND, MN

State : MN - Minnesota

Major Customers : 

Cause : patrolled feeder and did not find anything

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: RE [REDACTED] 1st Outage Notice-11/6/15-Various Communities
Date: Friday, November 06, 2015 8:06:25 AM

CORRECTION – DATE IS 11/6/15.

From: Jaede, Wendy L
Sent: Friday, November 06, 2015 8:03 AM
To: MN PUC (consumer.puc@state.mn.us); Renier, Doug (COMM)
Cc: dl Customer Advocate Team
Subject: FW: [REDACTED] First Outage Notice - 11/5/15 - Columbia Heights, Mendota Heights, Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul

Power outage - Columbia Heights, Mendota Heights, Minneapolis, New Brighton, Roseville, Saint Anthony & Saint Paul.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, November 06, 2015 12:25 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/6/2015 Date In :
Time Out : 00:04 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 8425

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MENDOTA HEIGHTS, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT ANTHONY, MN; SAINT
PAUL, MN; ST ANTHONY, MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up : BUS 1 LOCK.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] Final Outage Notice - 11/6/15 - Columbia Heights, Minneapolis & Saint Anthony - POWER RESTORED
Date: Friday, November 06, 2015 8:14:27 AM

Power outage - Columbia Heights, Minneapolis & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, November 06, 2015 2:42 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/6/2015

Date In : 11/6/2015

Time Out : 00:04

Time In : 01:20

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 1554

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED EQUIPMENT AT [REDACTED] SUBSTATION

Follow-Up : POSSIBLE FAILED HEAD END CABLE. ISOLATION IN PROGRESS.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Columbia Heights, Minneapolis & Saint Anthony - POWER RESTORED
Date: Friday, November 06, 2015 8:08:08 AM

Power outage - Columbia Heights, Minneapolis & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, November 06, 2015 2:36 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/6/2015

Date In : 11/6/2015

Time Out : 00:04

Time In : 01:08

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1940

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED EQUIPMENT AT [REDACTED] SUBSTATION.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Minneapolis & Saint Anthony - POWER RESTORED
Date: Friday, November 06, 2015 8:09:37 AM

Power outage - Minneapolis & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, November 06, 2015 2:38 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/6/2015

Date In : 11/6/2015

Time Out : 00:04

Time In : 01:18

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1661

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN; ST

ANTHONY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED EQUIPMENT AT [REDACTED] SUBSTATION.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Columbia Heights, Minneapolis & Saint Anthony - POWER RESTORED
Date: Friday, November 06, 2015 8:11:20 AM

Power outage - Columbia Heights, Minneapolis & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Friday, November 06, 2015 2:39 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/6/2015

Date In : 11/6/2015

Time Out : 00:04

Time In : 01:17

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 974

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED EQUIPMENT AT [REDACTED] SUBSTATION.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Mendota Hights, New Brighton & Saint Anthony - POWER RESTORED
Date: Monday, November 09, 2015 10:03:42 AM

Power outage - Roseville, Saint Anthony & Saint Paul – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Monday, November 09, 2015 9:07 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/6/2015 Date In : 11/6/2015

Time Out : 00:04 Time In : 02:23

Time Zone : CST

Duration : 2 hours, 19 mins

Number of Customers Affected : 1854

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : ■■■ substation bus 1 lock

Follow-Up : me tf field switched me feeders

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Mendota Heights, New Brighton & Saint Anthony - POWER RESTORED-UPDATE
Date: Monday, November 09, 2015 8:15:12 AM

Power outage - Mendota Heights, New Brighton & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Rubedor, Mark W
Sent: Monday, November 09, 2015 6:44 AM
To: Jaede, Wendy L; Browen, Troy A; Rubedor, Mark W
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/6/2015 Date In : 11/6/2015

Time Out : 00:52 Time In : 02:23

Time Zone : CST

Duration : 1 hours, 31 mins

Number of Customers Affected : 1854

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : NA

Cause : BURNT OPEN JUMPER IN SUBSTATION

Follow-Up : This is a correction to the [REDACTED] electric outage notification.
The start time on the outage was 00:52 not 00:06

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/6/15 - Mendota Heights, New Brighton & Saint Anthony - POWER RESTORED
Date: Friday, November 06, 2015 8:12:46 AM

Power outage - Mendota Heights, New Brighton & Saint Anthony – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Klemz, Keith R
Sent: Friday, November 06, 2015 2:40 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/6/2015 Date In : 11/6/2015

Time Out : 00:06 Time In : 02:23

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 1854

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : MENDOTA HEIGHTS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : UNKNOWN

Cause : BURNT OPEN JUMPER IN SUBSTATION

Follow-Up : REPAIRING JUMPER

From: [Jaede, Wendy L](#)
To: [MN PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC(consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/11/15 - Mankato
Date: Thursday, November 12, 2015 7:41:11 AM

Power outage – Mankato.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Wednesday, November 11, 2015 6:47 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/11/2015 Date In :

Time Out : 18:39 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : rain/lightning in area

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/11/15 - Mankato - UPDATE
Date: Thursday, November 12, 2015 7:41:50 AM

Power outage – Mankato – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Wednesday, November 11, 2015 7:54 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/11/2015

Date In : 11/11/2015

Time Out : 18:39

Time In : 19:48

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Wire burnt down [REDACTED] crew isolated feeder
and restored 605 customers

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Third Outage Notice - 11/11/15 - Mankato - UPDATE
Date: Thursday, November 12, 2015 7:42:43 AM

Power outage – Mankato – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Medellin, Victor J
Sent: Wednesday, November 11, 2015 8:45 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/11/2015

Date In : 11/11/2015

Time Out : 18:39

Time In : 20:24

Time Zone : CST

Duration : 1 hours, 45 mins

Number of Customers Affected : 627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Feeder burnt down 605 customers restored @ 19:48 17 more
customers restored @ 20:24 via switching

Follow-Up : 5 customers remain out until wire is put back up

From: [Jaede, Wendy L](#)
To: [MN PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/11/15 - Mankato - POWER RESTORED
Date: Thursday, November 12, 2015 7:43:17 AM

Power outage – Mankato – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Chase, Julie B
Sent: Thursday, November 12, 2015 12:21 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/11/2015

Date In : 11/11/2015

Time Out : 18:39

Time In : 23:10

Time Zone : CST

Duration : 4 hours, 31 mins

Number of Customers Affected : 627

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MANKATO, MN

State : MN - Minnesota

Major Customers :

Cause : Feeder burnt down 605 customers restored @ 19:48 17 more
customers restored @ 20:24 via switching

Follow-Up : final 5 customers restored at 2310

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/12/15 - Fridley, Minneapolis & Spring Lake Park
Date: Thursday, November 12, 2015 7:45:14 AM

Power outage - Fridley, Minneapolis & Spring Lake Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Thursday, November 12, 2015 3:41 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/12/2015 Date In :

Time Out : 03:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1616

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN; SPRING LAKE PARK,

MN

State : MN - Minnesota

Major Customers : 

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/12/15 - Fridley, Minneapolis & Spring Lake Park - POWER RESTORED
Date: Thursday, November 12, 2015 7:46:01 AM

Power outage - Fridley, Minneapolis & Spring Lake Park – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Cedar, Daren A
Sent: Thursday, November 12, 2015 4:49 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/12/2015

Date In : 11/12/2015

Time Out : 03:32

Time In : 04:45

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 1616

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN; SPRING LAKE PARK,
MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : TREE BRANCH AT [REDACTED]

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice Fort Snelling and Mpls
Date: Monday, November 16, 2015 8:50:31 AM

Power Outage – Fort Snelling and Mpls

From: Schwarz, John W
Sent: Saturday, November 14, 2015 3:00 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/14/2015 Date In :

Time Out : 14:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 12562

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FORT SNELLING, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : [REDACTED] BREAKER OPENED.....OPERATOR ON THE WAY

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice 11/14 Power Restored Ft Snelling and Mpls
Date: Monday, November 16, 2015 8:51:30 AM

Power Restored – Fort Snelling and Minneapolis

From: Schwarz, John W
Sent: Saturday, November 14, 2015 4:04 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/14/2015 Date In : 11/14/2015

Time Out : 14:48 Time In : 15:53

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 12562

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : FORT SNELLING, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : AN ANIMAL GOT ON TO A BREAKER LEAD IT THE SUB STATION TRIPPING OUT BUS ONE. 11,011 CUSTOMERS RESTORED @ 15:32 SOU 61 BREAKER WAS ISOLATED AND THE REMAINING 1,551 CUSTOMERS WEREC RESTORED @ 15:51

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/17/15 - Crystal Bay, Long Lake, Orono, Wayzata
Date: Tuesday, November 17, 2015 12:07:16 PM

Power out - Crystal Bay, Long Lake, Orono, Wayzata.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, November 17, 2015 11:22 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/17/2015 Date In :

Time Out : 11:17 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1307

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;

WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/17/15 - Crystal Bay, Long Lake, Orono, Wayzata - UPDATE
Date: Tuesday, November 17, 2015 2:18:53 PM

Power outage - Crystal Bay, Long Lake, Orono, Wayzata – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, November 17, 2015 12:31 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/17/2015 Date In : 11/17/2015

Time Out : 11:17 Time In : 12:14

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 1307

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : B/phase down at [REDACTED].

Follow-Up : 211 out till wire put up.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/17/15 - Crystal Bay, Long Lake, Orono, Wayzata - CORRECTION/UPDATE
Date: Tuesday, November 17, 2015 2:20:18 PM

Power outage - Crystal Bay, Long Lake, Orono, Wayzata – correction/update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, November 17, 2015 1:57 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/17/2015 Date In : 11/17/2015

Time Out : 11:17 Time In : 12:14

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 906

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : B/phase down at [REDACTED].

Follow-Up : Correction, restored 906. Not 1117.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/17/15 - Crystal Bay, Long Lake, Orono, Wayzata - POWER RESTORED
Date: Tuesday, November 17, 2015 2:21:33 PM

Power outage - Crystal Bay, Long Lake, Orono, Wayzata – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Kittock, Joseph C
Sent: Tuesday, November 17, 2015 1:51 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/17/2015 Date In : 11/17/2015

Time Out : 11:17 Time In : 13:46

Time Zone : CST

Duration : 2 hours, 29 mins

Number of Customers Affected : 211

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : O.H. wire down

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/19/15 - Burnsville
Date: Thursday, November 19, 2015 8:06:41 AM

Power outage - Burnsville

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Thursday, November 19, 2015 1:12 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/19/2015 Date In :

Time Out : 00:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1383

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : 

Cause : Unknown

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/19/15 - Burnsville - POWER RESTORED
Date: Thursday, November 19, 2015 8:07:19 AM

Power outage - Burnsville – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Thursday, November 19, 2015 2:36 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/19/2015

Date In : 11/19/2015

Time Out : 00:55

Time In : 02:27

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 1383

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Possible slack span at [REDACTED].

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] First Outage Notice - 11/19/15 - Minnetonka, Plymouth, Wayzata & Woodland
Date: Thursday, November 19, 2015 8:33:59 AM

Power outage - Minnetonka, Plymouth, Wayzata & Woodland.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, November 19, 2015 8:21 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/19/2015 Date In :

Time Out : 08:16 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1261

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN;

WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/19/15 - Minnetonka, Plymouth, Wayzata & Woodland - UPDATE
Date: Thursday, November 19, 2015 10:14:54 AM

Power outage - Minnetonka, Plymouth, Wayzata & Woodland – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, November 19, 2015 9:30 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED]) Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/19/2015 Date In :

Time Out : 08:06 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1261

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN;
WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT WIRES

Follow-Up : TROUBLE ON SITE WORKING TO RESTORE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/19/15 - Minnetonka, Plymouth, Wayzata & Woodland - POWER RESTORED
Date: Thursday, November 19, 2015 10:20:16 AM

Power outage - Minnetonka, Plymouth, Wayzata & Woodland – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, November 19, 2015 10:12 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/19/2015 Date In : 11/19/2015

Time Out : 08:16 Time In : 10:00

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 1261

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN; PLYMOUTH, MN; WAYZATA, MN;
WOODLAND, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRUCK HIT TELEPHONE & CABLE TV WIRES

Follow-Up : REPAIRS MADE BY TROUBLE TO RESTORE.REFER TO CABLE &
TELEPHONE

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/28/15 - Northfield & Slayton
Date: Monday, November 30, 2015 8:19:24 AM

Power outage - Northfield & Slayton.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Saturday, November 28, 2015 10:18 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/28/2015 Date In :

Time Out : 10:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2378

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : NORTHFIELD, MN; SLAYTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Pole fire at [REDACTED], Crew has been called in.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/28/15 - Northfield & Slayton - UPDATE
Date: Monday, November 30, 2015 8:20:10 AM

Power outage - Northfield & Slayton – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Saturday, November 28, 2015 11:26 AM
To: dl Electric Outage SE Notification
Subject: RE: [REDACTED] First Outage Notice

Crew is making repairs and estimate 30min. to bring feeder back in.

From: Jerhoff, Patrick D
Sent: Saturday, November 28, 2015 10:18 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice
Feeder/Bus : [REDACTED]

Date Out : 11/28/2015 Date In :
Time Out : 10:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2378

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : NORTHFIELD, MN; SLAYTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Pole fire at [REDACTED], Crew has been called in.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/28/15 - Northfield & Slayton - POWER RESTORED
Date: Monday, November 30, 2015 8:20:49 AM

Power outage - Northfield & Slayton – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Jerhoff, Patrick D
Sent: Saturday, November 28, 2015 11:51 AM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/28/2015

Date In : 11/28/2015

Time Out : 10:07

Time In : 11:44

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 2378

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : NORTHFIELD, MN; SLAYTON, MN

State : MN - Minnesota

Major Customers : [REDACTED]

Cause : Car hit a pole at [REDACTED].

Follow-Up : The crew repaired a couple broken insulators and we were able to energize the feeder.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/28/15 - Monticello
Date: Monday, November 30, 2015 8:23:23 AM

Power outage – Monticello.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Saturday, November 28, 2015 8:51 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/28/2015 Date In :

Time Out : 20:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 728

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : [REDACTED] Crew being called in.

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/28/15 - Monticello - POWER RESTORED
Date: Monday, November 30, 2015 8:23:56 AM

Power outage – Monticello – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Goulet, Terry W
Sent: Saturday, November 28, 2015 9:51 PM
To: dl Electric Outage NT Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/28/2015

Date In : 11/28/2015

Time Out : 20:38

Time In : 21:38

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 728

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : [REDACTED] Station pothead burnt open in Sub. Isolated and
restored on SP# [REDACTED]

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/30/15 - Edina, Hopkins, Minneapolis & Saint Louis Park
Date: Monday, November 30, 2015 8:32:08 AM

Power outage - Edina, Hopkins, Minneapolis & Saint Louis Park.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Schwarz, John W
Sent: Monday, November 30, 2015 7:35 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015 Date In :

Time Out : 07:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1106

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; SAINT

LOUIS PARK, MN

State : MN - Minnesota

Major Customers :



Cause : UNKNOWN @ THIS TIME

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/30/15 - Edina, Hopkins, Minneapolis & Saint Louis Park - UPDATE
Date: Monday, November 30, 2015 10:31:03 AM

Power outage - Edina, Hopkins, Minneapolis & Saint Louis Park – update.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Monday, November 30, 2015 10:14 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice - UPDATE

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015 Date In : 11/30/2015

Time Out : 07:29 Time In : 10:06

Time Zone : CST

Duration : 2 hours, 37 mins


Number of Customers Affected : 1106

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; SAINT
LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : Vehicle hit pole causing lines to slap together, thus resulting in a failed automatic sleeve. Repairs made permanent.

Follow-Up : SCADA team did not operate properly. Investigating. There was partial restoration via switching.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice ; Correction from First Notice - 11/30/15 - Edina, Hopkins, Minneapolis & Saint Louis Park
Date: Monday, November 30, 2015 10:31:59 AM

Power outage - Edina, Hopkins, Minneapolis & Saint Louis Park – update/correction from First Notice.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Babb, Randall J
Sent: Monday, November 30, 2015 10:19 AM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice ; Correction from First Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015

Date In : 11/30/2015

Time Out : 07:29

Time In : 10:06

Time Zone : CST

Duration : 2 hours, 37 mins

Number of Customers Affected : 1106

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : 

Cause : Vehicle hit pole causing lines to slap together, thus resulting in a failed automatic sleeve. Repairs made permanent.

Follow-Up : SCADA team did not operate properly. Investigating. There was partial restoration via switching.

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 11/30/15 - Eden Prairie & Minnetonka
Date: Tuesday, December 01, 2015 7:34:50 AM

Power outage - Eden Prairie & Minnetonka.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, November 30, 2015 6:25 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015 Date In :

Time Out : 18:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2088

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC(consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice - 11/30/15 -- Eden Prairie & Minnetonka - UPDATE
Date: Tuesday, December 01, 2015 7:35:34 AM

Power outage - Eden Prairie & Minnetonka – update.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Monday, November 30, 2015 7:22 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015 Date In :

Time Out : 18:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2088

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : TROUBLE PATROLLING

From: [Jaede, Wendy L](#)
To: [MN.PUC \(consumer.puc@state.mn.us\)](mailto:MN.PUC (consumer.puc@state.mn.us)); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 11/30/15 - Eden Prairie & Minnetonka - POWER RESTORED
Date: Tuesday, December 01, 2015 7:36:11 AM

Power outage - Eden Prairie & Minnetonka – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Hills, Thomas L
Sent: Monday, November 30, 2015 7:35 PM
To: dl Electric Outage MW Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 11/30/2015

Date In : 11/30/2015

Time Out : 18:13

Time In : 19:25

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 2088

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch 1 span east of [REDACTED].

Follow-Up : Trouble removed branch.

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice 12/5 Power Outage - St Paul
Date: Monday, December 07, 2015 7:55:59 AM

Power Outage – St Paul

From: Elden, Thomas L
Sent: Saturday, December 05, 2015 3:15 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/5/2015 Date In :

Time Out : 14:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3033

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : MN.

Cause : car hit pole at [REDACTED]

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice 12/5 Update St Paul
Date: Monday, December 07, 2015 7:56:44 AM

Update St Paul

From: Elden, Thomas L
Sent: Saturday, December 05, 2015 3:30 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/5/2015 Date In :

Time Out : 14:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3033

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn. picked up 1160 customers at 15:02

Cause : car hit pole

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] Third Outage Notice 12/5 Update St Paul
Date: Monday, December 07, 2015 7:57:29 AM

Update- St Paul

From: Elden, Thomas L
Sent: Saturday, December 05, 2015 3:37 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Third Outage Notice

Distribution System Status Outage Notification

[REDACTED] Third Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/5/2015 Date In :

Time Out : 14:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3033

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : MN 15:23 pit up 699 customers now we have 368
customers still out

Cause : car hit pole

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice 12/5 Power Restored St Paul
Date: Monday, December 07, 2015 7:58:11 AM

Power Restored – St Paul

From: Elden, Thomas L
Sent: Saturday, December 05, 2015 4:06 PM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/5/2015 Date In : 12/5/2015

Time Out : 14:24 Time In : 15:42

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 3033

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : MN

Cause : car hit [REDACTED] and broke pole off last 368 customers are
back on 14:42 all customers are back on 14:42

Follow-Up :

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 12/17/15 - Cottage Grove
Date: Thursday, December 17, 2015 10:29:39 AM

Power outage - Cottage Grove.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, December 17, 2015 1:55 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/17/2015

Date In :

Time Out : 00:36

Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 635

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up : CALLS COMING IN AFTER 

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] Final Outage Notice - 12/17/15 - Cottage Grove - POWER RESTORED - UPDATE
Date: Thursday, December 17, 2015 10:31:37 AM

Power outage - Cottage Grove – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive, St. Paul, MN 55113
P: 651-639-4513 F: 651-639-4322
E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, December 17, 2015 3:06 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/17/2015 Date In : 12/17/2015

Time Out : 00:36 Time In : 02:52

Time Zone : CST

Duration : 2 hours, 16 mins

Number of Customers Affected : 635

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN

State : MN - Minnesota

Major Customers : NA

Cause : JUMPERS BURNT OPEN EAST OF [REDACTED]

Follow-Up : CREW TO REPR JUMPERS, REPL. [REDACTED] , PROOF TEST
[REDACTED]

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice - 12/17/15 - Cottage Grove
Date: Thursday, December 17, 2015 10:30:10 AM

Power outage - Cottage Grove.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, December 17, 2015 2:30 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/17/2015 Date In :

Time Out : 02:23 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2568


For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN

State : MN - Minnesota

Major Customers : na

Cause : defective 

Follow-Up : CREW TO CLEAR SWITCH

From: [Jaede, Wendy L](#)
To: [MN_PUC \(consumer.puc@state.mn.us\)](mailto:MN_PUC_consumer.puc@state.mn.us); [Renier, Doug \(COMM\)](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice - 12/17/15 - Cottage Grove - POWER RESTORED
Date: Thursday, December 17, 2015 10:31:02 AM

Power outage - Cottage Grove – power restored.

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, December 17, 2015 2:55 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/17/2015

Date In : 12/17/2015

Time Out : 02:23

Time In : 02:33

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 1933

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN

State : MN - Minnesota

Major Customers : NA

Cause : [REDACTED] IS DEFECTIVE NEEDS REPLACE

Follow-Up :

From: [Rubedor, Mark W](#)
To: [Jaede, Wendy L](#)
Subject: RE: [REDACTED] First Outage Notice-Mark's Notes
Date: Thursday, December 17, 2015 8:56:26 AM

Yes

Mark Rubedor
Xcel Energy | Responsible By Nature
Manager *Metro Distribution CTRL CTR
825 Rice St. St Paul Mn 55117
P: 651-229-2450 C: 612-590-7848
E: Mark.W.Rubedor@xcelenergy.com

From: Jaede, Wendy L
Sent: Thursday, December 17, 2015 8:54 AM
To: Rubedor, Mark W
Subject: RE: [REDACTED] First Outage Notice

Yes but should I send them both?

From: Rubedor, Mark W
Sent: Thursday, December 17, 2015 8:47 AM
To: Jaede, Wendy L
Subject: RE: [REDACTED] First Outage Notice

Wendy

We had a momentary outage on [REDACTED] at 12:36, when this happened the [REDACTED] switch burnt open, leaving 635 customers out of service on the tail end of the feeder. In order to clear the [REDACTED] switch safely the breaker had to be opened at 2:23 de-energizing the entire feeder. At 2:34 the breaker was closed at the substation re-energizing all but 635 customers, the a tie switch was closed at 2:52 energizing the remaining 635 customers. All power was restored at 2:52.

Does that help?

Mark Rubedor
Xcel Energy | Responsible By Nature
Manager *Metro Distribution CTRL CTR
825 Rice St. St Paul Mn 55117
P: 651-229-2450 C: 612-590-7848
E: Mark.W.Rubedor@xcelenergy.com

From: Jaede, Wendy L
Sent: Thursday, December 17, 2015 7:51 AM
To: Rubedor, Mark W
Subject: FW: [REDACTED] First Outage Notice

Mark:

I got two outage notifications (first/final) from Terry for this same feeder with different start/end

times of the outage. Which one do I use? With the one below the outage started at 00:36 on 12/17 and service was restored at 02:52. The second one received is also for 12/17 and the outage started at 02:23 and service was restored at 02:33. I don't understand how there can be two outages with overlapping times. Please advise....

Thanks,

Wendy Jaede

Xcel Energy | Responsible By Nature

Customer Advocate Analyst

3115 Centre Pointe Drive, St. Paul, MN 55113

P: 651-639-4513 F: 651-639-4322

E: wendy.l.jaede@xcelenergy.com

NONPUBLIC DOCUMENT - CONTAINS TRADE SECRET DATA/PRIVATE DATA ON INDIVIDUALS

XCELENERGY.COM

Please consider the environment before printing this email

From: Wolf, Terry K
Sent: Thursday, December 17, 2015 1:55 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/17/2015 Date In :

Time Out : 00:36 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 635

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : COTTAGE GROVE, MN

State : MN - Minnesota

Major Customers : NA

Cause : UNKNOWN

Follow-Up : CALLS COMING IN AFTER 

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice 12/21/2015- Power Outage Delavan, Good Thunder, Mapleton, Minnesota Lake
Date: Monday, December 21, 2015 4:18:06 PM

Power Outage - Delavan, Good Thunder, Mapleton, Minnesota Lake

From: Medellin, Victor J
Sent: Monday, December 21, 2015 3:38 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/21/2015 Date In :

Time Out : 15:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1013

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DELAVAN, MN; GOOD THUNDER, MN; MAPLETON, MN;
MINNESOTA LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Cause unknown crew enroute non rtu substation calls indicate
breaker is open

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice 12/21/2015 Delavan, Good Thunder, Mapleton, Minnesota Lake
Date: Monday, December 21, 2015 4:52:03 PM

Update - Delavan, Good Thunder, Mapleton, Minnesota Lake

From: Medellin, Victor J
Sent: Monday, December 21, 2015 4:25 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/21/2015 Date In :

Time Out : 15:07 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1013

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DELAVAN, MN; GOOD THUNDER, MN; MAPLETON, MN;
MINNESOTA LAKE, MN

State : MN - Minnesota

Major Customers : n/a

Cause : Update ; Breaker failure in the sub crew isolating breaker to put
the load on the C bypass

Follow-Up :

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice 12/21/2015- Power Restored Delavan, Good Thunder, Mapleton, Minnesota Lake
Date: Monday, December 21, 2015 4:52:46 PM

Power Restored - Delavan, Good Thunder, Mapleton, Minnesota Lake

From: Medellin, Victor J
Sent: Monday, December 21, 2015 4:38 PM
To: dl Electric Outage SE Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/21/2015 Date In : 12/21/2015

Time Out : 15:07 Time In : 16:32

Time Zone : CST

Duration : 1 hours, 25 mins

Number of Customers Affected : 1013

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DELAVAN, MN; GOOD THUNDER, MN; MAPLETON, MN;
MINNESOTA LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Breaker failed isolated on sw plan [REDACTED]

Follow-Up : no regulation on feeder need to replace asap crew will check voltage and cap banks

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] Power Outage 12/23/2015- Blaine, Circle Pines, Lexington, Shoreview
Date: Wednesday, December 23, 2015 10:09:57 AM

Power Outage - Blaine, Circle Pines, Lexington, Shoreview

From: Klemz, Keith R
Sent: Wednesday, December 23, 2015 9:23 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/23/2015 Date In :

Time Out : 09:03 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1875

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : BLAINE, MN; CIRCLE PINES, MN; LEXINGTON, MN;
SHOREVIEW, MN

State : MN - Minnesota

Major Customers : NA

Cause : [REDACTED] LOCKED OUT UNKNOWN CAUSE.DAS SWITCH [REDACTED] -
[REDACTED] DIDNT OPERATE

Follow-Up : TECH ON THE WAY

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Final Outage Notice Power Restored 12/23 Blaine, Circle Pines, Lexington, Shoreview
Date: Wednesday, December 23, 2015 11:42:49 AM

Power Restored - Blaine, Circle Pines, Lexington, Shoreview

From: Klemz, Keith R
Sent: Wednesday, December 23, 2015 10:27 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/23/2015 Date In : 12/23/2015

Time Out : 09:04 Time In : 10:05

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 1875

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : BLAINE, MN; CIRCLE PINES, MN; LEXINGTON, MN;
SHOREVIEW, MN

State : MN - Minnesota

Major Customers : NA

Cause : [REDACTED] BURNT UP.TR 3 OPENED BECAUSE BOTH
FEEDERS SAW FAULT

Follow-Up : EVERYBODY BACK IN SWITCH WILL BE REPAIRED, RELAY ALSO
INVESTIGATING

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] First Outage Notice 12/26 Power Outage - Eagan, Inver Grove Heights
Date: Monday, December 28, 2015 7:40:45 AM

Power Outage – Eagan, Inver Grove Heights

From: Donelan, John R
Sent: Saturday, December 26, 2015 2:23 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] First Outage Notice

Distribution System Status Outage Notification

[REDACTED] First Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/26/2015 Date In :

Time Out : 02:13 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 591

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : unknown

Follow-Up : trouble dispatched

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\); "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW: [REDACTED] Second Outage Notice Update - Eagan, Inver Grove Heights
Date: Monday, December 28, 2015 7:41:13 AM

Update - Eagan, Inver Grove Heights

From: Donelan, John R
Sent: Saturday, December 26, 2015 3:35 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Second Outage Notice

Distribution System Status Outage Notification

[REDACTED] Second Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/26/2015 Date In : 12/26/2015

Time Out : 02:13 Time In : 03:21

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 261

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : car hit feeder pole broke it off at ground line trouble clearing up
wire at [REDACTED]

Follow-Up : opened up [REDACTED] closed breaker picked up 330 cust 261
still out.

From: [Guttormson, Allyson E](#)
To: [staff_cao \(PUC\): "Renier, Doug \(COMM\)"](#)
Cc: [dl Customer Advocate Team](#)
Subject: FW [REDACTED] Final Outage Notice Power Restored - Eagan, Inver Grove Heights
Date: Monday, December 28, 2015 7:41:43 AM

Power Restored - Eagan, Inver Grove Heights

From: Donelan, John R
Sent: Saturday, December 26, 2015 4:33 AM
To: dl Electric Outage ME Notification
Subject: [REDACTED] Final Outage Notice

Distribution System Status Outage Notification

[REDACTED] Final Outage Notice

Feeder/Bus : [REDACTED]

Date Out : 12/26/2015 Date In : 12/26/2015

Time Out : 02:13 Time In : 04:15

Time Zone : CST

Duration : 2 hours, 2 mins

Number of Customers Affected : 591

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2450

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN

State : MN - Minnesota

Major Customers : n/a

Cause : car took out feeder pole

Follow-Up : closed [REDACTED] at 04:15 picked up 92 cust and main line feeder. [REDACTED] out till pole replaced and wire put up leaves out 169 cust till work complete.