

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	7/2/12 7:39	FEEDER		CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED, REPAIRED TEMP	828835	NO	
2	x	x	1	ME	7/2/12 19:49	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	832518	NO	
3	x	x	1	ME	7/3/12 3:31	FEEDER		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	827935	YES	Storm Day
4	x	x	1	ME	7/3/12 3:33	FEEDER		CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED PERM	827946	YES	Storm Day
5	x	x	1	ME	7/6/12 10:38	FEEDER		CIRCUIT BREAKER	SPLICE UG PRIMARY COLD	100% RESTORED VIA SWITCHING	830856	NO	
6	x	x	1	ME	7/12/12 7:42	FEEDER		CIRCUIT BREAKER	CONNECTOR FAILURE AUTO	100% RESTORED VIA SWITCHING	833733	NO	
7	x	x	1	ME	7/13/12 17:39	FEEDER		LOAD BREAK DISC OH	SPLICE CONNECTOR	100% RESTORED, REPAIRED PERM			
8	x	x	1	ME	7/15/12 18:08	FEEDER		CIRCUIT BREAKER	PUBLIC DAMAGE OH LINE	PARTIAL RESTORATION	834055	NO	
9	x	x	1	ME	7/18/12 18:01	FEEDER		3P HV CONDUCTOR OH	CONNECTOR FAILURE AUTO	100% RESTORED, REPAIRED PERM	835249	NO	Start time adjusted when job was reviewed and approved.
10	x	x	1	ME	7/18/12 2:48	DIST SUBSTATION		CIRCUIT BREAKER	BREAKER FAIL VACUUM CIRCUIT	100% RESTORED VIA SWITCHING	835870	NO	
11	x	x	1	ME	7/18/12 17:38	FEEDER		CIRCUIT BREAKER	GLY WIRE FAILURE	100% RESTORED, REPAIRED PERM	836557	NO	
12	x	x	1	ME	7/19/12 15:13	DIST SUBSTATION		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	837141	NO	
13	x	x	1	ME	7/21/12 15:17	FEEDER		CIRCUIT BREAKER	TERMINATOR FAILURE PH P&L	100% RESTORED VIA SWITCHING	842780	NO	
14	x	x	1	ME	7/23/12 1:10	FEEDER		CIRCUIT BREAKER	CROSSARM ARM BROKEN	100% RESTORED, REPAIRED TEMP	836230	NO	
15	x	x	1	ME	7/24/12 4:23	FEEDER		CIRCUIT BREAKER	CROSSARM ARM BROKEN	100% RESTORED, REPAIRED TEMP	838782	NO	
16	x	x	1	ME	7/24/12 7:41	FEEDER		CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED PERM	839575	NO	
17	x	x	1	ME	7/29/12 7:41	FEEDER		CIRCUIT BREAKER	INSULATOR POLYMER LINE	100% RESTORED, REPAIRED TEMP	841880	NO	
18	x	x	1	MW	7/30/12 21:02	FEEDER		3P HV CONDUCTOR OH	CONNECTOR FAILURE AUTO	100% RESTORED VIA SWITCHING	843257	NO	Start time adjusted when job was reviewed and approved.
19	x	x	1	MW	7/2/12 10:11	FEEDER		3P HV CONDUCTOR OH	CONNECTOR FAILURE AUTO	100% RESTORED, REPAIRED PERM			
20	x	x	1	MW	7/2/12 18:10	FEEDER		CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED VIA SWITCHING	826967	NO	
21	x	x	1	MW	7/3/12 2:45	FEEDER		LOAD BREAK DISC OH	100% RESTORED VIA SWITCHING				
22	x	x	1	MW	7/3/12 3:45	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	827291	NO	Start time adjusted when job was reviewed and approved.
23	x	x	1	MW	7/3/12 7:18	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	827743	YES	Storm Day
24	x	x	1	MW	7/3/12 3:45	FEEDER		CIRCUIT BREAKER	BREAKER FAILURE OIL CIRCUIT	100% RESTORED VIA SWITCHING	828037	YES	Storm Day
25	x	x	1	MW	7/3/12 7:18	DIST SUBSTATION		BUS/TRANSFORMER	ANIMAL CONTACT OTHER	100% RESTORED, REPAIRED PERM	828434	YES	Storm Day
26	x	x	1	MW	7/4/12 11:04	FEEDER		CIRCUIT BREAKER	DISCONNECT UG	100% RESTORED, REPAIRED PERM	828720	NO	
27	x	x	1	MW	7/4/12 13:47	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	831071	NO	
28	x	x	1	MW	7/4/12 14:29	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	829801	NO	
29	x	x	1	MW	7/6/12 13:06	FEEDER		LOAD BREAK DISC OH	TERMINATOR FAILURE PH	100% RESTORED, REPAIRED PERM	829815	NO	
30	x	x	1	MW	7/6/12 15:10	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	830909	NO	Start time adjusted when job was reviewed and approved.
31	x	x	1	MW	7/6/12 23:37	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	830991	NO	
32	x	x	1	MW	7/9/12 0:57	FEEDER		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	831324	NO	
33	x	x	1	MW	7/10/12 12:42	FEEDER		CIRCUIT BREAKER	VOLTAGE REGULATOR FAILURE	100% RESTORED VIA SWITCHING	831959	NO	
34	x	x	1	MW	7/15/12 9:33	FEEDER		LOAD BREAK DISC OH	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	832558	NO	
35	x	x	1	MW	7/16/12 14:11	FEEDER		CIRCUIT BREAKER	PUBLIC DAMAGE OH LINE	100% RESTORED BY AUTO	835060	NO	
36	x	x	1	MW	7/16/12 14:43	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	835625	NO	
37	x	x	1	MW	7/18/12 14:31	FEEDER		LOAD BREAK DISC OH	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED PERM	836562	NO	Start time adjusted when job was reviewed and approved.
38	x	x	1	MW	7/18/12 6:23	FEEDER		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	836643	NO	
39	x	x	1	MW	7/18/12 14:31	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	836970	NO	
40	x	x	1	MW	7/21/12 22:49	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	838385	NO	
41	x	x	1	MW	7/22/12 21:52	FEEDER		3P HV CONDUCTOR OH	CONNECTOR FAILURE CRIMPED	100% RESTORED, REPAIRED PERM	838706	NO	
42	x	x	1	MW	7/23/12 18:11	FEEDER		LOAD BREAK DISC OH	CONNECTOR FAILURE CRIMPED	100% RESTORED, REPAIRED PERM	839257	NO	
43	x	x	1	MW	7/24/12 1:36	FEEDER		CIRCUIT BREAKER	SWITCH UG OR LOAD CENTER	100% RESTORED VIA SWITCHING	839485	NO	
44	x	x	1	MW	7/24/12 5:18	FEEDER		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	839605	NO	
45	x	x	1	MW	7/24/12 5:38	FEEDER		CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED VIA SWITCHING	839616	NO	
46	x	x	1	MW	7/25/12 3:13	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	839613	NO	
47	x	x	1	MW	7/25/12 17:44	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED, REPAIRED PERM	840575	NO	
48	x	x	1	MW	7/29/12 2:10	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED, REPAIRED PERM	841246	NO	
49	x	x	1	NW	7/18/12 14:00	DIST SUBSTATION		CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED, REPAIRED TEMP	841809	NO	
50	x	x	1	NW	7/30/12 21:27	DIST SUBSTATION		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	835566	NO	
51	x	x	1	NW	7/30/12 21:27	TRANSMISSION LINE/SYSTEM		CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED PERM	842529	NO	
52	x	x	1	NW	7/30/12 21:27	TRANSMISSION LINE/SYSTEM		CIRCUIT BREAKER	REPAIRS NOT NEEDED	REPAIRS NOT NEEDED	842526	NO	
53	x	x	1	NW	7/30/12 21:27	TRANSMISSION LINE/SYSTEM		CIRCUIT BREAKER	DETERMINED	REPAIRS NOT NEEDED	842525	NO	

1a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Monday, July 02, 2012 11:51 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/2/2012

Date In : 7/2/2012

Time Out : 07:38

Time In : 09:50

Time Zone : CST

Duration : 2 hours, 12 mins

Number of Customers Affected : 874

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A truck took down a trans pole with feeder
underbuilt. We had all but 1 customers in at 09:50..

Follow-Up : Trans.to set new pole.

1b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 02, 2012 12:01 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/2/12 - Rosemount - POWER RESTORED
Power outage - Rosemount- power restored.

Wendy

From: Driscoll, Paul M
Sent: Monday, July 02, 2012 11:51 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/2/2012
Time Out : 07:38

Date In : 7/2/2012
Time In : 09:50

Time Zone : CST

Duration : 2 hours, 12 mins

Number of Customers Affected : 874

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A truck took down a trans pole with feeder
underbuilt. We had all but 1 customers in at 09:50..

Follow-Up : Trans. to set new pole.

2a

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, July 02, 2012 11:11 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 19:49 Time In : 22:42

Time Zone : CST

Duration : 2 hours, 53 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BAD FEEDER CABLE BETWEEN AND
FEILD SWITCHED TO PICK UP ALL CUSTOMERS

Follow-Up : WILL HAVE RELAY BIDDLE CABLE AND CREW REPAIR
ASAP

2b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 8:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: al Outage Notice - 7/2/12 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, July 02, 2012 11:11 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 19:49 Time In : 22:42

Time Zone : CST

Duration : 2 hours, 53 mins

Number of Customers Affected : 2194

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : BAD FEEDER CABLE BETWEEN .ND
FEILD SWITCHED TO PICK UP ALL CUSTOMERS

Follow-Up : WILL HAVE RELAY BIDDLE CABLE AND CREW REPAIR
ASAP

8/16/2012

Palmer, Susan L

From: Abbott, Edward J
Sent: Tuesday, July 03, 2012 4:32 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/3/2012 Date In : 7/3/2012
Time Out : 03:33 Time In : 04:28

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1796

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : LARGE LIMB ON FEEDER AT CLEARED
BY TROUBLEMAN. FEEDER BACK INH

Follow-Up :

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 9:05 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/3/12 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, July 03, 2012 4:32 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/3/2012 Date In : 7/3/2012
Time Out : 03:33 Time In : 04:28

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1796

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : n/a

Cause : LARGE LIMB ON FEEDER AT CLEARED
BY TROUBLEMAN. FEEDER BACK INH

Follow-Up :

5a

Palmer, Susan L

From: Gilland, William P
Sent: Friday, July 06, 2012 11:27 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/6/2012
Time Out : 10:38 Time In : 11:22

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 1135

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : def head end cable

Follow-Up :

5b

Palmer, Susan L

From: Preston, Carly
Sent: Friday, July 06, 2012 11:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW Second Outage Notice 7/6/12 Power Restored NORTH OAKS, MN;
SHOREVIEW, MN
7/6/12 Power Restored

NORTH OAKS, MN; SHOREVIEW, MN

From: Gilland, William P
Sent: Friday, July 06, 2012 11:27 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus : 074

Date Out : 7/6/2012
Time Out : 10:38

Date In : 7/6/2012
Time In : 11:22

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 1135

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NORTH OAKS, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : none

Cause : def head end cable

Follow-Up :

6a

Palmer, Susan L

From: Abbott, Edward J
Sent: Thursday, July 12, 2012 10:02 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/12/2012 **Date In :** 7/12/2012
Time Out : 07:42 **Time In :** 08:40

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER BURNT DOWN ON LSO
CUSTOMERS ON AND FEEDER BACK IN

Follow-Up : CREW PUTTING UP FEEDER, FIELD SWITCHED FOR
NOW

6b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, July 12, 2012 10:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/12/12 - Saint Paul
Power outage - Saint Paul
Wendy

From: Abbott, Edward J
Sent: Thursday, July 12, 2012 10:02 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/12/2012
Time Out : 07:42

Date In : 7/12/2012
Time In : 08:40

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1990

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER BURNT DOWN ON CUSTOMERS ON AND FEEDER BACK IN ALSO

Follow-Up : CREW PUTTING UP FEEDER, FIELD SWITCHED FOR NOW

7a

Palmer, Susan L

From: Gilland, William P
Sent: Friday, July 13, 2012 7:39 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/13/2012 **Date In :** 7/13/2012
Time Out : 17:39 **Time In :** 19:25

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 2164

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branch on fdr

Follow-Up : 1482 custs back on at 18:55, 681 additional on at 19:25

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Saturday, July 14, 2012 6:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/13/12 - Maplewood & Woodbury - POWER RESTORED
Power outage - Maplewood & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Friday, July 13, 2012 7:39 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus

Date Out : 7/13/2012 Date In : 7/13/2012
Time Out : 17:39 Time In : 19:25

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 2164

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree branch on fdr

Follow-Up : 1482 custs back on at 18:55, 681 additional on at 19:25

8a

Palmer, Susan L

From: Chial, Terry L
Sent: Sunday, July 15, 2012 7:19 PM
To: dl Electric Outage ME Notification
Subject: inal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/15/2012 Date In : 7/15/2012
Time Out : 18:54 Time In : 19:13

Time Zone : CST

Duration : 0 hours, 19 mins

Number of Customers Affected : 2571

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : PUT UP FEEDER ,CLOSED BKR

Follow-Up : DONE

8b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 16, 2012 8:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: dl Outage Notice - 7/15/12 - Minneapolis & Saint Paul - POWER RESTORED
Power restored - Minneapolis & Saint Paul - POWER RESTORED

Wendy

From: Chial, Terry L
Sent: Sunday, July 15, 2012 7:19 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/15/2012 Date In : 7/15/2012
Time Out : 18:54 Time In : 19:13

Time Zone : CST

Duration : 0 hours, 19 mins

Number of Customers Affected : 2571

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MINNEAPOLIS, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : PUT UP FEEDER ,CLOSED BKR

Follow-Up : DONE

9a

Palmer, Susan L

From: Gilland, William P
Sent: Monday, July 16, 2012 7:57 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 18:01 Time In : 19:33

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 2966

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : combination problem at sub

Follow-Up :

9b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 17, 2012 8:58 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/16/12 - Eagan, Inver Grove Heights & Inver Grove - POWER RESTORED
Power outage - Eagan, Inver Grove Heights & Inver Grove - power restored.

Wendy

From: Gilland, William P
Sent: Monday, July 16, 2012 7:57 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 18:01 Time In : 19:33

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 2966

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : combination problem at sub

Follow-Up :

10a

Palmer, Susan L

From: Abbott, Edward J
Sent: Wednesday, July 18, 2012 3:38 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

nal Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 02:48 Time In : 03:34

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 2564

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FOUND SPAN GUY HIT BY LIGHTING THAT GOT INTO
FEEDER. CLEARED UP BY TROUBLEMAN AND FEEDER BACK IN

Follow-Up :

10b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, July 18, 2012 7:57 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/18/12 - White Bear Lake & White Bear Lk -
POWER RESTORED
Power outage - White Bear Lake & White Bear Lk - power restored.

Wendy

From: Abbott, Edward J
Sent: Wednesday, July 18, 2012 3:38 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 02:48 Time In : 03:34

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 2564

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FOUND SPAN GUY HIT BY LIGHTING THAT GOT INTO
FEEDER. CLEARED UP BY TROUBLEMAN AND FEEDER BACK IN

Follow-Up :

11a

Palmer, Susan L

From: Elden, Thomas L
Sent: Wednesday, July 18, 2012 5:53 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In :
Time Out : 17:38 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2407

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BAYPORT, MN; OAK PARK HEIGHTS, MN;
STILLWATER, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

11b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, July 18, 2012 7:57 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/18/12 - White Bear Lake & White Bear Lk -
POWER RESTORED
Power outage - White Bear Lake & White Bear Lk - power restored.

Wendy

From: Abbott, Edward J
Sent: Wednesday, July 18, 2012 3:38 AM
To: dl Electric Outage ME Notification
Subject: nal Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 02:48 Time In : 03:34

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 2564

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FOUND SPAN GUY HIT BY LIGHTING THAT GOT INTO
FEEDER. CLEARED UP BY TROUBLEMAN AND FEEDER BACK IN

Follow-Up :

12a

Palmer, Susan L

From: Elden, Thomas L
Sent: Thursday, July 19, 2012 4:54 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/19/2012 Date In : 7/19/2012
Time Out : 15:13 Time In : 16:10

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 3717

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bad cable from sub tc repair cable

Follow-Up :

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, July 19, 2012 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/18/12 - Bayport, Oak Park Heights & Stillwater - POWER RESTORED
Power outage - Bayport, Oak Park Heights & Stillwater - power restored.

Wendy

From: Elden, Thomas L
Sent: Wednesday, July 18, 2012 7:24 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 17:38 Time In : 18:59

Time Zone : CST

Duration : 1 hours, 21 mins

Number of Customers Affected : 2407

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BAYPORT, MN; OAK PARK HEIGHTS, MN;
STILLWATER, MN

State : MN - Minnesota

Major Customers :

Cause : unknown

Follow-Up :

130

Palmer, Susan L

From: Elden, Thomas L
Sent: Saturday, July 21, 2012 4:15 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/21/2012 Date In : 7/21/2012
Time Out : 15:17 Time In : 16:08

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 1760

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK
HEIGHTS, MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers : mn

Cause : arm burned up at

Follow-Up : crew is going to repair arm

13b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, July 20, 2012 7:28 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/19/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Thursday, July 19, 2012 4:54 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/19/2012 Date In : 7/19/2012
Time Out : 15:13 Time In : 16:10

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 3717

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bad cable from sub to repair cable

Follow-Up :

14a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Monday, July 23, 2012 2:01 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/23/2012 Date In : 7/23/2012
Time Out : 01:10 Time In : 01:56

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 2026

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers :

Cause : A X-arm burned up at My troubleman
was able to float this phase and we came in with the feeder.

Follow-Up : This arm is very temp and needs to be replaced ASAP.

14b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 23, 2012 9:01 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 7/21/12 - Bayport, Lakeland, Oak Park Heights, Stillwater, Lakeland Twp - POWER RESTORED
Power outage - Bayport, Lakeland, Oak Park Heights, Stillwater, Lakeland Twp - power restored.

Wendy

From: Elden, Thomas L
Sent: Saturday, July 21, 2012 4:15 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/21/2012 Date In : 7/21/2012
Time Out : 15:17 Time In : 16:08

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 1760

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BAYPORT, MN; LAKELAND, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; W LAKELAND TWP, MN

State : MN - Minnesota

Major Customers : mn

Cause : arm burned up at

Follow-Up : OH crew is going to repair arm

150

Palmer, Susan L

From: Elden, Thomas L
Sent: Tuesday, July 24, 2012 5:16 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 04:23 Time In : 05:11

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2338

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : removed tree from feeder

Follow-Up :

15b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 24, 2012 7:47 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/24/12 - Falcon Heights, Maplewood & Saint Paul -
POWER RESTORED
Power outage - Falcon Heights, Maplewood & Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Tuesday, July 24, 2012 5:16 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 04:23 Time In : 05:11

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 2338

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : FALCON HEIGHTS, MN; MAPLEWOOD, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : removed tree from feeder

Follow-Up :

160a

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, July 29, 2012 9:26 AM
To: dl Electric Outage ME Notification
Subject: inal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/29/2012 **Date In :** 7/29/2012
Time Out : 07:41 **Time In :** 09:04

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 4662

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : AFTON, MN; LAKE ELMO, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : mn

Cause : insulators burned up and line came down on arm

Follow-Up : gave job to OH crew to replace insulators

16b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 30, 2012 8:22 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/29/12 - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury - POWER RESTORED
Power outage - Afton, Lake Elmo, Oak Park Heights, Stillwater & Woodbury - power restored.

Wendy

From: Elden, Thomas L
Sent: Sunday, July 29, 2012 9:26 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/29/2012 Date In : 7/29/2012
Time Out : 07:41 Time In : 09:04

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 4662

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : AFTON, MN; LAKE ELMO, MN; OAK PARK HEIGHTS, MN; STILLWATER, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : mn

Cause : insulators burned up and line came down on arm

Follow-Up : gave job to OH crew to replace insulators

17a

Palmer, Susan L

From: Chial, Terry L
Sent: Monday, July 30, 2012 10:22 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/30/2012 Date In : 7/30/2012
Time Out : 21:34 Time In : 22:06

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 2964

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : no

Cause : automatic 336 sleeve let loose

Follow-Up : cut clear and reenergized.

17b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 31, 2012 8:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/30/12 - Eagan, Inver Grove Heights & Inver Grove
- POWER RESTORED
Power outage - Eagan, Inver Grove Heights & Inver Grove - power restored.

Wendy

From: Chial, Terry L
Sent: Monday, July 30, 2012 10:22 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/30/2012 Date In : 7/30/2012
Time Out : 21:34 Time In : 22:06

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 2964

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : no

Cause : automatic : leave let loose

Follow-Up : cut clear and reenergized.

18a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Monday, July 02, 2012 5:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 10:11 Time In : 16:50

Time Zone : CST

Duration : 6 hours, 39 mins

Number of Customers Affected : 54

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN;
ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : broken pole

Follow-Up :

18b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 10:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/2/12 - Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata - POWER RESTORED
Power outage - Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, July 02, 2012 5:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus : 062
Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 10:11 Time In : 16:50

Time Zone : CST

Duration : 6 hours, 39 mins

Number of Customers Affected : 54

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EXCELSIOR, MN; MINNETONKA BCH, MN; NAVARRE, MN;
ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : non

Cause : broken pole

Follow-Up :

19a

Palmer, Susan L

From: Knutson, David A
Sent: Monday, July 02, 2012 7:26 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 18:11 Time In : 19:15

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 2151

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : FAILED HEADEND CABLE

Follow-Up : AT SW SHOWED FAULT

19b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 8:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/2/12 - Crystal, Golden Valley, Minneapolis & New Hope - POWER RESTORED
Power outage - Crystal, Golden Valley, Minneapolis & New Hope - power restored.

Wendy

From: Knutson, David A
Sent: Monday, July 02, 2012 7:26 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus : 075
Date Out : 7/2/2012 Date In : 7/2/2012
Time Out : 18:11 Time In : 19:15

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 2151

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : FAILED HEADEND CABLE

Follow-Up : RFI AT SW SHOWED FAULT

206

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 1:15 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/3/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, July 03, 2012 1:03 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 7/3/2012 Date In : 7/3/2012
Time Out : 02:45 Time In : 05:11

Time Zone : CST

Duration : 2 hours, 26 mins

Number of Customers Affected : 143

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

between Cause : was carrying lue to cable fault from Another fault
and the tie

Follow-Up : First fault has been repaired.

21a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Tuesday, July 03, 2012 6:37 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/3/2012 Date In : 7/3/2012
Time Out : 03:45 Time In : 06:32

Time Zone : CST

Duration : 2 hours, 47 mins

Number of Customers Affected : 1729

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown will need to patrol feeder, possible lightning. operator
operated bkr sw. closed bkr feeder ok.

Follow-Up : all cust. in as of 6:32am, will need to do some field
switching to return feeder to normal.

21b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 9:01 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 7/3/12 - Richfield - POWER RESTORED
Power outage - Richfield - power restored.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 03, 2012 6:37 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/3/2012

Date In : 7/3/2012

Time Out : 03:45

Time In : 06:32

Time Zone : CST

Duration : 2 hours, 47 mins

Number of Customers Affected : 1729

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown will need to patrol feeder, possible lighting operator
operated bkr sw. closed bkr feeder ok.

Follow-Up : all cust. in as of 6:32am, will need to do some field
switching to return feeder to normal.

8/16/2012

22a

Palmer, Susan L

From: Karolevitz, Paul W
Sent: Tuesday, July 03, 2012 11:46 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/3/2012 Date In : 7/3/2012
Time Out : 07:18 Time In : 08:16

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 2706

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;
NAVARRE, MN; ORONO, MN; SHOREWOOD, MN; TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : squirell on buss

Follow-Up :

22b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 03, 2012 9:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 7/3/12 - Chanhassen, Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata
Power outage - Chanhassen, Excelsior, Minnetonka Bch, Navarre, Orono, Shorewood, Tonka Bay & Wayzata.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, July 03, 2012 7:26 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 7/3/2012 Date In :
Time Out : 07:18 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2706

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN;
MINNETONKA BCH, MN; NAVARRE, MN; ORONO, MN; SHOREWOOD, MN;
TONKA BAY, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BUSS LOCK AT EXC. SUB, CAUSE UNKNOWN AT TIME

Follow-Up :

24a

Palmer, Susan L

From: Schwarz, John W
Sent: Wednesday, July 04, 2012 3:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/4/2012 Date In : 7/4/3012
Time Out : 13:47 Time In : 15:13

Time Zone : CST

Duration : 8765809 hours, 26 mins

Number of Customers Affected : 1359

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HEAT. HEAD END CABLE FAILED.. 100% OF CUSTOMERS ARE
RESTORED @15:13

Follow-Up :

24b

Palmer, Susan L

From: Preston, Carly
Sent: Thursday, July 05, 2012 8:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 7/4/12 Power Restored COON RAPIDS, MN
7/4/12 Power Restored

COON RAPIDS, MN

From: Schwarz, John W
Sent: Wednesday, July 04, 2012 3:56 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/4/2012 Date In : 7/4/3012
Time Out : 13:47 Time In : 15:13

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1359

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : HEAT. HEAD END CABLE FAILED.. 100% OF CUSTOMERS ARE
RESTORED @15:13

Follow-Up :

25b

Palmer, Susan L

From: Preston, Carly
Sent: Thursday, July 05, 2012 8:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 7/4/12 Power Restored MINNEAPOLIS, MN
7/4/12 Power Restored

MINNEAPOLIS, MN

From: Knutson, David A
Sent: Wednesday, July 04, 2012 4:35 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/4/2012 Date In : 7/4/2012
Time Out : 14:29 Time In : 16:01

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 3664

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : bad from

Follow-Up : being carried by nd oads are high

26a

Palmer, Susan L

From: Hills, Thomas L
Sent: Friday, July 06, 2012 3:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/6/2012
Time Out : 13:03 Time In : 15:04

Time Zone : CST

Duration : 2 hours, 1 mins

Number of Customers Affected : 570

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : phase jumper burned open at

Follow-Up : All customers restored at 15:04.

266

Palmer, Susan L

From: Preston, Carly
Sent: Friday, July 06, 2012 3:18 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: ; Final Outage Notice 7/6/12 Power Restored EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK, MN
7/6/12 Power Restored

EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK, MN

From: Hills, Thomas L
Sent: Friday, July 06, 2012 3:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/6/2012
Time Out : 13:03 Time In : 15:04

Time Zone : CST

Duration : 2 hours, 1 mins

Number of Customers Affected : 570

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : phase jumper burned open at

Follow-Up : All customers restored at 15:04.

27a

Palmer, Susan L

From: Hills, Thomas L
Sent: Friday, July 06, 2012 4:13 PM
To: dl Electric Outage MW Notification
Subject: SLP. Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/6/2012
Time Out : 15:10 Time In : 16:03

Time Zone : CST

Duration : 0 hours, 53 mins

Number of Customers Affected : 870

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up : All restored.

27b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 09, 2012 9:21 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW Final Outage Notice - 7/6/12 - Edina & Hopkins - POWER RESTORED
Power outage - Edina & Hopkins - power restored.

Wendy

From: Hills, Thomas L
Sent: Friday, July 06, 2012 4:13 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/6/2012
Time Out : 15:10 Time In : 16:03

Time Zone : CST

Duration : 0 hours, 53 mins

Number of Customers Affected : 870

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up : All restored.

28a

Palmer, Susan L

From: Beckius, John J
Sent: Saturday, July 07, 2012 2:35 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/7/2012
Time Out : 23:37 Time In : 01:45

Time Zone : CST

Duration : 2 hours, 8 mins

Number of Customers Affected : 1118

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown possible lightning

Follow-Up :

28b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 09, 2012 9:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/6/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Beckius, John J
Sent: Saturday, July 07, 2012 2:35 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/6/2012 Date In : 7/7/2012
Time Out : 23:37 Time In : 01:45

Time Zone : CST

Duration : 2 hours, 8 mins

Number of Customers Affected : 1118

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown possible lightning

Follow-Up :

29a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Monday, July 09, 2012 7:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2012 Date In : 7/9/2012
Time Out : 00:57 Time In : 07:24

Time Zone : CST

Duration : 6 hours, 27 mins

Number of Customers Affected : 1217

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LESTER PRAIRIE, MN; NEW GERMANY, MN; PLATO, MN;
WINSTED, MN

State : MN - Minnesota

Major Customers : non

Cause : Bad regulator at the sub.

Follow-Up : sw. out for repair / ASAP

29b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 09, 2012 9:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: al Outage Notice - 7/9/12 - Lester Prairie, New Germany, Plato & Winsted - POWER RESTORED
Power outage - Lester Prairie, New Germany, Plato & Winsted - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, July 09, 2012 7:57 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/9/2012 Date In : 7/9/2012
Time Out : 00:57 Time In : 07:24

Time Zone : CST

Duration : 6 hours, 27 mins

Number of Customers Affected : 1217

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LESTER PRAIRIE, MN; NEW GERMANY, MN; PLATO, MN;
WINSTED, MN

State : MN - Minnesota

Major Customers : non

Cause : Bad regulator at the sub.

Follow-Up : sw. out for repair / ASAP

30a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Tuesday, July 10, 2012 1:48 PM
To: dl Electric Outage MW Notification
Subject: inal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/10/2012 Date In : 7/10/2012
Time Out : 12:42 Time In : 13:39

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 1267

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : CABLE FAULT BTWN SWITCH

Follow-Up :

306

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 10, 2012 1:57 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW Final Outage Notice - 7/10/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, July 10, 2012 1:48 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/10/2012 Date In : 7/10/2012
Time Out : 12:42 Time In : 13:39

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 1267

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : CABLE FAULT BTWN & SWITCH

Follow-Up :

31a

Palmer, Susan L

From: Schwarz, John W
Sent: Sunday, July 15, 2012 3:07 PM
To: dl Electric Outage MW Notification
Subject: nal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/15/2012 Date In : 7/15/2012
Time Out : 09:33 Time In : 15:00

Time Zone : CST

Duration : 5 hours, 27 mins

Number of Customers Affected : 6321

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN;
EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CONSTRUCTION EQUIPMENT MADE CONTACT WITH THE FEEDER.
5327 CUSTOMERS IN @ 09:33 BY RECLOSE. 994 IN @ 11:18, AND REMAINING CUSTOMERS
RESTORED @ 15:00

Follow-Up :

31b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 16, 2012 8:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/15/12 - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - POWER RESTORED
Power outage - Chanhassen, Chaska, Eden Prairie, Excelsior, Minnetonka, Shorewood & Victoria - power restored.

Wendy

From: Schwarz, John W
Sent: Sunday, July 15, 2012 3:07 PM
To: dl Electric Outage ^{MM} Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/15/2012 Date In : 7/15/2012
Time Out : 09:33 Time In : 15:00

Time Zone : CST

Duration : 5 hours, 27 mins

Number of Customers Affected : 6321

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; EDEN PRAIRIE, MN;
EXCELSIOR, MN; MINNETONKA, MN; SHOREWOOD, MN; VICTORIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CONSTRUCTION EQUIPMENT MADE CONTACT WITH THE FEEDER.
5327 CUSTOMERS IN @ 09:33 BY RECLOSE. 994 IN @ 11:18, AND REMAINING CUSTOMERS
RESTORED @ 15:00

Follow-Up :

32a

Palmer, Susan L

From: Hills, Thomas L
Sent: Monday, July 16, 2012 4:17 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:11 Time In : 15:45

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 913

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up : All restored at 1545.

32b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 17, 2012 8:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/16/12 - Bloomington, Eden Prairie & Edina - POWER RESTORED

Power outage - Bloomington, Eden Prairie & Edina - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, July 16, 2012 4:17 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:11 Time In : 15:45

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 913

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up : All restored at 1545.

8/16/2012

33a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Monday, July 16, 2012 3:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:41 Time In : 15:42

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 1090

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK,

MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE BRANCH ACROSS ST. FROM
BRANCH REMOVED BY TRBL.BRANCH ON ALL 3 PHASES.

Follow-Up : ALL CUST. RESTORED AS OF 1542.PICKED UP
REMAINING 967 CUST.

33b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 16, 2012 3:59 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/16/12 - Edina, Hopkins & Saint Louis Park -
POWER RESTORED
Power outage - Edina, Hopkins & Saint Louis Park - power restored.

Wendy

From: Ayers, Patrick S
Sent: Monday, July 16, 2012 3:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:41 Time In : 15:42

Time Zone : CST

Duration : 1 hours, 1 mins

Number of Customers Affected : 1090

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : EDINA, MN; HOPKINS, MN; SAINT LOUIS PARK,
MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE BRANCH ACROSS ST. FROM
BRANCH REMOVED BY TRBL.BRANCH ON ALL 3 PHASES.

Follow-Up : ALL CUST. RESTORED AS OF 1542.PICKED UP
REMAINING 967 CUST.

34a

Palmer, Susan L

From: Hills, Thomas L
Sent: Wednesday, July 18, 2012 8:04 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 06:23 Time In : 07:57

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 2804

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown - Possibly trees along

Follow-Up :

34b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, July 18, 2012 8:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/18/12 - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - POWER RESTORED
Power outage - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, July 18, 2012 8:04 AM
To: dl Electric Outage MW Notification
Subject: al Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 06:23 Time In : 07:57

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 2804

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown - Possibly trees along

Follow-Up :

35a

Palmer, Susan L

From: Hills, Thomas L
Sent: Wednesday, July 18, 2012 3:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 14:31 Time In : 15:44

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 914

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up :

35b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, July 18, 2012 4:01 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/18/12 - Bloomington, Eden Prairie & Edina - POWER RESTORED

Power outage - Bloomington, Eden Prairie & Edina - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, July 18, 2012 3:47 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/18/2012 Date In : 7/18/2012
Time Out : 14:31 Time In : 15:44

Time Zone : CST

Duration : 1 hours, 13 mins

Number of Customers Affected : 914

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN; EDINA, MN

State : MN - Minnesota

Major Customers : None

Cause : Bad head end cable.

Follow-Up :

7360

Palmer, Susan L

From: Hills, Thomas L
Sent: Sunday, July 22, 2012 12:26 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/21/2012 Date In : 7/22/2012
Time Out : 22:49 Time In : 00:12

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1577

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : Cable

Follow-Up :

36b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 23, 2012 8:42 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/21/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Hills, Thomas L
Sent: Sunday, July 22, 2012 12:26 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/21/2012 Date In : 7/22/2012
Time Out : 22:49 Time In : 00:12

Time Zone : CST

Duration : 1 hours, 23 mins

Number of Customers Affected : 1577

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : Cable

Follow-Up :

37a

Palmer, Susan L

From: Hills, Thomas L
Sent: Monday, July 23, 2012 12:38 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/22/2012 Date In : 7/23/2012
Time Out : 21:52 Time In : 00:17

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 2036

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Wirre down at ntentional outage needed for crew to put line
back up.

Follow-Up : All restored at 0017.

37b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 23, 2012 8:44 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: ' Final Outage Notice - 7/22/12 - Minneapolis, Richfield & Woodbury - POWER RESTORED

Power outage - Minneapolis, Richfield & Woodbury - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, July 23, 2012 12:38 AM
To: dl Electric Outage MW Notification
Subject: , Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/22/2012 Date In : 7/23/2012
Time Out : 21:52 Time In : 00:17

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 2036

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Wirre down at ntentional outage needed for crew to put line

back up.

Follow-Up : All restored at 0017.

38a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Monday, July 23, 2012 8:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/23/2012 Date In : 7/23/2012
Time Out : 18:11 Time In : 20:47

Time Zone : CST

Duration : 2 hours, 36 mins

Number of Customers Affected : 2817

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : non

Cause : phase jumper on burnt off...repaired.

Follow-Up :

386

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 24, 2012 7:33 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/23/12 - Edina, Minneapolis & Saint Louis Park
- POWER RESTORED

Power outage - Edina, Minneapolis & Saint Louis Park - power restored.

Wendy

From: Kittock, Joseph C
Sent: Monday, July 23, 2012 8:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/23/2012 Date In : 7/23/2012
Time Out : 18:11 Time In : 20:47

Time Zone : CST

Duration : 2 hours, 36 mins

Number of Customers Affected : 2817

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : non

Cause : Phase jumper on burnt off...repaired.

Follow-Up :

39a

Palmer, Susan L

From: Aspinwall, David P
Sent: Tuesday, July 24, 2012 4:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 01:36 Time In : 03:04

Time Zone : CST

Duration : 1 hours, 28 mins

Number of Customers Affected : 1577

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : BAD , NO VISUAL SIGNS OF DAMAGE BUT CAUSED FEEDER

LOCK.

Follow-Up : THAT IS ALL.

39b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 24, 2012 7:42 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/24/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Aspinwall, David P
Sent: Tuesday, July 24, 2012 4:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

: Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 01:36 Time In : 03:04

Time Zone : CST

Duration : 1 hours, 28 mins

Number of Customers Affected : 1577

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : BAD , NO VISUAL SIGNS OF DAMAGE BUT CAUSED FEEDER

LOCK.

Follow-Up : THAT IS ALL.

8/16/2012

400

Palmer, Susan L

From: Karolevitz, Paul W
Sent: Tuesday, July 24, 2012 7:28 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 05:18 Time In : 06:52

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 1374

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : patrolled and found no cause. Possible lighting strike

Follow-Up :

40b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 24, 2012 7:54 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW Final Outage Notice - 7/24/12 - Burnsville - POWER RESTORED
Power outage - Burnsville - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, July 24, 2012 7:28 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 05:18 Time In : 06:52

Time Zone : CST

Duration : 1 hours, 34 mins

Number of Customers Affected : 1374

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BURNSVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : patrolled and found no cause. Possible lighting strike

Follow-Up :

4a

Palmer, Susan L

From: Schwarz, John W
Sent: Tuesday, July 24, 2012 7:34 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 05:38 Time In : 07:24

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 3283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FEEDER WIRE DOWN ON

Follow-Up :

41b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 24, 2012 7:58 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/24/12 - Hamel, Medina, Minneapolis, Plymouth & Wayzata - POWER RESTORED
Power outage - Hamel, Medina, Minneapolis, Plymouth & Wayzata - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, July 24, 2012 7:34 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/24/2012 Date In : 7/24/2012
Time Out : 05:38 Time In : 07:24

Time Zone : CST

Duration : 1 hours, 46 mins

Number of Customers Affected : 3283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FEEDER WIRE DOWN ON

Follow-Up :

42a

Palmer, Susan L

From: Aspinwall, David P
Sent: Wednesday, July 25, 2012 4:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/25/2012 Date In : 7/25/2012
Time Out : 03:13 Time In : 04:17

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1866

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : FAULTED CABLE BETWEEN THE AND SWITCHES.

Follow-Up : THAT IS ALL.

42b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, July 25, 2012 8:53 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/25/12 - Chanhassen & Eden Prairie - POWER RESTORED

Power outage - Chanhassen & Eden Prairie - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, July 25, 2012 4:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/25/2012 Date In : 7/25/2012
Time Out : 03:13 Time In : 04:17

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1866

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : FAULTED CABLE BETWEEN THE AND SWITCHES.

Follow-Up : THAT IS ALL.

430

Palmer, Susan L

From: Knutson, David A
Sent: Thursday, July 26, 2012 7:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/26/2012 Date In : 7/26/2012
Time Out : 17:44 Time In : 19:04

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 2914

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN;
SHOREWOOD, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME

Follow-Up : PHASE TIME TARGET ON STILL PATROLLING AT THIS

TIME

43b

Palmer, Susan L

From: Preston, Carly
Sent: Friday, July 27, 2012 9:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 7/26/12 Update CHANHASSEN, MN;
EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD, MN
7/26/12 Update

CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN; SHOREWOOD, MN

From: Knutson, David A
Sent: Thursday, July 26, 2012 7:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus : 061, 062
Date Out : 7/26/2012 Date In : 7/26/2012
Time Out : 17:44 Time In : 19:04

Time Zone : CST

Duration : 1 hours, 20 mins

Number of Customers Affected : 2914

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EDGERTON, MN; EXCELSIOR, MN;
SHOREWOOD, MN

State : MN - Minnesota

Major Customers :

Cause : UNKNOWN AT THIS TIME

Follow-Up : PHASE TIME TARGET ON : STILL PATROLLING AT THIS

TIME

440

Palmer, Susan L

From: Schwarz, John W
Sent: Sunday, July 29, 2012 6:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 7/29/2012 Date In : 7/29/2012
Time Out : 02:10 Time In : 06:10

Time Zone : CST

Duration : 4 hours, 0 mins

Number of Customers Affected : 4620

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PUBLIC DAMAGE,, BROKEN POLE @ THREE PARTIAL
RESTORATIONS 100% RESTORED @ 06:10

Follow-Up :

44b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 30, 2012 8:26 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 7/29/12 - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - POWER RESTORED

Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Schwarz, John W
Sent: Sunday, July 29, 2012 6:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 311

Date Out : 7/29/2012 Date In : 7/29/2012
Time Out : 02:10 Time In : 06:10

Time Zone : CST

Duration : 4 hours, 0 mins

Number of Customers Affected : 4620

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PUBLIC DAMAGE,, BROKEN POLE @ .. THREE PARTIAL
RESTORATIONS 100% RESTORED @ 06:10

Follow-Up :

Palmer, Susan L

From: Medellin, Victor J
Sent: Monday, July 16, 2012 3:56 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:00 Time In : 15:33

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 1830

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTICELLO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TROBLEMAN REPLACED 2 HIGH SIDE FUSES ON
ALL CUSTOMERS 100% RESTORED TO OIL SAMPLE TX. NO VISIBLE
SIGNS OF DAMAGE AT THE SUB

Follow-Up :

45b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 16, 2012 4:04 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 7/16/12 - Monticello - POWER RESTORED
Power outage - Monticello - power restored.

Wendy

From: Medellin, Victor J
Sent: Monday, July 16, 2012 3:56 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/16/2012 Date In : 7/16/2012
Time Out : 14:00 Time In : 15:33

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 1830

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MONTICELLO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TROUBLEMAN REPLACED ; HIGH SIDE FUSES ON
ALL CUSTOMERS 100% RESTORED TO OIL SAMPLE TX. NO VISIBLE
SIGNS OF DAMAGE AT THE SUB

Follow-Up :

4600

Palmer, Susan L

From: Peterson, Mark S
Sent: Monday, July 30, 2012 11:12 PM
To: dl Electric Outage NT Notification
Subject: nd Outage Notice
Distribution System Status Outage Notification

1 Outage Notice

Feeder/Bus :

Date Out : 7/30/2012 Date In : 7/30/2012
Time Out : 21:27 Time In : 23:05

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 2874

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; DELANO, MN; HOWARD LAKE,
MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : none

Cause :

Follow-Up : 2874 customers picked up.. 1002 remain out until repairs
are made.

466b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 31, 2012 8:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: 2ND Outage Notice - 7/30/12 -
Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - UPDATE
Power outage - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - update.

Wendy

From: Peterson, Mark S
Sent: Monday, July 30, 2012 11:12 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 7/30/2012

Date In : 7/30/2012

Time Out : 21:27

Time In : 23:05

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 2874

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; DELANO, MN; HOWARD LAKE,
MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : none

Cause : UNKNOWN

Follow-Up : 2874 customers picked up.. 1002 remain out until repairs
are made.

8/16/2012

46c

Palmer, Susan L

From: Peterson, Mark S
Sent: Monday, July 30, 2012 11:40 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 7/30/2012 Date In : 7/30/2012
Time Out : 21:27 Time In : 23:31

Time Zone : CST

Duration : 2 hours, 4 mins

Number of Customers Affected : 1002

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COKATO, MN; HOWARD LAKE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : final 1002 customers picked up at this time

460d

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, July 31, 2012 8:51 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: 3RD Outage Notice - 7/30/12 - Cokato & Howard
Lake - POWER RESTORED
Power outage - Cokato & Howard Lake - power restored.

Wendy

From: Peterson, Mark S
Sent: Monday, July 30, 2012 11:40 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

rd Outage Notice

Feeder/Bus :

Date Out : 7/30/2012 Date In : 7/30/2012
Time Out : 21:27 Time In : 23:31

Time Zone : CST

Duration : 2 hours, 4 mins

Number of Customers Affected : 1002

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COKATO, MN; HOWARD LAKE, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown

Follow-Up : final 1002 customers picked up at this time

#	Report	email to PUC	Count	Region	Time	Name	Outage Level	Device Type	Cause	Follow-Up	Event Index	Escalated	Comments
1	x	x	1	ME	8/1/12 0:25		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	844119	NO	
2	x	x	1	ME	8/3/12 23:25		FEEDER	CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED VIA SWITCHING	847081	YES	Storm Day - time was adjusted when reviewed and approved.
3	x	x	1	ME	8/3/12 23:26		FEEDER	LOAD BREAK DISC OH	LIGHTNING STRIKE	100% RESTORED, REPAIRED	847082	YES	Storm Day - time was adjusted when reviewed and approved.
4	x	x	1	ME	8/3/12 23:47		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED	845188	YES	Storm Day - disturbance report not found.
5	x	x	1	ME	8/4/12 1:31		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED	845371	NO	
6	x	x	1	ME	8/23/12 23:47		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	PARTIAL RESTORATION	854306	NO	
7	x	x	1	ME	8/23/12 23:56		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE AUTO SPLICE	100% RESTORED VIA SWITCHING	854057	NO	
8	x	x	1	ME	8/24/12 0:03		DIST SUBSTATION	CIRCUIT BREAKER	ACCIDENTAL COORDINATION ERRO	100% RESTORED, REPAIRED	854090	NO	
9	x	x	1	ME	8/26/12 13:46		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED	854198	NO	
10	x	x	1	ME	8/25/12 18:49		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE AUTO SPLICE	100% RESTORED VIA SWITCHING	854302	NO	
11	x	x	1	ME	8/30/12 14:45		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED, REPAIRED	854946	NO	
12	x	x	1	ME	8/30/12 15:19		FEEDER	CIRCUIT BREAKER	SPLICE UG PRIMARY HEAT SHRINK	100% RESTORED VIA SWITCHING	854950	NO	
13	x	x	1	MW	8/3/02 22:42		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	844510	YES	Storm Day
14	x	x	1	MW	8/3/12 22:43		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	844466	YES	Storm Day
15	x	x	1	MW	8/3/12 23:08		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT	REPAIRS NOT NEEDED	844632	YES	Storm Day
16	x	x	1	MW	8/3/12 23:18		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED	844774	YES	Storm Day
17	x	x	1	MW	8/3/12 23:19		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED VIA SWITCHING	844775	YES	Storm Day
18	x	x	1	MW	8/6/12 2:13		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED, REPAIRED	846590	NO	
19	x	x	1	MW	8/21/12 18:41		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	851937	NO	
20	x	x	1	MW	8/23/12 3:32		FEEDER	CIRCUIT BREAKER	ANIMAL CONTACT OH	100% RESTORED, REPAIRED	852329	NO	
21	x	x	1	NW	8/2/12 16:38		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	843780	NO	
22	x	x	1	NW	8/3/12 21:55		DIST SUBSTATION	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	844414	YES	Storm Day - time was adjusted when reviewed and approved.
23	x	x	1	NW	8/3/12 22:27		FEEDER	2P CONDUCTOR OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED	844434	YES	Storm Day
24	x	x	1	NW	8/11/12 5:00		FEEDER	CIRCUIT BREAKER	XCEL PLANNED CONSTRUCTION	100% RESTORED, REPAIRED	848511	NO	
25	x	x	1	SE	8/1/12 9:23		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE OTHER/UNKNOWN	100% RESTORED, REPAIRED	843122	NO	
26	x	x	1	SE	8/4/12 0:04		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	845273	YES	Storm Day
27	x	x	1	SE	8/4/12 0:05		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED	845275	YES	Storm Day
28	x	x	1	SE	8/14/12 3:50		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRIMARY LC	100% RESTORED VIA SWITCHING	849241	NO	
29	x	x	1	SE	8/19/12 5:49		DIST SUBSTATION	CIRCUIT BREAKER	ANIMAL CONTACT OH	100% RESTORED VIA SWITCHING	850805	NO	

Palmer, Susan L

From: Gilland, William P
Sent: Wednesday, August 01, 2012 2:17 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/1/2012 Date In : 8/1/2012
Time Out : 00:25 Time In : 02:09

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 7109

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree on fdr at :

Follow-Up : remaining 1277 cust's back on

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, August 01, 2012 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/1/12 - Afton, Saint Paul & Woodbury - POWER RESTORED
Power outage - Afton, Saint Paul & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Wednesday, August 01, 2012 2:17 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/1/2012 Date In : 8/1/2012
Time Out : 00:25 Time In : 02:09

Time Zone : CST

Duration : 1 hours, 44 mins

Number of Customers Affected : 7109

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : tree on fdr at

Follow-Up : remaining 1277 cust's back on

2a 3a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Saturday, August 04, 2012 3:00 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 Date In : 8/5/2012
Time Out : 23:27 Time In : 01:55

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 9477

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BLAINE, MN; CENTERVILLE, MN; CIRCLE PINES, MN; HUGO, MN; LINO LAKES, MN; NORTH OAKS, MN; NORTH SAINT PAUL, MN; SAINT PAUL, MN; SHOREVIEW, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : A line from me down on l .Our
troublemen cleared this and got all customers on at 01:55

Follow-Up : Lines will need to be put back up..

(2b) (3b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 8:57 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: econd Outage Notice - Blaine, Centerville, Circle Pines, Hugo, Lino Lakes, North Oaks, No St. Paul, Saint Paul & Shoreview. Stillwater, White Bear Lake, White Bear - POWER RESTORED

Power outage - Blaine, Centerville, Circle Pines, Hugo, Lino Lakes, North Oaks, No St. Paul, Saint Paul & Shoreview. Stillwater, White Bear Lake, White Bear - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, August 04, 2012 3:00 AM
To: dl Electric Outage ME Notification
Subject: cond Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus : 311, 322

Date Out : 8/4/2012

Date In : 8/5/2012

Time Out : 23:27

Time In : 01:55

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 9477

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : BLAINE, MN; CENTERVILLE, MN; CIRCLE PINES, MN; HUGO, MN; LINO LAKES, MN; NORTH OAKS, MN; NORTH SAINT PAUL, MN; SAINT PAUL, MN; SHOREVIEW, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : A line from me down on . Our
troublemen cleared this and got all customers on at 01:55

Follow-Up : Lines will need to be put back up..

Palmer, Susan L

From: Driscoll, Paul M
Sent: Saturday, August 04, 2012 3:06 AM
To: dl Electric Outage ME Notification
Subject: econd Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 **Date In :** 8/4/2012
Time Out : 01:31 **Time In :** 02:48

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 1335

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NORTH SAINT PAUL, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : We have an unfused tap at _____, this
came down and took out the feeder.

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:15 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/4/12 - Maplewood, North Saint Paul & Saint Paul - POWER RESTORED
Power outage - Maplewood, North Saint Paul & Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, August 04, 2012 3:06 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/4/2012

Date In : 8/4/2012

Time Out : 01:31

Time In : 02:48

Time Zone : CST

Duration : 1 hours, 17 mins

Number of Customers Affected : 1335

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NORTH SAINT PAUL, MN;
SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : We have an unfused tap at
came down and took out the feeder.

,this

Follow-Up :

60a

Palmer, Susan L

From: Chial, Terry L
Sent: Friday, August 24, 2012 10:08 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/23/2012 Date In : 8/24/2012
Time Out : 23:47 Time In : 02:00

Time Zone : CST

Duration : 2 hours, 13 mins

Number of Customers Affected : 1823

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell across feeder witted out
area with switching and cut jumpers

Follow-Up : everyone was in but 12 transformers at 02:00

6b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, August 24, 2012 10:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: : utage Notice - 8/23/12 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Friday, August 24, 2012 10:08 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/23/2012 Date In : 8/24/2012

Time Out : 23:47 Time In : 02:00

Time Zone : CST

Duration : 2 hours, 13 mins

Number of Customers Affected : 1823

For information about this alert, contact :

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell across feeder , switched out
area with switching and cut jumpers

Follow-Up : everyone was in but 12 transformers at 02:00

7a

Palmer, Susan L

From: Chial, Terry L
Sent: Friday, August 24, 2012 10:28 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/23/2012 Date In : 8/24/2012
Time Out : 23:35 Time In : 04:44

Time Zone : CST

Duration : 5 hours, 9 mins

Number of Customers Affected : 2602

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL,
MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : no

Cause : sleeve let loose .did not confirm if it was an
automatic

Follow-Up : 100 % 04:44

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, August 24, 2012 7:44 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Outage Notice - 8/24/12 - Maplewood, Newport, Saint Paul & Woodbury
Power outage - Maplewood, Newport, Saint Paul & Woodbury
Wendy

From: Driscoll, Paul M
Sent: Friday, August 24, 2012 12:23 AM
To: dl Electric Outage MF Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/24/2012 Date In :
Time Out : 23:55 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2602

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Storm

Follow-Up :

8a

Palmer, Susan L

From: Chial, Terry L
Sent: Friday, August 24, 2012 11:18 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/24/2012 Date In : 8/24/2012
Time Out : 00:03 Time In : 01:22

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1768

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : relay misop bus trip for fault corrected time in was
01:22 not 12:20

Follow-Up : refered to relay dept

8b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, August 24, 2012 11:21 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/24/12 - Newport, Saint Paul Park, Saint Paul & Woodbury
Power outage - Newport, Saint Paul Park, Saint Paul & Woodbury - power restored.

Wendy

From: Chial, Terry L
Sent: Friday, August 24, 2012 11:18 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/24/2012 Date In : 8/24/2012
Time Out : 00:03 Time In : 01:22

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1768

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : relay misop bus trip for ault corrected time in was
01:22 not 12:20

Follow-Up : refered to relay dept

Qa

Palmer, Susan L

From: Elden, Thomas L
Sent: Saturday, August 25, 2012 2:40 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

al Outage Notice

Feeder/Bus :

Date Out : 8/25/2012 Date In : 8/25/2012
Time Out : 13:45 Time In : 14:33

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 1748

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : imb on feeder line removed limb 100% of
the customers are back on at 14:33

Follow-Up :

9b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 27, 2012 8:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/25/12 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Eiden, Thomas L
Sent: Saturday, August 25, 2012 2:40 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/25/2012 Date In : 8/25/2012
Time Out : 13:45 Time In : 14:33

Time Zone : CST

Duration : 0 hours, 48 mins

Number of Customers Affected : 1748

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : limb on feeder line removed limb 100% of
the customers are back on at 14:33

Follow-Up :

10a

Palmer, Susan L

From: Elden, Thomas L
Sent: Saturday, August 25, 2012 8:56 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/25/2012 Date In : 8/25/2012
Time Out : 18:49 Time In : 20:51

Time Zone : CST

Duration : 2 hours, 2 mins

Number of Customers Affected : 1462

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LANDFALL VLG, MN; LANDFALL, MN;
MAPLEWOOD, MN; OAKDALE, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : here was wire down eveyone was back on
at 20:51 repaired temp

Follow-Up :

10b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 27, 2012 8:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/25/12 - Landfall Vlg, Landfall, Maplewood, Oakdale, Saint Paul & Woodbury - POWER RESTORED
Power outage - Landfall Vlg, Landfall, Maplewood, Oakdale, Saint Paul & Woodbury - power restored.

Wendy

From: Elden, Thomas L
Sent: Saturday, August 25, 2012 8:56 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/25/2012 Date In : 8/25/2012
Time Out : 18:49 Time In : 20:51

Time Zone : CST

Duration : 2 hours, 2 mins

Number of Customers Affected : 1462

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LANDFALL VLG, MN; LANDFALL, MN;
MAPLEWOOD, MN; OAKDALE, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : there was wire down eveyone was back on
at 20:51 repaired temp

Follow-Up :

11a

Palmer, Susan L

From: Chial, Terry L
Sent: Thursday, August 30, 2012 4:32 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/30/2012 Date In : 8/30/2012
Time Out : 14:45 Time In : 16:00

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 2066

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : no

Cause : bad feeder cable

Follow-Up : will biddle and repair asap

11b

Palmer, Susan L

From: Preston, Carly
Sent: Thursday, August 30, 2012 4:34 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Outage Notice 8/30/12 Power Restored LAKEVILLE, MN
8/30/12 Power Restored

LAKEVILLE, MN

From: Chial, Terry L
Sent: Thursday, August 30, 2012 4:32 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/30/2012 Date In : 8/30/2012
Time Out : 14:45 Time In : 16:00

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 2066

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LAKEVILLE, MN

State : MN - Minnesota

Major Customers : no

Cause : bad feeder cable

Follow-Up : will biddle and repair asap

12a

Palmer, Susan L

From: Chial, Terry L
Sent: Thursday, August 30, 2012 5:04 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/30/2012 Date In : 8/30/2012
Time Out : 15:19 Time In : 17:00

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 683

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers : ecolab ups

Cause : bad head end cable sub to

Follow-Up : biddle and repair .

Palmer, Susan L

From: Preston, Carly
Sent: Friday, August 31, 2012 7:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 8/30/12 Power Restored EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN
8/30/12 Power Restored

EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

From: Chial, Terry L
Sent: Thursday, August 30, 2012 5:04 PM
To: dl Electric Outage ME Notification
Subject: al Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/30/2012 Date In : 8/30/2012
Time Out : 15:19 Time In : 17:00

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 683

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN

State : MN - Minnesota

Major Customers :

Cause : bad head end cable sub to

Follow-Up : biddle and repair .

13a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 5:09 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:42 Time In : 04:59

Time Zone : CST

Duration : 6 hours, 17 mins

Number of Customers Affected : 1209

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;
WACONIA TWP, MN; WACONIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER, TREE ON FDR

Follow-Up : PATROL, REMOVE TREE

13b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:23 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/3/12 - Cologne, Mayer, New Germany, Nya, Waconia Twp & Waconia - POWER RESTORED 8/4
Power outage - Cologne, Mayer, New Germany, Nya, Waconia Twp & Waconia - power restored - 8/4

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 5:09 AM
To: dl Electric Outage MW Notification
Subject: al Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:42 Time In : 04:59

Time Zone : CST

Duration : 6 hours, 17 mins

Number of Customers Affected : 1209

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;
WACONIA TWP, MN; WACONIA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER, TREE ON FDR

Follow-Up : PATROL, REMOVE TREE

Palmer, Susan L

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 5:51 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:43 Time In : 05:46

Time Zone : CST

Duration : 7 hours, 3 mins

Number of Customers Affected : 1440

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER, TREE

Follow-Up : PATROL, REMOVE TREE

14b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:19 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Mayer, Waconia & Watertown - POWER RESTORED

Power outage - Mayer, Waconia & Watertown - power restored.

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 5:51 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:43 Time In : 05:46

Time Zone : CST

Duration : 7 hours, 3 mins

Number of Customers Affected : 1440

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER, TREE

Follow-Up : PATROL, REMOVE TREE

15a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 1:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:08 Time In : 00:59

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 919

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER

Follow-Up : PATROL

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 8:50 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/3/12 - Deephaven, Excelsior, Minnetonka & Wayzata - POWER RESTORED
Power outage - Deephaven, Excelsior, Minnetonka & Wayzata - power restored.

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 1:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:08 Time In : 00:59

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 919

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; MINNETONKA, MN;
WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WEATHER

Follow-Up : PATROL

16a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 1:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:18 Time In : 01:06

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 2265

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : WEATHER

Follow-Up : PATROL, CREATE JOB TO TRANSFER BACK
CYPRESS

16b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 8:54 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Outage Notice - 8/3/12 - Bloomington & Eagan - POWER RESTORED
Power outage - Bloomington & Eagan - power restored.

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 1:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:18 Time In : 01:06

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 2265

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : WEATHER

Follow-Up : PATROL, CREATE JOB TO TRANSFER BACK
CYPRESS

17a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 4:21 AM
To: dl Electric Outage MW Notification
Subject: inal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:19 Time In : 04:15

Time Zone : CST

Duration : 4 hours, 56 mins

Number of Customers Affected : 2700

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FDR

Follow-Up : PATROL, REMOVE TREE, RESTORE BRKR WILL NOT CLOSE BY
RC OR LOCAL, ISOLATE, FIELD SWITCH FDR BACK IN

17b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:02 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: itage Notice - 8/3/12 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored..

Wendy

From: Anderson, Timothy K
Sent: Saturday, August 04, 2012 4:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 23:19 Time In : 04:15

Time Zone : CST

Duration : 4 hours, 56 mins

Number of Customers Affected : 2700

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FDR

Follow-Up : PATROL, REMOVE TREE, RESTORE. BRKR WILL NOT CLOSE BY
RC OR LOCAL, ISOLATE, FIELD SWITCH FDR BACK IN

18a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Monday, August 06, 2012 5:18 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/6/2012 Date In : 8/6/2012
Time Out : 2:13 Time In : 4:38

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 2819

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FDR CABLE FAULT BTWN

Follow-Up : ISOLATE,RESTORE

18b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:37 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/6/12 - Eden Prairie - POWER RESTORED
Power outage - Eden Prairie - power restored.

Wendy

From: Anderson, Timothy K
Sent: Monday, August 06, 2012 5:18 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 091

Date Out : 8/6/2012 Date In : 8/6/2012
Time Out : 2:13 Time In : 4:38

Time Zone : CST

Duration : 2 hours, 25 mins

Number of Customers Affected : 2819

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FDR CABLE FAULT BTWN

Follow-Up : ISOLATE,RESTORE

19a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Tuesday, August 21, 2012 7:37 PM
To: dl Electric Outage MW Notification
Subject: Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/21/2012 Date In : 8/21/2012
Time Out : 18:41 Time In : 19:32

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 2794

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : Headend cable bad

Follow-Up : arrying

19b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, August 22, 2012 7:27 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/21/12 - Coon Rapids - POWER RESTORED
Power outage - Coon Rapids - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Tuesday, August 21, 2012 7:37 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/21/2012 Date In : 8/21/2012
Time Out : 18:41 Time In : 19:32

Time Zone : CST

Duration : 0 hours, 51 mins

Number of Customers Affected : 2794

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers :

Cause : Headend cable bad

Follow-Up : Carrying

20a

Palmer, Susan L

From: Knutson, David A
Sent: Thursday, August 23, 2012 6:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 8/23/2012 Date In : 8/23/2012
Time Out : 03:32 Time In : 06:11

Time Zone : CST

Duration : 2 hours, 39 mins

Number of Customers Affected : 1140

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : WINSTED, MN

State : MN - Minnesota

Major Customers : none

Cause : raccoon on tap line with no cutout troubleman cleared up wire feeder back
on at 0611

Follow-Up : troubleman going back to install cutout and put tap wire back up if he can

20b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, August 23, 2012 7:58 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: ' Final Outage Notice - 8/23/12 - Winsted - POWER RESTORED
Power outage - Winsted - power restored.

Wendy

From: Knutson, David A
Sent: Thursday, August 23, 2012 6:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/23/2012 Date In : 8/23/2012
Time Out : 03:32 Time In : 06:11

Time Zone : CST

Duration : 2 hours, 39 mins

Number of Customers Affected : 1140

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : WINSTED, MN

State : MN - Minnesota

Major Customers : none

Cause : raccoon on tap line with no cutout troubleman cleared up wire feeder back
on at 0611

Follow-Up : troubleman going back to install cutout and put tap wire back up if he can

21a

Palmer, Susan L

From: Vorachek, Kelly
Sent: Thursday, August 02, 2012 4:08 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 8/2/2012 Date In : 8/2/2012
Time Out : 15:38 Time In : 15:47

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 2329

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Feeder Cable failed btwn
under U-Guard, feeder tied together with doing restoration or caused both feeders
to lock out.

Follow-Up :

21b

Palmer, Susan L

From: Vorachek, Kelly
Sent: Thursday, August 02, 2012 4:08 PM
To: dl Electric Outage NT Notification
Subject:) First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bu:

Date Out : 8/2/2012 Date In : 8/2/2012
Time Out : 15:38 Time In : 15:47

Time Zone : CST

Duration : 0 hours, 9 mins

Number of Customers Affected : 2329

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; SAUK RAPIDS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Feeder Cable failed btwn _____ and _____ switch
under U-Guard, feeder tied together with doing restoration on used both feeders
to lock out.

Follow-Up :

220

Palmer, Susan L

From: Bui, Tien V
Sent: Saturday, August 04, 2012 2:57 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 21:55 Time In : 02:20

Time Zone : CST

Duration : 4 hours, 25 mins

Number of Customers Affected : 692

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : HECTOR, MN

State : MN - Minnesota

Major Customers : DIST REP FOUND : PHASES DOWN SPAN
OF SUB / ALSO PHASE HIGHSIDE FUSE BLOWN.

Cause : DIST REP PUTUP WIRE REPLACE HIGHSIDE FUSE 100% RESTORE AT

0220

Follow-Up :

22b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:04 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 8/3/12 - Hector - POWER RESTORED
Power outage - Hector - power restored.

Wendy

From: Bui, Tien V
Sent: Saturday, August 04, 2012 2:57 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 21:55 Time In : 02:20

Time Zone : CST

Duration : 4 hours, 25 mins

Number of Customers Affected : 692

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : HECTOR, MN

State : MN - Minnesota

Major Customers : DIST REP FOUND PHASES DOWN SPAN
IF SUB / ALSO PHASE HIGHSIDE FUSE BLOWN.

Cause : DIST REP PUTUP WIRE REPLACE HIGHSIDE FUSE 100% RESTORE AT

0220

Follow-Up :

23a

From: Kaveny, Michael J
Sent: Saturday, August 04, 2012 2:37 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:27 Time In : 02:20

Time Zone : CST

Duration : 3 hours, 53 mins

Number of Customers Affected : 748

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers : None

Cause : Final 57 customers restored at 02:20. is 100% restored.

Follow-Up :

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 8:47 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/3/12 - Saint Joseph - POWER RESTORED
Power outage - Saint Joseph - power restored.

Wendy

From: Kaveny, Michael J
Sent: Saturday, August 04, 2012 2:37 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/3/2012 Date In : 8/4/2012
Time Out : 22:27 Time In : 02:20

Time Zone : CST

Duration : 3 hours, 53 mins

Number of Customers Affected : 748

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT JOSEPH, MN

State : MN - Minnesota

Major Customers : None

Cause : Final 57 customers restored at 02:20. 100% restored.

Follow-Up :

24a

Palmer, Susan L

From: Vorachek, Kelly
Sent: Saturday, August 11, 2012 9:10 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/11/2012 Date In : 8/11/2012
Time Out : 05:00 Time In : 08:41

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 857

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN;
HAZEL RUN, MN

State : MN - Minnesota

Major Customers : N/A

Cause : - Scheduled intentional outage to do voltage conversion in
Cottonwood on

Follow-Up :

24b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 13, 2012 8:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: ' Second Outage Notice - 8/11/12 - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - POWER RESTORED
Power outage - Cottonwood, Granite Falls, Hanley Falls & Hazel Run - power restored.

Wendy

From: Vorachek, Kelly
Sent: Saturday, August 11, 2012 9:10 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/11/2012 Date In : 8/11/2012
Time Out : 05:00 Time In : 08:41

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 857

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COTTONWOOD, MN; GRANITE FALLS, MN; HANLEY FALLS, MN;
HAZEL RUN, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Scheduled intentional outage to do voltage conversion in
Cottonwood on

Follow-Up :

25a

Palmer, Susan L

From: Bui, Tien V
Sent: Wednesday, August 01, 2012 10:23 AM
To: dl Electric Outage SE Notification
Subject: al Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/1/2012 Date In : 8/1/2012
Time Out : 09:23 Time In : 10:13

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 914

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK DUE TO TRUCK HIT TEL & CATV
CAUSE FEEDER LOCK / OPER CLOSE FEEDER 100% RESTORE 10:13

Follow-Up :

25b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, August 01, 2012 11:17 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 8/1/12 - Elko New Market, Elko & Webster - POWER RESTORED

Power outage - Elko New Market, Elko & Webster - power restored.

Wendy

From: Bui, Tien V
Sent: Wednesday, August 01, 2012 10:23 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 8/1/2012 Date In : 8/1/2012
Time Out : 09:23 Time In : 10:13

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 914

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : ELKO NEW MARKET, MN; ELKO, MN; WEBSTER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK DUE TO TRUCK HIT TEL & CATV
CAUSE FEEDER LOCK / OPER CLOSE FEEDER 100% RESTORE 10:13

Follow-Up :

260

Palmer, Susan L

From: Vorachek, Kelly
Sent: Saturday, August 04, 2012 9:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 Date In : 8/4/2012
Time Out : 00:04 Time In : 07:47

Time Zone : CST

Duration : 7 hours, 43 mins

Number of Customers Affected : 1996

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Trees into feeder at multiple locations
1049 Customers back in @ 03:26 from witch - Remaining 947 back on @ 7:47 closed breaker.

Follow-Up :

26b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:11 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/4/12 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Vorachek, Kelly
Sent: Saturday, August 04, 2012 9:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 Date In : 8/4/2012
Time Out : 00:04 Time In : 07:47

Time Zone : CST

Duration : 7 hours, 43 mins

Number of Customers Affected : 1996

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Trees into feeder at multiple locations
Customers back in @ 03:26 from witch - Remaining 947 back on @ 7:47 closed breaker.

Follow-Up :

27a

Palmer, Susan L

From: Kaveny, Michael J
Sent: Saturday, August 04, 2012 6:05 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 Date In : 8/4/2012
Time Out : 00:06 Time In : 05:52

Time Zone : CST

Duration : 5 hours, 46 mins

Number of Customers Affected : 1495

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Trees and Limbs, Possibly Lightning. Structure Fire also delayed
Restoration. 100% Restored at 0552

Follow-Up :

27b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 06, 2012 9:08 AM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 8/4/12 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Kaveny, Michael J
Sent: Saturday, August 04, 2012 6:05 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 8/4/2012 Date In : 8/4/2012
Time Out : 00:06 Time In : 05:52

Time Zone : CST

Duration : 5 hours, 46 mins

Number of Customers Affected : 1495

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : None

Cause : Trees and Limbs, Possibly Lightning. Structure Fire also delayed
Restoration. 100% Restored at 0552

Follow-Up :

28a

Palmer, Susan L

From: Reinschmidt, Brad A
Sent: Tuesday, August 14, 2012 7:05 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/14/2012 Date In : 8/14/2012
Time Out : 03:50 Time In : 06:14

Time Zone : CST

Duration : 2 hours, 24 mins

Number of Customers Affected : 1015

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PINE ISLAND, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : None

Cause : Faulted feeder cable between switch & switch. Had 590 customers on at 0541 and the remaining 425 customers on at 06:14.

Follow-Up :

285

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, August 14, 2012 7:28 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/14/12 - Pine Island, West Concord & Zumbrota
- POWER RESTORED

Power outage - Pine Island, West Concord & Zumbrota - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Tuesday, August 14, 2012 7:05 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/14/2012 Date In : 8/14/2012
Time Out : 03:50 Time In : 06:14

Time Zone : CST

Duration : 2 hours, 24 mins

Number of Customers Affected : 1015

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PINE ISLAND, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : None

Cause : Faulted feeder cable between switch & switch. Had 590
customers on at 0541 and the remaining 425 customers on at 06:14.

Follow-Up :

29a

Palmer, Susan L

From: Chase, Julie B
Sent: Sunday, August 19, 2012 7:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/19/2012 Date In : 8/19/2012
Time Out : 06:49 Time In : 07:31

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 1284

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CANNON FALLS, MN; PIPESTONE, MN

State : MN - Minnesota

Major Customers :

Cause : squirrel in sub

Follow-Up : all customers returned to service. Operator enroute to assess damage

29b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, August 20, 2012 8:11 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 8/19/12 - Cannon Falls & Pipestone -
POWER RESTORED
Power outage - Cannon Falls & Pipestone - power restored.

Wendy

From: Chase, Julie B
Sent: Sunday, August 19, 2012 7:37 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 8/19/2012 Date In : 8/19/2012
Time Out : 06:49 Time In : 07:31

Time Zone : CST

Duration : 0 hours, 42 mins

Number of Customers Affected : 1284

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CANNON FALLS, MN; PIPESTONE, MN

State : MN - Minnesota

Major Customers :

Cause : OC squirrel in sub

Follow-Up : all customers returned to service. Operator enroute to assess damage

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	MW	9/3/12 16:38		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	856088	NO	
2	x	x	1	MW	9/4/12 20:43		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED	852794	NO	
3	x	x	1	MW	9/5/12 8:33		DIST SUBSTATION	CIRCUIT BREAKER	RD SPRAY OH SW FLASH OVER	100% RESTORED VIA SWITCHING	856920	NO	
4	x	x	1	MW	9/8/12 16:14		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	858370	NO	
5	x	x	1	MW	9/15/12 9:24		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED	860088	NO	
6	x	x	1	MW	9/18/12 12:15		FEEDER	CIRCUIT BREAKER DISCONNECT UG LOAD BREAK DISC OH	RELAY FAILURE	100% RESTORED VIA SWITCHING	861686	NO	
7	x	x	1	MW	9/19/12 6:32		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	861112	NO	
8	x	x	1	MW	9/21/12 21:22		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	REPAIRS NOT NEEDED	861851	NO	
9	x	x	1	MW	9/24/12 13:03		FEEDER	CIRCUIT BREAKER DISCONNECT UG	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	863254	NO	
10	x	x	1	MW	9/25/12 5:34		DIST SUBSTATION BUS/TRANSFORMER	CIRCUIT BREAKER	RELAY FAILURE	100% RESTORED VIA SWITCHING	862464 862462	NO	
11	x	x	1	NW	9/6/12 22:21		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE CRIMPED	100% RESTORED, REPAIRED	857857	NO	
12	x	x	1	NW	9/29/12 1:01		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED	863681	NO	
13	x	x	1	SE	9/4/12 23:33		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED PERM 100% RESTORED	856679	NO	
14	x	x	1	SE	9/5/12 1:02		TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED VIA SWITCHING	856742 856748	YES	Storm Day
15	x	x	1	SE	9/5/12 3:14		FEEDER	CIRCUIT BREAKER RECLOSER OH	ACCIDENTAL PROTECTION MISOP VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	856806	YES	Storm Day

Palmer, Susan L

From: Boland, Mike
Sent: Tuesday, September 04, 2012 8:54 AM
To: Horn, David W
Subject: FW: Final Outage Notice

Mike Boland
Xcel Energy | Responsible By Nature
Manager, Process & Compliance
Gas and Electric Emergency Response
825 Rice Street, 1st Floor Saint Paul, MN 55117
P: 651.229.2461 F: 651.229.2347
E: michael.p.boland@xcelenergy.com

From: Beckius, John J
Sent: Monday, September 03, 2012 6:50 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Outage Notice

Feeder/Bus :

Date Out : 9/3/2012 Date In : 9/3/2012
Time Out : 16:38 Time In : 18:04

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1832

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : none

Cause : failed head end cable also carrying part of

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, September 04, 2012 9:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/3/12 - Bloomington - POWER RESTORED
Power outage - Bloomington - power restored.

Wendy

From: Beckius, John J
Sent: Monday, September 03, 2012 6:50 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/3/2012 Date In : 9/3/2012
Time Out : 16:38 Time In : 18:04

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1832

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN

State : MN - Minnesota

Major Customers : none

Cause : failed head end cable also carrying part of

Follow-Up :

2a

Palmer, Susan L

From: Knutson, David A
Sent: Tuesday, September 04, 2012 10:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/4/2012 Date In : 9/4/2012
Time Out : 20:43 Time In : 22:02

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 2080

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PHASE BURNED DOWN

Follow-Up : ALL CUSTOMERS SHOULD BE BACK ON

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 05, 2012 7:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/4/12 - Edina, Minneapolis & Richfield - POWER RESTORED

Power outage - Edina, Minneapolis & Richfield - power restored.

Wendy

From: Knutson, David A
Sent: Tuesday, September 04, 2012 10:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/4/2012 Date In : 9/4/2012
Time Out : 20:43 Time In : 22:02

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 2080

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : PHASE BURNED DOWN

Follow-Up : ALL CUSTOMERS SHOULD BE BACK ON

Palmer, Susan L

From: Davis, Percyell
Sent: Wednesday, September 05, 2012 10:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/5/2012 Date In : 9/5/2012
Time Out : 08:33 Time In : 10:03

Time Zone : CST

Duration : 1 hours, 30 mins

Number of Customers Affected : 2676

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : FLASH ON MAIN BUS DISC ON LOW SIDE

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 05, 2012 10:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/5/12 - Minneapolis, Saint Anthony & Saint Paul - POWER RESTORED
Power outage - Minneapolis, Saint Anthony & Saint Paul - power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, September 05, 2012 10:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/5/2012 Date In : 9/5/2012
Time Out : 08:33 Time In : 10:03

Time Zone : CST

Duration : 1 hours, 30 mins

Number of Customers Affected : 2676

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : FLASH ON MAIN BUS DISC ON LOW SIDE

Follow-Up :

Palmer, Susan L

From: Ayers, Patrick S
Sent: Saturday, September 08, 2012 5:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/8/2012 Date In : 9/8/2012
Time Out : 16:14 Time In : 17:22

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 2083

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN;
MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE ON FEEDER AT

Follow-Up : TROUBLEMAN REMOVED TREE FROM
FEEDER,PATROLLED FEEDER,FEEDER RESTORED TO NORMAL,ALL SWITCH
GEAR RETURNED TO NORMAL.

4b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, September 10, 2012 8:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/8/12 - Eden Prairie, Hopkins & Minnetonka -
POWER RESTORED
Power outage - Eden Prairie, Hopkins & Minnetonka - power restored.

Wendy

From: Ayers, Patrick S
Sent: Saturday, September 08, 2012 5:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/8/2012

Date In : 9/8/2012

Time Out : 16:14

Time In : 17:22

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 2083

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : EDEN PRAIRIE, MN; HOPKINS, MN;
MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE ON FEEDER AT

Follow-Up : TROUBLEMAN REMOVED TREE FROM
FEEDER,PATROLLED FEEDER,FEEDER RESTORED TO NORMAL,ALL SWITCH
GEAR RETURNED TO NORMAL.

10/12/2012

5a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Saturday, September 15, 2012 10:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/15/2012 Date In : 9/15/2012
Time Out : 09:24 Time In : 10:01

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 1581

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time

Follow-Up :

5b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Saturday, September 15, 2012 10:20 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/15/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, September 15, 2012 10:17 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/15/2012 Date In : 9/15/2012
Time Out : 09:24 Time In : 10:01

Time Zone : CST

Duration : 0 hours, 37 mins

Number of Customers Affected : 1581

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : Unknown at this time

Follow-Up :

600

Palmer, Susan L

From: Anderson, Timothy K
Sent: Tuesday, September 18, 2012 1:55 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/18/2012 Date In : 9/18/2012
Time Out : 12:15 Time In : 13:52

Time Zone : CST

Duration : 1 hours, 37 mins

Number of Customers Affected : 5145

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP,
MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BLOWN ARRESTOR

Follow-Up :

(6b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, September 20, 2012 9:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/18/12 - Corcorna, Dayton, Hamel, Hassan Twp, Maple Grove, Osseo & Rogers - CLARIFICATION/POWER RESTORED

Clarification to the outage notifications that were sent on 9/18/12 for ECK-ELM Creek 322.

Power outage - Corcoran, Dayton, Hamel, Hassan Twp, Maple Grove, Osseo & Rogers - clarification (see cause) - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Thursday, September 20, 2012 9:28 AM
To: Jaede, Wendy L; Karolevitz, Paul W
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/18/2012 Date In : 9/18/2012
Time Out : 12:15 Time In : 20:05

Time Zone : CST

Duration : 7 hours, 50 mins

Number of Customers Affected : 230

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP, MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers : none

Cause : cable fault. 30 customers restored at 19:00. Last 200 customers restored at 20:05.

Follow-Up :

7a

Palmer, Susan L

From: Aspinwall, David P
Sent: Wednesday, September 19, 2012 8:50 AM
To: dl Electric Outage MW Notification
Subject: inal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2012 Date In : 9/19/2012
Time Out : 06:32 Time In : 07:35

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 1584

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : FAULTED URD FEEDER CABLE.

Follow-Up : THAT IS ALL.

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 19, 2012 8:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/19/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Aspinwall, David P
Sent: Wednesday, September 19, 2012 8:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/19/2012 Date In : 9/19/2012
Time Out : 06:32 Time In : 07:35

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 1584

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : FAULTED URD FEEDER CABLE.

Follow-Up : THAT IS ALL.

Palmer, Susan L

From: Ayers, Patrick S
Sent: Friday, September 21, 2012 10:24 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/21/2012 Date In : 9/21/2012
Time Out : 21:22 Time In : 22:19

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 931

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN,NIGHT TIME PATROL FOUND NOTHING

Follow-Up : CLOSED IN FEEDER BKR,WILL NEED TO PATROL
BETTER IN DAYLIGHT.

8b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, September 25, 2012 7:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/25/12 - Bloomington &
Eden Prairie - POWER RESTORED
Power outage - Bloomington & Eden Prairie - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, September 25, 2012 6:49 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/25/2012 Date In : 9/25/2012
Time Out : 5:38 Time In : 6:43

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 2742

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : unkown

Follow-Up : used field ties to restore feeders. Tr out for inspection of lockout



Palmer, Susan L

From: Hills, Thomas L
Sent: Monday, September 24, 2012 2:12 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/24/2012 Date In : 9/24/2012
Time Out : 13:02 Time In : 14:09

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 1635

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : Failed cable in the field.

Follow-Up : All restored at 1409.

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, September 24, 2012 2:14 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 9/24/12 - Minnetonka - POWER RESTORED
Power outage - Minnetonka - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, September 24, 2012 2:12 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 9/24/2012	Date In : 9/24/2012
Time Out : 13:02	Time In : 14:09

Time Zone : CST
Duration : 1 hours, 7 mins
Number of Customers Affected : 1635
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369
Communities Affected : MINNETONKA, MN
State : MN - Minnesota
Major Customers : none
Cause : Failed cable in the field.
Follow-Up : All restored at 1409.

10a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Tuesday, September 25, 2012 6:49 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 9/25/2012 Date In : 9/25/2012
Time Out : 5:38 Time In : 6:43

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 2742

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BLOOMINGTON, MN; EDEN PRAIRIE, MN

State : MN - Minnesota

Major Customers :

Cause : unkown

Follow-Up : used field ties to restore feeders. Tr out for inspection of lockout

106

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, September 07, 2012 7:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/6/12 - Becker, Big Lake & Monticello -
POWER RESTORED
Power outage - Becker, Big Lake & Monticello - power restored.

Wendy

From: Goulet, Terry W
Sent: Thursday, September 06, 2012 11:43 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/6/2012 Date In : 9/6/2012
Time Out : 22:26 Time In : 23:37

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2190

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down on feeder at Crew put
wire back up and closed breaker @ 2337

Follow-Up :

11a

Palmer, Susan L

From: Goulet, Terry W
Sent: Thursday, September 06, 2012 11:43 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/6/2012 Date In : 9/6/2012
Time Out : 22:26 Time In : 23:37

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2190

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down on feeder at _____ in _____ Crew put
wire back up and closed breaker @ 2337

Follow-Up :

11b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, September 07, 2012 7:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: . Second Outage Notice - 9/6/12 - Becker, Big Lake & Monticello -
POWER RESTORED
Power outage - Becker, Big Lake & Monticello - power restored.

Wendy

From: Goulet, Terry W
Sent: Thursday, September 06, 2012 11:43 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/6/2012 Date In : 9/6/2012
Time Out : 22:26 Time In : 23:37

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 2190

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BECKER, MN; BIG LAKE, MN; MONTICELLO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down on feeder at Crew put
wire back up and closed breaker @ 2337

Follow-Up :

12a

Palmer, Susan L

From: Goulet, Terry W
Sent: Saturday, September 29, 2012 4:57 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/29/2012 Date In : 9/29/2012
Time Out : 01:00 Time In : 03:56

Time Zone : CST

Duration : 2 hours, 56 mins

Number of Customers Affected : 781

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers : NA

Cause : PLANNED OUTAGE ON

Follow-Up : INTERNET DOWN

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, October 01, 2012 7:44 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject:) Second Outage Notice - 9/29/12 - Clara City, Maynard & Sacred Heart -
POWER RESTORED
Power outage - Clara City, Maynard & Sacred Heart - power restored.

Wendy

From: Goulet, Terry W
Sent: Saturday, September 29, 2012 4:57 AM
To: dl Electric Outage NT Notification
Subject: (Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/29/2012 Date In : 9/29/2012
Time Out : 01:00 Time In : 03:56

Time Zone : CST

Duration : 2 hours, 56 mins

Number of Customers Affected : 781

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers : NA

Cause : PLANNED OUTAGE ON

Follow-Up : INTERNET DOWN

13a

Palmer, Susan L

From: Goulet, Terry W
Sent: Wednesday, September 05, 2012 2:45 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 9/4/2012 Date In : 9/5/2012
Time Out : 23:33 Time In : 02:21

Time Zone : CST

Duration : 2 hours, 48 mins

Number of Customers Affected : 1143

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Temp repairs made and remaining 367 customers restored by
closing witch @ 0221

Follow-Up :

13b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 05, 2012 7:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/4/12 - Mankato & North Mankato - Update
Power outage - Mankato & North Mankato - update.

Wendy

From: Goulet, Terry W
Sent: Wednesday, September 05, 2012 2:12 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/4/2012 Date In : 9/5/2012
Time Out : 23:33 Time In : 00:25

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1143

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : MANKATO, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Large tree down on feeder with broken pole at
Opened switch to restore 777 customers while crew works on holding broken pole and
repairing broken X arm.

Follow-Up : 367 customers still out

10/12/2012

14a

Palmer, Susan L

From: Goulet, Terry W
Sent: Wednesday, September 05, 2012 4:13 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/5/2012 Date In : 9/5/2012
Time Out : 01:02 Time In : 03:14

Time Zone : CST

Duration : 2 hours, 12 mins

Number of Customers Affected : 1966

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PINE ISLAND, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission outage

Follow-Up : Storm

14b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 05, 2012 7:51 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW. Second Outage Notice - 9/5/12 - Pine Island, West
Concord & Zumbrota - POWER RESTORED
Power outage - Pine Island, West Concord & Zumbrota - power restored.

Wendy

From: Goulet, Terry W
Sent: Wednesday, September 05, 2012 4:13 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/5/2012 Date In : 9/5/2012
Time Out : 01:02 Time In : 03:14

Time Zone : CST

Duration : 2 hours, 12 mins

Number of Customers Affected : 1966

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PINE ISLAND, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers :

Cause : Transmission outage

Follow-Up : Storm

15b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, September 05, 2012 7:53 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 9/5/12 - Pine Island, West Concord & Zumbrota -
POWER RESTORED
Power outage - Pine Island, West Concord & Zumbrota - power restored.

Wendy

From: Vorachek, Kelly
Sent: Wednesday, September 05, 2012 6:26 AM
To: dl Electric Outage SF Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 9/5/2012 Date In : 9/5/2012
Time Out : 03:14 Time In : 05:34

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 1012

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : PINE ISLAND, MN; WEST CONCORD, MN; ZUMBROTA, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Broken poles from tree down at was
behind reclosers that failed to operate, opened reclosers and closed breaker.

Follow-Up :

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm Escalated Ops	Comments
1	x	x	1	ME	10/5/12 2:50		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED	866000	NO	
2	x	x	1	ME	10/7/12 14:26		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	866667	NO	
3	x	x	1	ME	10/8/12 21:53		DIST SUBSTATION	CIRCUIT BREAKER	ANIMAL CONTACT OTHER	100% RESTORED VIA SWITCHING	867133	NO	
4	x	x	1	ME	10/23/12 6:49		FEEDER	CIRCUIT BREAKER	SPLICE UG PRIMARY PAPER & LEAD	100% RESTORED VIA SWITCHING	869972	NO	
5	x	x	1	ME	10/28/12 14:19		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	PUBLIC DAMAGE BROKEN POLE UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED TEMP 100% RESTORED,	871258	NO	
6	x	x	1	MW	10/3/12 10:35		FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER PORCELAIN	100% RESTORED, REPAIRED	865332	NO	
7	x	x	1	MW	10/3/12 12:19		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	865373	NO	
8	x	x	1	MW	10/4/12 17:06		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	865882	NO	
9	x	x	1	MW	10/4/12 18:59		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	865948	NO	
10	x	x	1	MW	10/5/12 1:42		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	866086	NO	
11	x	x	1	MW	10/5/12 22:13		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	866400	NO	
12	x	x	1	NW	10/4/12 2:45		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED	865494	NO	
13	x	x	1	NW	10/4/12 4:40		FEEDER	CIRCUIT BREAKER	CONDUCTOR CONTACT - GALLOPING	100% RESTORED, REPAIRED	865523	NO	
14	x	x	1	NW	10/5/12 3:26		TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED VIA SWITCHING	866016 866012 866013	NO	
15	x	x	1	NW	10/19/12 14:00		FEEDER	CIRCUIT BREAKER	CAPACITOR BANK FAILURE OH	100% RESTORED, REPAIRED	869453	NO	

Palmer, Susan L

From: Abbott, Edward J
Sent: Friday, October 05, 2012 4:00 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 02:50 Time In : 03:52

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 673

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE BRANCHES FELL THROUGH FEEDER AT
AND 2 PHASES OF SLACK SPAN WRAPPED TOGETHER.
TROUBLEMAN CLEARED UP PROBLEM AND FEEDER BACK IN.

Follow-Up :

16

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, October 05, 2012 7:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/5/12 - Little Canada, Maplewood & Saint Paul
- POWER RESTORED
Power outage - Little Canada, Maplewood & Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Friday, October 05, 2012 4:00 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 02:50 Time In : 03:52

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 673

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE BRANCHES FELL THROUGH FEEDER AT
AND 2 PHASES OF SLACK SPAN WRAPPED TOGETHER.
TROUBLEMAN CLEARED UP PROBLEM AND FEEDER BACK IN.

Follow-Up :

Palmer, Susan L

From: Driscoll, Paul M
Sent: Sunday, October 07, 2012 3:07 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/7/2012 Date In : 10/7/2012
Time Out : 14:26 Time In : 14:58

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 2034

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : head end cable failed..

Follow-Up :

2b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, October 08, 2012 9:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 10/7/12 Power Restored LITTLE CANADA, MN;
ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN
10/7/12 Power Restored

LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN;
VADNAIS HEIGHTS, MN

From: Driscoll, Paul M
Sent: Sunday, October 07, 2012 3:07 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/7/2012 Date In : 10/7/2012
Time Out : 14:26 Time In : 14:58

Time Zone : CST

Duration : 0 hours, 32 mins

Number of Customers Affected : 2034

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT
PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : N/A

Cause : head end cable failed..

Follow-Up :

Palmer, Susan L

From: Chial, Terry L
Sent: Monday, October 08, 2012 11:28 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/8/2012 Date In : 10/8/2012
Time Out : 21:53 Time In : 23:17

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1881

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : str sub

Cause : cable between and

Follow-Up : will refer to str u

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, October 09, 2012 8:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 10/8/12 Power Restored SAINT PAUL, MN
10/8/12 Power Restored

SAINT PAUL, MN

From: Chial, Terry L
Sent: Monday, October 08, 2012 11:28 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/8/2012 Date In : 10/8/2012

Time Out : 21:53 Time In : 23:17

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 1881

For information about this alert, contact :

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : str sub

Cause : cable between and

Follow-Up : will refer to



Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, October 23, 2012 7:44 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/23/2012 **Date In :** 10/23/2012
Time Out : 06:49 **Time In :** 07:15

Time Zone : CST

Duration : 0 hours, 26 mins

Number of Customers Affected : 2706

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : head end cable failed

Follow-Up :

4b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, October 23, 2012 3:17 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 10/23/12 Power Restored - MAPLEWOOD, MN; SAINT PAUL, MN
10/23/12 Power Restored

MAPLEWOOD, MN; SAINT PAUL, MN

From: Gilland, William P.
Sent: Tuesday, October 23, 2012 7:44 AM
To: dl Electric Outage ME Notification
Subject: econd Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/23/2012 Date In : 10/23/2012
Time Out : 06:49 Time In : 07:15

Time Zone : CST

Duration : 0 hours, 26 mins

Number of Customers Affected : 2706

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : head end cable failed

Follow-Up :

5a

Palmer, Susan L

From: Chial, Terry L
Sent: Sunday, October 28, 2012 3:18 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/28/2012 Date In : 10/28/2012
Time Out : 14:19 Time In : 15:11

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 2037

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT
PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : no

Cause : broken pole at

Follow-Up : cleared and reenergized.

5b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, October 29, 2012 9:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/28/12 - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - POWER RESTORED
Power outage - Little Canada, Roseville, Saint Paul, Shoreview & Vadnais Heights - power restored.

Wendy

From: Chial, Terry L
Sent: Sunday, October 28, 2012 3:18 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/28/2012 Date In : 10/28/2012
Time Out : 14:19 Time In : 15:11

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 2037

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : LITTLE CANADA, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN; VADNAIS HEIGHTS, MN

State : MN - Minnesota

Major Customers : no

Cause : broken pole at

Follow-Up : cleared and reenergized.

609

Palmer, Susan L

From: Davis, Percyell
Sent: Wednesday, October 03, 2012 11:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/3/2012 Date In : 10/3/2012
Time Out : 10:35 Time In : 11:16

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 1267

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : ON UNFUSED TAP ARRESTERS BLOW BURNED DOWN WIRE TOOK
OUT FEEDER.

Follow-Up : TRBL IS GOING TO PUT BACK UP TAP AND REFER FOR TAP TO BE
FUSED.

(eb)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, October 03, 2012 11:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/3/12 - Columbia Heights & Minneapolis - POWER RESTORED

Power outage - Columbia Heights & Minneapolis - power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, October 03, 2012 11:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/3/2012 Date In : 10/3/2012
Time Out : 10:35 Time In : 11:16

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 1267

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : ON UNFUSED TAP ARRESTERS BLOW BURNED DOWN WIRE TOOK
OUT FEEDER.

Follow-Up : TRBL IS GOING TO PUT BACK UP TAP AND REFER FOR TAP TO BE
FUSED.

11/27/2012

7a

Palmer, Susan L

From: Davis, Percyell
Sent: Wednesday, October 03, 2012 2:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/3/2012 Date In : 10/3/2012
Time Out : 12:19 Time In : 13:51

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 2071

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD CABLE HASE BTWN SUB AND NUMBER SWITCH

Follow-Up :

(7b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, October 04, 2012 7:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/3/12 - Golden Valley & Minneapolis - POWER RESTORED

Power outage - Golden Valley & Minneapolis - power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, October 03, 2012 2:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/3/2012 Date In : 10/3/2012
Time Out : 12:19 Time In : 13:51

Time Zone : CST

Duration : 1 hours, 32 mins

Number of Customers Affected : 2071

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : GOLDEN VALLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BAD CABLE PHASE BTWN SUB AND NUMBER SWITCH

Follow-Up :



Palmer, Susan L

From: Karolevitz, Paul W
Sent: Friday, October 05, 2012 7:41 AM
To: Jaede, Wendy L
Cc: Karolevitz, Paul W
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 17:06 Time In : 17:36

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 2356

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder @ :

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, October 05, 2012 7:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/4/12 - Brooklyn Center & Minneapolis - POWER RESTORED

Power outage - Brooklyn Center & Minneapolis - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Friday, October 05, 2012 7:41 AM
To: Jaede, Wendy L
Cc: Karolevitz, Paul W
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 17:06 Time In : 17:36

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 2356

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree on feeder @

Follow-Up :

9a

Palmer, Susan L

From: Aspinwall, David P
Sent: Thursday, October 04, 2012 8:05 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 18:59 Time In : 20:02

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2495

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : WILLOW TREE AT

Follow-Up : THAT IS ALL.

ab

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, October 05, 2012 7:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/4/12 - Corcoran, Hamel, Medina, Minneapolis & Plymouth - POWER RESTORED
Power outage - Corcoran, Hamel, Medina, Minneapolis & Plymouth - power restored.

Wendy

From: Aspinwall, David P
Sent: Thursday, October 04, 2012 8:05 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 18:59 Time In : 20:02

Time Zone : CST

Duration : 1 hours, 3 mins

Number of Customers Affected : 2495

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : WILLOW TREE AT

Follow-Up : THAT IS ALL.

10a

Palmer, Susan L

From: Aspinwall, David P
Sent: Friday, October 05, 2012 3:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 01:42 Time In : 02:48

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1824

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : FAULTED URD FEEDER CABLE BETWEEN THE AND SWITCH.

Follow-Up : THAT IS ALL.

106

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, October 05, 2012 7:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/5/12 - Hopkins, Minneapolis, Minnetonka & Saint Louis Park - POWER RESTORED
Power outage - Hopkins, Minneapolis, Minnetonka & Saint Louis Park - power restored.

Wendy

From: Aspinwall, David P
Sent: Friday, October 05, 2012 3:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 01:42 Time In : 02:48

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 1824

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE.

Cause : FAULTED URD FEEDER CABLE BETWEEN THE AND SWITCH.

Follow-Up : THAT IS ALL.

11a

Palmer, Susan L

From: Schwarz, John W
Sent: Saturday, October 06, 2012 12:00 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 22:13 Time In : 23:23

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1945

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED FEEDER CABLE BETWEEN

Follow-Up :

11b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, October 08, 2012 9:44 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 10/5/12 Power Restored - Minneapolis
10/5/12 Power Restored

Minneapolis

From: Schwarz, John W
Sent: Friday, October 05, 2012 11:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 22:13 Time In : 23:23

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1945

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED FEEDER CABLE BETWEEN

Follow-Up :

12a

Palmer, Susan L

From: Bui, Tien V
Sent: Thursday, October 04, 2012 4:22 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 02:45 Time In : 04:09

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 782

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK (SUB NONE | PATROL FEEDER
FOUND NOTHING CLOSE BREAKER IN AND HOLDING FOUND PHASE . 100% RESTORE

Follow-Up :

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, October 04, 2012 7:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 10/4/12 - Clara City, Maynard & Sacred Heart -
POWER RESTORED

Power outage - Clara City, Maynard & Sacred Heart - power restored.

Wendy

From: Bui, Tien V
Sent: Thursday, October 04, 2012 4:22 AM
To: dl Electric Outage NT Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 022

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 02:45 Time In : 04:09

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 782

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED HEART, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK (SUB NONE) PATROL FEEDER
FOUND NOTHING CLOSE BREAKER IN AND HOLDING FOUND PHASE TARGET. 100% RESTORE

Follow-Up :

13a

Palmer, Susan L

From: Medellin, Victor J
Sent: Thursday, October 04, 2012 7:05 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/4/2012 Date In : 10/4/2012
Time Out : 04:40 Time In : 05:09

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 782

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED
HEART, MN

State : MN - Minnesota

Major Customers : NONE

Cause : GALLOPING WIRES CREW MADE REPAIRS 100%
RESTORED

Follow-Up :

136

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, October 04, 2012 7:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 10/4/12 - Clara City, Maynard & Sacred Heart -
POWER RESTORED

Power outage - Clara City, Maynard & Sacred Heart - power restored.

Wendy

From: Medellin, Victor J
Sent: Thursday, October 04, 2012 7:05 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/4/2012

Date In : 10/4/2012

Time Out : 04:40

Time In : 05:09

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 782

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : CLARA CITY, MN; MAYNARD, MN; SACRED
HEART, MN

State : MN - Minnesota

Major Customers : NONE

Cause : GALLOPING WIRES CREW MADE REPAIRS 100%
RESTORED

Follow-Up :

14a

Palmer, Susan L

From: Goulet, Terry W
Sent: Friday, October 05, 2012 5:30 AM
To: dl Electric Outage NT Notification
Subject: Notice

Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 03:26 Time In : 04:59

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 3878

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; COKATO, MN; DELANO, MN; HOWARD LAKE,
MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : NA

Cause : Transmission Outage / back in @ 0459

Follow-Up :

146

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, October 05, 2012 7:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage
Notice - 10/5/12 - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - POWER RESTORED
Power outage - Buffalo, Cokato, Delano, Howard Lake, Montrose & Waverly - power restored.

Wendy

From: Goulet, Terry W
Sent: Friday, October 05, 2012 5:30 AM
To: dl Electric Outage NT Notification
Subject: Second Outage
Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/5/2012 Date In : 10/5/2012
Time Out : 03:26 Time In : 04:59

Time Zone : CST

Duration : 1 hours, 33 mins

Number of Customers Affected : 3878

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : BUFFALO, MN; COKATO, MN; DELANO, MN; HOWARD LAKE,
MN; MONTROSE, MN; WAVERLY, MN

State : MN - Minnesota

Major Customers : NA

Cause : Transmission Outage / back in @ 0459

Follow-Up :

15a

Palmer, Susan L

From: Kaveny, Michael J
Sent: Friday, October 19, 2012 2:34 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/19/2012 Date In : 10/19/2012
Time Out : 14:00 Time In : 14:28

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 3418

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : at initial report of cutout failed to clear
fault. 100% restored

Follow-Up : Cutouts and leads cleared off Feeder at

(15b)

Palmer, Susan L

From: Preston, Carly
Sent: Friday, October 19, 2012 2:36 PM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 10/19/12 Power Restored SAINT CLOUD, MN;
WAITE PARK, MN
10/19/12 Power Restored

SAINT CLOUD, MN; WAITE PARK, MN

From: Kaveny, Michael J
Sent: Friday, October 19, 2012 2:34 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 10/19/2012 Date In : 10/19/2012
Time Out : 14:00 Time In : 14:28

Time Zone : CST

Duration : 0 hours, 28 mins

Number of Customers Affected : 3418

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : at initial report of cutout failed to clear
fault. 100% restored

Follow-Up : Cutouts and leads cleared off Feeder at

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	11/10/12 23:14		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	874182	YES	Storm Day
2	x	x	1	ME	11/10/12 23:13		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC	VEG TREE INSIDE MAINT CORRIDOR INTENTIONAL	100% RESTORED, REPAIRED PERM	875236	YES	Storm Day
3	x	x	1	ME	11/10/12 23:28		FEEDER	3P HV CONDUCTOR OH	POLE BROKEN / GOOD CONDITION INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED PERM PARTIAL	874940 874952	YES	Storm Day
4	x	x	1	ME	11/12/12 3:16		FEEDER DIST SUBSTATION	3P HV CONDUCTOR	CONNECTOR FAILURE AUTO	100% RESTORED VIA	876162	NO	
5	x	x	1	MW	11/5/12 6:57		US/TRANSFORMER	CIRCUIT BREAKER	ANIMAL CONTACT OTHER	PERM	872913 872925 872909 872908	NO	
6	x	x	1	MW	11/11/12 1:21		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED	875050	NO	
7	x	x	1	MW	11/27/12 13:08		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRIMARY LC	100% RESTORED VIA	877478	NO	
8	x	x	1	SE	11/7/12 8:31		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED	873503	NO	

1a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Sunday, November 11, 2012 3:49 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/10/2012 Date In : 11/11/2012
Time Out : 23:11 Time In : 03:42

Time Zone : CST

Duration : 4 hours, 31 mins

Number of Customers Affected : 1747

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : There where several trees on this feeder..We took them off
and put feeder in..

Follow-Up :

Palmer, Susan L

From: Preston, Carly
Sent: Monday, November 12, 2012 10:01 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 11/11/12 Power Restored MENDOTA HEIGHTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN
11/11/12 Power Restored

MENDOTA HEIGHTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

From: Driscoll, Paul M
Sent: Sunday, November 11, 2012 3:49 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/10/2012 Date In : 11/11/2012
Time Out : 23:11 Time In : 03:42

Time Zone : CST

Duration : 4 hours, 31 mins

Number of Customers Affected : 1747

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : There where several trees on this feeder..We took them off
and put feeder in..

Follow-Up :

Palmer, Susan L

From: Driscoll, Paul M
Sent: Sunday, November 11, 2012 5:15 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :

Date Out : 11/10/2012 Date In : 11/11/2012
Time Out : 23:12 Time In : 05:02

Time Zone : CST

Duration : 5 hours, 50 mins

Number of Customers Affected : 1799

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Crew fixed pole at

Follow-Up :

2b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, November 12, 2012 10:02 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 11/11/12 Power Restored MENDOTA HEIGHTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN
11/11/12 Power Restored

MENDOTA HEIGHTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

From: Driscoll, Paul M
Sent: Sunday, November 11, 2012 5:15 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus : 073

Date Out : 11/10/2012

Date In : 11/11/2012

Time Out : 23:12

Time In : 05:02

Time Zone : CST

Duration : 5 hours, 50 mins

Number of Customers Affected : 1799

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Crew fixed pole at

Follow-Up :

3a

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, November 11, 2012 12:59 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/10/2012 Date In : 11/11/2012
Time Out : 23:28 Time In : 12:14

Time Zone : CST

Duration : 12 hours, 46 mins

Number of Customers Affected : 5850

For information about this alert, contact :

For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : CHISAGO CITY, MN; CHISAGO LAKE, MN; CLEAR LAKE, MN; FOREST LAKE, MN; HUGO, MN; MAHTOMEDI, MN; MARINE SAINT CROIX, MN; NEW SCANDIA, MN; SAINT PAUL, MN; SCANDIA, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WITHROW, MN

State : MN - Minnesota

Major Customers : 11/10/2012 23:28 5310 customers were back on and at 11/11/2012 520 more customers were back on 5830 and at 11/11/2012 12:14 5850 or all customers were back on

Cause : mn

Follow-Up :

3b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, November 12, 2012 10:11 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice 11/11/12 Additional Info CHISAGO CITY, MN; CHISAGO LAKE, MN; CLEAR LAKE, MN; FOREST LAKE, MN; HUGO, MN; MAHTOMEDI, MN; MARINE SAINT CROIX, MN; NEW SCANDIA, MN; SAINT PAUL, MN; SCANDIA, MN; STILLWATER, MN;
11/11/12 Additional Info

CHISAGO CITY, MN; CHISAGO LAKE, MN; CLEAR LAKE, MN; FOREST LAKE, MN; HUGO, MN; MAHTOMEDI, MN; MARINE SAINT CROIX, MN; NEW SCANDIA, MN; SAINT PAUL, MN; SCANDIA, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WITHROW, MN

From: Elden, Thomas L
Sent: Sunday, November 11, 2012 12:59 PM
To: dl Electric Outage ME Notification
Subject: inal Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/10/2012 Date In : 11/11/2012
Time Out : 23:28 Time In : 12:14

Time Zone : CST

Duration : 12 hours, 46 mins

Number of Customers Affected : 5850

For information about this alert, contact :
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : CHISAGO CITY, MN; CHISAGO LAKE, MN; CLEAR LAKE, MN; FOREST LAKE, MN; HUGO, MN; MAHTOMEDI, MN; MARINE SAINT CROIX, MN; NEW SCANDIA, MN; SAINT PAUL, MN; SCANDIA, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WITHROW, MN

State : MN - Minnesota

Major Customers : 11/10/2012 23:28 5310 customers were back on and at 11/11/2012 520 more customers were back on 5830 and at 11/11/2012 12:14 5850 or

4a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Monday, November 12, 2012 4:43 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/12/2012 Date In : 11/12/2012
Time Out : 03:15 Time In : 04:10

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1523

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : ARDEN HILLS, MN; SHOREVIEW, MN; WHITE
BEAR LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : 1 phase line burned down at .We
had to open the breaker to cut this in the cleas. This line burned down at about 03:15...

Follow-Up :

4b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, November 12, 2012 10:15 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: First Outage Notice 11/12/12 Outage/Power Restored ARDEN HILLS, MN; SHOREVIEW, MN; WHITE BEAR LAKE, MN
11/12/12 Outage/Power Restored

ARDEN HILLS, MN; SHOREVIEW, MN; WHITE BEAR LAKE, MN

From: Driscoll, Paul M
Sent: Monday, November 12, 2012 4:43 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/12/2012 Date In : 11/12/2012
Time Out : 03:15 Time In : 04:10

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1523

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Dan Kegley: (651) 229-2391

Communities Affected : ARDEN HILLS, MN; SHOREVIEW, MN; WHITE BEAR LAKE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : phase line burned down at .We had to open the breaker to cut this in the cleas. This line burned down at about 03:15...

Follow-Up :

50

Palmer, Susan L

From: Beckius, John J
Sent: Monday, November 05, 2012 7:02 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/5/2012 Date In :
Time Out : 06:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 11473

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : unknown tr out & buss tie opened

Follow-Up :

5b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, November 05, 2012 8:04 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: : First Outage Notice - 11/5/12 - Edina,
Hopkins, Minneapolis, Minnetonka & Saint Louis Park
Power outage - Edina, Hopkins, Minneapolis, Minnetonka & Saint Louis Park.

Wendy

From: Beckius, John J
Sent: Monday, November 05, 2012 7:02 AM
To: dl Electric Outage MW Notification
Subject: : First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 11/5/2012 Date In :
Time Out : 06:57 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 11473

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; HOPKINS, MN; MINNEAPOLIS, MN; MINNETONKA,
MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers :

Cause : unknown tr out & buss tie opened

Follow-Up :

6a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Sunday, November 11, 2012 3:07 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/11/2012 Date In : 11/11/2012
Time Out : 01:21 Time In : 02:59

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 1955

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire down on

Follow-Up :

6b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, November 12, 2012 10:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 11/11/12 Power Restored MINNEAPOLIS, MN
11/11/12 Power Restored

MINNEAPOLIS, MN

From: Peterson, Kenneth W
Sent: Sunday, November 11, 2012 3:07 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/11/2012 Date In : 11/11/2012
Time Out : 01:21 Time In : 02:59

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 1955

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Wire down on

Follow-Up :

7a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Tuesday, November 27, 2012 4:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/27/2012 Date In : 11/27/2012
Time Out : 13:08 Time In : 15:57

Time Zone : CST

Duration : 2 hours, 49 mins

Number of Customers Affected : 82

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : double fault

Follow-Up :

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, November 28, 2012 8:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: nal Outage Notice - 11/27/12 - Minnetonka - POWER RESTORED/UPDATE
Power outage - Minnetonka - power restored/update.

Wendy

From: Kittock, Joseph C
Sent: Tuesday, November 27, 2012 4:14 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 11/27/2012 Date In : 11/27/2012
Time Out : 13:08 Time In : 15:57

Time Zone : CST

Duration : 2 hours, 49 mins

Number of Customers Affected : 82

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : double fault

Follow-Up :

80

Palmer, Susan L

From: Goulet, Terry W
Sent: Wednesday, November 07, 2012 10:29 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 11/7/2012 Date In : 11/7/2012
Time Out : 08:31 Time In : 10:23

Time Zone : CST

Duration : 1 hours, 52 mins

Number of Customers Affected : 726

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COURTLAND, MN; NICOLLET, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down on
Troubleman put up wire and closed breaker.

Follow-Up :

8b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, November 07, 2012 10:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Outage Notice - 11/7/12 - Courtland, Nicollet & North Mankato -
POWER RESTORED
Power outage - Courtland, Nicollet & North Mankato - power restored.

Wendy

From: Goulet, Terry W
Sent: Wednesday, November 07, 2012 10:29 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

: Second Outage Notice
Feeder/Bus :

Date Out : 11/7/2012 Date In : 11/7/2012
Time Out : 08:31 Time In : 10:23

Time Zone : CST

Duration : 1 hours, 52 mins

Number of Customers Affected : 726

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 330-5870

Communities Affected : COURTLAND, MN; NICOLLET, MN; NORTH MANKATO, MN

State : MN - Minnesota

Major Customers : NA

Cause : Wire down on
Troubleman put up wire and closed breaker.

Follow-Up :

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	12/5/12 18:33		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED PERM	878365	NO	
2	x	x	1	ME	12/15/12 18:34		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE COMPR	100% RESTORED, REPAIRED PERM	880536	NO	
3	x	x	1	ME	12/20/12 1:55		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	PUBLIC DAMAGE BROKEN POLE	PARTIAL RESTORATION 100% RESTORED, REPAIRED PERM	881881	NO	
4	x	x	1	ME	12/21/12 1:40		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE AUTO	100% RESTORED VIA SWITCHING	881843	NO	
5	x	x	1	ME	12/28/12 9:49		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE GUY WIRE	100% RESTORED, REPAIRED TEMP	882856	NO	
6	x	x	1	MW	12/3/12 12:55		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	877951	NO	
7	x	x	1	MW	12/15/12 18:34		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE COMPR	100% RESTORED, REPAIRED PERM	880536	NO	
8	x	x	1	MW	12/15/12 21:54		FEEDER	3- HV CONDUCTOR OH CIRCUIT BREAKER LOAD BREAK DISC OH	POLE FIRE	100% RESTORED, REPAIRED PERM 100% RESTORED VIA SWITCHING 100% RESTORED VIA SWITCHING	881712	NO	

1a

From: Abbott, Edward J
Sent: Wednesday, December 05, 2012 8:01 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/5/2012
Time Out : 18:33

Date In : 12/5/2012
Time In : 19:55

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1783

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE CLEARED AND
FINAL 125 CUSTOMERS.

SWITCH CLOSED BRINGING IN

Follow-Up :

1b

From: Jaede, Wendy L
Sent: Thursday, December 06, 2012 7:34 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/5/12 - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - POWER RESTORED
Power outage - Arden Hills, New Brighton, Roseville, Saint Paul & Shoreview - power restored.

Wendy

From: Abbott, Edward J
Sent: Wednesday, December 05, 2012 8:01 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/5/2012

Date In : 12/5/2012

Time Out : 18:33

Time In : 19:55

Time Zone : CST

Duration : 1 hours, 22 mins

Number of Customers Affected : 1783

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE CLEARED AND
FINAL 125 CUSTOMERS.

SWITCH CLOSED BRINGING IN

Follow-Up :

2a

From: Driscoll, Paul M
Sent: Saturday, December 15, 2012 7:48 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/15/2012
Time Out : 18:34 Time In : 19:46

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 3794

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COLUMBIA HEIGHTS, MN; MENDOTA HEIGHTS, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : My guys worked with 2 West guys and put up this .It let go at
an Automatic sleeve...

Follow-Up :

From: Jaede, Wendy L
Sent: Monday, December 17, 2012 10:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 12/15/12 - Columbia Heights, Mendota Heights, Minneapolis, New Brighton & Saint Anthony - POWER RESTORED
Power outage - Columbia Heights, Mendota Heights, Minneapolis, New Brighton & Saint Anthony - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, December 15, 2012 7:48 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/15/2012
Time Out : 18:34 Time In : 19:46

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 3794

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COLUMBIA HEIGHTS, MN; MENDOTA HEIGHTS, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : My guys worked with 2 West guys and put up this 336...It let go at an Automatic sleeve...

Follow-Up :

3a

From: Chial, Terry L
Sent: Thursday, December 20, 2012 3:04 AM
To: dl Electric Outage MF Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/20/2012
Time Out : 01:55

Date In : 12/20/2012
Time In : 03:02

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 3655

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : car hit pole

Follow-Up : will refer to area

From: Jaede, Wendy L
Sent: Thursday, December 20, 2012 8:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/20/12 - Maplewood & Saint Paul
- POWER RESTORED
Power outage - Maplewood & Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Thursday, December 20, 2012 3:04 AM
To: dl Electric Outage MF Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/20/2012
Time Out : 01:55

Date In : 12/20/2012
Time In : 03:02

Time Zone : CST

Duration : 1 hours, 7 mins

Number of Customers Affected : 3655

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : car hit pole

Follow-Up : will refer to area

From: Chial, Terry L
Sent: Friday, December 21, 2012 5:22 AM
To: dl Electric Outage ME Notification
Subject: nal Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/21/2012 Date In : 12/21/2012
Time Out : 01:40 Time In : 03:45

Time Zone : CST

Duration : 2 hours, 5 mins

Number of Customers Affected : 1990

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : auto sleeves let loose in two differant locations .causing feeder
out .

Follow-Up : refered to st paul oh .immediate repairs needed.

From: Preston, Carly
Sent: Friday, December 21, 2012 8:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
PAUL, MN
12/21/12 Power Restored

Final Outage Notice 12/21/12 Power Restored SAINT

SAINT PAUL, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 F: 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Friday, December 21, 2012 5:22 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/21/2012
Time Out : 01:40

Date In : 12/21/2012
Time In : 03:45

Time Zone : CST

Duration : 2 hours, 5 mins

Number of Customers Affected : 1990

For information about this alert, contact :

For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

4b

Major Customers : no

out . Cause : auto sleeves let loose in two differant locations .causing feeder

Follow-Up : refered to st paul oh .immediate repairs needed.

From: Chial, Terry L
Sent: Friday, December 28, 2012 11:18 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/28/2012 Date In : 12/28/2012
Time Out : 09:49 Time In : 10:54

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 881

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : NO

Cause : CAR HIT DOWN GUY FLIPPING INTO FEEDER ,ALSO STATIC
LINE CAME DOWN TRIPPING TRANSMISSION HASE NEEDS REPAIR
SLEAVE OR SPLICED OUT .BURNED 25 %.

Follow-Up : REFERED TO AREAS

5b

From: Guttormson, Allyson E
Sent: Friday, December 28, 2012 12:42 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/28/2012 - Rosemount- POWER
RESTORED
Power Restored- Rosemount

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Friday, December 28, 2012 11:18
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/28/2012 Date In : 12/28/2012
Time Out : 09:49 Time In : 10:54

Time Zone : CST

Duration : 1 hours, 5 mins

Number of Customers Affected : 881

For information about this alert, contact :
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : NO

Cause : CAR HIT DOWN GUY FLIPPING INTO FEEDER ,ALSO STATIC
LINE CAME DOWN TRIPPING TRANSMISSION PHASE NEEDS REPAIR
SLEAVE OR SPLICED OUT .BURNED 25 %.

Follow-Up : REFERED TO AREAS

From: Ayers, Patrick S
Sent: Monday, December 03, 2012 1:42 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/3/2012

Date In : 12/3/2012

Time Out : 12:55

Time In : 13:39

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 709

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : FAILED HEAD END FEEDER CABLE FROM SUB TO

Follow-Up : ISOLATED BAD FEEDER CABLE ,SWITCHED TO RESTORE

POWER

6b

From: Preston, Carly
Sent: Monday, December 03, 2012 1:47 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 12/3/12 Power Restored EDEN PRAIRIE, MN;
EDINA, MN; MINNEAPOLIS, MN
12/3/12 Power Restored

EDEN PRAIRIE, MN; EDINA, MN; MINNEAPOLIS, MN

Carly Preston
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Drive St. Paul, MN 55113
P: 651.639.4367 F: 651.639.4322
E: carly.preston@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Ayers, Patrick S
Sent: Monday, December 03, 2012 1:42 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/3/2012 Date In : 12/3/2012
Time Out : 12:55 Time In : 13:39

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 709

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; EDINA, MN; MINNEAPOLIS, MN

State : MN - Minnesota

6b

Major Customers : NONE

Cause : FAILED HEAD END FEEDER CABLE FROM SUB TO

Follow-Up : ISOLATED BAD FEEDER CABLE ,SWITCHED TO RESTORE

POWER

From: Driscoll, Paul M
Sent: Saturday, December 15, 2012 7:48 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/15/2012
Time Out : 18:34 Time In : 19:46

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 3794

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COLUMBIA HEIGHTS, MN; MENDOTA HEIGHTS, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : My guys worked with 2 West guys and put up this ...It let go at
an Automatic sleeve...

Follow-Up :

From: Jaede, Wendy L
Sent: Monday, December 17, 2012 10:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
Mendota Heights, Minneapolis, New Brighton & Saint Anthony - POWER RESTORED
Power outage - Columbia Heights, Mendota Heights, Minneapolis, New Brighton & Saint Anthony - power restored.

Wendy

From: Driscoll, Paul M
Sent: Saturday, December 15, 2012 7:48 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/15/2012
Time Out : 18:34 Time In : 19:46

Time Zone : CST

Duration : 1 hours, 12 mins

Number of Customers Affected : 3794

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Joe LaCasse: (651) 229-2243

Communities Affected : COLUMBIA HEIGHTS, MN; MENDOTA HEIGHTS, MN;
MINNEAPOLIS, MN; NEW BRIGHTON, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : My guys worked with 2 West guys and put up this ..It let go at
an Automatic sleeve...

Follow-Up :

8a

From: Hills, Thomas L
Sent: Sunday, December 16, 2012 4:55 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/16/2012
Time Out : 21:54 Time In : 04:51

Time Zone : CST

Duration : 6 hours, 57 mins

Number of Customers Affected : 4619

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Top of pole burned up.

Follow-Up :

8b

From: Jaede, Wendy L
Sent: Monday, December 17, 2012 10:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 12/15/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Sunday, December 16, 2012 4:55 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 12/15/2012 Date In : 12/16/2012
Time Out : 21:54 Time In : 04:51

Time Zone : CST

Duration : 6 hours, 57 mins

Number of Customers Affected : 4619

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Top of pole burned up.

Follow-Up :