

In the Matter of Xcel Energy's 2023 Integrated Distribution Plan

Docket No. E002/M-23-452

Commissioner Sieben proposes the following amended decision options:

Revised Sieben 27

27. Require Xcel Energy to engage in additional stakeholder discussions on approaches to apply CBAs, or a similar type of evaluation, strategically to program-level investments for discretionary projects for cost recovery proceedings.

Revised Sieben 49

49. For its 2025 IDP, require Xcel to refine its PNL methodology by increasing the PV dependability factor for summer-peaking areas. Xcel shall also evaluate alternative approaches to applying the dependability factor, including applying it to hourly PV generation and to PV nameplate capacity. Xcel shall engage parties that commented on PNL in this proceeding as it evaluates seasonal dependability factors and alternative PNL approaches. Xcel shall include a report describing the results of this evaluation and changes to its proposed PNL methodology in its next IDP.