Appendix J
Operations and Maintenance Schedule

Equipment	Short Description	Long Description	
	Primary Site Inspection	Visual inspection of general site conditions, including solar arrays, balance of plant, fencing, shading, vegetation, animal damage, erosion, roads, drainage systems and other civil infrastructure, signs of corrosion. Clear debris within the fence perimeter as needed.	Quarterly (4x)
SITE	Primary Site Inspection	Visual inspection of spare parts containers, communication cabinets, shelters, and any other enclosures on site for signs of secure & intact doors/windows, signs of forced entry or vandalism, animal nesting, damage, roof integrity, erosion that may compromise any part, obstruction to any ventilation	Quarterly (4x)
	Primary Site Inspection	Inspect all switches, fuses, and disconnects.	Annually (1x)
PV MODULES	Primary DC Field Inspection	Visual inspection of modules for cracks, discoloration, environmental seal deterioration, frame damage, backsheet damage, junction box problems, excessive soiling, cord-plate separation/arching, position movement, animal damage/nesting and vegetation overgrowth causing shading	Annually (1x)
	IR SCAN	Perform aerial IR scans on 100 percent (100%) of the modules to identify string outages, faulty modules, and any other string/module related issues	Annually (1x)

<u> </u>	Primary DC Field Inspection	enance Tasks and Free Visual inspection of posts, sub-structure frames,	Annually (1x)
MODULE SUPPORT		mounting systems, module	
STRUCTURES		clips, removed/damaged	
STRUCTURES		modules, grounding system,	
		and other relevant equipment	
	Primary DC Field Inspection	Inspect tracking/racking	Annually (1x)
	Trimary Berriela inspection	system for proper positioning,	/ mindany (1x)
		lose/worn	
		joints/couplings/bushings,	
		signs of cracked/damaged	
		drive components,	
		obstructions to normal	
		travel/movement, proper	
		operation and mounting of	
		any sensors and masts, rust	
		and corrosion, grounding	
		systems. Visual inspections of	
		all piles/foundations and	
		other steel	
	Maintenance	Lubricate slew gears	Every 2 years
	Maintenance	Perform preventive	Annually (1x)
TRACKER/		maintenance per	
RACKING SYSTEM		manufacturer's warranty	
(IF APPLICABLE)		requirements and	
,		recommended operations and	
		maintenance manual	
	Maintenance	Inspect module table for	Annually (1x)
		proper alignment and check a	
		sample of module rail	
		fasteners for proper	
	Maintenance	connection Tost wind stow functionality	Appually (1s)
	iviaintenance	Test wind stow functionality. Repeat for snow or flood	Annually (1x)
		sensors if installed	
	Maintenance	Inspect bearing housing	Annually (1x)
	iviaiiiteilaiite	assemblies for misalignment	Ailliually (1X)
		due to settling of piles and	
		adjust position if necessary	
	Maintenance	Inspect all electrical	Annually (1x)
	TVIGITICE TIGHTICE	•	/
		enclosures for cracking, pests,	

-	Maintenance	Check a sample of torque tube adapter torqued connections for proper torque value	Annually (1x)
DC HARNESS, CABLE AND WIRING	Primary DC Field Inspection	Visual inspection of all string level wiring (from modules through combiner box) and wire management and DC harnesses, including looking for fuse issues, compromised cable, stained, exposed or melted wiring, disconnected/separated connectors, crimped wire radii, unsecured wire harnesses/clips, animal damage/nesting, and grounding. Inspect the system for loose electrical connections	Annually (1x)
	Primary DC Field Inspection	Perform short circuit current (Isc) and open circuit voltage (Voc) testing of strings (10%)	Annually (1x)
COMBINER BOX	Primary DC Field Inspection	Perform IR scans on 100 percent (100%) of combiner boxes, recombiner boxes, string boxes, and tighten connections. Provide reporting on observed issues and address corrective maintenance items.	Annually (1x)
	Primary Site Inspection	Visual inspection of exterior for obstruction to ventilation, corrosion and environmental seals.	Quarterly (4x)
	Primary DC Field Inspection	Physical inspection of internal filters, wire terminations for torque mark alignment, exposed wires, pull tests, and any other checks recommended by OEM. Includes power blocks, terminal strips, DIN rails, grounding bus and systems, back panel, fuses, etc. Clean any dirt/debris	Annually (1x)

•	Maintenance	enance Tasks and Free Weekly pyranometer cleanings and visual inspection of sensor alignment	Weekly (52x)
	Maintenance	Weekly soiling station cleaning of 1 module or reference cell	Weekly (52x)
METEOROLOGICAL STATION	Primary Site Inspection	Full visual and operational inspection of weather stations, including pyranometers, BOM temperature sensors, temp/RH/wind/precipitation sensors, enclosures, tower, foundation, grounding and wiring. Clean any dirt/debris	Quarterly (4x)
	Primary DC Field Inspection	Desiccant pack replacement at meteorological and soiling station enclosures	Annually (1x)
	Maintenance	Support pyranometer recalibration effort managed by Owner or 3rd party (receive sensors, perform physical swap, perform SCADA system updates as necessary, ship sensors back, documentation of all items)	Every 2 years
	Primary Site Inspection	Full visual and operational inspection of soiling station equipment, including cabling, data logger, etc.	Quarterly (4x)
	Maintenance	Check protective cover, torques and contact resistors of the low-voltage connections between inverter and MV block	Annually (1x)
PCS ENCLOSURE	Maintenance	Check labels on Tracker Auxiliary Rack, check function of the TAR disconnect switches	Every 2 years
	Primary Site Inspection	Perform visual check of all equipment, enclosures, conduit for integrity, exhaust fans, louvers, actuators, general PCS inspection.	Quarterly (4x)

		Includes grounding system. Clean any dirt/debris	
HVAC	Maintenance	Inspection and check of site HVAC systems, including fans, compressors, filters, thermostats, timers, power and control wiring. Clean any dirt/debris. May be included in monthly substation maintenance.	Monthly (12x)
	Primary DC Field Inspection	Perform 100 percent (100%) inverter thermal imaging on connections, terminations, and other relevant areas	Annually (1x)
INVERTER	Primary Site Inspection	Visual inspection of exterior cabinet for: obstruction to ventilation, corrosion and environmental seals. Clean any dirt/debris	Quarterly (4x)
	Maintenance	Physical inspection of internal filters, capacitors for bulging, leaking or discoloration), wire terminations for torque mark alignment, exposed wires, pull tests, grounding systems and any other checks recommended by OEM. Clean any dirt/debris	Semi-Annual (
	Maintenance	Annual "heavy" physical inspection of internal filters, capacitors for bulging, leaking or discoloration), wire terminations for torque mark alignment, exposed wires, pull tests, grounding systems and any other checks recommended by OEM	Annually (1x)
	Maintenance	Enclosure status Doors and locks are in good state and close/seal properly. All keys and handles present Internal general cleanness; Change inverter air filters per	Annually (1x)

Proiect O	perations and Main	tenance Tasks and Fre	auencv*
1 10,000	porumonio una mum	requirements and recommended operations and	
		maintenance manual	
		Change inverter heat sinks per	
		manufacturer's warranty	
		requirements and	
		recommended operations and	
		maintenance manual	
		Check torque marks and retightening appropriate wiring	
		connections	
		AC wires and bolts status.	
		Control connections	-
		LCL filter capacitance	-
		MV connectors in MV	
		switchgear in good state SF6 pressure visual inspection	-
		(MV switchgear)	
		GFDI hardware trigger	-
	Maintenance	DC sources in proper range	Semi-Annual (2x)
	Wallediance	DC leakage detector	Jerm Amidai (2x)
		Surge protection devices	-
		feedback	
		GFDI feedback	-
		Signaling elements. LEDs and display work	
		Main temperatures in range	
		Verify meter power readings from the inverter against the SCADA data	
	Primary Site Inspection	Visually inspect exterior for obstruction to heat-sink fins, corrosion, leaking, and ensure the oil gauges are functioning properly, elbows, gauges,	Quarterly (4x)
MEDIUM-VOLTAGE TRANSFORMER		drain, test valves, grounding systems. Clean any dirt/debris. Check meters, oil	
		gauge, and temperature gauge. Verify transformer	
		temperatures in acceptable	
	Maintenance	Perform DGA on 100 percent (100%) of units	Annually (1x)

Project O	perations and Maint Maintenance	enance Tasks and Free Check labels for integrity	quency* Annually (1x)
	Maintenance	Check the bolted connection of the low-voltage connection	Annually (1x)
	Maintenance	Adjust the MV transformer tank pressure	Annually (1x)
	Primary DC Field Inspection	Perform 100 percent (100%) thermal imaging	Annually (1x)
GROUNDING SYSTEM	Maintenance	Including all site grounding wires, test wells, lightning protection and grounding plates. Maintenance included in inverter, tracker, module support structures, transformer, PCS enclosure, combiner box and substation items	Annually (1x)
PHOTOVOLTAIC INTERCONNECTION SWITCHGEAR	Primary DC Field Inspection	Includes bus work, exposures, circuit breaker and switches. Clean any dirt/debris	Annually (1x)
(PVIS)	Primary DC Field Inspection	Perform 100 percent (100%) thermal imaging	Annually (1x)
FIRE ALARMS/SAFETY	Maintenance	Inspection and check of site fire and security alarm systems, including wiring and associated devices. Testing of all alarms and related equipment. Inspection and general maintenance of eyewash station.	Monthly (12x)
AC CABLE AND WIRING	Maintenance	Physical inspection of all wire terminations for torque mark alignment, exposed wires and pull tests of clamped wire ends before and after seasonal temperature swings. Includes AC cables and wires from inverters to MV transformers, to the switchgear/substation, and any AC cables serving ancillary equipment and power panels. Inspect the system for loose electrical connections.	Annually (1x)

-	perations and Maint Maintenance	Visual inspections of Gentie	Annually (1x)
		for loose connections,	(2,
		structural issues and	
		grounding matters	
	Primary DC Field Inspection	Perform 100 percent (100%)	Annually (1x)
	,	thermal imaging, including any	(2,
		overhead AC system lines	
	Maintenance	Visual inspection and cleaning	Annually (1x)
		of all SCADA system	, , ,
		equipment. Includes power	
		and control wiring, SCADA	
		panels and enclosures,	
		structural and support	
		components, power supply,	
		interfaces, logic and controller	
		devices, monitoring devices	
	Maintenance	Technical/cyber inspection	Annually (1x)
		and cleanup, maintenance of	, , ,
		SCADA systems	
	Maintenance	IT maintenance includes VPN	Monthly (12x)
		account management and	
CADA CVCTENA		manufacturer required	
SCADA SYSTEM		maintenance on Servers,	
		Network Switches and	
		Firewalls.	
	Maintenance	Performance scheduled	Monthly (12x)
		maintenance on SCADA and	
		data acquisition systems, in	
		accordance with	
		manufacturer's instructions.	
		Perform software updates	
		within 30 days of software	
		update release.	
	Maintenance	SCADA system functional	Annually (1x)
		testing of batteries, validation	
		of data and server	
		maintenance	
	Maintenance	5-year major routine	Every 5 years
		maintenance (outage)	
HIGH VOLTAGE	Maintenance	Annual substation routine	Annually (1x)
STEP-UP		maintenance (outage)	
RANSFORMER (IF	Maintenance	Perform DGA on GSU	Annually (1x)
APPLICABLE)	Maintenance	Perform 100 percent (100%)	Annually (1x)
	Widirectionice	thermal imaging	,

	erations and Mai	5-year major substation routine maintenance (outage)	Every 5 years
	Maintenance	Annual substation routine	Annually (1x)
		maintenance (outage)	/ (2x)
	Maintenance	Annual substation and	Annually (1x)
		collector system IR scan	, (2 <i>N</i>)
	Maintenance	Monthly substation and	Monthly (12x)
		interconnection/gen-tie	, (==,
		inspection (fencing,	
		grounding, roads, debris, veg,	
		corrosion, leaks, enclosures &	
		all equipment, etc.). Includes	
		inspection of GSU oil	
		containment structures and	
		for leaks	
	Maintenance	Substation battery and backup	Monthly (12x)
CLIDCTATION		systems maintenance,	, ,,
SUBSTATION		including measurements of	
		float cell voltage, pilot cell	
		voltage, electrolyte	
		temperature of pilot cell,	
		specific gravity as required	
	Maintenance	Perform DGA on GSU (IF	Annually (1x)
		APPLICABLE)	, , ,
	Maintenance	Control building - integrity	Monthly (12x)
		inspection, cleaning of	
		dust/water from interior and	
		exterior areas and all	
		equipment, inspection and	
		operating check of HVAC	
		systems, fire alarms, security	
		systems, etc. Clean any	
		dirt/debris. Includes HVAC line	
		above	
	Maintenance	Perform annual meter	Annually (1x)
		calibrations and other	
		maintenance per	
		manufacturer	
METERS		recommendations. Includes	
		site energy meters, telecom	
		equipment and meters,	
		relaying and other electronic	
		equipment houses within the	
		control building. Clean any	
		dirt/debris	l

Project Operations and Maintenance Tasks and Frequency*				
TRANSMISSION LINE	Maintenance	Lemon Hill Solar will generally inspect the transmission lines annually as part of normal practices. These inspections will be limited to the right-of-way and to areas where obstructions or terrain may require off-right-of-way access. If issues are identified during inspection, repairs will be performed, and damage restored.	Annually (1x)	

^{*}Typical schedule subject to change based on the needs of the site.