



#	Disturbance Report	Advocates email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	1/15/12 2:29		FEEDER	DISCONNECT OH LOAD BREAK DISC OH	PUBLIC DAMAGE BROKEN POLE	100% RESTORED, REPAIRED PERM PARTIAL RESTORATION	774794	NO	
2	x	x	1	ME	1/27/12 14:53		FEEDER	CIRCUIT BREAKER	POLE FIRE	100% RESTORED VIA	777242	NO	
3	x	x	1	ME	1/27/12 18:51		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED, REPAIRED	776871	NO	
4	x	x	1	MW	1/1/12 1:40		FEEDER	CIRCUIT BREAKER	CONDUCTOR CONTACT -	100% RESTORED, REPAIRED	773734	NO	
5	x	x	1	MW	1/12/12 3:49		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA	774558	NO	
6	x	x	1	MW	1/26/12 3:27		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE GUY WIRE	100% RESTORED, REPAIRED	776489	NO	
7	x	x	1	MW	1/26/12 12:47		FEEDER	3P HV CONDUCTOR OH	SWITCH OH GANG OPERATED	100% RESTORED VIA	776540	NO	
8	x	x	1	MW	1/27/12 12:47		FEEDER	CIRCUIT BREAKER	SWITCH OH GANG OPERATED	100% RESTORED, REPAIRED	776703	NO	

Palmer, Susan L

From: Gilland, William P
Sent: Sunday, January 15, 2012 7:57 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 1/15/2012 Date In : 1/15/2012
Time Out : 02:29 Time In : 03:05

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 2978

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : remaining 642 cust's restored at 07:51

Follow-Up :

1b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, January 16, 2012 7:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 1/15/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Sunday, January 15, 2012 7:57 AM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 1/15/2012 Date In : 1/15/2012
Time Out : 02:29 Time In : 03:05

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 2978

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : remaining 642 cust's restored at 07:51

Follow-Up :

29

Palmer, Susan L

From: Elden, Thomas L
Sent: Friday, January 27, 2012 4:01 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/27/2012 Date In : 1/27/2012
Time Out : 14:53 Time In : 15:50

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 2071

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : wire down at cut in clear 100% are back
on cause pole fire

Follow-Up :

(2b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, January 30, 2012 7:52 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/27/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Friday, January 27, 2012 4:01 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/27/2012 Date In : 1/27/2012
Time Out : 14:53 Time In : 15:50

Time Zone : CST

Duration : 0 hours, 57 mins

Number of Customers Affected : 2071

For information about this alert, contact :

For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : wire down at cut in clear 100% are back
on cause pole fire

Follow-Up :

Palmer, Susan L

From: Elden, Thomas L
Sent: Friday, January 27, 2012 7:32 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/27/2012 **Date In :** 1/27/2012
Time Out : 18:51 **Time In :** 19:16

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 2277

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : car hit pole 2242 customers are back on and 35 customers are still out they will be out till pole is replaced

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, January 30, 2012 8:25 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 1/27/12 - Maplewood, Roseville & Saint Paul -
POWER RESTORED
Power outage - Maplewood, Roseville & Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Friday, January 27, 2012 7:32 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 1/27/2012 Date In : 1/27/2012
Time Out : 18:51 Time In : 19:16

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 2277

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : MAPLEWOOD, MN; ROSEVILLE, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : car hit pole 2242 customers are back on and 35 customers
are still out they will be out till pole is replaced

Follow-Up :

Palmer, Susan L

From: Kittock, Joseph C
Sent: Sunday, January 01, 2012 4:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/1/2012 Date In : 1/1/2012
Time Out : 01:40 Time In : 04:11

Time Zone : CST

Duration : 2 hours, 31 mins

Number of Customers Affected : 1044

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : WIRE DOWN

Follow-Up :

4b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, January 03, 2012 10:57 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/1/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Sunday, January 01, 2012 4:16 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/1/2012 Date In : 1/1/2012
Time Out : 01:40 Time In : 04:11

Time Zone : CST

Duration : 2 hours, 31 mins

Number of Customers Affected : 1044

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : WIRE DOWN

Follow-Up :

Palmer, Susan L

From: Goar, Bradford A
ent: Thursday, January 12, 2012 4:56 AM
o: dl Electric Outage M/W Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/12/2012
Time Out : 03:49

Date In : 1/12/2012
Time In : 04:47

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1621

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS,

MN

State : MN - Minnesota

Major Customers :

Cause : failed headend cable

Follow-Up : none

5b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, January 12, 2012 7:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: Final Outage Notice - 1/12/12 - Columbia Heights, Fridley & Minneapolis - POWER RESTORED

Power outage - Columbia Heights, Fridley & Minneapolis - power restored.

Wendy

From: Goar, Bradford A
Sent: Thursday, January 12, 2012 4:56 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/12/2012
Time Out : 03:49

Date In : 1/12/2012
Time In : 04:47

Time Zone : CST

Duration : 0 hours, 58 mins

Number of Customers Affected : 1621

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS,

MN

State : MN - Minnesota

Major Customers :

Cause : failed headend cable

Follow-Up : none

Palmer, Susan L

From: Ayers, Patrick S
Sent: Thursday, January 26, 2012 5:12 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/26/2012 Date In : 1/26/2012
Time Out : 03:27 Time In : 05:08

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 1096

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit guy wire

Follow-Up : cleared wire across freeway,cleared guy wire wrapped up
in feeder,restored power to feeder

(6b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, January 26, 2012 8:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: Final Outage Notice - 1/26/12 - Brooklyn Park & Osseo - POWER RESTORED

Power outage - Brooklyn Park & Osseo - power restored.

Wendy

From: Ayers, Patrick S
Sent: Thursday, January 26, 2012 5:12 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/26/2012 Date In : 1/26/2012
Time Out : 03:27 Time In : 05:08

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 1096

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit guy wire

Follow-Up : cleared wire across freeway,cleared guy wire wrapped up in feeder,restored power to feeder

7a

Palmer, Susan L

From: Knutson, David A
Sent: Thursday, January 26, 2012 1:21 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/26/2012 Date In : 1/26/2012
Time Out : 12:47 Time In : 12:53

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 1474

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BURNED UP

Follow-Up : TO BE REPLACED

76

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, January 26, 2012 2:09 PM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/26/12 - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth

I'm going to resend this...for whatever reason, it came back undeliverable to the PUC.

Wendy

From: Jaede, Wendy L
Sent: Thursday, January 26, 2012 1:52 PM
To: 'consumer.puc@state.mn.us'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 1/26/12 - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth

Power outage - Crystal, Golden Valley, Minneapolis, New Hope & Plymouth.

Wendy

From: Knutson, David A
Sent: Thursday, January 26, 2012 1:21 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 1/26/2012 Date In : 1/26/2012
Time Out : 12:47 Time In : 12:53

Time Zone : CST

Duration : 0 hours, 6 mins

Number of Customers Affected : 1474

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN; PLYMOUTH, MN

3/28/2012

State : MN - Minnesota

Major Customers : NONE

Cause : BURNED UP

Follow-Up : TO BE REPLACED

8a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Friday, January 27, 2012 3:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 1/27/2012 Date In : 1/27/2012
Time Out : 12:47 Time In : 14:25

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 2417

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause : Flash at

Follow-Up :

(8b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, January 27, 2012 3:25 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 1/27/12 - Corcoran, Hamel, Medina, Minneapolis & Plymouth - POWER RESTORED
Power outage - Corcoran, Hamel, Medina, Minneapolis & Plymouth - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Friday, January 27, 2012 3:04 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 1/27/2012 Date In : 1/27/2012
Time Out : 12:47 Time In : 14:25

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 2417

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : None

Cause :

Follow-Up :

3/28/2012

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	2/15/12 17:13		FEEDER	3P HV CONDUCTOR OH	OVERLOADED FUSE	100% RESTORED, REPAIRED	778881	NO	Start time adjusted when job was reviewed and
2	x	x	1	ME	2/20/12 22:20		DIST SUBSTATION BUS/TRANSFORMER DIST SUBSTATION BUS/TRANSFORMER	CIRCUIT BREAKER CIRCUIT BREAKER CIRCUIT BREAKER	ACCIDENTAL PROTECTION MISOP ACCIDENTAL PROTECTION MISOP POLE FIRE	100% RESTORED VIA SWITCHING 100% RESTORED VIA SWITCHING 100% RESTORED, REPAIRED	779466 779468 779469	NO	
3	x	x	1	ME	2/26/12 19:55		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	PARTIAL RESTORATION	780365	NO	
4	x	x	1	ME	2/28/12 17:55		FEEDER	CIRCUIT BREAKER	POLE FIRE	100% RESTORED, REPAIRED	782781	NO	
5	x	x	1	ME	2/29/12 6:44		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	781356	YES	STORM DAY
6	x	x	1	MW	2/21/12 1:15		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	779535	NO	
7	x	x	1	MW	2/28/12 23:58		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	780849	NO	
8	x	x	1	MW	2/29/12 3:10		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	781032	YES	STORM DAY
9	x	x	1	MW	2/29/12 6:21		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	783405	YES	STORM DAY
10	x	x	1	MW	2/29/12 7:08		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	781521	YES	STORM DAY
11	x	x	1	MW	2/29/12 9:28		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	782061	YES	STORM DAY
12	x	x	1	MW	2/29/12 10:03		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	782117	YES	STORM DAY
13	x	x	1	MW	2/29/12 10:04		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	782118	YES	STORM DAY
14	x	x	1	MW	2/29/12 13:19		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED VIA SWITCHING 100% RESTORED, REPAIRED	782371	YES	STORM DAY
15	x	x	1	NW	2/6/12 10:21		FEEDER	CIRCUIT BREAKER	ENVIRONMENT ICE FALLING	100% RESTORED, REPAIRED	777795	NO	
16	x	x	1	NW	2/9/12 13:57		TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	SWITCH OH GANG OPERATED	100% RESTORED VIA SWITCHING	778210	NO	
17	x	x	1	NW	2/20/12 19:03		FEEDER	3P HV CONDUCTOR OH CIRCUIT BREAKER	POLE FIRE	100% RESTORED, REPAIRED PERM	780019	NO	

Palmer, Susan L

From: Elden, Thomas L
Sent: Wednesday, February 15, 2012 7:31 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/15/2012 Date In : 2/15/2012
Time Out : 18:51 Time In : 19:04

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 3650

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : BLAINE, MN; CENTERVILLE, MN; CIRCLE PINES, MN; HUGO, MN; LINO LAKES, MN; NORTH OAKS, MN; NORTH SAINT PAUL, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : opened at 18:51 and closed at 19:04 to fix
jumper everyone is back on at 19:04 2891 customers were out

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, February 16, 2012 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: 1st Outage Notice - 2/15/12 - Blaine, Ctrville, Cir Pines, Hugo, Lino Lakes, N Oaks, N St Paul, St Paul, Shoreview - POWER RESTORED
Power outage - Blaine, Centerville, Circle Pines, Hugo, Lino Lakes, North Oaks, North Saint Paul, Saint Paul & Shoreview - power restored.

Wendy

From: Elden, Thomas L
Sent: Wednesday, February 15, 2012 7:31 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/15/2012 Date In : 2/15/2012
Time Out : 18:51 Time In : 19:04

Time Zone : CST

Duration : 0 hours, 13 mins

Number of Customers Affected : 3650

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : BLAINE, MN; CENTERVILLE, MN; CIRCLE PINES, MN; HUGO, MN; LINO LAKES, MN; NORTH OAKS, MN; NORTH SAINT PAUL, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : opened at 18:51 and closed at 19:04 to fix
jumper everyone is back on at 19:04 2891 customers were out

Follow-Up :

(2a)

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, February 20, 2012 10:55 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/20/2012 Date In : 2/20/2012
Time Out : 22:20 Time In : 22:49

Time Zone : CST

Duration : 0 hours, 29 mins

Number of Customers Affected : 6581

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; CIRCLE PINES, MN; LEXINGTON, MN; LINO LAKES, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : POLE FIRE
CLEARED LOCKOUT AND AND BACK IN

Follow-Up : TROUBLEMEN LOOKING OVER TO SEE WHAT
WE CAN DO TO BRING IN

2c

Palmer, Susan L

From: Abbott, Edward J
Sent: Tuesday, February 21, 2012 12:32 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/20/2012 Date In : 2/21/2012
Time Out : 22:20 Time In : 00:31

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 2724

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; MOUNDS VIEW,
MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : POLE FIRE, TOP OF POLE BURNT OFF

Follow-Up : TROUBLE TEMPED FOR THE NIGHT, REFERED TO
OVERHEAD TO REPLACE POLE

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, February 21, 2012 7:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/20/12 - Arden Hills, Blaine, Mounds View & Shoreview - POWER RESTORED
Power outage - Arden Hills, Blaine, Mounds View & Shoreview - power restored.

Wendy

From: Abbott, Edward J
Sent: Tuesday, February 21, 2012 12:32 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/20/2012 Date In : 2/21/2012

Time Out : 22:20 Time In : 00:31

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 2724

For information about this alert, contact :

For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; MOUNDS VIEW, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers : N/A

Cause : POLE FIRE, TOP OF POLE BURNT OFF

Follow-Up : TROUBLE TEMPED FOR THE NIGHT, REFERED TO OVERHEAD TO REPLACE POLE

3a

Palmer, Susan L

From: Rubedor, Mark W
Sent: Monday, February 27, 2012 8:28 AM
To: dl Electric Outage ME Notification
Subject: 1) Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/26/2012 Date In : 2/26/2012
Time Out : 19:55 Time In : 20:14

Time Zone : CST

Duration : 0 hours, 19 mins

Number of Customers Affected : 1828

For information about this alert, contact :

For follow-up information or questions, contact : Chuck Plummer: (651) 229-2240

Communities Affected : CENTER CITY, MN; CHISAGO LAKE, MN; MARINE SAINT CROIX,
MN; SHAFER, MN; TAYLORS FALLS, MN

State : MN - Minnesota

Major Customers :

Cause : Opened breaker and repaired burnt open jumper, closed breaker
after jumper was repaired. breaker tripped open again. opened and closed breaker at 20:14,
1197 customers restored. 631 customers were out until fault was cleared. was closed at 22:33
and all customers were restored.

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, February 27, 2012 8:53 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/26/12 - Center City, Chisago Lake, Marine Saint Croix, Shafer & Taylors Falls - POWER RESTORED
Power outage - Center City, Chisago Lake, Marine Saint Croix, Shafer & Taylors Falls - power restored.

Wendy

From: Rubedor, Mark W
Sent: Monday, February 27, 2012 8:28 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/26/2012 Date In : 2/26/2012
Time Out : 19:55 Time In : 20:14

Time Zone : CST

Duration : 0 hours, 19 mins

Number of Customers Affected : 1828

For information about this alert, contact :

For follow-up information or questions, contact : Chuck Plummer: (651) 229-2240

Communities Affected : CENTER CITY, MN; CHISAGO LAKE, MN; MARINE SAINT CROIX, MN; SHAFER, MN; TAYLORS FALLS, MN

State : MN - Minnesota

Major Customers :

Cause : Opened breaker and repaired burnt open jumper, closed breaker after jumper was repaired. breaker tripped open again. opened and closed breaker at 20:14, 1197 customers restored. 631 customers were out until fault was cleared. was closed at 22:33 and all customers were restored.

Follow-Up :

4a

Palmer, Susan L

From: Plummer, Charles H
Sent: Tuesday, February 28, 2012 8:23 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/28/2012 Date In : 2/28/2012
Time Out : 17:55 Time In : 19:43

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 2675

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-2240

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : n/a

Cause : top of pole burnt off, will need a crew to repair,

Follow-Up : there will be 32 customers out until repairs are made

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 7:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 2/28/12 - Marine Saint Croix & Stillwater - POWER RESTORED

Power outage - Marine Saint Croix & Stillwater - power restored.

Wendy

From: Plummer, Charles H
Sent: Tuesday, February 28, 2012 8:23 PM
To: dl Electric Outage ME Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/28/2012 Date In : 2/28/2012
Time Out : 17:55 Time In : 19:43

Time Zone : CST

Duration : 1 hours, 48 mins

Number of Customers Affected : 2675

For information about this alert, contact :
For follow-up information or questions, contact : Chuck Plummer: (651) 229-2240

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : n/a

Cause : top of pole burnt off, will need a crew to repair,

Follow-Up : there will be 32 customers out until repairs are made

5a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Wednesday, February 29, 2012 8:35 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 06:44 Time In : 08:19

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 2166

For information about this alert, contact : T.F
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : MAPLEWOOD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : We had a large tree on our feeder of
on My men got this tree off the feeder and we got the rest of the feeder
in at 08:19.

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 8:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/29/12 - Maplewood & Woodbury - POWER RESTORED
Power outage - Maplewood & Woodbury - power restored.

Wendy

From: Driscoll, Paul M
Sent: Wednesday, February 29, 2012 8:35 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 06:44 Time In : 08:19

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 2166

For information about this alert, contact : T.F
For follow-up information or questions, contact : Chuck Plummer: (651) 229-

2240

Communities Affected : MAPLEWOOD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : We had a large tree on our feeder of
on My men got this tree off the feeder and we got the rest of the feeder
in at 08:19.

Follow-Up :

60a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Tuesday, February 21, 2012 4:06 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/21/2012 Date In : 2/21/2012
Time Out : 01:15 Time In : 04:02

Time Zone : CST

Duration : 2 hours, 47 mins

Number of Customers Affected : 1271

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BUS LOCKOUT AT ,POSSIBLE CABLE FAILURE
OR LD CTR FAILURE IN T,

Follow-Up : ISOLATE FEEDER /PATROL AND RESTORE POWER
VIA SWITCHING



Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, February 21, 2012 7:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/21/12 - Columbia Heights & Minneapolis - POWER RESTORED

Power outage - Columbia Heights & Minneapolis - power restored.

Wendy

From: Ayers, Patrick S
Sent: Tuesday, February 21, 2012 4:06 AM
To: dl Electric Outage M/M Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/21/2012 Date In : 2/21/2012
Time Out : 01:15 Time In : 04:02

Time Zone : CST

Duration : 2 hours, 47 mins

Number of Customers Affected : 1271

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BUS LOCKOUT AT POSSIBLE CABLE FAILURE
OR LD CTR FAILURE IN AT

Follow-Up : ISOLATE FEEDER /PATROL AND RESTORE POWER
VIA SWITCHING

7a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Wednesday, February 29, 2012 2:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/28/2012 Date In : 2/29/2012
Time Out : 23:58 Time In : 02:05

Time Zone : CST

Duration : 2 hours, 7 mins

Number of Customers Affected : 1843

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch on wire

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 7:44 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/28/12 - Edina & Saint Louis Park - POWER RESTORED
Power outage - Edina & Saint Louis Park - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, February 29, 2012 2:08 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/28/2012 Date In : 2/29/2012
Time Out : 23:58 Time In : 02:05

Time Zone : CST

Duration : 2 hours, 7 mins

Number of Customers Affected : 1843

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : None

Cause : Branch on wire

Follow-Up :

8a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Wednesday, February 29, 2012 5:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 03:10 Time In : 05:16

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 1189

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : none

Cause : Trees on feeder /

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 7:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/29/12 - Minnetrista & Mound - POWER RESTORED
Power outage - Minnetrista & Mound - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, February 29, 2012 5:19 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 03:10 Time In : 05:16

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 1189

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : none

Cause : Trees on feeder /

Follow-Up :

Palmer, Susan L

From: Davis, Percyell
Sent: Wednesday, February 29, 2012 8:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 06:21 Time In : 08:19

Time Zone : CST

Duration : 1 hours, 58 mins

Number of Customers Affected : 4592

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : trees on feeder

Follow-Up : last 756 customers picked up

qb

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 8:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/29/12 -- UPDATE/POWER RESTORED
Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - update/power restored.

Wendy

From: Davis, Percyell
Sent: Wednesday, February 29, 2012 8:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 06:21 Time In : 08:19
Time Zone : CST
Duration : 1 hours, 58 mins
Number of Customers Affected : 4592
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : none

Cause : trees on feeder

Follow-Up : last 756 customers picked up

10a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 8:38 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 07:06 Time In : 08:17

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1749

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCHES ON FEEDER AT

Follow-Up :

106

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 8:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/29/12 - Brooklyn Park - POWER RESTORED
Power outage - Brooklyn Park - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 8:38 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012
Time Out : 07:06

Date In : 2/29/2012
Time In : 08:17

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1749

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCHES ON FEEDER AT

Follow-Up :

11a

Palmer, Susan L

From: Beckius, John J
Sent: Wednesday, February 29, 2012 10:50 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 09:28 Time In : 10:43

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 1961

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;
MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE LIMB ACCROSS FEEDER OF

Follow-Up :

nb

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 10:52 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/29/12 - Crystal Bay, & Wayzata - POWER RESTORED

Power outage - Crystal Bay, Excelsior, Minnetonka Bch, Mound, Navarre, Orono, Spring Park & Wayzata - power restored.

Wendy

From: Beckius, John J
Sent: Wednesday, February 29, 2012 10:50 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 09:28 Time In : 10:43

Time Zone : CST

Duration : 1 hours, 15 mins

Number of Customers Affected : 1961

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL BAY, MN; EXCELSIOR, MN; MINNETONKA BCH, MN;
MOUND, MN; NAVARRE, MN; ORONO, MN; SPRING PARK, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE LIMB ACCROSS FEEDER

JF

Follow-Up :

12a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 1:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 062

Date Out : 2/29/2012

Date In : 2/29/2012

Time Out : 10:03

Time In : 12:54

Time Zone : CST

Duration : 2 hours, 51 mins

Number of Customers Affected : 1394

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : LONG LAKE, MN; MAPLE PLAIN, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER AT

Follow-Up : PATROLLED FEEDER, REMOVED TREE BRANCHES FROM FEEDER.

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 1:45 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/29/12 - Long Lake, Maple Plain, Orono & Wayzata - POWER RESTORED
Power outage - Long Lake, Maple Plain, Orono & Wayzata - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 1:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 10:03 Time In : 12:54

Time Zone : CST

Duration : 2 hours, 51 mins

Number of Customers Affected : 1394

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : LONG LAKE, MN; MAPLE PLAIN, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FEEDER AT

Follow-Up : PATROLLED FEEDER, REMOVED TREE BRANCHES FROM FEEDER.

13a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 1:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 10:04 Time In : 12:55

Time Zone : CST

Duration : 2 hours, 51 mins

Number of Customers Affected : 1283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO,
MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCH ON FEEDER AT

Follow-Up : PATROL FEEDER CLEARED UP TREE BRANCH

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 1:05 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 2/29/12 - Crystal Bay, Long Lake, Orono & Wayzata - POWER RESTORED
Power outage - Crystal Bay, Long Lake, Orono & Wayzata - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 1:00 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 10:04 Time In : 12:55

Time Zone : CST

Duration : 2 hours, 51 mins

Number of Customers Affected : 1283

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CRYSTAL BAY, MN; LONG LAKE, MN; ORONO, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE BRANCH ON FEEDER AT

Follow-Up : PATROL FEEDER CLEARED UP TREE BRANCH

17a

Palmer, Susan L

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 3:38 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 **Date In :** 2/29/2012
Time Out : 13:19 **Time In :** 15:34

Time Zone : CST

Duration : 2 hours, 15 mins

Number of Customers Affected : 1555

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : NEUTRAL WIRE IN FEEDER,FEEDER WIRE BURNED
NEEDED REPAIRS

Follow-Up : REPAIRS COMPLETE ON FEEDER,ALL CUST IN ON
FEEDER LOCK.467 CUST RESTORED AS OF1534

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, February 29, 2012 3:14 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 2/29/12 - Hopkins & Minnetonka - POWER RESTORED

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Ayers, Patrick S
Sent: Wednesday, February 29, 2012 3:08 PM
To: dl Electric Outage MW Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/29/2012 Date In : 2/29/2012
Time Out : 13:19 Time In : 14:47

Time Zone : CST

Duration : 1 hours, 28 mins

Number of Customers Affected : 1555

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : NEUTRAL WIRE IN FEEDER

Follow-Up : AS OF 1447 WE HAVE 1088 CUST. RESTORED, NEED TO REPAIR FEEDER TO RESTORE LAST 467 CUST.

Palmer, Susan L

From: Chase, Julie B
Sent: Monday, February 06, 2012 11:10 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/6/2012 Date In : 2/6/2012
Time Out : 10:21 Time In : 11:07

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1123

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : found nothing on patrol

15b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, February 06, 2012 11:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 2/6/12 - Glenwood - POWER RESTORED
Power outage - Glenwood - power restored.

Wendy

From: Chase, Julie B
Sent: Monday, February 06, 2012 11:10 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 2/6/2012 Date In : 2/6/2012
Time Out : 10:21 Time In : 11:07

Time Zone : CST

Duration : 0 hours, 46 mins

Number of Customers Affected : 1123

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN

State : MN - Minnesota

Major Customers :

Cause :

Follow-Up : found nothing on patrol

16a

Palmer, Susan L

From: Reinschmidt, Brad A
Sent: Thursday, February 09, 2012 2:13 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/9/2012 Date In : 2/9/2012
Time Out : 13:57 Time In : 14:07

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 1148

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : None

Cause : Pole fire on transmission line

Follow-Up :

166

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, February 09, 2012 2:16 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 2/9/12 - Glenwood, Lowry & Starbuck -
POWER RESTORED
Power outage - Glenwood, Lowry & Starbuck - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Thursday, February 09, 2012 2:13 PM
To: dl Electric Outage NT Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 2/9/2012 Date In : 2/9/2012
Time Out : 13:57 Time In : 14:07

Time Zone : CST

Duration : 0 hours, 10 mins

Number of Customers Affected : 1148

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN; LOWRY, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : None

Cause : Pole fire on transmission line

Follow-Up :

17a

Palmer, Susan L

From: Reinschmidt, Brad A
Sent: Tuesday, February 21, 2012 1:28 AM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/20/2012 Date In : 2/21/2012
Time Out : 19:03 Time In : 01:20

Time Zone : CST

Duration : 6 hours, 17 mins

Number of Customers Affected : 1600

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN; LONG BEACH, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : None

Cause : Pole fire

Follow-Up : Repaired pole

17b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, February 21, 2012 7:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 2/20/12 - Glenwood, Long Beach & Starbuck -
POWER RESTORED
Power outage - Glenwood, Long Beach & Starbuck - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Tuesday, February 21, 2012 1:28 AM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 2/20/2012 Date In : 2/21/2012
Time Out : 19:03 Time In : 01:20

Time Zone : CST

Duration : 6 hours, 17 mins

Number of Customers Affected : 1600

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GLENWOOD, MN; LONG BEACH, MN; STARBUCK, MN

State : MN - Minnesota

Major Customers : None

Cause : Pole fire

Follow-Up : Repaired pole

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	3/19/12 20:01		FEEDER	CIRCUIT BREAKER	CAPACITOR BANK FAILURE OH	100% RESTORED, REPAIRED	786298	NO	
2	x	x	1	ME	3/27/12 13:03		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	787633	NO	
3	x	x	1	ME	3/29/12 9:09		FEEDER	CIRCUIT BREAKER	ACCIDENTAL PROTECTION MISOP	100% RESTORED, REPAIRED	788089	NO	
4	x	x	1	MW	3/14/12 14:48		FEEDER	CIRCUIT BREAKER	SPLICE UG PRIMARY HEAT SHRINK	100% RESTORED VIA SWITCHING	784751	NO	
5	x	x	1	MW	3/14/12 15:27		FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER PORCELAIN	100% RESTORED, REPAIRED	784775	NO	
6	x	x	1	MW	3/15/12 22:39		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	784990	NO	
7	x	x	1	MW	3/17/12 0:13		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING 100% RESTORED, REPAIRED	785484	NO	
8	x	x	1	MW	3/18/12 18:05		FEEDER	3P HV CONDUCTOR OH CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED VIA SWITCHING	785664	NO	
9	x	x	1	MW	3/19/12 19:42		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	786122	NO	
10	x	x	1	MW	3/19/12 19:43		TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	POLE BROKEN / GOOD CONDITION	100% RESTORED VIA SWITCHING	786128 786129	NO	
11	x	x	1	MW	3/27/12 16:58		FEEDER	CIRCUIT BREAKER DISCONNECT OH	SWITCH OH SINGLE BLADE DISC	100% RESTORED VIA SWITCHING	787726	NO	
12	x	x	1	MW	3/29/12 16:15		FEEDER	LOAD BREAK DISC OH	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED	788288	NO	
13	x	x	1	MW	3/31/12 23:34		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI JACKETED	100% RESTORED VIA SWITCHING	788622	NO	
14	x	x	1	SE	3/10/12 14:54		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED	784136	NO	
15	x	x	1	SE	3/19/12 21:38		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	CONDUCTOR CONTACT - POOR SAG	100% RESTORED VIA SWITCHING	786376	NO	
16	x	x	1	SE	3/29/12 11:59		DIST SUBSTATION	3P HV CONDUCTOR OH	LIGHTNING ARRESTER	100% RESTORED, REPAIRED	788772	NO	

1a

Palmer, Susan L

From: Gilland, William P
Sent: Monday, March 19, 2012 8:58 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 20:01 Time In : 20:55

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 3238

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : cap bank failure at

Follow-Up :

16

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, March 20, 2012 8:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/19/12 - Roseville & Saint Paul - POWER RESTORED

Power outage - Roseville and Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Monday, March 19, 2012 8:58 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 20:01 Time In : 20:55

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 3238

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : cap bank failure at

Follow-Up :

Palmer, Susan L

From: Chial, Terry L
Sent: Tuesday, March 27, 2012 2:24 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/27/2012 Date In : 3/27/2012
Time Out : 13:03 Time In : 14:11

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 1775

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : tree on line man cleared

Follow-Up : very windy

(26)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, March 27, 2012 2:26 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/27/12 - Newport, Saint Paul Park & Woodbury -
POWER RESTORED
Power outage - Newport, Saint Paul Park & Woodbury - power restored.

Wendy

From: Chial, Terry L
Sent: Tuesday, March 27, 2012 2:24 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/27/2012 Date In : 3/27/2012
Time Out : 13:03 Time In : 14:11

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 1775

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : tree on line man cleared

Follow-Up : very windy

Palmer, Susan L

From: Abbott, Edward J
Sent: Thursday, March 29, 2012 10:15 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/29/2012 Date In : 3/29/2012
Time Out : 09:09 Time In : 10:01

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1227

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH
LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : problems with relays, showed no targets, referred to emp to
check relays on Feeder back in

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, March 29, 2012 10:24 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/29/12 - Inver Grove Hghts, Inver Grove, Mendota Hghts, St Paul, Sunfish Lake, W St Paul - POWER RESTD
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Thursday, March 29, 2012 10:15 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/29/2012 Date In : 3/29/2012
Time Out : 09:09 Time In : 10:01

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1227

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : problems with relays, showed no targets, referred to emp to
check relays on Feeder back in

Follow-Up :

4a

Palmer, Susan L

From: Hills, Thomas L
Sent: Wednesday, March 14, 2012 4:30 PM
To: dl Electric Outage MW Notification
Subject: nal Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/14/2012 Date In : 3/14/2012
Time Out : 14:46 Time In : 16:27

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 4130

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Failed cable.

Follow-Up : All customers restored at 16:27.

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, March 15, 2012 7:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/14/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Wednesday, March 14, 2012 4:30 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/14/2012 Date In : 3/14/2012
Time Out : 14:46 Time In : 16:27

Time Zone : CST

Duration : 1 hours, 41 mins

Number of Customers Affected : 4130

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Failed cable.

Follow-Up : All customers restored at 16:27.

Palmer, Susan L

From: Knutson, David A
Sent: Wednesday, March 14, 2012 5:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/14/2012 Date In : 3/14/2012
Time Out : 15:27 Time In : 17:55

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 1330

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : blown arrestors neutral down pole fire by

Follow-Up :

56

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, March 15, 2012 7:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 3/14/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Knutson, David A
Sent: Wednesday, March 14, 2012 5:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 3/14/2012 Date In : 3/14/2012
Time Out : 15:27 Time In : 17:55

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 1330

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : blown arrestors neutral down pole fire by

Follow-Up :

6a

Palmer, Susan L

From: Beckius, John J
Sent: Thursday, March 15, 2012 11:33 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 3/15/2012 Date In : 3/15/2012
Time Out : 22:39 Time In : 23:15

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 2134

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : failed head end cable

Follow-Up :

(6b)

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, March 16, 2012 7:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/15/12 - Brooklyn Center & Brooklyn Park -
POWER RESTORED

Power outage - Brooklyn Center & Brooklyn Park - power restored.

Wendy

From: Beckius, John J
Sent: Thursday, March 15, 2012 11:33 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/15/2012 Date In : 3/15/2012
Time Out : 22:39 Time In : 23:15

Time Zone : CST

Duration : 0 hours, 36 mins

Number of Customers Affected : 2134

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; BROOKLYN PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : failed head end cable

Follow-Up :

7a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Saturday, March 17, 2012 12:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/17/2012 Date In : 3/17/2012
Time Out : 00:13 Time In : 12:00

Time Zone : CST

Duration : 11 hours, 47 mins

Number of Customers Affected : 38

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : Tree down on feeder / cleared tree / repaired x-arm / replaced

Follow-Up :

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, March 19, 2012 8:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/17/12 - Crystal, Golden Valley & New Hope -
POWER RESTORED/UPDATE
Power outage - Crystal, Golden Valley & New Hope - power restored/update.

Wendy

From: Peterson, Kenneth W
Sent: Saturday, March 17, 2012 12:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 069

Date Out : 3/17/2012 Date In : 3/17/2012
Time Out : 00:13 Time In : 12:00

Time Zone : CST

Duration : 11 hours, 47 mins

Number of Customers Affected : 38

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : Tree down on feeder / cleared tree /repaired x-arm / replaced

Follow-Up :

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Sunday, March 18, 2012 7:51 PM
To: dl Electric Outage MW Notification
Subject: (Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/18/2012 Date In : 3/18/2012
Time Out : 18:05 Time In : 19:23

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1557

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : automatic let loose ph

Follow-Up : Picked up cust at 1918 and remaining 141 at 1923

8b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, March 19, 2012 8:40 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: . inal Outage Notice - 3/18/12 - Hopkins & Minnetonka - POWER RESTORED

Power outage - Hopkins & Minnetonka - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, March 18, 2012 7:51 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/18/2012 Date In : 3/18/2012
Time Out : 18:05 Time In : 19:23

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 1557

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : none

Cause : automatic let loose ph

Follow-Up : Picked up 1416 cust at 1918 and remaining 141 at 1923

9a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Monday, March 19, 2012 9:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 19:42 Time In : 21:01

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1860

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : large pine tree on feeder / removed tree

Follow-Up :

9b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, March 20, 2012 8:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/19/12 - Brooklyn Park, Maple Grove & Osseo -
POWER RESTORED
Power outage - Brooklyn Park, Maple Grove & Osseo - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, March 19, 2012 9:08 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 19:42 Time In : 21:01

Time Zone : CST

Duration : 1 hours, 19 mins

Number of Customers Affected : 1860

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : none

Cause : large pine tree on feeder / removed tree

Follow-Up :

10a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Monday, March 19, 2012 9:15 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 19:43 Time In : 20:51

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 3770

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : transmission line out

Follow-Up :

10b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, March 20, 2012 8:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/19/12 - Brooklyn Park, Maple Grove & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Maple Grove & Osseo - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, March 19, 2012 9:15 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/19/2012
Time Out : 19:43 Time In : 20:51

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 3770

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers :

Cause : transmission line out

Follow-Up :

Palmer, Susan L

From: Hills, Thomas L
Sent: Tuesday, March 27, 2012 7:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/27/2012 Date In : 3/27/2012
Time Out : 16:58 Time In : 19:25

Time Zone : CST

Duration : 2 hours, 27 mins

Number of Customers Affected : 1423

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CARVER, MN; CHASKA, MN

State : MN - Minnesota

Major Customers : None

Also at Cause : At we have burned up.
station the reclosure has a burned up pushing.

Follow-Up : All customers restored at 1925.

11b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, March 28, 2012 7:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/27/12 - Carver & Chaska - POWER RESTORED
Power outage - Carver & Chaska - power restored.

Wendy

From: Hills, Thomas L
Sent: Tuesday, March 27, 2012 7:27 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 061

Date Out : 3/27/2012 Date In : 3/27/2012
Time Out : 16:58 Time In : 19:25

Time Zone : CST

Duration : 2 hours, 27 mins

Number of Customers Affected : 1423

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CARVER, MN; CHASKA, MN

State : MN - Minnesota

Major Customers : None

Also at Cause : At we have : burned up.
station the reclosure has a burned up bushing.

Follow-Up : All customers restored at 1925.

Palmer, Susan L

From: Ayers, Patrick S
Sent: Thursday, March 29, 2012 8:10 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 311

Date Out : 3/29/2012 Date In : 3/29/2012
Time Out : 16:15 Time In : 20:07

Time Zone : CST

Duration : 3 hours, 52 mins

Number of Customers Affected : 570

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : DUMP TRUCK HIT CABLE TV AND NEUTRAL WIRE, BROKE 2 CROSS ARMS, NEUTRAL WIRE.

Follow-Up : CREW REPAIRED CROSS ARMS, FEEDER AND NEUTRAL WIRE

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, March 30, 2012 8:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 3/29/12 - POWER RESTORED
Power outage - Chanhassen, Chaska, Cologne, Excelsior, Minnetonka, Minnetrista, Mound, Saint Bonifacius, Shorewood, Victoria, Waconia, Watertown Twp, Watertown & Wayzata - power restored.

Wendy

From: Ayers, Patrick S
Sent: Thursday, March 29, 2012 8:10 PM
To: dl Electric Outage MW Notification
Subject:) Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/29/2012 Date In : 3/29/2012
Time Out : 16:15 Time In : 20:07

Time Zone : CST

Duration : 3 hours, 52 mins

Number of Customers Affected : 570

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : CHANHASSEN, MN; CHASKA, MN; COLOGNE, MN; EXCELSIOR, MN; MINNETONKA, MN; MINNETRISTA, MN; MOUND, MN; SAINT BONIFACIUS, MN; SHOREWOOD, MN; VICTORIA, MN; WACONIA, MN; WATERTOWN TWP, MN; WATERTOWN, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : DUMP TRUCK HIT CABLE TV AND NEUTRAL WIRE, BROKE 2 CROSS ARMS, NEUTRAL WIRE.

Follow-Up : CREW REPAIRED CROSS ARMS, FEEDER AND NEUTRAL WIRE

4/11/2012

Palmer, Susan L

From: Kittock, Joseph C
Sent: Sunday, April 01, 2012 12:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2012 Date In : 4/1/2012
Time Out : 23:34 Time In : 00:15

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 1586

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NON

Cause : HEAD END CABLE FAULT

Follow-Up :

13b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, April 02, 2012 7:40 AM
To: staff, cao (PUC)
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 4/1/12 Power Restored Edina, Saint Louis Park
4/1/12 Power Restored
Edina, Saint Louis Park

From: Kittock, Joseph C
Sent: Sunday, April 01, 2012 12:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 3/31/2012 Date In : 4/1/2012
Time Out : 23:34 Time In : 00:15

Time Zone : CST

Duration : 0 hours, 41 mins

Number of Customers Affected : 1586

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NON

Cause : HEAD END CABLE FAULT

Follow-Up :

(Ka)

Palmer, Susan L

From: Goulet, Terry W
Sent: Saturday, March 10, 2012 3:56 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/10/2012 Date In : 3/10/2012
Time Out : 14:54 Time In : 15:48

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 1152

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GOODVIEW, MN; MINNESOTA CITY, MN; WINONA, MN

State : MN - Minnesota

Major Customers : NA

Cause : FEEDER LOCK DUE TO COTTONWOOD LIMB FALLING ON
TOP OF FEEDER @

Follow-Up :



Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, March 12, 2012 8:22 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/10/12 - Goodview, Minnesota City, Winona -
POWER RESTORED
Power outage - Goodview, Minnesota City, Winona - power restored.

Wendy

From: Goulet, Terry W
Sent: Saturday, March 10, 2012 3:56 PM
To: dl Electric Outage SF Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/10/2012 Date In : 3/10/2012
Time Out : 14:54 Time In : 15:48

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 1152

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GOODVIEW, MN; MINNESOTA CITY, MN; WINONA, MN

State : MN - Minnesota

Major Customers : NA

Cause : FEEDER LOCK DUE TO COTTONWOOD LIMB FALLING ON
TOP OF FEEDER @

Follow-Up :

15a

Palmer, Susan L

From: Kaveny, Michael J
Sent: Tuesday, March 20, 2012 12:28 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/20/2012
Time Out : 21:38 Time In : 00:21

Time Zone : CST

Duration : 2 hours, 43 mins

Number of Customers Affected : 2077

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : DAKOTA, MN; HOMER, MN; HOUSTON, MN; NODINE, MN;
WINONA, MN; WITOKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Crew put wire back up and closed
1667 customers. 100% Restored at 00:21.

Switch restoring remaining

Follow-Up :

15b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, March 20, 2012 8:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 3/19/12 - Dakota, Homer, Houston, Nodine, Winona & Witoka - POWER RESTORED
Power outage - Dakota, Homer, Houston, Nodine, Winona & Witoka - power restored.

Wendy

From: Kaveny, Michael J
Sent: Tuesday, March 20, 2012 12:28 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 3/19/2012 Date In : 3/20/2012
Time Out : 21:38 Time In : 00:21

Time Zone : CST

Duration : 2 hours, 43 mins

Number of Customers Affected : 2077

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : DAKOTA, MN; HOMER, MN; HOUSTON, MN; NODINE, MN;
WINONA, MN; WITOKA, MN

State : MN - Minnesota

Major Customers : None

Cause : Crew put wire back up and closed Switch restoring remaining
1667 customers. 100% Restored at 00:21.

Follow-Up :

169

Palmer, Susan L

From: Chase, Julie B
Sent: Thursday, March 29, 2012 2:34 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus : 021

Date Out : 3/29/2012 Date In : 3/29/2012

Time Out : 11:59 Time In : 14:25

Time Zone : CST

Duration : 2 hours, 26 mins

Number of Customers Affected : 624

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : FAIRFAX, MN; GIBBON, MN

State : MN - Minnesota

Major Customers :

Cause : Blown fuse in substation. Blown lightning arrester on transformer.

Follow-Up : Did troubleshooting of transformer with operator and EM&P to verify that it had not failed. No field ties. After consult with substation, worked with transmission to safely energize transformer and bring town back in.

166b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, March 29, 2012 2:35 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 3/29/12 - Fairfax & Gibbon - POWER RESTORED
Power outage - Fairfax & Gibbon - power restored.

Wendy

From: Chase, Julie B
Sent: Thursday, March 29, 2012 2:34 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 3/29/2012 Date In : 3/29/2012
Time Out : 11:59 Time In : 14:25

Time Zone : CST

Duration : 2 hours, 26 mins

Number of Customers Affected : 624

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : FAIRFAX, MN; GIBBON, MN

State : MN - Minnesota

Major Customers :

Cause : Blown v fuse in substation. Blown lightning arrester on transformer.

Follow-Up : Did troubleshooting of transformer with operator and EM&P to verify that it had not failed. No field ties. After consult with substation, worked with transmission to safely energize transformer and bring town back in.

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	4/13/12 22:08	FEEDER		CIRCUIT BREAKER	LIGHTNING ARRESTER PORCELAIN	100% RESTORED VIA SWITCHING	792515	FALSE	
2	x	x	1	ME	4/16/12 4:34	FEEDER		CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	791774	FALSE	Start time adjusted when job was reviewed and approved.
3	x	x	1	ME	4/18/12 3:44	FEEDER		CIRCUIT BREAKER	CABLE FAILURE PRIMARY P&L	100% RESTORED VIA SWITCHING	792304	FALSE	
4	x	x	1	ME	4/29/12 8:34	FEEDER		3P HV CONDUCTOR OH CIRCUIT BREAKER LOAD BREAK DISC OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	794847	FALSE	
5	x	x	1	MW	4/15/12 10:01	FEEDER		CIRCUIT BREAKER	ANIMAL CONTACT OTHER	REPAIRS NOT NEEDED	791463	FALSE	Start time adjusted when job was reviewed and approved.
6	x	x	1	MW	4/15/12 19:22	FEEDER		CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED, REPAIRED	792466	FALSE	
7	x	x	1	MW	4/16/12 3:39	FEEDER		CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED	791760	FALSE	
8	x	x	1	MW	4/21/12 14:54	FEEDER		CIRCUIT BREAKER	INSULATOR GLASS/PORC DEADEND	100% RESTORED VIA SWITCHING	792951	FALSE	

1a

Palmer, Susan L

From: Chial, Terry L
Sent: Saturday, April 14, 2012 12:37 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/13/2012
Time Out : 22:06

Date In : 4/14/2012
Time In : 00:26

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 2013

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : ARESTERS FAILED AT SWITCH ,PHASE
BURNED DOWN

Follow-Up : REFERED FOR REPAIRS .

16

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 16, 2012 8:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/13/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Chial, Terry L
Sent: Saturday, April 14, 2012 12:37 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/13/2012 Date In : 4/14/2012
Time Out : 22:06 Time In : 00:26

Time Zone : CST

Duration : 2 hours, 20 mins

Number of Customers Affected : 2013

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : NO

Cause : ARESTERS FAILED AT SWITCH ,PHASE
BURNED DOWN

Follow-Up : REFERED FOR REPAIRS .

2a

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, April 16, 2012 5:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/16/2012 Date In : 4/16/2012
Time Out : 04:35 Time In : 05:34

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1811

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE ON FEEDER AT
REMOVED BY TROUBLEMAN AND FEEDER BACK IN

Follow-Up :

26

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 16, 2012 8:28 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/16/12 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, April 16, 2012 5:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 4/16/2012 Date In : 4/16/2012
Time Out : 04:35 Time In : 05:34

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1811

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : LARGE TREE ON FEEDER AT
REMOVED BY TROUBLEMAN AND FEEDER BACK IN

Follow-Up :

3a

Palmer, Susan L

From: Elden, Thomas L
Sent: Wednesday, April 18, 2012 6:33 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/18/2012 Date In : 4/18/2012
Time Out : 03:44 Time In : 05:35

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 1742

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bad urd cable from to sub

Follow-Up :

3b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, April 18, 2012 8:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/18/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Wednesday, April 18, 2012 6:33 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus : 085

Date Out : 4/18/2012 Date In : 4/18/2012
Time Out : 03:44 Time In : 05:35

Time Zone : CST

Duration : 1 hours, 51 mins

Number of Customers Affected : 1742

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : bad urd cable from o sub

Follow-Up :

4a

Palmer, Susan L

From: Chial, Terry L
Sent: Sunday, April 29, 2012 4:21 PM
To: dl Electric Outage ME Notification
Subject: ial Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/29/2012 Date In : 4/29/2012
Time Out : 08:34 Time In : 14:15

Time Zone : CST

Duration : 5 hours, 41 mins

Number of Customers Affected : 2598

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL,
MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : ALL CUSTMERS IN AT 14:15.

Cause : TREE FELL THROUGH PRIMARY

Follow-Up : ONLY 177 CUSTOMERS WERE OUT PAST 10:34

4b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 30, 2012 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: al Outage Notice - 4/29/12 - Maplewood, Newport, Saint Paul & Woodbury - POWER RESTORED/UPDATE
Power outage - Maplewood, Newport, Saint Paul & Woodbury - power restored/update.

Wendy

From: Chial, Terry L
Sent: Sunday, April 29, 2012 4:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/29/2012 Date In : 4/29/2012
Time Out : 08:34 Time In : 14:15

Time Zone : CST

Duration : 5 hours, 41 mins

Number of Customers Affected : 2598

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : ALL CUSTMERS IN AT 14:15.

Cause : TREE FELL THROUGH PRIMARY

Follow-Up : ONLY 177 CUSTOMERS WERE OUT PAST 10:34

5a

Palmer, Susan L

From: Aspinwall, David P
Sent: Sunday, April 15, 2012 11:49 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/15/2012 Date In : 4/15/2012
Time Out : 10:10 Time In : 11:45

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 4521

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN;
MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : GOOSE

Follow-Up :

5b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 16, 2012 8:21 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/15/12 - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - POWER RESTORED
Power outage - Brooklyn Park, Champlin, Coon Rapids, Maple Grove & Osseo - power restored.

Wendy

From: Aspinwall, David P
Sent: Sunday, April 15, 2012 11:49 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/15/2012 Date In : 4/15/2012
Time Out : 10:10 Time In : 11:45

Time Zone : CST

Duration : 1 hours, 35 mins

Number of Customers Affected : 4521

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN PARK, MN; CHAMPLIN, MN; COON RAPIDS, MN;
MAPLE GROVE, MN; OSSEO, MN

State : MN - Minnesota

Major Customers : NONE

Cause : GOOSE AT

Follow-Up :

609

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Sunday, April 15, 2012 8:09 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/15/2012 Date In : 4/15/2012
Time Out : 19:22 Time In : 20:02

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 1008

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Lightning

Follow-Up : is further to the East then mapped / additional 55
customers out



Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 16, 2012 8:23 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/15/12 - Minnetonka - POWER RESTORED
Power outage - Minnetonka - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, April 15, 2012 8:09 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/15/2012 Date In : 4/15/2012
Time Out : 19:22 Time In : 20:02

Time Zone : CST

Duration : 0 hours, 40 mins

Number of Customers Affected : 1008

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETONKA, MN

State : MN - Minnesota

Major Customers :

Cause : Lightning

Follow-Up : s further to th then mapped / additional 55
customers out

79

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Monday, April 16, 2012 5:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/16/2012 Date In : 4/16/2012
Time Out : 03:39 Time In : 05:18

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 1189

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree fell into feeder at ut tree off of feeder

Follow-Up :

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 16, 2012 8:26 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 4/16/12 - Minnetrista & Mound - POWER RESTORED
Power outage - Minnetrista & Mound - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Monday, April 16, 2012 5:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/16/2012 Date In : 4/16/2012
Time Out : 03:39 Time In : 05:18

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 1189

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNETRISTA, MN; MOUND, MN

State : MN - Minnesota

Major Customers : none

Cause : Tree fell into feeder at / cut tree off of feeder

Follow-Up :



Palmer, Susan L

From: Schwarz, John W
Sent: Saturday, April 21, 2012 4:23 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 4/21/2012 Date In : 4/21/2012
Time Out : 14:54 Time In : 16:10

Time Zone : CST

Duration : 1 hours, 16 mins

Number of Customers Affected : 987

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : BURNT JUMPERS, X ARM & BELLS .
100% RESTORED @ 16:10

Follow-Up :

gb

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, April 23, 2012 7:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 4/21/12 - Edina & Richfield - UPDATE
Power outage - Edina & Richfield - update.

Wendy

From: Ayers, Patrick S
Sent: Saturday, April 21, 2012 3:59 PM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 4/21/2012 Date In :
Time Out : 14:54 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 987

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-

2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers :

Cause : x arms burned, dead end bells broken, feeder wire almost on
ground at :

Follow-Up : troubleman patrolled feeder found bad x arms, feeder wire
burned. isolated bad x arms, reattached feeder to clear area, switching to restore power

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm Escalated Ops	Comments
	x	x	1	ME	5/5/12 15:59		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	797776	NO	
2	x	x	1	ME	5/19/12 18:43		FEEDER	CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED, REPAIRED TEMP	800828	NO	
3	x	x	1	ME	5/19/12 18:49		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	800872	NO	
4	x	x	1	ME	5/19/12 19:00		FEEDER	LOAD BREAK DISC OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED PERM	800913	NO	
5	x	x	1	ME	5/19/12 19:31		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	800954	NO	
6	x	x	1	ME	5/23/12 14:44		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	802337	NO	
7	x	x	1	ME	5/23/12 18:16		FEEDER	CIRCUIT BREAKER	CONDUCTOR CONTACT - FLOATING	100% RESTORED, REPAIRED PERM	802581	NO	
8	x	x	1	ME	5/23/12 22:38		FEEDER	CIRCUIT BREAKER	CROSSARM ARM BROKEN	100% RESTORED, REPAIRED TEMP	802827	NO	
9	x	x	1	ME	5/24/12 8:12		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED VIA SWITCHING	806460 806459	NO	
10	x	x	1	ME	5/29/12 14:19		FEEDER	CIRCUIT BREAKER	ACCIDENTAL DIG IN BY XCEL ELEC	100% RESTORED, REPAIRED PERM	806203	NO	
11	x	x	1	MW	5/4/12 7:00		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE DIG-IN	100% RESTORED VIA SWITCHING	798152	NO	
12	x	x	1	MW	5/5/12 5:04		DIST SUBSTATION		XCEL PLANNED CONSTRUCTION		796428		
							BUS/TRANSFORMER		OUTAGE		796430 796431	NO	
13	x	x	1	MW	5/5/12 18:00		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	796612	NO	
14	x	x	1	MW	5/5/12 18:03		FEEDER	3P HV CONDUCTOR OH CIRCUIT BREAKER LOAD BREAK DISC OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	798257	NO	
15	x	x	1	MW	5/6/12 2:26		FEEDER	CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED VIA SWITCHING	797005	NO	
16	x	x	1	MW	5/6/12 2:27		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	REPAIRS NOT NEEDED	797010	NO	
17	x	x	1	MW	5/11/12 15:34		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED PERM	798676	NO	
18	x	x	1	MW	5/13/12 20:03		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	799052	NO	
19	x	x	1	MW	5/19/12 5:05		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR CONSTRUCT	100% RESTORED VIA SWITCHING	800608 800608 800608	NO	Start time adjusted when job was reviewed and approved.
20	x	x	1	MW	5/22/12 18:16		FEEDER	3P HV CONDUCTOR OH	UNKNOWN CAUSE UNDER INVEST	100% RESTORED VIA SWITCHING	801954	NO	
21	x	x	1	MW	5/24/12 12:11		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED PERM	803313	NO	
22	x	x	1	MW	5/27/12 19:43		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	805245	NO	
23	x	x	1	MW	5/27/12 20:06		FEEDER	CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED, REPAIRED PERM	805284	NO	
24	x	x	1	MW	5/27/12 22:01		FEEDER	CIRCUIT BREAKER LOAD BREAK DISC OH	PUBLIC DAMAGE BROKEN POLE	100% RESTORED VIA SWITCHING	805500	NO	
25	x		1	NW	5/24/12 7:53		FEEDER	CIRCUIT BREAKER	INTENTIONAL CLEAR FOR	100% RESTORED, REPAIRED PERM	803025	NO	
26	x	x	1	SE	5/6/12 1:46		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT DETERMINED	100% RESTORED, REPAIRED PERM	798939	NO	
27	x	x	1	SE	5/22/12 22:50		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	802084	NO	
28	x	x	1	SE	5/24/12 18:28		FEEDER	CIRCUIT BREAKER FUSE OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED, REPAIRED PERM	803538	NO	

Palmer, Susan L

From: Chial, Terry L
Sent: Saturday, May 05, 2012 5:53 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/5/2012
Time Out : 15:59 Time In : 17:44

Time Zone : CST

Duration : 1 hours, 45 mins

Number of Customers Affected : 1502

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : tree fell on feeder along side off , cut clear and
feed from down side .

Follow-Up : tree crew on route

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/5/12 - Eagan - POWER RESTORED
Power outage - Eagan - power restored.

Wendy

From: Chial, Terry L
Sent: Saturday, May 05, 2012 5:53 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/5/2012
Time Out : 15:59 Time In : 17:44

Time Zone : CST

Duration : 1 hours, 45 mins.

Number of Customers Affected : 1502

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : EAGAN, MN

State : MN - Minnesota

Major Customers :

Cause : tree fell on pp feeder ; cut clear and
feed from down side .

Follow-Up : tree crew on route

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 7:58 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 18:43 Time In : 19:27

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 2453

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : mn

Cause : jumper was burned open at

Follow-Up :

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Monday, May 21, 2012 8:36 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: 'nal Outage Notice 5/19/2012 POWER RESTORED *final*
5/19/2012 Power Restored

FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 07:58
To: dl Electric Outage ME Notification
Subject: Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 18:43 Time In : 19:27

Time Zone : CST

Duration : 0 hours, 44 mins

Number of Customers Affected : 2453

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 7:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 18:49 Time In : 22:12

Time Zone : CST

Duration : 3 hours, 23 mins

Number of Customers Affected : 1775

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ARDEN HILLS, MN; NEW BRIGHTON, MN;
ROSEVILLE, MN; SAINT PAUL, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : tree on feeder line

Follow-Up :

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Monday, May 21, 2012 8:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/19/2012 POWER RESTORED
5/19/2012 Power Restored

ARDEN HILLS, MN; NEW BRIGHTON, MN; ROSEVILLE, MN; SAINT PAUL, MN;
SHOREVIEW, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 08:07
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 18:49 Time In : 22:12

Time Zone : CST

Duration : 3 hours, 23 mins

Number of Customers Affected : 1775

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 7:40 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012
Time Out : 19:00

Date In : 5/19/2012
Time In : 20:43

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 669

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ARDEN HILLS, MN; ROSEVILLE, MN

State : MN - Minnesota

Major Customers :

Cause : tree was on feeder

Follow-Up :

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Monday, May 21, 2012 8:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/19/2012 POWER RESTORED ARDEN HILLS,
MN; ROSEVILLE, MN
5/19/2012 Power Restored

ARDEN HILLS, MN; ROSEVILLE, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Eiden, Thomas L
Sent: Sunday, May 20, 2012 07:40
To: dl Electric Outage MF Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 074

Date Out : 5/19/2012
Time Out : 19:00

Date In : 5/19/2012
Time In : 20:43

Time Zone : CST

Duration : 1 hours, 43 mins

Number of Customers Affected : 669

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

6/22/2012

Palmer, Susan L

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 7:37 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 072, 075

Date Out : 5/20/2012

Date In : 5/20/2012

Time Out : 19:31

Time In : 20:39

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 3637

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : storm

Follow-Up : : load was on . it time of outage

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Monday, May 21, 2012 8:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/19/2012 POWER RESTORED
5/19/2012 Power Restored

INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Elden, Thomas L
Sent: Sunday, May 20, 2012 07:37
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/20/2012 Date In : 5/20/2012
Time Out : 19:31 Time In : 20:39

Time Zone : CST

Duration : 1 hours, 8 mins

Number of Customers Affected : 3637

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

6a

Palmer, Susan L

From: Chial, Terry L
Sent: Wednesday, May 23, 2012 4:55 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/23/2012 Date In : 5/23/2012
Time Out : 14:44 Time In : 16:50

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 831

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : FARMINGTON, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell across primary took out feeder

Follow-Up : t man cleared feeder and reenergized.

(ceb)

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Thursday, May 24, 2012 8:19 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/23/12 POWER RESTORED FARMINGTON, MN
5/23/12 Power Restored

FARMINGTON, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Chial, Terry L
Sent: Wednesday, May 23, 2012 16:55
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 062

Date Out : 5/23/2012

Date In : 5/23/2012

Time Out : 14:44

Time In : 16:50

Time Zone : CST

Duration : 2 hours, 6 mins

Number of Customers Affected : 831

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

6/22/2012

Palmer, Susan L

From: Chial, Terry L
Sent: Wednesday, May 23, 2012 8:04 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/23/2012 Date In : 5/23/2012
Time Out : 18:16 Time In : 20:01

Time Zone : CST

Duration : 1 hours, 45 mins

Number of Customers Affected : 1207

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : EAGAN, MN; ROSEMOUNT, MN

State : MN - Minnesota

Major Customers : NO

Cause : WIRE DOWN AT ' SWITCH TOOK OUT
RECLOSER AT

Follow-Up :

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Thursday, May 24, 2012 8:30 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/23/12 Power Restored EAGAN, MN;
ROSEMOUNT, MN
5/23/12 Power Restored

EAGAN, MN; ROSEMOUNT, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Chial, Terry L
Sent: Wednesday, May 23, 2012 20:04
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 061

Date Out : 5/23/2012 Date In : 5/23/2012
Time Out : 18:16 Time In : 20:01

Time Zone : CST

Duration : 1 hours, 45 mins

Number of Customers Affected : 1207

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

8b

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Tuesday, May 29, 2012 1:16 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: _____ Second Outage Notice 5/24/2012 OUTAGE/UPDATE NEWPORT,
MN; SAINT PAUL PARK, MN; WOODBURY, MN
5/24/12 Outage/Update

NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Driscoll, Paul M
Sent: Thursday, May 24, 2012 06:33
To: dl Electric Outage ME Notification
Subject: _____ second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus : 063, 071

Date Out : 5/24/2012 Date In : 5/25/2012
Time Out : 22:38 Time In : 01:24

Time Zone : CST

Duration : 2 hours, 46 mins

Number of Customers Affected : 1824

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

6/22/2012

8c

Palmer, Susan L

From: Chial, Terry L
Sent: Thursday, May 24, 2012 12:00 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/23/2012 Date In :
Time Out : 22:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1772

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : ALLEY ARM BURNED OFF AND FELL ON LOWER DECK
FEEDER

Follow-Up : WORKING ON IT

8d

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Thursday, May 24, 2012 8:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 5/23/12 OUTAGE NEWPORT, MN; SAINT PAUL
PARK, MN; WOODBURY, MN
5/23/12 Outage

NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Chial, Terry L
Sent: Thursday, May 24, 2012 00:00
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/23/2012 Date In :
Time Out : 22:24 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1772

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

6/22/2012

9a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Thursday, May 24, 2012 9:46 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 08:12 Time In : 09:36

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 4843

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : AFTON, MN; COTTAGE GROVE, MN; HASTINGS,
MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : My troublemen wound nothing wrong,we closed
breaker at 09:36..

Follow-Up :

9b

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Thursday, May 24, 2012 10:11 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 5/24/12 Update AFTON, MN;
COTTAGE GROVE, MN; HASTINGS, MN; WOODBURY, MN
5/24/12 Update

AFTON, MN; COTTAGE GROVE, MN; HASTINGS, MN; WOODBURY, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Driscoll, Paul M
Sent: Thursday, May 24, 2012 09:46
To: dl Electric Outage MF Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus : 063, 064

Date Out : 5/24/2012
Time Out : 08:12

Date In : 5/24/2012
Time In : 09:36

Time Zone : CST

Duration : 1 hours, 24 mins

Number of Customers Affected : 4843

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

10a

Palmer, Susan L

From: Elden, Thomas L
Sent: Tuesday, May 29, 2012 2:59 PM
To: dl Electric Outage ME Notification
Subject: () Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/29/2012 Date In : 5/29/2012
Time Out : 14:19 Time In : 14:54

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 1811

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : relay prob

Follow-Up :

106

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, May 29, 2012 3:03 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/29/12 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - power restored.

Wendy

From: Eiden, Thomas L
Sent: Tuesday, May 29, 2012 2:59 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 072

Date Out : 5/29/2012 Date In : 5/29/2012
Time Out : 14:19 Time In : 14:54

Time Zone : CST

Duration : 0 hours, 35 mins

Number of Customers Affected : 1811

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : relay prob

Follow-Up :

11a

Palmer, Susan L

From: Schwarz, John W
Sent: Friday, May 04, 2012 8:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/4/2012 Date In : 5/4/2012
Time Out : 07:00 Time In : 07:52

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1848

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT CABLE BETWNNT THE THE

Follow-Up :

11b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, May 04, 2012 8:48 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/4/12 - Edina & Saint Louis Park - POWER RESTOREDQ
Power outage - Edina & Saint Louis Park - power restored.

Wendy

From: Schwarz, John W
Sent: Friday, May 04, 2012 8:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 5/4/2012 Date In : 5/4/2012
Time Out : 07:00 Time In : 07:52
Time Zone : CST
Duration : 0 hours, 52 mins
Number of Customers Affected : 1848
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CUT CABLE BETWNNT THE & THE

Follow-Up :

12a

Palmer, Susan L

From: Aspinwall, David P
Sent: Saturday, May 05, 2012 7:24 AM
To: dl Electric Outage MW Notification
Subject:) Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/5/2012
Time Out : 05:04 Time In : 06:10

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 3866

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;
OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : .

Cause : SWITCHING

Follow-Up : .

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:23 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: ' Final Outage Notice - 5/5/12 - POWER RESTORED/UPDATE
Power outage - Cologne, Mayer, New Germany, Nya, Osakis, Waconia Twp, Waconia & Watertown - power restored/update.

Wendy

From: Hayman, Craig A
Sent: Saturday, May 05, 2012 7:29 AM
To: Aspinwall, David P; dl Electric Outage MW Notification
Subject: RE: Final Outage Notice

This was a planned, intentional outage to repair a defective arc snuffer on a disconnect switch.

From: Aspinwall, David P
Sent: Saturday, May 05, 2012 7:24 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus : 061, 062, 064

Date Out : 5/5/2012 Date In : 5/5/2012
Time Out : 05:04 Time In : 06:10

Time Zone : CST

Duration : 1 hours, 6 mins

Number of Customers Affected : 3866

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;
OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

13a

Palmer, Susan L

From: Aspinwall, David P
Sent: Saturday, May 05, 2012 4:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 097

Date Out : 5/5/2012

Date In : 5/5/2012

Time Out : 04:00 PM

Time In : 04:54 PM

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 2043

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE @

Follow-Up : NONE

13b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:30 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/5/12 - Minneapolis, Richfield & Woodbury - POWER RESTORED

Power outage - Minneapolis, Richfield & Woodbury - power restored.

Wendy

From: Aspinwall, David P
Sent: Saturday, May 05, 2012 4:59 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/5/2012
Time Out : 04:00 PM Time In : 04:54 PM

Time Zone : CST

Duration : 0 hours, 54 mins

Number of Customers Affected : 2043

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; RICHFIELD, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE @

Follow-Up : NONE

14a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Sunday, May 06, 2012 8:18 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/6/2012
Time Out : 16:03 Time In : 14:00

Time Zone : CST

Duration : 21 hours, 57 mins

Number of Customers Affected : 377

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : non

Cause : broken poles / wind

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:) Final Outage Notice - 5/5/12 - Richfield - POWER RESTORED
Power outage - Richfield - power restored.

Wendy

From: Kittock, Joseph C
Sent: Sunday, May 06, 2012 8:18 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/5/2012 Date In : 5/6/2012

Time Out : 16:03 Time In : 14:00

Time Zone : CST

Duration : 21 hours, 57 mins

Number of Customers Affected : 377

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : non

Cause : broken poles / wind

Follow-Up :

15a

Palmer, Susan L

From: Kittock, Joseph C
Sent: Sunday, May 06, 2012 7:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 02:26 Time In : 07:39

Time Zone : CST

Duration : 5 hours, 13 mins

Number of Customers Affected : 1699

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : bad cable

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:40 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/6/12 - Columbia Heights, Fridley & Minneapolis
- POWER RESTORED
Power outage - Columbia Heights, Fridley & Minneapolis - power restored.

Wendy

From: Kittock, Joseph C
Sent: Sunday, May 06, 2012 7:50 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 02:26 Time In : 07:39

Time Zone : CST
Duration : 5 hours, 13 mins

Number of Customers Affected : 1699

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; FRIDLEY, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : bad cable

Follow-Up :

16a

Palmer, Susan L

From: Beckius, John J
Sent: Sunday, May 06, 2012 5:15 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 02:27 Time In : 05:03

Time Zone : CST

Duration : 2 hours, 36 mins

Number of Customers Affected : 1606

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown possible lightning patrolled ok

Follow-Up :

16ab

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: Final Outage Notice - 5/6/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored

Wendy

From: Beckius, John J
Sent: Sunday, May 06, 2012 5:15 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 02:27 Time In : 05:03

Time Zone : CST

Duration : 2 hours, 36 mins

Number of Customers Affected : 1606

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : unknown possible lightning patrolled ok

Follow-Up :

17a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Friday, May 11, 2012 4:32 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/11/2012 Date In : 5/11/2012
Time Out : 15:34 Time In : 16:26

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1120

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; SHOREWOOD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FDR : TREE CLEARED

Follow-Up :

17b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 14, 2012 8:02 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/11/12 - Chanhassen, Excelsior, Shorewood -
POWER RESTORED
Power outage - Chanhassen, Excelsior, Shorewood - power restored.

Wendy

From: Anderson, Timothy K
Sent: Friday, May 11, 2012 4:32 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/11/2012 Date In : 5/11/2012
Time Out : 15:34 Time In : 16:26

Time Zone : CST

Duration : 0 hours, 52 mins

Number of Customers Affected : 1120

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; SHOREWOOD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON FDR REE CLEARED

Follow-Up :

18a

Palmer, Susan L

From: Hills, Thomas L
Sent: Sunday, May 13, 2012 9:53 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/13/2012 Date In : 5/13/2012
Time Out : 20:03 Time In : 21:50

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 2622

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree across

Follow-Up : All cust. restored.

186

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 14, 2012 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 5/13/12 - Crystal, Minneapolis & New Hope -
POWER RESTORED
Power outage - Crystal, Minneapolis & New Hope - power restored.

Wendy

From: Hills, Thomas L
Sent: Sunday, May 13, 2012 9:53 PM
To: dl Electric Outage ^{MW} Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/13/2012 Date In : 5/13/2012
Time Out : 20:03 Time In : 21:50

Time Zone : CST

Duration : 1 hours, 47 mins

Number of Customers Affected : 2622

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : None

Cause : Tree across

Follow-Up : All cust. restored.

19a

Palmer, Susan L

From: Davis, Percyell
Sent: Saturday, May 19, 2012 7:29 AM
To: dl Electric Outage MW Notification
Subject: \ Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 05:08 Time In : 06:17

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 3863

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN;
OSAKIS, MN; WACONIA TWP, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : none

Cause : intentional : backin service

Follow-Up :

196

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Monday, May 21, 2012 8:31 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/19/2012 POWER RESTORED
5/19/2012 Power Restored

COLOGNE, MN; MAYER, MN; NEW GERMANY, MN; NYA, MN; OSAKIS, MN; WACONIA TWP, MN;
WACONIA, MN; WATERTOWN, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Davis, Percyell
Sent: Saturday, May 19, 2012 07:29
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 5/19/2012 Date In : 5/19/2012
Time Out : 05:08 Time In : 06:17
Time Zone : CST
Duration : 1 hours, 9 mins
Number of Customers Affected : 3863

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

20a

Palmer, Susan L

From: Beckius, John J
Sent: Wednesday, May 23, 2012 4:58 AM
To: dl Electric Outage MW Notification
Subject: (Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/22/2012 Date In : 5/22/2012
Time Out : 18:16 Time In : 23:15

Time Zone : CST

Duration : 4 hours, 59 mins

Number of Customers Affected : 1439

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CARVER, MN; CHASKA, MN

State : MN - Minnesota

Major Customers : none

Cause : failed cable & jumpers cut open for crane

Follow-Up :

206

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Wednesday, May 23, 2012 9:08 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/22/2012 POWER RESTORED CARVER, MN;
CHASKA, MN
5/22/2012 Power Restored
CARVER, MN; CHASKA, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Beckius, John J
Sent: Wednesday, May 23, 2012 04:58
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/22/2012 Date In : 5/22/2012
Time Out : 18:16 Time In : 23:15

Time Zone : CST

Duration : 4 hours, 59 mins

Number of Customers Affected : 1439

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

6/22/2012

21a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Thursday, May 24, 2012 1:10 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 12:11 Time In : 13:06

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 2915

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : WIRE DOWN BTWN

Follow-Up :

216

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Thursday, May 24, 2012 1:21 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/24/12 POWER RESTORED EDINA, MN; RICHFIELD, MN

5/24/12 Power Restored

EDINA, MN; RICHFIELD, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

From: Anderson, Timothy K
Sent: Thursday, May 24, 2012 13:10
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 12:11 Time In : 13:06

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 2915

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

6/22/2012

22a

Palmer, Susan L

From: Beckius, John J
Sent: Sunday, May 27, 2012 8:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/27/2012 Date In : 5/27/2012
Time Out : 19:43 Time In : 20:47

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1553

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON LINE AT

Follow-Up :

22b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, May 29, 2012 11:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/27/12 - Deephaven, Minnetonka & Wayzata -
POWER RESTORED
Power outage - Deephaven, Minnetonka & Wayzata - power restored.

Wendy

From: Beckius, John J
Sent: Sunday, May 27, 2012 8:52 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/27/2012 Date In : 5/27/2012
Time Out : 19:43 Time In : 20:47

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 1553

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREE ON LINE AT

Follow-Up :

23a

Palmer, Susan L

From: Beckius, John J
Sent: Sunday, May 27, 2012 9:13 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/27/2012 Date In : 5/27/2012
Time Out : 20:08 Time In : 21:10

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 2156

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers : .

Cause : CUTOUTS BURN'T UP AT

Follow-Up :

236

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, May 29, 2012 11:41 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice -5/27/12 - Crystal, Golden Valley, Minneapolis & New Hope - POWER RESTORED
Power outage - Crystal, Golden Valley, Minneapolis & New Hope - power restored.

Wendy

From: Beckius, John J
Sent: Sunday, May 27, 2012 9:13 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/27/2012 Date In : 5/27/2012
Time Out : 20:08 Time In : 21:10

Time Zone : CST

Duration : 1 hours, 2 mins

Number of Customers Affected : 2156

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; MINNEAPOLIS, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : CUTOUTS BURN'T UP AT

Follow-Up :

6/22/2012

24a

Palmer, Susan L

From: Hills, Thomas L
Sent: Monday, May 28, 2012 1:20 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/27/2012 Date In : 5/28/2012
Time Out : 22:01 Time In : 01:16

Time Zone : CST

Duration : 3 hours, 15 mins

Number of Customers Affected : 1654

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN;
SHOREWOOD, MN

State : MN - Minnesota

Major Customers : None

Cause : Truck hit pole at ,

Follow-Up : All customers restored.

6/22/2012

24b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, May 29, 2012 11:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 5/27/12 - Deephaven, Excelsior, Greenwood & Shorewood - POWER RESTORED
Power outage - Deephaven, Excelsior, Greenwood & Shorewood - power restored.

Wendy

From: Hills, Thomas L
Sent: Monday, May 28, 2012 1:20 AM
To: dl Electric Outage M/W Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 5/27/2012 Date In : 5/28/2012
Time Out : 22:01 Time In : 01:16

Time Zone : CST
Duration : 3 hours, 15 mins
Number of Customers Affected : 1654

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; EXCELSIOR, MN; GREENWOOD, MN;
SHOREWOOD, MN

State : MN - Minnesota

Major Customers : None

Cause : Truck hit pole at

Follow-Up : All customers restored.

25a

Palmer, Susan L

From: Chase, Julie B
Sent: Thursday, May 24, 2012 8:12 AM
To: dl Electric Outage NT Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 07:53 Time In : 08:10

Time Zone : CST

Duration : 0 hours, 17 mins

Number of Customers Affected : 5170

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : BUFFALO, MN; MONTICELLO, MN; SAINT MICHAEL, MN

State : MN - Minnesota

Major Customers :

Cause : ntentional to remove tracking arrestor.

Follow-Up :

2609

Palmer, Susan L

From: Bui, Tien V
Sent: Sunday, May 06, 2012 4:39 AM
To: dl Electric Outage SE Notification
Subject:) Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 01:46 Time In : 04:28

Time Zone : CST

Duration : 2 hours, 42 mins

Number of Customers Affected : 812

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : JORDAN, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK SUB NON RTU / CREW PATROL
FOUND NOTHING / RECLOSE BREAKER 100% RESTORE.

Follow-Up :

266b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, May 07, 2012 8:43 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 5/6/12 - Jordan & Shakopee - POWER RESTORED
Power outage - Jordan & Shakopee - power restored.

Wendy

From: Bui, Tien V
Sent: Sunday, May 06, 2012 4:39 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 5/6/2012 Date In : 5/6/2012
Time Out : 01:46 Time In : 04:28

Time Zone : CST

Duration : 2 hours, 42 mins

Number of Customers Affected : 812

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : JORDAN, MN; SHAKOPEE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK SUB NON RTU / CREW PATROL
FOUND NOTHING / RECLOSE BREAKER 100% RESTORE.

Follow-Up :

276

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Wednesday, May 23, 2012 9:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/23/12 Power Restored RED WING, MN
5/23/12 Power Restored

RED WING, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Bui, Tien V
Sent: Wednesday, May 23, 2012 02:54
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/22/2012 Date In : 5/23/2012
Time Out : 22:50 Time In : 02:20

Time Zone : CST

Duration : 3 hours, 30 mins

Number of Customers Affected : 2079

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : RED WING, MN

28a

Palmer, Susan L

From: Bui, Tien V
Sent: Friday, May 25, 2012 12:18 AM
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 16:28 Time In : 23:55

Time Zone : CST

Duration : 7 hours, 27 mins

Number of Customers Affected : 1154

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : GOODVIEW, MN; MINNESOTA CITY, MN; WINONA, MN

State : MN - Minnesota

Major Customers : N/A

Cause : FEEDER LOCK - STRAIGHT WIND KNOCK DOWN
TREES ON TO FEEDER (€ ALONG MINNESOTA CITY) CREW CLEAR ALONG
CLOSE BKR PICKUP 1138 CUSTOMERS REMAINING OF 16 CUSTOMER BACKIN AT
23:55

Follow-Up : THE LAST 16 CUST PICKUP AT 23:55

286

Palmer, Susan L

From: Guttormson, Allyson E
Sent: Friday, May 25, 2012 8:18 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 5/24/12 POWER RESTORED GOODVIEW, MN;
MINNESOTA CITY, MN; WINONA, MN
5/24/12 Power Restored

GOODVIEW, MN; MINNESOTA CITY, MN; WINONA, MN

Allyson Guttormson
Xcel Energy | Responsible By Nature
Customer Advocate Analyst
3115 Centre Pointe Dr, Roseville, MN 55113
P: (651) 639-4526 F: (651) 639-4322
E: allyson.e.guttormson@xcelenergy.com

XCELENERGY.COM
Please consider the environment before printing this email

From: Bui, Tien V
Sent: Friday, May 25, 2012 00:18
To: dl Electric Outage SE Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 5/24/2012 Date In : 5/24/2012
Time Out : 16:28 Time In : 23:55

Time Zone : CST

Duration : 7 hours, 27 mins

Number of Customers Affected : 1154

For information about this alert, contact :
For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

#	Disturbance Report	Advocates - email to PUC	Count	Region	Begin Date & Time	Feeder Name	Outage Level	Device Type	Cause	Follow-Up	Primary Event Index	Storm/ Escalated Ops	Comments
1	x	x	1	ME	6/7/12 23:43		FEEDER	3P HV CONDUCTOR OH	PUBLIC DAMAGE BROKEN POLE	100% RESTORED, REPAIRED PERM 100% RESTORED	809271	NO	
2	x	x	1	ME	6/10/12 12:53		FEEDER	LOAD BREAK DISC	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	823188	YES	Storm day
3	x	x	1	ME	6/10/12 14:05		FEEDER	CIRCUIT BREAKER	POLE FIRE	100% RESTORED, REPAIRED	810362	YES	Storm day
4	x	x	1	ME	6/10/12 21:04		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	810787	YES	Storm day
5	x	x	1	ME	6/10/12 21:05		FEEDER	CIRCUIT BREAKER	LIGHTNING STRIKE	100% RESTORED VIA SWITCHING	823182	YES	Storm day
6	x	x	1	ME	6/10/12 21:14		FEEDER	CIRCUIT BREAKER	POLE ROTTEN	100% RESTORED, REPAIRED	810917	YES	Storm day
7	x	x	1	ME	6/11/12 15:38		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRIMARY LC	100% RESTORED, REPAIRED	811686	NO	
8	x	x	1	ME	6/17/12 23:38		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	823959	NO	
9	x	x	1	ME	6/17/12 23:49		FEEDER	CIRCUIT BREAKER	LOAD BREAK DISC	100% RESTORED, REPAIRED	815300	NO	
10	x	x	1	ME	6/18/12 20:50		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED BY AUTO	816126	NO	
11	x	x	1	ME	6/19/12 3:35		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	816510	YES	Storm day
12	x	x	1	ME	6/19/12 4:23		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	816716	YES	Storm day
13	x	x	1	ME	6/19/12 4:24		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	818183	YES	Storm day
14	x	x	1	ME	6/19/12 4:25		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	824248		
								CORRIDOR VEG TREE	100% RESTORED, REPAIRED	816794	YES	Storm day	
								OUTSIDE MAIN CORRIDOR	PERM 100% RESTORED	816736			
15	x	x	1	ME	6/19/12 4:29		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	816851		Storm day -
								CORRIDOR PARALLEL	PERM 100% RESTORED	816830			
								LOAD BREAK DISC	VIA SWITCHING 100%	816830	YES		
								OH	RESTORED, REPAIRED PERM	816932			
								CIRCUIT BREAKER	PARTIAL RESTORATION	816932		CGR061 SENT OUT INCORRECTLY AS CGR062	
16	x	x	1	ME	6/19/12 4:30		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	824269		
								LOAD BREAK DISC	100% RESTORED VIA SWITCHING	824269			
								OH	100% RESTORED, REPAIRED	816925	YES	Storm day	
								CIRCUIT BREAKER	TEMP 100%	816925			
								LOAD BREAK DISC	RESTORED, REPAIRED PERM	816844			
17	x	x	1	ME	6/19/12 4:32		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	817028		Storm day - ONE MINUTE DIFFERENCE ON START
								LOAD BREAK DISC	CORRIDOR LIGHTNING	100% RESTORED VIA SWITCHING	817028		
								OH	STRIKE VEG	100% RESTORED, REPAIRED	816928	YES	TIME OF STY072 FEEDER ALERT, LATER CHANGED
								3P HV CONDUCTOR OH	TREE INSIDE MAINT CORRIDOR	PERM PARTIAL	816928		
								CIRCUIT BREAKER	POLE BROKEN / GOOD CONDITION	RESTORATION	817201		
								CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	PARTIAL RESTORATION	817201		TO MATCH 06/19/12 04:32.
18	x	x	1	ME	6/19/12 4:34		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	817009	YES	Storm day
19	x	x	1	ME	6/19/12 14:54		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	820167	YES	Storm day
20	x	x	1	ME	6/21/12 4:58		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	822326	NO	
21	x	x	1	ME	6/25/12 10:15		FEEDER	CIRCUIT BREAKER	CONDUCTOR CONTACT -	100% RESTORED VIA SWITCHING	827055	NO	
22	x	x	1	ME	6/28/12 8:10		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	824987	NO	
23	x	x	1	ME	6/28/12 15:46		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	825164	NO	
24	x	x	1	MW	6/3/12 6:49		FEEDER	CIRCUIT BREAKER	ANIMAL CONTACT OTHER	100% RESTORED, REPAIRED	807540	NO	
25	x	x	1	MW	6/3/12 4:18		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED, REPAIRED	808100	NO	
26	x	x	1	MW	6/6/12 7:43		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	808420	NO	
27	x	x	1	MW	6/9/12 13:16		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE DIG-IN	100% RESTORED VIA SWITCHING	809803	NO	
28	x	x	1	MW	6/9/12 22:54		FEEDER	CIRCUIT BREAKER	SWITCH UG OR LOG CENTER	100% RESTORED VIA SWITCHING	810092	NO	
29	x	x	1	MW	6/10/12 19:41		FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER	100% RESTORED, REPAIRED	810647	YES	Storm day
30	x	x	1	MW	6/10/12 21:10		FEEDER	LOAD BREAK DISC	LIGHTNING STRIKE	100% RESTORED, REPAIRED PERM	810865	YES	Storm day - DATA CORRECTION MADE TO ADJUST START TIME TO 06/10/12 21:10
31	x	x	1	MW	6/11/12 12:53		FEEDER	CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED VIA SWITCHING	823172	NO	
								FUSE OH	100% RESTORED, REPAIRED				
								LOAD BREAK DISC	PERM 100% RESTORED VIA SWITCHING				
								OH XFM OH	100%				
32	x	x	1	MW	6/14/12 12:10		FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED	813261	NO	
33	x	x	1	MW	6/17/12 22:43		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	815084	NO	
34	x	x	1	MW	6/18/12 5:54		FEEDER	CIRCUIT BREAKER	CABLE FAILURE PRI UNJACKETED	100% RESTORED VIA SWITCHING	815529	NO	
35	x	x	1	MW	6/18/12 21:48		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE COMPR	100% RESTORED VIA SWITCHING	816245	NO	
36	x	x	1	MW	6/19/12 3:21		FEEDER	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED, REPAIRED	816487	YES	Storm day
37	x	x	1	MW	6/19/12 3:50		FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER POLYMER	100% RESTORED VIA SWITCHING	824558	YES	Storm day
38	x	x	1	MW	6/19/12 4:34		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED VIA SWITCHING	817012	YES	Storm day
								LOAD BREAK DISC	CORRIDOR				
39	x	x	1	MW	6/19/12 19:58		FEEDER	CIRCUIT BREAKER	INSULATOR GLASS/PORC	100% RESTORED, REPAIRED	820975	YES	Storm day
40	x	x	1	MW	6/19/12 23:40		FEEDER	CIRCUIT BREAKER	VEG TREE OUTSIDE MAIN	100% RESTORED, REPAIRED	821235	YES	Storm day
41	x	x	1	MW	6/22/12 9:21		FEEDER	CIRCUIT BREAKER	FUSED CUTOFF FAILURE	100% RESTORED, REPAIRED	823084	NO	
42	x	x	1	MW	6/22/12 21:46		FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER POLYMER	100% RESTORED, REPAIRED	823277	NO	
43	x	x	1	MW	6/27/12 20:00		FEEDER	CIRCUIT BREAKER	CONNECTOR FAILURE AUTO	100% RESTORED, REPAIRED	824806	NO	

44	x	x	1	MW	6/30/12 8:37
45	x	x	1	NW	6/8/12 16:48
46	x	x	1	NW	6/17/12 21:07
47	x	x	1	NW	6/17/12 21:24
48	x	x	1	NW	6/29/12 13:20
49	x	x	1	NW	6/30/12 22:10
50	x	x	1	SE	6/3/12 6:42
51	x	x	1	SE	6/14/12 17:51
52	x	x	1	SE	6/18/12 1:00
53	x	x	1	SE	6/18/12 3:11
54	x	x	1	SE	6/20/12 16:12

DIST SUBSTATION BUS/TRANSFORMER	CIRCUIT BREAKER	ANIMAL CONTACT OTHER	100% RESTORED, REPAIRED PERM 100% RESTORED VIA	826111 826108	NO	
TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	PUBLIC DAMAGE BROKEN POLE	100% RESTORED VIA SWITCHING	809602	NO	
TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	CROSSARM ARM BROKEN	100% RESTORED VIA SWITCHING	814984 815005 814985	YES	Storm day
TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	POLE BROKEN / GOOD CONDITION	100% RESTORED, REPAIRED	815043	YES	Storm day
FEEDER	CIRCUIT BREAKER DISCONNECT UG	CABLE FAILURE PRI UNJACKETED	100% RESTORED, REPAIRED PERM	825881	NO	
FEEDER	CIRCUIT BREAKER	LIGHTNING ARRESTER POLYMER	100% RESTORED, REPAIRED PERM	826338 826380	NO	
FEEDER	CIRCUIT BREAKER FUSE OH	ANIMAL CONTACT OTHER	100% RESTORED, REPAIRED PERM	807486	NO	
TRANSMISSION LINE/SYSTEM	CIRCUIT BREAKER	VEG TREE INSIDE MAINT	100% RESTORED VIA SWITCHING	813628	YES	Storm day
FEEDER	CIRCUIT BREAKER DISCONNECT OH	VEG TREE OUTSIDE MAIN CORRIDOR	100% RESTORED, REPAIRED PERM	815361	NO	
FEEDER	CIRCUIT BREAKER DISCONNECT OH	VEG TREE INSIDE MAINT CORRIDOR	100% RESTORED VIA SWITCHING	815431	NO	
FEEDER	CIRCUIT BREAKER	UNKNOWN CAUSE NOT	100% RESTORED, REPAIRED	821981	NO	

1a

Palmer, Susan L

From: Chial, Terry L
Sent: Friday, June 08, 2012 12:52 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/7/2012
Time Out : 23:43

Date In : 6/8/2012
Time In : 00:42

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 2675

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : NO

Cause : CAR HIT POLE

Follow-Up : CUT CLEAR , CALLED FOR CREW STILL OUT TILL
FRIDAY SOMETIME .

1b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, June 08, 2012 8:17 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/7/12 - Marine Saint Croix & Stillwater - POWER RESTORED

Power outage - Marine Saint Croix & Stillwater - power restored.

Wendy

From: Chial, Terry L
Sent: Friday, June 08, 2012 12:52 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/7/2012 Date In : 6/8/2012
Time Out : 23:43 Time In : 00:42

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 2675

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : NO

Cause : CAR HIT POLE

Follow-Up : CUT CLEAR ,CALLED FOR CREW STILL OUT TILL
FRIDAY SOMETIME .

2a

Palmer, Susan L

From: Abbott, Edward J
Sent: Sunday, June 10, 2012 1:01 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In :
Time Out : 12:53 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 7066

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : N/A

Cause : UNKNOWN AT THIS TIME, OPENED FROM TO
TIE SWITCH

Follow-Up :

2b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 12, 2012 3:58 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice *** Momentary Outage *** - 6/10/12 - Afton, Saint Paul & Woodbury - MOMENTARY/POWER RESTORED
THIS WAS PREVIOUSLY SENT ON 6/11 (FIRST NOTIFICATION WAS SENT). TURNS OUT IT WAS A MOMENTARY OUTAGE & NOTIFICATION WAS NOT NECESSARY.

WENDY

From: Chial, Terry L
Sent: Sunday, June 10, 2012 2:20 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice *** Momentary Outage ***

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 12:53 Time In : 12:53

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 7066

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell on feeder.t man cleared .everyone is back on

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

7/17/2012

3a

Palmer, Susan L

From: Chial, Terry L
Sent: Sunday, June 10, 2012 3:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 14:05 Time In : 15:14

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 1384

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : , phase floated off insulater and contacted b
phase .

Follow-Up : retide phase and refered for new 8 ft arm.

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:01 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored
6/10/12 Power Restored

FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT PAUL, MN

From: Chial, Terry L
Sent: Sunday, June 10, 2012 3:21 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 14:05 Time In : 15:14

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 1384

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : FALCON HEIGHTS, MN; ROSEVILLE, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : phase floated off insulater and contacted b
phase .

Follow-Up : retide phase and refered for new 8 ft arm.

4a

Palmer, Susan L

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:06 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:04 Time In : 23:50

Time Zone : CST

Duration : 2 hours, 46 mins

Number of Customers Affected : 2003

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell across feeder ,

Follow-Up : cleared tree and restored

4b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:06 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored
6/10/12 Power Restored

SAINT PAUL, MN

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:06 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:04 Time In : 23:50

Time Zone : CST

Duration : 2 hours, 46 mins

Number of Customers Affected : 2003

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : tree fell across feeder ,

Follow-Up : cleared tree and restored

Palmer, Susan L

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:10 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:05 Time In : 23:16

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 3344

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : wire burned down 2 locations ,tree across feeder at

Follow-Up : cleared tree switched out around feeder and reenergized

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:08 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored SAINT PAUL, MN
6/10/12 Power Restored

SAINT PAUL, MN

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:10 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:05 Time In : 23:16

Time Zone : CST

Duration : 2 hours, 11 mins

Number of Customers Affected : 3344

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers : no

Cause : wire burned down 2 locations ,tree across feeder at

Follow-Up : cleared tree switched out around feeder and reenergized

60

Palmer, Susan L

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:14 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:14 Time In : 23:10

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 1384

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : BIRCHWOOD, MN; MAHTOMEDI, MN; SAINT
PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : broken pole ,truck

Follow-Up : will refere

6b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:09 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored
6/10/12 Power Restored

BIRCHWOOD, MN; MAHTOMEDI, MN; SAINT PAUL, MN; WHITE BEAR LAKE, MN;
WHITE BEAR LK, MN

From: Chial, Terry L
Sent: Monday, June 11, 2012 12:14 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:14 Time In : 23:10

Time Zone : CST

Duration : 1 hours, 56 mins

Number of Customers Affected : 1384

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : BIRCHWOOD, MN; MAHTOMEDI, MN; SAINT
PAUL, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN

State : MN - Minnesota

Major Customers :

Cause : broken pole ,truck

Follow-Up : will refere

7a

Palmer, Susan L

From: Gilland, William P
Sent: Monday, June 11, 2012 4:06 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/11/2012 Date In : 6/11/2012
Time Out : 15:38 Time In : 16:02

Time Zone : CST

Duration : 0 hours, 24 mins

Number of Customers Affected : 1342

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE
BEAR LK, MN

State : MN - Minnesota

Major Customers : none

Cause : head end cable failed

Follow-Up :

7b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 12, 2012 7:38 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/11/12 - Gem Lake & White Bear Lake -
POWER RESTORED
Power outage - Gem Lake & White Bear Lake - power restored.

Wendy

From: Gilland, William P
Sent: Monday, June 11, 2012 4:06 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/11/2012 Date In : 6/11/2012
Time Out : 15:38 Time In : 16:02

Time Zone : CST

Duration : 0 hours, 24 mins

Number of Customers Affected : 1342

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : GEM LAKE, MN; WHITE BEAR LAKE, MN; WHITE
BEAR LK, MN

State : MN - Minnesota

Major Customers : none

Cause : head end cable failed

Follow-Up :

8a

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, June 18, 2012 1:57 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 23:38 Time In : 01:52

Time Zone : CST

Duration : 2 hours, 14 mins

Number of Customers Affected : 1771

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : TREE DAMAGED FEEDER, CUT OPEN JUMPERS AT
PICKED UP FEEDER. ABOUT 10 TRANSFORMERS WILL BE OUT
TILL FEEDER REPAIRED AND JUMPERS CLOSED

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/17/12 - Newport, Saint Paul Park & Woodbury -
POWER RESTORED
Power outage - Newport, Saint Paul Park & Woodbury - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, June 18, 2012 1:57 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 23:38 Time In : 01:52

Time Zone : CST

Duration : 2 hours, 14 mins

Number of Customers Affected : 1771

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : TREE DAMAGED FEEDER, CUT OPEN JUMPERS AT
PICKED UP FEEDER. ABOUT 10 TRANSFORMERS WILL BE OUT
TILL FEEDER REPAIRED AND JUMPERS CLOSED

Follow-Up :

9a

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, June 18, 2012 2:40 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 23:49 Time In : 02:17

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 1818

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT
BY TROUBLE AND FEEDER BACK IN

CLEARED

Follow-Up :

9b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:25 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: al Outage Notice - 6/17/12 - Inver Grove Heights, Inver Grove & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove & South Saint Paul - power restored.

Wendy

From: Abbott, Edward J
Sent: Monday, June 18, 2012 2:40 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 23:49 Time In : 02:17

Time Zone : CST

Duration : 2 hours, 28 mins

Number of Customers Affected : 1818

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : TREE ON FEEDER AT
BY TROUBLE AND FEEDER BACK IN

CLEARED

Follow-Up :

10a

Palmer, Susan L

From: Abbott, Edward J
Sent: Monday, June 18, 2012 10:13 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 20:50 Time In : 21:39

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 2587

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : ARDEN HILLS, MN; MAPLEWOOD, MN; ROSEVILLE, MN; SAINT
PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bus lockout, found nothing at sub. reset and bus back in.

Follow-Up :

10b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/18/12 Power Restored ARDEN HILLS, MN; MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN
6/18/12 Power Restored

ARDEN HILLS, MN; MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN

From: Abbott, Edward J
Sent: Monday, June 18, 2012 10:13 PM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 20:50 Time In : 21:39

Time Zone : CST

Duration : 0 hours, 49 mins

Number of Customers Affected : 2587

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : ARDEN HILLS, MN; MAPLEWOOD, MN; ROSEVILLE, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bus lockout, found nothing at sub. reset and bus back in.

Follow-Up :

11a

Palmer, Susan L

From: Abbott, Edward J
Sent: Tuesday, June 19, 2012 3:55 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 03:35 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2678

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : N/A

Cause : STORMING/ UNKNOWN AT THIS TIME

Follow-Up :

11b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 9:52 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Marine Saint Croix & Stillwater -
POWER RESTORED
Power outage - Marine Saint Croix & Stillwater - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 9:41 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 03:35 Time In : 09:38

Time Zone : CST

Duration : 6 hours, 3 mins

Number of Customers Affected : 2678

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MARINE SAINT CROIX, MN; STILLWATER, MN

State : MN - Minnesota

Major Customers : none

Cause : storm

Follow-Up :

Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:47 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:23 Time In : 06:38

Time Zone : CST

Duration : 2 hours, 15 mins

Number of Customers Affected : 1706

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : storm damage

Follow-Up :

12b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 8:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul
Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:47 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:23 Time In : 06:38

Time Zone : CST

Duration : 2 hours, 15 mins

Number of Customers Affected : 1706

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : storm damage

Follow-Up :

13a

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 12:13 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:24 Time In : 10:49

Time Zone : CST

Duration : 6 hours, 25 mins

Number of Customers Affected : 1748

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL,
MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 12:46 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 12:13 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:24 Time In : 10:49

Time Zone : CST

Duration : 6 hours, 25 mins

Number of Customers Affected : 1748

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

14a

Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:53 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:25 Time In : 08:50

Time Zone : CST

Duration : 4 hours, 25 mins

Number of Customers Affected : 1806

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : storm damage

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 9:00 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - POWER RESTORED
Power outage - Eagan, Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, Sunfish Lake & West Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:53 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:25 Time In : 08:50

Time Zone : CST

Duration : 4 hours, 25 mins

Number of Customers Affected : 1806

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : EAGAN, MN; INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SUNFISH LAKE, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : none

Cause : storm damage

Follow-Up :

14c

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1795

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL,
MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

14d

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 8:14 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/19/12 Outage MENDOTA HEIGHTS, MN;
MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN
6/19/12 Outage

MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL, MN; WEST SAINT PAUL, MN

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:48 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:25 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1795

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL,
MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

7/17/2012

14e

Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:50 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:25 Time In : 08:02

Time Zone : CST

Duration : 3 hours, 37 mins

Number of Customers Affected : 1909

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : storm damage

Follow-Up :

14f

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 8:58 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Saint Paul - POWER RESTORED
Power outage - Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:50 AM
To: dl Electric Outage MF Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:25 Time In : 08:02

Time Zone : CST

Duration : 3 hours, 37 mins

Number of Customers Affected : 1909

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : storm damage

Follow-Up :

15a

Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, June 19, 2012 9:22 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:29 Time In : 09:19

Time Zone : CST

Duration : 4 hours, 50 mins

Number of Customers Affected :

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : COTTAGE GROVE, MN; NEWPORT, MN; SAINT
PAUL PARK, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : storm

Follow-Up :

Palmer, Susan L

15b

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 9:45 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: econd Outage Notice - 6/19/12 - Cottage Grove, Newport, Saint Paul Park & Woodbury - POWER RESTORED
Power outage - Cottage Grove, Newport, Saint Paul Park & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 9:22 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:29 Time In : 09:19

Time Zone : CST

Duration : 4 hours, 50 mins

Number of Customers Affected :

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : COTTAGE GROVE, MN; NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : storm

Follow-Up :

15c

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:26 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3258

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL,

MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol Feeder

15a

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 12:44 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 12:10 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :
Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:29 Time In : 10:04

Time Zone : CST

Duration : 5 hours, 35 mins

Number of Customers Affected : 3260

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL,

MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

15e

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:20 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2195

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

15f

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 8:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: rst Outage Notice 6/19/12 Outage INVER GROVE HEIGHTS, MN;
INVER GROVE, MN; SOUTH SAINT PAUL, MN
6/19/12 Outage

INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH SAINT PAUL, MN

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:20 AM
To: dl Electric Outage ME Notification
Subject: rst Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:29 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2195

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SOUTH
SAINT PAUL, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

16a

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:18 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1771

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up : Patrol feeder

16b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/19/12 Outage NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN
6/19/12 Outage

NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:18 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice
Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1771

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : NEWPORT, MN; SAINT PAUL PARK, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up : Patrol feeder

16c

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 12:11 PM
To: dl Electric Outage ME Notification
Subject: TLK-TANNERS LAKE (067) Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:30 Time In : 10:53

Time Zone : CST

Duration : 6 hours, 23 mins

Number of Customers Affected : 2711

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

16d

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 12:45 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Maplewood, Saint Paul & Woodbury - POWER RESTORED
Power outage - Maplewood, Saint Paul & Woodbury - power restored.

Wendy

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 12:11 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:30 Time In : 10:53

Time Zone : CST

Duration : 6 hours, 23 mins

Number of Customers Affected : 2711

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up :

16e

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:19 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:30 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3533

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; SAINT PAUL,
MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up : Patrol feeder

16f

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 8:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Mendota Heights, Mendota Hts, Saint Paul & West Saint Paul - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 8:51 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 **Date In :** 6/19/2012
Time Out : 04:30 **Time In :** 08:11

Time Zone : CST

Duration : 3 hours, 41 mins

Number of Customers Affected : 3534

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : MENDOTA HEIGHTS, MN; MENDOTA HTS, MN;
SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : storm damage

Follow-Up :

17a

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:02 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2605

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

17b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 8:10 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/19/12 Outage MAPLEWOOD, MN; NEWPORT, MN;
SAINT PAUL, MN; WOODBURY, MN
6/19/12 Outage

MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN; WOODBURY, MN

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:02 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2605

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : MAPLEWOOD, MN; NEWPORT, MN; SAINT PAUL, MN;
WOODBURY, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

17c

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:11 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:31 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1805

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL,
MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up : Patrol feeder

17d

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 4:19 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Saint Paul & South Saint Paul - power restored.

Wendy

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 4:12 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:31 Time In : 09:59

Time Zone : CST

Duration : 5 hours, 28 mins

Number of Customers Affected : 1805

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : Storm

Follow-Up : Partial restoration on feeder is cut open at
to the 700 customers still out. Crew is replacing pole

17e

Palmer, Susan L

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 6:01 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:32 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1361

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : HASTINGS, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : Patrol feeder

178

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 4:20 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/19/12 - Hastings - POWER RESTORED
Power outage - Hastings - power restored.

Wendy

From: Rubedor, Mark W
Sent: Tuesday, June 19, 2012 4:19 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus : 021
Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:32 Time In : 12:57
Time Zone : CST
Duration : 8 hours, 25 mins
Number of Customers Affected : 1361
For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-2391

Communities Affected : HASTINGS, MN

State : MN - Minnesota

Major Customers : None

Cause : Storm

Follow-Up : partial restoration open at the switch. 996 customers still out.
Crew is repairing broken cross arms

Event Details

Event #	816928	Device	
Sw Plan/OC #		Device Location	
Phase	ABC	Zone	
Feeder			
Event Began	06/19/12 04:32	Est # of Cust Out	
Event Restored	06/19/12 09:59		
Est Time to Restore(HH:MM)	###:##	Est Restore Time	06/19/12 09:42
		Est Time to Repair(HH:MM)	###:##

Operations Event Note

Operations Event Note	As Found
TRG:B & C TOPS: 2? 50' double dead end pole broken. Crew working on pole.	iker locked out. Patrolled the feeder. Broken feeder pole at the
Work Performed	Assessment Comment
Cut the downed wire in the clear and rest of to the south of chestnut. Foreman closed in breaker restoring power to all oi except where it runs	

17a,b

Partial Restoration Log

# Cust Out Before	Operation Time	Device	# Cust Restored	# Cust Added	# Cust Out After	Event #
	06/19/12 09:59		0			816928
	06/19/12 21:15		0	0		819093

Event Details

Details

Level of Outage	Feeder	Weather	Wind & Lightning	Corrective Action	Partial Restoration
Interrupting Device	Feeder Breaker/Recloser	Cause Code	Pole Broken / Good condition	Approve	null: Y

17a,b

Palmer, Susan L

From: Gilland, William P
Sent: Tuesday, June 19, 2012 9:21 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:34 Time In : 07:48

Time Zone : CST

Duration : 3 hours, 14 mins

Number of Customers Affected : 7081

For information about this alert, contact :

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : storm/tree on fdr

Follow-Up :

18b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 10:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/19/12 - Afton, Saint Paul & Woodbury - POWER RESTORED
Power outage - Afton, Saint Paul & Woodbury - power restored.

Wendy

From: Gilland, William P
Sent: Tuesday, June 19, 2012 9:21 AM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 04:34 Time In : 07:48

Time Zone : CST

Duration : 3 hours, 14 mins

Number of Customers Affected : 7081

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : AFTON, MN; SAINT PAUL, MN; WOODBURY, MN

State : MN - Minnesota

Major Customers : none

Cause : storm/tree on fdr

Follow-Up :

19a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Tuesday, June 19, 2012 3:32 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 14:54 Time In : 15:19

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 1706

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A tree came down on our feeder at

Follow-Up : Our crew took tree off and we closed the breaker..

19b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 3:43 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice - 6/19/12 - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Lilydale, Mendota Heights, Mendota Hts, Mendota & Saint Paul - power restored.

Wendy

From: Driscoll, Paul M
Sent: Tuesday, June 19, 2012 3:32 PM
To: dl Electric Outage ME Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 14:54 Time In : 15:19

Time Zone : CST

Duration : 0 hours, 25 mins

Number of Customers Affected : 1706

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; LILYDALE, MN;
MENDOTA HEIGHTS, MN; MENDOTA HTS, MN; MENDOTA, MN; SAINT PAUL, MN

State : MN - Minnesota

Major Customers : N/A

Cause : A tree came down on our feeder at

Follow-Up : Our crew took tree off and we closed the breaker..

20a

Palmer, Susan L

From: Elden, Thomas L
Sent: Thursday, June 21, 2012 6:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2012 Date In : 6/21/2012
Time Out : 04:58 Time In : 06:02

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 2637

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE,
MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN;
WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bad cable from sub to biddle and repair

Follow-Up :

20b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, June 21, 2012 7:37 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/21/12 - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - POWER RESTORED
Power outage - Inver Grove Heights, Inver Grove, Mendota Heights, Saint Paul, South Saint Paul & West Saint Paul - power restored.

Wendy

From: Elden, Thomas L
Sent: Thursday, June 21, 2012 6:53 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/21/2012 Date In : 6/21/2012
Time Out : 04:58 Time In : 06:02

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 2637

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : INVER GROVE HEIGHTS, MN; INVER GROVE, MN; MENDOTA HEIGHTS, MN; SAINT PAUL, MN; SOUTH SAINT PAUL, MN; WEST SAINT PAUL, MN

State : MN - Minnesota

Major Customers :

Cause : bad cable from sub to middle and repair

Follow-Up :

21a

Palmer, Susan L

From: Elden, Thomas L
Sent: Monday, June 25, 2012 11:31 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2012 Date In : 6/25/2012
Time Out : 10:15 Time In : 10:58

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 2731

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; MOUNDS VIEW,
MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : car hit pole

Follow-Up :

21b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 25, 2012 11:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/25/12 - Arden Hills, Blaine, Mounds View & Shoreview - POWER RESTORED
Power outage - Arden Hills, Blaine, Mounds View & Shoreview - POWER RESTORED.

Wendy

From: Elden, Thomas L
Sent: Monday, June 25, 2012 11:31 AM
To: dl Electric Outage ME Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/25/2012 Date In : 6/25/2012
Time Out : 10:15 Time In : 10:58

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 2731

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : ARDEN HILLS, MN; BLAINE, MN; MOUNDS VIEW, MN; SHOREVIEW, MN

State : MN - Minnesota

Major Customers :

Cause : car hit pole

Follow-Up :

22a

Palmer, Susan L

From: Driscoll, Paul M
Sent: Thursday, June 28, 2012 8:52 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/28/2012 Date In : 6/28/2012
Time Out : 08:10 Time In : 08:48

Time Zone : CST

Duration : 0 hours, 38 mins

Number of Customers Affected : 3240

For information about this alert, contact : T.F.

For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : DELLWOOD, MN; MAHTOMEDI, MN; PINE
SPRINGS, MN; SAINT PAUL, MN; STILLWATER, MN; WHITE BEAR LAKE, MN;
WHITE BEAR LK, MN; WILLERNIE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Our troubleman took a branch off the feeder on
of .

Follow-Up :

22b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, June 28, 2012 9:13 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/28/12 - Dellwood, Mahtomedi, Pine Springs, Saint Paul, Stillwater, White Bear Lake, White Bear Lk & Willernie - POWER RESTORED
Power outage - Dellwood, Mahtomedi, Pine Springs, Saint Paul, Stillwater, White Bear Lake, White Bear Lk & Willernie - power restored.

Wendy

From: Driscoll, Paul M
Sent: Thursday, June 28, 2012 8:52 AM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/28/2012 Date In : 6/28/2012
Time Out : 08:10 Time In : 08:48

Time Zone : CST

Duration : 0 hours, 38 mins

Number of Customers Affected : 3240

For information about this alert, contact : T.F.
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : DELLWOOD, MN; MAHTOMEDI, MN; PINE SPRINGS, MN; SAINT PAUL, MN; STILLWATER, MN; WHITE BEAR LAKE, MN; WHITE BEAR LK, MN; WILLERNIE, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Our troubleman took a branch off the feeder on
of

Follow-Up :

230

Palmer, Susan L

From: Gilland, William P
Sent: Thursday, June 28, 2012 4:34 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/28/2012 Date In : 6/28/2012
Time Out : 15:46 Time In : 16:29

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 1362

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : HASTINGS, MN

State : MN - Minnesota

Major Customers : none

Cause : non-xcel tree contractor dropped branch against fdr/no one
hurt & no damage to conductors

Follow-Up :

23b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, June 29, 2012 7:27 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/28/12 - Hastings - POWER RESTORED
Power outage - Hastings - power restored.

Wendy

From: Gilland, William P
Sent: Thursday, June 28, 2012 4:34 PM
To: dl Electric Outage ME Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/28/2012 Date In : 6/28/2012
Time Out : 15:46 Time In : 16:29

Time Zone : CST

Duration : 0 hours, 43 mins

Number of Customers Affected : 1362

For information about this alert, contact :
For follow-up information or questions, contact : Mark Rubedor: (651) 229-

2391

Communities Affected : HASTINGS, MN

State : MN - Minnesota

Major Customers : none

Cause : non-xcel tree contractor dropped branch against fdr/no one
hurt & no damage to conductors

Follow-Up :

24a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Sunday, June 03, 2012 8:02 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/3/2012 Date In : 6/3/2012
Time Out : 06:49 Time In : 07:58

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 1273

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up : Patrol found nothing

24b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 04, 2012 8:16 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/3/12 - Columbia Heights & Minneapolis - POWER RESTORED

Power outage - Columbia Heights & Minneapolis - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Sunday, June 03, 2012 8:02 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/3/2012 Date In : 6/3/2012
Time Out : 06:49 Time In : 07:58

Time Zone : CST

Duration : 1 hours, 9 mins

Number of Customers Affected : 1273

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLUMBIA HEIGHTS, MN; MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : none

Cause : Unknown

Follow-Up : Patrol found nothing

7/17/2012

25a

Palmer, Susan L

From: Hills, Thomas L
Sent: Tuesday, June 05, 2012 7:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/5/2012 Date In : 6/5/2012
Time Out : 04:18 Time In : 07:31

Time Zone : CST

Duration : 3 hours, 13 mins

Number of Customers Affected : 1301

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Failed cable.

Follow-Up : All customers restored at 07:31

25b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 05, 2012 8:33 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/5/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Hills, Thomas L
Sent: Tuesday, June 05, 2012 7:36 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice
Feeder/Bus :
Date Out : 6/5/2012 Date In : 6/5/2012
Time Out : 04:18 Time In : 07:31
Time Zone : CST
Duration : 3 hours, 13 mins
Number of Customers Affected : 1301
For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers :

Cause : Failed cable.

Follow-Up : All customers restored at 07:31

26a

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Wednesday, June 06, 2012 9:47 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/6/2012 Date In : 6/6/2012
Time Out : 07:43 Time In : 09:38

Time Zone : CST

Duration : 1 hours, 55 mins

Number of Customers Affected : 2803

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : underground feeder cable

Follow-Up : picked up final 1140 customers

26b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, June 06, 2012 9:55 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/6/12 - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - POWER RESTORED
Power outage - Brooklyn Center, Crystal, Minneapolis, New Hope & Robbinsdale - power restored.

Wendy

From: Peterson, Kenneth W
Sent: Wednesday, June 06, 2012 9:47 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/6/2012 Date In : 6/6/2012
Time Out : 07:43 Time In : 09:38

Time Zone : CST

Duration : 1 hours, 55 mins

Number of Customers Affected : 2803

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN; CRYSTAL, MN; MINNEAPOLIS, MN;
NEW HOPE, MN; ROBBINSDALE, MN

State : MN - Minnesota

Major Customers : none

Cause : underground feeder cable

Follow-Up : picked up final 1140 customers

270

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Saturday, June 09, 2012 2:54 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2012 Date In : 6/9/2012
Time Out : 13:16 Time In : 14:15

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 4054

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : Backhoe hit cable between and / on between
no one hurt

Follow-Up :

27b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 7:54 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: age Notice 6/9/12 - Power Restored MINNEAPOLIS, MN; SAINT ANTHONY, MN
6/9/12 Power Restored

MINNEAPOLIS, MN; SAINT ANTHONY, MN

From: Peterson, Kenneth W
Sent: Saturday, June 09, 2012 2:24 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2012 Date In : 6/9/2012
Time Out : 13:16 Time In : 14:15

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 4054

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN; SAINT ANTHONY, MN

State : MN - Minnesota

Major Customers : none

Cause : Bad Cable to switch

Follow-Up : Tail end of feeder to :

280

Palmer, Susan L

From: Kittock, Joseph C
Sent: Sunday, June 10, 2012 3:01 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2012 Date In : 6/10/2012
Time Out : 22:54 Time In : 02:57

Time Zone : CST

Duration : 4 hours, 3 mins

Number of Customers Affected : 1456

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

center Cause : bkr at station would not operate by r/c. failed on opening, and a load
burnt up.

Follow-Up :

286

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 7:56 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/9/12 Power Restored EDEN PRAIRIE, MN;
MINNETONKA, MN
6/9/12 Power Restored

EDEN PRAIRIE, MN; MINNETONKA, MN

From: Kittock, Joseph C
Sent: Sunday, June 10, 2012 3:01 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/9/2012 Date In : 6/10/2012
Time Out : 22:54 Time In : 02:57

Time Zone : CST

Duration : 4 hours, 3 mins

Number of Customers Affected : 1456

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDEN PRAIRIE, MN; MINNETONKA, MN

State : MN - Minnesota

Major Customers : non

Cause : bkr at station would not operate by r/c. sw failed on opening, and a load
center burnt up.

Follow-Up :

290

Palmer, Susan L

From: Kittock, Joseph C
Sent: Monday, June 11, 2012 1:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/11/2012
Time Out : 19:41 Time In : 01:20

Time Zone : CST

Duration : 5 hours, 39 mins

Number of Customers Affected : 1152

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; DAHLGREN, MN; NYA, MN; WACONIA TWP,
MN; WACONIA, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : phase jumper burnt open at sw. - repaired permanent.

Follow-Up :

29b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored
6/10/12 Power Restored

COLOGNE, MN; DAHLGREN, MN; NYA, MN; WACONIA TWP, MN; WACONIA, MN; YOUNG AMERICA, MN

From: Kittock, Joseph C
Sent: Monday, June 11, 2012 1:27 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus : 321

Date Out : 6/10/2012 Date In : 6/11/2012
Time Out : 19:41 Time In : 01:20

Time Zone : CST

Duration : 5 hours, 39 mins

Number of Customers Affected : 1152

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; DAHLGREN, MN; NYA, MN; WACONIA TWP, MN; WACONIA, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : phase jumper burnt open at sw. - repaired permanet.

Follow-Up :

300

Palmer, Susan L

From: Peterson, Kenneth W
Sent: Sunday, June 10, 2012 9:14 PM
To: dl Electric Outage MW Notification
Subject: Momentary Outage *** Momentary Outage ***
Distribution System Status Outage Notification

..... Momentary Outage
Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:10 Time In : 21:10

Time Zone : CST

Duration : Momentary Outage

Number of Customers Affected : 5149

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP,
MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers : None

Cause : Unknown / possible lightning

Follow-Up : Work Requested - Retrieve Targets and Patrol Line

30b

Palmer, Susan L

From: Kittock, Joseph C
Sent: Monday, June 11, 2012 12:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:12 Time In : 23:29

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 3327

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP,
MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers : non

Cause : opened due to lightning.

Follow-Up :

30c

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 8:12 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/10/12 Power Restored
6/10/12 Power Restored

CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP, MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

From: Kittock, Joseph C
Sent: Monday, June 11, 2012 12:13 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/10/2012 Date In : 6/10/2012
Time Out : 21:12 Time In : 23:29

Time Zone : CST

Duration : 2 hours, 17 mins

Number of Customers Affected : 3327

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; DAYTON, MN; HAMEL, MN; HASSAN TWP, MN; MAPLE GROVE, MN; OSSEO, MN; ROGERS, MN

State : MN - Minnesota

Major Customers : non

Cause : : opened due to lightning.

Follow-Up :

Event Details

Event #	810865	Device	
Sw Plan/OC #		Device Location	
Phase		Zone	
Feeder			
Event Began	06/10/12 21:10	Est # of Cust Out	
Event Restored	06/10/12 23:29		
Est Time to Restore(HH:MM)	##:##	Est Restore Time	06/11/12 10:00
		Est Time to Repair(HH:MM)	##:##

Next Crew Contact Required At

Crew ID	Contact	Mobile #	En Route Date	Onsite Date	Date
---------	---------	----------	---------------	-------------	------

Post Restoration Edit Log

Who	Date	Reason	Changed Field	Original Value
SCXD40	06/10/12 23:46	Completion Order:		
SCHT62	06/15/12 11:57	Control Center paper record more accurate	Event Began	06/10/12 21:12
SCHT62	06/15/12 11:57	Control Center paper record more accurate	Cause	Unknown Cause Under Invest
SCHT62	06/15/12 11:57	Control Center paper record more accurate	Operations Event Note	
SCHT62	06/15/12 11:57	Approve Event	Approved	
SCHT62	06/15/12 12:06	Outage Correction Record	Approved	Y
SCHT62	06/15/12 12:10	Outage Correction Record	Assessment Comment	
SCHT62	06/15/12 12:10	Approve Event	Approved	N

300-10

3/a

Palmer, Susan L

From: Karolevitz, Paul W
Sent: Tuesday, June 12, 2012 3:30 PM
To: Jaede, Wendy L
Cc: Karolevitz, Paul W
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/11/2012 Date In : 6/11/2012
Time Out : 12:53 Time In : 20:20

Time Zone : CST

Duration : 7 hours, 27 mins

Number of Customers Affected : 2061

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit pole

Follow-Up : this restored the final 10 customers. replaced pole

31a

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 12, 2012 3:55 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/11/12 - Coon Rapids - POWER RESTORED
Power outage - Coon Rapids - power restored.

Wendy

From: Karolevitz, Paul W
Sent: Tuesday, June 12, 2012 3:30 PM
To: Jaede, Wendy L
Cc: Karolevitz, Paul W
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/11/2012 Date In : 6/11/2012
Time Out : 12:53 Time In : 20:20

Time Zone : CST

Duration : 7 hours, 27 mins

Number of Customers Affected : 2061

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COON RAPIDS, MN

State : MN - Minnesota

Major Customers : none

Cause : car hit pole

Follow-Up : this restored the final 10 customers. replaced pole

320

Palmer, Susan L

From: Davis, Percyell
Sent: Thursday, June 14, 2012 2:05 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/14/2012 Date In : 6/14/2012
Time Out : 12:10 Time In : 13:48

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 1323

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

32b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, June 14, 2012 2:29 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/14/12 - Minneapolis - POWER RESTORED
Power outage - Minneapolis - power restored.

Wendy

From: Davis, Percyell
Sent: Thursday, June 14, 2012 2:05 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/14/2012 Date In : 6/14/2012
Time Out : 12:10 Time In : 13:48

Time Zone : CST

Duration : 1 hours, 38 mins

Number of Customers Affected : 1323

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up :

330

Palmer, Susan L

From: Schwarz, John W
Sent: Monday, June 18, 2012 7:09 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 22:43 Time In : 03:42

Time Zone : CST

Duration : 4 hours, 59 mins

Number of Customers Affected : 1440

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE FELL ON THE FEEDER @
CLEARED AND FEEDER RESTORES @ 03:42

TREE WAS

Follow-Up :

33b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:39 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: inal Outage Notice - 6/18/12 - Mayer, Waconia & Watertown - POWER RESTORED
Power outage - Mayer, Waconia & Watertown - power restored.

Wendy

From: Schwarz, John W
Sent: Monday, June 18, 2012 7:09 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 22:43 Time In : 03:42

Time Zone : CST

Duration : 4 hours, 59 mins

Number of Customers Affected : 1440

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LARGE TREE FELL ON THE FEEDER @ TREE WAS
CLEARED AND FEEDER RESTORES @ 03:42

Follow-Up :

34a

Palmer, Susan L

From: Knutson, David A
Sent: Monday, June 18, 2012 7:03 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 05:54 Time In : 06:53

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1576

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : bad urd feeder cable between and

Follow-Up :

34b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/18/12 - Brooklyn Center - POWER RESTORED
Power outage - Brooklyn Center - power restored.

Wendy

From: Knutson, David A
Sent: Monday, June 18, 2012 7:03 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 05:54 Time In : 06:53

Time Zone : CST

Duration : 0 hours, 59 mins

Number of Customers Affected : 1576

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : BROOKLYN CENTER, MN

State : MN - Minnesota

Major Customers :

Cause : bad urd feeder cable between

Follow-Up :

35a

Palmer, Susan L

From: Anderson, Timothy K
Sent: Monday, June 18, 2012 10:00 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In :
Time Out : 21:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3920

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : CARRYING PART OF

35b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 7:58 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: First Outage Notice 6/18/12 Outage EDINA, MN; MINNEAPOLIS, MN;
RICHFIELD, MN
6/18/12 Outage

EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

From: Anderson, Timothy K
Sent: Monday, June 18, 2012 10:00 PM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In :
Time Out : 21:48 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 3920

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : EDINA, MN; MINNEAPOLIS, MN; RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : CARRYING PART OF

360

Palmer, Susan L

From: Knutson, David A
Sent: Tuesday, June 19, 2012 5:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 03:21 Time In : 05:18

Time Zone : CST

Duration : 1 hours, 57 mins

Number of Customers Affected : 2817

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES WEATHER LIGHTNING

Follow-Up :

36b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 8:03 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice 6/19/12 Power Restored MINNEAPOLIS, MN
6/19/12 Power Restored

MINNEAPOLIS, MN

From: Knutson, David A
Sent: Tuesday, June 19, 2012 5:21 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 03:21 Time In : 05:18

Time Zone : CST

Duration : 1 hours, 57 mins

Number of Customers Affected : 2817

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MINNEAPOLIS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TREES WEATHER LIGHTNING

Follow-Up :

37a

Palmer, Susan L

From: Schwarz, John W
Sent: Tuesday, June 19, 2012 8:25 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 03:50 Time In : 07:59

Time Zone : CST

Duration : 4 hours, 9 mins

Number of Customers Affected : 1440

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN @ THIS TIME

Follow-Up : 1324 CUSTOMERS IN @ 07:59... 116 CUSTOMERS STILL OUT.
TROUBLE IS STILL PATROLING REMAINING FEEDER

37b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Tuesday, June 19, 2012 9:50 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/19/12 - Mayer, Waconia & Watertown - POWER RESTORED

Power outage - Mayer, Waconia & Watertown - power restored.

Wendy

From: Schwarz, John W
Sent: Tuesday, June 19, 2012 9:40 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 03:50 Time In : 09:25

Time Zone : CST

Duration : 5 hours, 35 mins

Number of Customers Affected : 1440

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : MAYER, MN; WACONIA, MN; WATERTOWN, MN

State : MN - Minnesota

Major Customers : NONE

Cause : LIGHTING HIT CAP BANK

Follow-Up : 1324 CUSTOMERS IN @ 07:59. REMAINING 116 CUSTOMERS
RESTORED @ 09:25

38a

Palmer, Susan L

From: Knutson, David A
Sent: Tuesday, June 19, 2012 4:42 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice
Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1725

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : PATROL ASAP

38b

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 7:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: First Outage Notice 6/19/12 Outage RICHFIELD, MN
6/19/12 Outage
RICHFIELD, MN

From: Knutson, David A
Sent: Tuesday, June 19, 2012 4:42 AM
To: dl Electric Outage MW Notification
Subject: First Outage Notice

Distribution System Status Outage Notification

First Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In :
Time Out : 04:34 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 1725

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : RICHFIELD, MN

State : MN - Minnesota

Major Customers : NONE

Cause : UNKNOWN

Follow-Up : PATROL ASAP

390

Palmer, Susan L

From: Anderson, Timothy K
Sent: Tuesday, June 19, 2012 9:21 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 19:58 Time In : 21:16

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 2064

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : JUMPER BURNT OPEN

Follow-Up : TRBL REPAIR TEMP 100% RESTORE. TRBL WILL REFER FOR
PERM.REPAIR

7/17/2012

39b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, June 20, 2012 7:32 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - Crystal, Golden Valley & New Hope - POWER RESTORED

Power outage - Crystal, Golden Valley & New Hope - power restored.

Wendy

From: Anderson, Timothy K
Sent: Tuesday, June 19, 2012 9:21 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/19/2012
Time Out : 19:58 Time In : 21:16

Time Zone : CST

Duration : 1 hours, 18 mins

Number of Customers Affected : 2064

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CRYSTAL, MN; GOLDEN VALLEY, MN; NEW HOPE, MN

State : MN - Minnesota

Major Customers :

Cause : JUMPER BURNT OPEN

Follow-Up : TRBL REPAIR TEMP 100% RESTORE. TRBL WILL REFER FOR PERM.REPAIR

400

Palmer, Susan L

From: Anderson, Timothy K
Sent: Wednesday, June 20, 2012 12:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/20/2012
Time Out : 23:40 Time In : 00:44

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 916

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH ON FEEDER BTWN SWITCH

Follow-Up : REMOVE BRANCH,RESTORE 100%

40b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Wednesday, June 20, 2012 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/19/12 - Deephaven, Minnetonka & Wayzata -
POWER RESTORED
Power outage - Deephaven, Minnetonka & Wayzata - power restored.

Wendy

From: Anderson, Timothy K
Sent: Wednesday, June 20, 2012 12:48 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/19/2012 Date In : 6/20/2012
Time Out : 23:40 Time In : 00:44

Time Zone : CST

Duration : 1 hours, 4 mins

Number of Customers Affected : 916

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : DEEPHAVEN, MN; MINNETONKA, MN; WAYZATA, MN

State : MN - Minnesota

Major Customers : NONE

Cause : BRANCH ON FEEDER BTWN WITCH

Follow-Up : REMOVE BRANCH,RESTORE 100%

410

Palmer, Susan L

From: Beckius, John J
Sent: Friday, June 22, 2012 11:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/22/2012 Date In : 6/22/2012
Time Out : 09:21 Time In : 09:51

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 1127

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; SHOREWOOD, MN

State : MN - Minnesota

Major Customers : none

Cause : BURN'T UP CUTOUT AT .

Follow-Up :

41b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, June 22, 2012 12:15 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/22/12 - Chanhassen, Excelsior & Shorewood -
POWER RESTORED
Chanhassen, Excelsior & Shorewood - POWER RESTORED.

Wendy

From: Beckius, John J
Sent: Friday, June 22, 2012 11:29 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/22/2012 Date In : 6/22/2012
Time Out : 09:21 Time In : 09:51

Time Zone : CST

Duration : 0 hours, 30 mins

Number of Customers Affected : 1127

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CHANHASSEN, MN; EXCELSIOR, MN; SHOREWOOD, MN

State : MN - Minnesota

Major Customers : none

Cause : BURN'T UP CUTOUT AT

Follow-Up :

420

Palmer, Susan L

From: Davis, Percyell
Sent: Friday, June 22, 2012 11:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/22/2012 Date In : 6/22/2012
Time Out : 21:46 Time In : 22:02

Time Zone : CST

Duration : 0 hours, 16 mins

Number of Customers Affected : 2460

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS,
MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : three arrester blow on

Follow-Up : refered

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 25, 2012 8:59 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: nal Outage Notice - 6/22/12 - Corcoran, Hamel, Media, Minneapolis & Plymouth - POWER RESTORED
Power outage - Corcoran, Hamel, Media, Minneapolis & Plymouth - power restored.

Wendy

From: Davis, Percyell
Sent: Friday, June 22, 2012 11:07 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/22/2012 Date In : 6/22/2012
Time Out : 21:46 Time In : 22:02

Time Zone : CST

Duration : 0 hours, 16 mins

Number of Customers Affected : 2460

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : CORCORAN, MN; HAMEL, MN; MEDINA, MN; MINNEAPOLIS, MN; PLYMOUTH, MN

State : MN - Minnesota

Major Customers : none

Cause : three arrester blow on

Follow-Up : refered

43a

Palmer, Susan L

From: Beckius, John J
Sent: Wednesday, June 27, 2012 9:29 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/27/2012 Date In : 6/27/2012
Time Out : 20:00 Time In : 21:10

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1421

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : 336 pulled loose from auto sleeve just outside

Follow-Up :

43b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, June 28, 2012 7:35 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/27/12 - Hopkins & Saint Louis Park - POWER RESTORED
Power outage - Hopkins & Saint Louis Park - power restored.

Wendy

From: Beckius, John J
Sent: Wednesday, June 27, 2012 9:29 PM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/27/2012 Date In : 6/27/2012
Time Out : 20:00 Time In : 21:10

Time Zone : CST

Duration : 1 hours, 10 mins

Number of Customers Affected : 1421

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : HOPKINS, MN; SAINT LOUIS PARK, MN

State : MN - Minnesota

Major Customers : none

Cause : 336 pulled loose from auto sleeve just outside

Follow-Up :

440

Palmer, Susan L

From: Kittock, Joseph C
Sent: Saturday, June 30, 2012 10:32 AM
To: dl Electric Outage MW Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 6/30/2012
Time Out : 08:37 Time In : 09:51

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1160

For information about this alert, contact :
For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LAKE WILSON, MN; NYA, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : Squirrel on the bus tie

Follow-Up :

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 02, 2012 7:46 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: 'cond Outage Notice - 6/30/12 - Lake Wilson, Nya, Young America - POWER RESTORED

Power outage - Lake Wilson, Nya, Young America - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, June 30, 2012 10:32 AM
To: dl Electric Outage MW Notification
Subject: \ Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 6/30/2012
Time Out : 08:37 Time In : 09:51

Time Zone : CST

Duration : 1 hours, 14 mins

Number of Customers Affected : 1160

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : LAKE WILSON, MN; NYA, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : Squirrel on the bus tie

Follow-Up :

44c

Palmer, Susan L

From: Kittock, Joseph C
Sent: Saturday, June 30, 2012 10:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice
Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 6/30/2012
Time Out : 08:37 Time In : 10:03

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1024

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; NYA, MN;
PLATO, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : Squirrel on the bus tie

Follow-Up :

44d

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 02, 2012 7:42 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Final Outage Notice - 6/30/12 - Cologne, Green Isle, Hamburg, Nya, Plato & Young America - POWER RESTORED
Power outage - Cologne, Green Isle, Hamburg, Nya, Plato & Young America - power restored.

Wendy

From: Kittock, Joseph C
Sent: Saturday, June 30, 2012 10:33 AM
To: dl Electric Outage MW Notification
Subject: Final Outage Notice

Distribution System Status Outage Notification

Final Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 6/30/2012
Time Out : 08:37 Time In : 10:03

Time Zone : CST

Duration : 1 hours, 26 mins

Number of Customers Affected : 1024

For information about this alert, contact :

For follow-up information or questions, contact : Paul Karolevitz: (612) 337-2369

Communities Affected : COLOGNE, MN; GREEN ISLE, MN; HAMBURG, MN; NYA, MN;
PLATO, MN; YOUNG AMERICA, MN

State : MN - Minnesota

Major Customers : non

Cause : Squirrel on the bus tie

Follow-Up :

45a

Palmer, Susan L

From: Medellin, Victor J
Sent: Friday, June 08, 2012 6:04 PM
To: dl Electric Outage NT Notification
Subject: Third Outage Notice

Distribution System Status Outage Notification

rd Outage Notice

Feeder/Bus :

Date Out : 6/8/2012
Time Out : 16:48

Date In : 6/8/2012
Time In : 17:59

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1481

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : BROWNTON, MN; BROWNTOWN, MN; BUFFALO LAKE, MN; HECTOR, MN; STEWART, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT REMAINING 407 CUSTOMERS

RESTORED

Follow-Up :

45b

Palmer, Susan L

From: Preston, Carly
Sent: Monday, June 11, 2012 7:49 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW:
Outage Notice 6/8/12 Power Restored
6/8/12 Power Restored

Third

BROWNTON, MN; BROWNTOWN, MN; BUFFALO LAKE, MN; HECTOR, MN;
STEWART, MN

From: Medellin, Victor J
Sent: Friday, June 08, 2012 6:04 PM
To: dl Electric Outage NT Notification
Subject:
Third Outage Notice

Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/8/2012 Date In : 6/8/2012
Time Out : 16:48 Time In : 17:59

Time Zone : CST

Duration : 1 hours, 11 mins

Number of Customers Affected : 1481

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : BROWNTON, MN; BROWNTOWN, MN; BUFFALO
LAKE, MN; HECTOR, MN; STEWART, MN

State : MN - Minnesota

Major Customers : NONE

Cause : TRANSMISSION EVENT REMAINING 407 CUSTOMERS
RESTORED

Follow-Up :

460

Palmer, Susan L

From: Peterson, Mark S
Sent: Sunday, June 17, 2012 9:58 PM
To: dl Electric Outage NT Notification
Subject: Notice

Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/17/2012
Time Out : 21:07 Time In : 21:54

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 2856

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : COLD SPRING, MN; RICHMOND, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

46b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:05 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: Outage Notice - 6/17/12 - Cold Spring & Richmond - POWER RESTORED :cond
Power outage - Cold Spring & Richmond - power restored.

Wendy

From: Peterson, Mark S
Sent: Sunday, June 17, 2012 9:58 PM
To: dl Electric Outage NT Notification
Subject: Notice Second Outage

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/17/2012
Time Out : 21:07 Time In : 21:54

Time Zone : CST

Duration : 0 hours, 47 mins

Number of Customers Affected : 2856

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : COLD SPRING, MN; RICHMOND, MN

State : MN - Minnesota

Major Customers :

Cause : storm in area

Follow-Up :

47a

Palmer, Susan L

From: Medellin, Victor J
Sent: Monday, June 18, 2012 6:30 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice
Feeder/Bus :
Date Out : 6/17/2012 **Date In :** 6/18/2012
Time Out : 21:24 **Time In :** 17:13

Time Zone : CST
Duration : 19 hours, 49 mins
Number of Customers Affected : 642

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

MN
Communities Affected : ATWATER, MN; GROVE CITY, MN; PAYNESVILLE,

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION EVENT RESTORED @ 17:13

Follow-Up :

Palmer, Susan L

From: Preston, Carly
Sent: Tuesday, June 19, 2012 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice 6/18/12 Power Restored
ATWATER, MN; GROVE CITY, MN; PAYNESVILLE, MN
6/18/12 Power Restored

ATWATER, MN; GROVE CITY, MN; PAYNESVILLE, MN

From: Medellin, Victor J
Sent: Monday, June 18, 2012 6:30 PM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Outage Notice

Feeder/Bus :

Date Out : 6/17/2012 Date In : 6/18/2012
Time Out : 21:24 Time In : 17:13

Time Zone : CST

Duration : 19 hours, 49 mins

Number of Customers Affected : 642

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : ATWATER, MN; GROVE CITY, MN; PAYNESVILLE,

MN

State : MN - Minnesota

Major Customers :

Cause : TRANSMISSION EVENT RESTORED @ 17:13

Follow-Up :

480

Palmer, Susan L

From: Vorachek, Kelly
Sent: Friday, June 29, 2012 2:19 PM
To: dl Electric Outage NT Notification
Subject: econd Outage Notice
Distribution System Status Outage Notification

econd Outage Notice

Feeder/Bus :

Date Out : 6/29/2012 Date In : 6/29/2012
Time Out : 13:20 Time In : 14:10

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 843

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers : N/A

Cause : iled feeder cable btw switches, Isolated on
ust restored at 13:55 / Remaining restored at 14:10

Follow-Up :

48b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, June 29, 2012 2:22 PM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/29/12 - Saint Cloud - POWER RESTORED
Power outage - Saint Cloud - power restored.

Wendy

From: Vorachek, Kelly
Sent: Friday, June 29, 2012 2:19 PM
To: dl Electric Outage NT Notification
Subject: econd Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/29/2012 Date In : 6/29/2012

Time Out : 13:20 Time In : 14:10

Time Zone : CST

Duration : 0 hours, 50 mins

Number of Customers Affected : 843

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : SAINT CLOUD, MN

State : MN - Minnesota

Major Customers : N/A

Cause : -ailed feeder cable btw switches, Isolated on
Just restored at 13:55 / Remaining restored at 14:10

Follow-Up :

49a

Palmer, Susan L

From: Vorachek, Kelly
Sent: Sunday, July 01, 2012 10:40 AM
To: dl Electric Outage NT Notification
Subject: nd Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 7/1/2012
Time Out : 22:10 Time In : 01:50

Time Zone : CST

Duration : 3 hours, 40 mins

Number of Customers Affected : 3413

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Crew found blown arrestor behind cleared and
closed breaker at 23:38 restoring 968 customers, calls continued, crew found switch had
opened for unexplained reasons, patrolled and closed at 01:50 restoring remaining 2,436 customers.

Follow-Up :

49b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, July 02, 2012 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/30/12 - Saint Cloud & Waite Park - POWER RESTORED

Power outage - Saint Cloud & Waite Park - power restored.

Wendy

From: Vorachek, Kelly
Sent: Sunday, July 01, 2012 10:40 AM
To: dl Electric Outage NT Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/30/2012 Date In : 7/1/2012
Time Out : 22:10 Time In : 01:50

Time Zone : CST

Duration : 3 hours, 40 mins

Number of Customers Affected : 3413

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : SAINT CLOUD, MN; WAITE PARK, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Crew found blown arrester behind cleared and
closed breaker at 23:38 restoring 968 customers, calls continued, crew found switch had
opened for unexplained reasons, patrolled and closed at 01:50 restoring remaining 2,436 customers.

Follow-Up :

50a

Palmer, Susan L

From: Reinschmidt, Brad A
Sent: Sunday, June 03, 2012 11:40 AM
To: dl Electric Outage SE Notification
Subject: Fourth Outage Notice
Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 6/3/2012 Date In : 6/3/2012
Time Out : 06:42 Time In : 11:02

Time Zone : CST

Duration : 4 hours, 20 mins

Number of Customers Affected : 2819

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Squirrel damaged ocr and fault burned down 3 spans of primary. All customers back on.

Follow-Up :

50b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 04, 2012 8:15 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Fourth Outage Notice - 6/3/12 - Dundas & Northfield - POWER RESTORED
Power outage - Dundas & Northfield - power restored.

Wendy

From: Reinschmidt, Brad A
Sent: Sunday, June 03, 2012 11:40 AM
To: dl Electric Outage SE Notification
Subject: Fourth Outage Notice

Distribution System Status Outage Notification

Fourth Outage Notice

Feeder/Bus :

Date Out : 6/3/2012 Date In : 6/3/2012
Time Out : 06:42 Time In : 11:02

Time Zone : CST

Duration : 4 hours, 20 mins

Number of Customers Affected : 2819

For information about this alert, contact :

For follow-up information or questions, contact : Tony Wishard: (612) 330-5870

Communities Affected : DUNDAS, MN; NORTHFIELD, MN

State : MN - Minnesota

Major Customers : None

Cause : Squirrel damaged ocr and fault burned down of primary. All
customers back on.

Follow-Up :

7/17/2012

51a

Palmer, Susan L

From: Goulet, Terry W
Sent: Thursday, June 14, 2012 7:05 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/14/2012 Date In : 6/14/2012
Time Out : 17:57 Time In : 18:57

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 724

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : FRONTENAC, MN; LAKE CITY, MN; RED WING, MN

State : MN - Minnesota

Major Customers : na

Cause : Transmission Outage / Storm passing through area

Follow-Up :

51b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Friday, June 15, 2012 7:47 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/14/12 - Frontenac, Lake City
& Red Wing - POWER RESTORED
Power outage - Frontenac, Lake City & Red Wing - power restored.

Wendy

From: Goulet, Terry W
Sent: Thursday, June 14, 2012 7:05 PM
To: dl Electric Outage SF Notification
Subject: cond Outage Notice

Distribution System Status Outage Notification

cond Outage Notice

Feeder/Bus :

Date Out : 6/14/2012 Date In : 6/14/2012
Time Out : 17:57 Time In : 18:57

Time Zone : CST

Duration : 1 hours, 0 mins

Number of Customers Affected : 724

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : FRONTENAC, MN; LAKE CITY, MN; RED WING, MN

State : MN - Minnesota

Major Customers : na

Cause : Transmission Outage / Storm passing through area

Follow-Up :

520

Palmer, Susan L

From: Peterson, Mark S
Sent: Monday, June 18, 2012 2:19 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In :
Time Out : 01:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2083

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CLOSED UP TO THE THIS
PICKED UP 2005 CUSTOMERS AT 2:02

Follow-Up :

52b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:29 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/18/12 - Red Wing
Power outage - Red Wing.

Wendy

From: Peterson, Mark S
Sent: Monday, June 18, 2012 2:19 AM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In :
Time Out : 01:00 Time In :

Time Zone : CST

Duration :

Number of Customers Affected : 2083

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CLOSED UP TO THE THIS
PICKED UP 2005 CUSTOMERS AT 2:02

Follow-Up :

530

Palmer, Susan L

From: Vorachek, Kelly
Sent: Monday, June 18, 2012 7:34 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus :

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 03:18 Time In : 04:57

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 2083

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Large tree toppled into feeder next to the Tie
SW by also had branch in Feeder by the switch, open sw and closed BKR at
0336 restoring 2005 customers, closed at 0457 restoring remaining 78 customers.
Switch Open and Held for tree crew on customers from 8 switch to

Follow-Up :

53b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Monday, June 18, 2012 8:30 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Third Outage Notice - 6/18/12 - Red Wing - POWER RESTORED
Power outage - Red Wing - power restored.

Wendy

From: Vorachek, Kelly
Sent: Monday, June 18, 2012 7:34 AM
To: dl Electric Outage SE Notification
Subject: Third Outage Notice
Distribution System Status Outage Notification

Third Outage Notice

Feeder/Bus : 023

Date Out : 6/18/2012 Date In : 6/18/2012
Time Out : 03:18 Time In : 04:57

Time Zone : CST

Duration : 1 hours, 39 mins

Number of Customers Affected : 2083

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : RED WING, MN

State : MN - Minnesota

Major Customers : N/A

Cause : Large tree toppled into feeder next to the Tie
SW by had branch in Feeder by the open sw and closed BKR at
0336 restoring 2005 customers, closed at ing 78 customers.
switch Open and Held for tree crew on customers from 8 switch to |

Follow-Up :

540

Palmer, Susan L

From: Medellin, Victor J
Sent: Wednesday, June 20, 2012 5:14 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice
Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/20/2012
Time Out : 16:12

Date In : 6/20/2012
Time In : 17:07

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1114

For information about this alert, contact :

For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : CANNON FALLS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAUSE UNKNOWN POSSIBLE LIGHTNING STRIKE
NOTHING FOUND ON PATROL

Follow-Up :

54b

Palmer, Susan L

From: Jaede, Wendy L
Sent: Thursday, June 21, 2012 7:27 AM
To: 'staff, cao (PUC)'
Cc: dl Customer Advocate Team
Subject: FW: Second Outage Notice - 6/20/12 - Cannon Falls - POWER RESTORED
Power outage - Cannon Falls - power restored.

Wendy

From: Medellin, Victor J
Sent: Wednesday, June 20, 2012 5:14 PM
To: dl Electric Outage SE Notification
Subject: Second Outage Notice

Distribution System Status Outage Notification

Second Outage Notice

Feeder/Bus :

Date Out : 6/20/2012 Date In : 6/20/2012
Time Out : 16:12 Time In : 17:07

Time Zone : CST

Duration : 0 hours, 55 mins

Number of Customers Affected : 1114

For information about this alert, contact :
For follow-up information or questions, contact : Lisa Lund: (612) 630-4293

Communities Affected : CANNON FALLS, MN

State : MN - Minnesota

Major Customers : NONE

Cause : CAUSE UNKNOWN POSSIBLE LIGHTNING STRIKE
NOTHING FOUND ON PATROL

Follow-Up :