

In the Matter of Site Permit Amendment Application for Proposed Upgrades to Xcel Energy's Nobles Wind Farm in Nobles County, Minnesota.

Docket No. IP6646/WS-09-584

Commissioner Tuma moves to amend the revised decision options by adding the following condition:

1. (f) Staff, in consultation with DOC EERA, shall modify section 7.2 of the permit regarding shadow flicker to require the permittee to develop, in a timely manner, a project wide Shadow Flicker Management Plan that reduces shadow flicker exposure to less than 30 hours per year for all occupied residences, but the permittee may, as an alternative to this 30 hour requirement, file in a timely manner proof of Specific Alternative Flicker Mitigation Agreement for impacted individual residences.