

# **Noise Analysis**

---

**Proposed Palmer's Creek Wind Farm**

**Prepared for:**

**Palmer's Creek Wind Farm, LLC**

**February 3, 2017**

**Prepared by:**

**WSB & Associates, Inc.  
701 Xenia Avenue South, Suite 300  
Minneapolis, MN 55416**

**Title Page**  
**Table of Contents**  
**Definitions**

I. Purpose..... 1

II. Noise..... 1

    A. Noise from Wind Turbines ..... 2

    B. Assessment and Regulation..... 2

III. Monitoring Conditions ..... 3

IV. Comparison to Minnesota Noise Standards ..... 10

V. Modeling ..... 15

VI. Conclusion ..... 19

**List of Tables**

- Table 1 – Decibel Levels of Common Noise Sources
- Table 2 - MPCA State Noise Standards – Hourly A-Weighted Sound Levels
- Table 3 – Daytime and Nighttime Noise Monitoring Results
- Table 4 – Noise Modeling Results (Scenario 1)
- Table 5– Noise Modeling Results (Scenario 2)

**List of Figures**

- Figure 1 – Project Limits and Monitoring Locations
- Figure 2 – Noise Monitoring Results, Site M1
- Figure 3 – Noise Monitoring Results, Site M2
- Figure 4 – Noise Monitoring Results, Site M3
- Figure 5 – Noise Monitoring Results, Site M4
- Figure 6 – Noise Monitoring Results, Site M1 L<sub>10</sub> and L<sub>50</sub> Values Only
- Figure 7 – Noise Monitoring Results, Site M2 L<sub>10</sub> and L<sub>50</sub> Values Only
- Figure 8 – Noise Monitoring Results, Site M3 L<sub>10</sub> and L<sub>50</sub> Values Only
- Figure 9 – Noise Monitoring Results, Site M4 L<sub>10</sub> and L<sub>50</sub> Values Only
- Figure 10 – Closest Receiver to Turbine Impact
- Figure 11 – Turbine Scenario 1- All Turbines at 80m Hub Height
- Figure 12 – Turbine Scenario 2 – 2.3 WM Turbines at 80m Hub Height, 2.5 WM Turbines at 90m Hub Height

# Definitions

---

**A-Weighting:** A-weighting is applied to instrument-measured sound levels in an effort to account for the relative loudness perceived by the human ear

**C-Weighting:** C-weighting measures uniformly over the frequency range of 30 to 10,000 Hz. This weighting scale is useful for monitoring sources such as engines, and machinery

**dBA:** A-weighted decibel level

**dBC:** C-weighted decibel level

**L<sub>10</sub>:** Statistical noise level that is exceeded 10% of the time in a defined time frame

**L<sub>50</sub>:** Statistical noise level that is exceeded 50% of the time in a defined time frame, or the arithmetic mean of all data in a defined time frame.

**L<sub>eq</sub>:** When a noise varies over time, the L<sub>eq</sub> is the equivalent continuous sound which would contain the same sound energy as the time varying sound

**LA<sub>eq</sub>:** A-weighted equivalent continuous sound

**LC<sub>eq</sub>:** C-weighted equivalent continuous sound

**MW:** Megawatt, unit of power equivalent to 1 million watts, commonly used for classifying outputs of wind turbines.

**NOAA:** National Oceanic and Atmospheric Administration

**Pascal (Pa):** Unit of air pressure, normal atmosphere is equal to 101,325 Pa

## I. Purpose

Palmer's Creek Wind Farm, LLC has proposed the installation of 18 wind turbines for the Palmer's Creek Wind Farm Project just north of Granite Falls, MN. The boundaries of the proposed wind farm are 100<sup>th</sup> Street SE to the north, 30<sup>th</sup> Avenue SE to the east, Palmer Creek Road to the south, and Palmer Creek to the west. The area of study can be found in **Figure 1**. This report details the existing conditions found within the proposed project limits and also the modeled results for two configurations of turbines upon the identified receptors.

## II. Noise

Any unwanted sound is called noise. Sound is carried through the air in compression waves of measurable frequency and amplitude. Sound can be tonal, predominating at a few frequencies, or it can contain a random mix of a broad range of frequencies and lack any tonal quality. This type of noise is often called white noise.

The human ear is sensitive to only a relatively narrow frequency range of air pressure changes – approximately 20-20,000 cycles per second or Hertz (Hz). Sub-audible frequency sound is often called infrasound. It cannot be heard, but it may be sensed as a vibration. Humans are also sensitive to changes in the amplitude of the air compression waves. Increasing amplitude, or increasing sound pressure, is perceived as increasing volume or loudness. The sound pressure level (SPL) is measured in micro Pascals ( $\mu\text{Pa}$ ). SPLs are typically converted to decibels (dB), which is a log scale, relative to a reference air pressure value of 20  $\mu\text{Pa}$ . When measuring sound, A-weighted decibels (dBA) are typically used to normalize readings to equal loudness over the audible range of frequencies at low loudness. **Table 1** shows a range of sound pressure levels and the associated Noise sources.

**Table 1 – Decibel Levels of Common Noise Sources**

Sound Pressure Level (dBA)	Noise Source
140	Jet Engine (at 25 meters)
130	Jet Aircraft (at 100 meters)
120	Rock and Roll Concert
110	Pneumatic Chipper
100	Jointer/Planer
90	Chainsaw
80	Heavy Truck Traffic
70	Business Office
60	Conversational Speech
50	Library
40	Bedroom
30	Secluded Woods
20	Whisper

Source: "A Guide to Noise Control in Minnesota," MPCA

Along with the volume of the noise source there are other factors (such as topography of the area) that contribute to the loudness of noise. The distance of a receptor from a sound's source is also an important factor. Sound levels decrease as distance from a source increases. The following rule of thumb regarding sound decreases due to distance is commonly used: beyond approximately 50 feet, each time the distance between a source and a receptor is doubled, sound levels decrease by three decibels over hard ground (such as pavement or water) and by 4.5 decibels over vegetated areas.

## **A. Noise from Wind Turbines**

### **Mechanical Noise**

Mechanical noise from a wind turbine is sound that originates in the generator, gearbox, yaw motors (that intermittently turn the nacelle and blades to face the wind), tower ventilation system, and transformer. Generally, these sounds are limited in new wind turbines so that they are a negligible fraction of the aerodynamic noise. Mechanical noise from the turbine or gearbox would only be heard above aerodynamic noise when they are not functioning properly.

### **Aerodynamic Noise**

Aerodynamic noise is caused by wind passing over the blade of the wind turbine. As wind passes over a moving blade, the blade interrupts the laminar flow of air, causing turbulence and noise. Unexpectedly high aerodynamic noise can be caused by improper blade angle or improper alignment of the rotor to the wind. This is correctable and is usually adjusted during the turbine break-in period. This is the primary source of noise produced by wind turbines. Wind turbines are generally quiet enough for people to hold a normal conversation while standing at the base of the tower.

### **Modulation of Aerodynamic Noise**

Rhythmic modulation of noise, especially low frequency noise, is also perceptible by the human ear. To a receptor on the ground in front of the wind turbine, the detected blade noise is loudest as the blade is at the bottom of its rotation, and quietest when the blade is at the top of its rotation. For a modern 3-blade turbine, this distance-to-blade effect can cause a pulsing of the blade noise about once per second (1 Hz). The distance-to-blade effect diminishes as receptor distance increases because the relative difference in distance from the receptor to the top or bottom of the blade becomes smaller.

Another source of rhythmic modulation may occur if the wind through the rotor is not uniform. Horizontal layers with different wind speeds or directions can form in the atmosphere. This wind condition is called shear. If the winds at the top and bottom of the blade rotation are different, blade noise will vary between the top and bottom of blade rotation, causing modulation of aerodynamic noise.

### **Wind Farm Noise**

The noise from multiple turbines similarly distant from a residence can be noticeably louder than a lone turbine through the addition of multiple noise sources. Under steady wind conditions, noise from a wind turbine farm may be greater than noise from the nearest turbine due to synchrony between noise from more than one turbine. If the dominant frequencies of different turbines vary by small amounts, an audible dissonance may be heard when wind conditions are stable.

## **B. Assessment and Regulation**

The Minnesota Pollution Control Agency (MPCA) is given power to adopt noise standards in Minnesota Statute 116.07 Subd. 2. The adopted standards are given in Minnesota Administrative Rules Chapter 7030. The MPCA standards require A-weighted noise measurements. Different standards are specified for daytime (7:00 AM – 10:00 PM) and nighttime (10:00 PM – 7:00 AM) hours. The noise standards specify the maximum allowable noise volumes that may not be exceeded for more than 10 percent of any hour ( $L_{10}$ ) and 50 percent of any hour ( $L_{50}$ ). Household units, including farm houses, are included in Noise Area Classification (NAC)-1. **Table 2** shows the MPCA State noise standards. All the land within the project area is considered NAC-1.

**Table 2 - MPCA State Noise Standards – Hourly A-Weighted Sound Levels**

Land Use	NAC: Noise Area Classification	Exterior Hourly Noise Level Limit, dBA			
		Daytime		Nighttime	
		7:00 am to 10:00 pm		10:00 pm to 7:00 am	
		L10	L50	L10	L50
Residential	NAC-1	65	60	55	50
Commercial	NAC-2	70	65	70	65
Industrial	NAC-3	80	75	80	75
Notes,					
1. NAC-1 includes household units, transient lodging and hotels, educational, religious, cultural entertainment, camping, and picnicking land uses					
2. NAC-2 includes retail and restaurants, transportation terminals, professional offices, parks, recreational and amusement land uses					
3. NAC-3 includes industrial, manufacturing, transportation facilities (except terminals), and utilities land uses					
4. From Minnesota Pollution Control Agency, Minn. Rules sec 7030.0040					

Since wind farms generate a relatively constant noise volume, the anticipated noise from wind farms are typically reported in terms of an equivalent sound level ( $L_{eq}$ ) that has the same energy and A-weighted level as the community noise over a given time interval rather than reporting both  $L_{10}$  and  $L_{50}$ . When describing relatively constant sound levels, the  $L_{10}$  and  $L_{50}$  values will be roughly equal. This equivalent sound level is most appropriately compared to the State  $L_{50}$  standards. The difference between  $L_{eq}$  and  $L_{50}$  is mathematically similar to the difference between the mean and the median for a data set. These values will be roughly equal for data sets without extreme values or statistical outliers (such as wind turbine noise).

### III. Monitoring Conditions & Methodology

Noise monitoring was conducted at four sites; three within the project area and a fourth that is outside (but nearby) the project area. All four noise monitors were left to collect data for seven days (January 3 to January 10, 2017) at locations that represent the receptors within the project area. The monitoring locations can be found in **Figure 1**. The conditions for the seven days were typical of a Minnesota winter, with temperatures in the single digits and snow on two of the seven days.

Each of the three locations within the project limits (M1-M3) was picked to represent typical distances from receptors to the proposed turbines and were all within public road right-of-way. As required by the LWECs Guidance for Noise Study Protocol and Report, one of the monitoring locations (M1) was located in proximity to the worst-case receptor as predicted by the model (R36). Since the topographical surroundings of the project area are predominately flat, distance from the proposed turbines was the most important factor in collecting the existing conditions. Monitoring location M2 was selected because it represents a total of six receptors in proximity to five proposed turbines on the east edge of the project boundary. Monitoring location M3 was selected because it represents a receptor that may be impacted by at least six proposed turbines. Monitoring location M4 was selected for its similarity to the existing conditions found at the other three monitoring locations, such as near an impacted receptor on a township road.

Each of the monitoring sites was equipped with a Larson Davis 831 Precision Integrating Sound Level Meter that meets compliance with the following American National Standards Institute (ANSI) regulations:

- S1.4-1983 (R2006) Type1
- S1.4A-185 (10Hz-26kHz)
- S1.43-1997 (R2007) Type 1

- S1.11-2004: 1/1 & 1/3 Octave Band Class 0
- S1.25-1991 (R2002)

The microphones attached to the monitoring units were mounted to tripods at a height of at least 3 feet above the ground. Monitoring units were calibrated prior to, and following, the monitoring period. A Vaisala weather station was attached to each of the monitoring locations to record not only wind speed and direction, but also temperature, barometric pressure, humidity, and precipitation. The weather data are included in each of the noise measurements recorded by the Larson Davis 831 units. The average wind speed for the one-hour measurement histories varied between calm conditions and 19 miles per hour with gusts over 30 miles per hour in some cases. Wind direction was typically out of the west or west-southwest. Temperatures remained low and varied from -16°F to 27°F with the coldest conditions in the first three days of collection. There was no rain recorded but the M1 weather station recorded trace amounts of precipitation on January 10. NOAA data reported up to an inch of snow falling in the area between January 9 and January 10.

The instrumentation was set up to collect the following noise values:

- 1/3 Octave Band Data
- A – Weighted Time History (60 second)
- A-Weighted Measurement History (1 hour)
- C-Weighted Time History (60 second,  $L_{min}$ ,  $L_{max}$  and  $L_{eq}$  only)
- C-Weighted Measurement History (1 hour,  $L_{min}$ ,  $L_{max}$  and  $L_{eq}$  only)

All data from the noise monitors were downloaded and exported to Excel spreadsheets for analysis. Data points were collected every 60 seconds and supplemented with a 60-minute measurement history that is used to represent the monitoring data results.

Graphs were created from the seven days of data for each monitoring location to compare noise levels to wind speed and create a reasonable expectation for background noise while modeling the proposed turbine locations. The following values were used for the graphs based on protocol found in the Minnesota Department of Commerce's LWECs Guidance for Noise Study Protocol and Report:

- $LA_{eq}$
- $LC_{eq}$
- $L_{10}$  (A-Weighted)
- $L_{50}$  (A-Weighted)
- $L_{90}$  (A-Weighted)
- Wind Speed

The graphs can be found in **Figures 2, 3, 4, and 5.**

The 21-amp batteries powering the noise monitors had to be replaced on January 7 due to the extreme cold conditions experienced at each of the sites. During this process, it was found that the off-site monitor (site M4) had stopped recording data for a period of nearly 54 hours. This was due to battery failure caused by the cold conditions. The unit was able to resume recording data after the batteries were exchanged, but then failed again during the afternoon of January 9. The data in **Figure 5** indicates these gaps. Data gaps are not uncommon when monitoring noise for long periods of time. These gaps in data can be caused by natural events that the MPCA requests be removed from data analysis (e.g., wind speeds in excess of 11 mph, rain events) or mechanical failure. Although some data loss was experienced, there was enough data collected on January 3, 4, 7, 8 and 9 to provide an accurate portrayal of ambient noise for this off-site location. Site M1 also experienced a short gap in data near the end of the collection period on the afternoon of January 9 and during the morning of January 10. This was found to be also due to low battery power caused by cold weather over the course of the final three

days of data collection. The data collected during between January 3 and January 9 is sufficient to provide an accurate portrayal of the ambient noise in that location.



Figure 2 – Noise Monitoring Results, Site M1




Figure 3 – Noise Monitoring Results, Site M2




Figure 4 – Noise Monitoring Results, Site M3





Figure 5 – Noise Monitoring Results, Site M4



#### IV. Comparison to Minnesota Noise Standards

Figures 6, 7, 8 and 9 show the hourly  $L_{10}$  and  $L_{50}$  values over the seven days with any measurements indicating wind speeds over 11 miles-per-hour (mph) removed. Wind speeds in excess of 11 mph may distort sound; therefore those measurements are removed at the request of MPCA. With a few exceptions, the existing sound levels at most sites are below Minnesota standards for daytime and nighttime  $L_{10}$  and  $L_{50}$  values. Site M3 experiences a spike in noise around noon on January 8. This spike in noise reaches the threshold for the daytime  $L_{10}$  standard and exceeds the  $L_{50}$  standard. Nighttime standards are also already exceeded at two of the four monitoring locations. The  $L_{10}$  and  $L_{50}$  range for each of the monitoring sites is found below in Table 3. Existing sound levels that exceed the State Noise Standards are bolded.

**Table 3 – Daytime and Nighttime Noise Monitoring Results**

Time Period	Location	$L_{10}$ Range (dBA)	$L_{50}$ Range (dBA)
Daytime 7:00 AM to 10:00 PM	M1	27.7 - <b>67</b>	20.3 - <b>61.2</b>
	M2	39 - 63.1	26.8 - 45.8
	M3	24 - 65	21.3 - <b>60.4</b>
	M4	25.9 - 51.7	22.2 - 48.1
Nighttime 10:00 PM to 7:00 AM	M1	23.2 - <b>57.7</b>	18.2 - <b>51.2</b>
	M2	25.9 - <b>57.4</b>	24.2 - 48.4
	M3	22.6 - 54.8	19.2 - 45.2
	M4	22.6 - 42.6	19.4 - 37.5
MN State Standards		$L_{10}$	$L_{50}$
Daytime		65	60
Nighttime		55	50



Figure 7 - Noise Monitoring Results, Site M2 L<sub>10</sub> and L<sub>50</sub> Values Only




Figure 8 - Noise Monitoring Results, Site M3 L<sub>10</sub> and L<sub>50</sub> Values Only







Figure 9 - Noise Monitoring Results, Site M4 L<sub>10</sub> and L<sub>50</sub> Values Only



## V. Modeling and Results

Along with the noise data collected in the field, a model of the proposed turbines and existing receptors was created to determine the impact of the proposed wind farm. Cadna A software was used for analysis and assumes the attenuation of sound propagation as specified by the International Organization for Standardization (ISO) Standard 9613-2 and a ground attenuation factor of 0.5. Turbine locations were provided by Palmer's Creek Wind Farm, LLC. The turbines modeled were 16 General Electric (GE) 2.5-116 and two GE 2.3-116 that produce 2.5 and 2.3 MW respectively. The models included two scenarios:

1. All 18 turbines with an 80-meter hub-height
2. Two 2.3 MW turbines at an 80-meter hub-height (Turbine 14 and Turbine 15) with the remaining 2.5 MW turbines at a 90-meter hub-height.

The 2.5 MW turbines are projected to generate an apparent maximum sound level of 107 dB per the manufacturer's specifications adjacent to the turbine hub, and the 2.3 MW turbines will generate a maximum 107.5 dB output per the manufacturer's specifications (also adjacent to the turbine hub). All conditions were modeled slightly above these specifications at 109 dB.

For a single 2.3 MW turbine at an 80-meter hub-height, the worst-case noise output would produce the sound contours found in **Figure 10**. The resultant noise produced drops below 50 dBA at distances greater than approximately 160 meters (500 feet). Turbine WTG 08 was found to be the closest to any of the proposed receptors, and is 1,076 feet away from Receptor R36.

**Figures 11** and **12** represent the sound contours predicted by the construction of the 18 turbines in the two scenarios. These contours only represent the turbine-generated sound and do not include any cumulative noise from existing background sources. The existing background noise is not known for each specific receptor. Due to this unknown, values of 35, 40, 45, 50, 55 and 60 dBA were used to depict varying degrees of existing noise. This is consistent with the results of the noise monitoring data in the previous section of the report, which showed the existing noise levels at monitoring locations within the project area to range between 45.2 and 60.4 dBA. The resultant noise from the turbines on each receptor was added to the six projected background noise levels, and the summaries of Scenario 1 and 2 can be found in **Tables 4** and **5**.

With background noise levels of 45 dBA and above, the largest increase is predicted to be 2.8 decibels at R36 (Scenario 2) which is considered to be barely perceptible to the human ear.

**Table 4 – Noise Modeling Results (Scenario 1)**

Receptor ID	Turbine Impact (dBA) (Calculated)	Background Sound Levels + Turbine Impact (dBA)					
		35.0	40.0	45.0	50.0	55.0	60.0
R01	30.9	36.4	40.5	45.2	50.1	55.0	60.0
R02	31.4	36.6	40.6	45.2	50.1	55.0	60.0
R03	32.9	37.1	40.8	45.3	50.1	55.0	60.0
R04	34.4	37.7	41.1	45.4	50.1	55.0	60.0
R05	36.6	38.9	41.6	45.6	50.2	55.1	60.0
R06	38	39.8	42.1	45.8	50.3	55.1	60.0
R07	38.7	40.2	42.4	45.9	50.3	55.1	60.0
R08	38.5	40.1	42.3	45.9	50.3	55.1	60.0
R09	39.8	41.0	42.9	46.1	50.4	55.1	60.0
R10	29.6	36.1	40.4	45.1	50.0	55.0	60.0

Receptor ID	Turbine Impact (dBA) (Calculated)	Background Sound Levels + Turbine Impact (dBA)					
		35.0	40.0	45.0	50.0	55.0	60.0
R11	37.3	39.3	41.9	45.7	50.2	55.1	60.0
R12	34.8	37.9	41.1	45.4	50.1	55.0	60.0
R13	34.8	37.9	41.1	45.4	50.1	55.0	60.0
R14	32.5	36.9	40.7	45.2	50.1	55.0	60.0
R15	33.2	37.2	40.8	45.3	50.1	55.0	60.0
R16	29.9	36.2	40.4	45.1	50.0	55.0	60.0
R17	28.4	35.9	40.3	45.1	50.0	55.0	60.0
R18	27.9	35.8	40.3	45.1	50.0	55.0	60.0
R19	28.6	35.9	40.3	45.1	50.0	55.0	60.0
R20	32.2	36.8	40.7	45.2	50.1	55.0	60.0
R21	32.9	37.1	40.8	45.3	50.1	55.0	60.0
R22	36.6	38.9	41.6	45.6	50.2	55.1	60.0
R23	32.5	36.9	40.7	45.2	50.1	55.0	60.0
R24	40.4	41.5	43.2	46.3	50.5	55.1	60.0
SWENSEN MUSEUM	35.8	38.4	41.4	45.5	50.2	55.1	60.0
R25	38.5	40.1	42.3	45.9	50.3	55.1	60.0
R26	38.8	40.3	42.5	45.9	50.3	55.1	60.0
R27	35.2	38.1	41.2	45.4	50.1	55.0	60.0
R28	30.1	36.2	40.4	45.1	50.0	55.0	60.0
R29	36.8	39.0	41.7	45.6	50.2	55.1	60.0
R30	32.5	36.9	40.7	45.2	50.1	55.0	60.0
R31	41.9	42.7	44.1	46.7	50.6	55.2	60.1
R32	42.4	43.1	44.4	46.9	50.7	55.2	60.1
R33	36.6	38.9	41.6	45.6	50.2	55.1	60.0
R34	37.4	39.4	41.9	45.7	50.2	55.1	60.0
R35	37.7	39.6	42.0	45.7	50.2	55.1	60.0
R36	42.5	43.2	44.4	46.9	50.7	55.2	60.1
R37	39.8	41.0	42.9	46.1	50.4	55.1	60.0
R38	37.1	39.2	41.8	45.7	50.2	55.1	60.0
R39	41	42.0	43.5	46.5	50.5	55.2	60.1
R40	38.7	40.2	42.4	45.9	50.3	55.1	60.0
R41	39.1	40.5	42.6	46.0	50.3	55.1	60.0
R42	41.5	42.4	43.8	46.6	50.6	55.2	60.1
R43	39.1	40.5	42.6	46.0	50.3	55.1	60.0
R44	39	40.5	42.5	46.0	50.3	55.1	60.0
R45	35.8	38.4	41.4	45.5	50.2	55.1	60.0
R46	34.9	38.0	41.2	45.4	50.1	55.0	60.0
R47	32.2	36.8	40.7	45.2	50.1	55.0	60.0

**Guide to Reading Tables 4 and 5:**

At receptor 11, we can predict that the sound impact from the proposed turbines will be 37.3 dBA. However, the existing sound levels at this specific location can only be estimated based on the sound monitoring results presented earlier. If the existing sound level is 45 dBA, the resulting cumulative sound level (background noise + turbine noise) at receptor 11 will be 45.7 dBA, an imperceptible increase.

Receptor ID	Turbine Impact (dBA) (Calculated)	Background Sound Levels + Turbine Impact (dBA)					
		35.0	40.0	45.0	50.0	55.0	60.0
SUBSTATION	32.1	36.8	40.7	45.2	50.1	55.0	60.0

**Table 5– Noise Modeling Results (Scenario 2)**

Receptor ID	Turbine Impact (Calculated)	Background Sound Levels + Turbine Impact (dBA)					
		35.0	40.0	45.0	50.0	55.0	60.0
R01	32.5	36.9	40.7	45.2	50.1	55.0	60.0
R02	33	37.1	40.8	45.3	50.1	55.0	60.0
R03	34.5	37.8	41.1	45.4	50.1	55.0	60.0
R04	36	38.5	41.5	45.5	50.2	55.1	60.0
R05	38.2	39.9	42.2	45.8	50.3	55.1	60.0
R06	39.6	40.9	42.8	46.1	50.4	55.1	60.0
R07	40.3	41.4	43.2	46.3	50.4	55.1	60.0
R08	40.2	41.3	43.1	46.2	50.4	55.1	60.0
R09	41.5	42.4	43.8	46.6	50.6	55.2	60.1
R10	31.5	36.6	40.6	45.2	50.1	55.0	60.0
R11	39.3	40.7	42.7	46.0	50.4	55.1	60.0
R12	36.8	39.0	41.7	45.6	50.2	55.1	60.0
R13	36.7	38.9	41.7	45.6	50.2	55.1	60.0
R14	34.4	37.7	41.1	45.4	50.1	55.0	60.0
R15	35.2	38.1	41.2	45.4	50.1	55.0	60.0
R16	31.9	36.7	40.6	45.2	50.1	55.0	60.0
R17	30.3	36.3	40.4	45.1	50.0	55.0	60.0
R18	29.9	36.2	40.4	45.1	50.0	55.0	60.0
R19	30.6	36.3	40.5	45.2	50.0	55.0	60.0
R20	34.2	37.6	41.0	45.3	50.1	55.0	60.0
R21	34.9	38.0	41.2	45.4	50.1	55.0	60.0
R22	38.6	40.2	42.4	45.9	50.3	55.1	60.0
R23	34.4	37.7	41.1	45.4	50.1	55.0	60.0
R24	42.4	43.1	44.4	46.9	50.7	55.2	60.1
SWENSEN MUSEUM	37.7	39.6	42.0	45.7	50.2	55.1	60.0
R25	40.5	41.6	43.3	46.3	50.5	55.2	60.0
R26	40.8	41.8	43.4	46.4	50.5	55.2	60.1
R27	37.2	39.2	41.8	45.7	50.2	55.1	60.0
R28	32.1	36.8	40.7	45.2	50.1	55.0	60.0
R29	38.8	40.3	42.5	45.9	50.3	55.1	60.0
R30	34.5	37.8	41.1	45.4	50.1	55.0	60.0
R31	43.9	44.4	45.4	47.5	51.0	55.3	60.1

Receptor ID	Turbine Impact (Calculated)	Background Sound Levels + Turbine Impact (dBA)					
		35.0	40.0	45.0	50.0	55.0	60.0
R32	44.3	44.8	45.7	47.7	51.0	55.4	60.1
R33	38.6	40.2	42.4	45.9	50.3	55.1	60.0
R34	39.4	40.7	42.7	46.1	50.4	55.1	60.0
R35	39.7	41.0	42.9	46.1	50.4	55.1	60.0
R36	44.5	45.0	45.8	47.8	51.1	55.4	60.1
R37	41.8	42.6	44.0	46.7	50.6	55.2	60.1
R38	39	40.5	42.5	46.0	50.3	55.1	60.0
R39	43	43.6	44.8	47.1	50.8	55.3	60.1
R40	40.7	41.7	43.4	46.4	50.5	55.2	60.1
R41	41	42.0	43.5	46.5	50.5	55.2	60.1
R42	43.4	44.0	45.0	47.3	50.9	55.3	60.1
R43	41.1	42.1	43.6	46.5	50.5	55.2	60.1
R44	40.9	41.9	43.5	46.4	50.5	55.2	60.1
R45	37.8	39.6	42.0	45.8	50.3	55.1	60.0
R46	36.8	39.0	41.7	45.6	50.2	55.1	60.0
R47	33.9	37.5	41.0	45.3	50.1	55.0	60.0
SUBSTATION	33.9	37.5	41.0	45.3	50.1	55.0	60.0

## VI. Conclusion

WSB collected noise and meteorological data at four different sites representing the proposed Palmer's Creek Wind Farm. For monitoring locations within the proposed project area, the current  $L_{50}$  sound levels range from 45.1 dBA to 60.4 dBA for both daytime and nighttime. The existing sound levels met or exceeded State daytime noise standards at monitoring location 3, and met or exceeded nighttime noise standards at monitoring locations 1 and 2.

Two turbine layout scenarios were modeled to determine the sound-related impact of the proposed wind farm. **Tables 6 and 7** provide a summary of the sound impacts predicted under both turbine layout scenarios. The highest predicted change in sound level above 45 dBA is 2.8 dBA. Changes in sound levels less than 3 dBA are barely perceptible to the human ear.


**Table 6: Summary of Scenario 1 Sound Impacts**

Background Sound (dBA)	Highest Cumulative Sound (dBA)	Change in Sound Level (dBA)
45	46.9	1.9
50	50.7	0.7
55	55.2	0.2
60	60.1	0.1

**Table 7: Summary of Scenario 2 Sound Impacts**

Background Sound (dBA)	Highest Cumulative Sound (dBA)	Change in Sound Level (dBA)
45	47.8	2.8
50	51.1	1.1
55	55.4	0.4
60	60.1	0.1

In Minnesota, the MPCA State Noise Standards ( $L_{50}$ ) restrict noise levels to 60 dBA during the daytime and 50 dBA during the nighttime. The analysis indicates that construction of the Palmer's Creek Wind Farm project will not have an impact of 60 dBA or greater on any modeled receptor, nor will the cumulative impact on any receptor exceed 60 dBA when assuming a 35 dBA, 40 dBA, 45 dBA, 50 dBA, or 55 dBA background sound level. During the daytime, and only with a background sound level already approaching or exceeding the 60 dBA threshold would the cumulative sound level (background and wind turbine sound) exceed 60 dBA. The same is true for the nighttime threshold; only with a background sound level already approaching or exceeding the 50 dBA threshold would the cumulative sound level exceed 50 dBA.



**Figure 1 - Project Limits & Monitoring Locations**  
 Palmer's Creek Wind Farm  
 Fagen Engineering



0 3,600 Feet  
 1 inch = 3,600 feet






**Legend**

- Receivers
- Proposed Turbine Locations


**DB**

- 35.000
- 40.000
- 45.000
- 50.000
- 55.000


**Figure 10 - Closest Receiver to Turbine Impact**  
Palmer's Creek Wind Farm  
Fagen Engineering








**Figure 11 - Turbine Scenario 1,  
All Turbines at 80m Hub Height**  
Palmer's Creek Wind Farm  
Fagen Engineering



Document Path: K:\02\08\_020\GIS\Map\Figures\11 - Turbine Scenario 1 - 12/20/2017 3:47:20 PM



**Figure 12 - Turbine Scenario 2**  
**2.3 WM Turbines at 80m Hub Height, 2.5 MW Turbines at 90m Hub Height**  
 Palmer's Creek Wind Farm  
 Fagen Engineering



0 3,000  
 Feet  
 1 inch = 3,000 feet

