

Appendix M

Operating Equipment Noise Levels

In accordance with Minnesota Rules, part 7829.0500, and Minnesota Statutes Chapter 13, Otter Tail has designated portions of Appendix M as **NONPUBLIC DATA—NOT FOR PUBLIC DISCLOSURE** because it contains commercially-sensitive information, i.e., certain inverter sound power levels, which are considered confidential and proprietary information, which, if released, would have a detrimental effect on Otter Tail's equipment suppliers by providing potential competitors and others in the energy marketplace with valuable information not otherwise readily ascertainable and from which these persons would obtain economic value. Otter Tail and its suppliers take measures to ensure this information is not released publicly, including securing the data and entering into confidentiality agreements, as necessary, if the information is provided to another party. Given the need to include nonpublic information, Otter Tail has prepared and is electronically filing both **NONPUBLIC** and public versions of Appendix M.

This Page Intentionally Blank

Operating Equipment Noise Levels			
Facility Type	Equipment Model	Distance to 50 dBA (feet)	SPL at 50 feet (dBA)
Inverter	Sungrow SG4400UD-MV-US	[NONPUBLIC DATA HAS BEEN EXCISED]	
Tracker	Nextracker NX Horizon	17	41
Substation Transformer	Typical (130 MVA)	240	63

This Page Intentionally Blank