



Alliant Energy Corporate Services
Legal Department
319.786.4742 – Telephone
319.786.4533 – Fax

Paula N. Johnson
Senior Attorney – Regulatory

Interstate Power and Light Company
An Alliant Energy Company

Alliant Tower
200 First Street SE
P.O. Box 351
Cedar Rapids, IA 52406-0351

Office: 1.800.822.4348
www.alliantenergy.com

May 1, 2014

Dr. Burl W. Haar
Executive Secretary
Minnesota Public Utilities Commission
121 Seventh Place East, Suite 350
St. Paul, MN 55101-2147

RE: Interstate Power and Light Company
Docket No. E001/RP-14-77
Informational Filing

Dear Dr. Haar:

Enclosed for eFiling with the Minnesota Public Utilities Commission (Commission) please find a copy of the following Interstate Power and Light Company (IPL) documents filed with the Iowa Utilities Board (Board):

- *First Semi-Annual Status Report Marshalltown Generating Station* filed on March 3, 2014 (see Attachment A); and
- *Request for Issuance of a Generating Certificate* filed on April 17, 2014 (see Attachment B).

Please note that this is not a Notice of Changed Circumstances filing. IPL has not made any official changes to its Integrated Resource Plan (IRP) action plan at this time. IPL provides this information to keep parties informed about the construction, transmission, permitting, and other activities related to the approximate 650 megawatt natural gas-fired Marshalltown Generating Station (MGS) located in Marshalltown, Iowa. Based upon the information currently available to IPL, IPL continues to anticipate that MGS will be on-line in the second quarter of 2017.

IPL seeks no action by the Commission, but felt it appropriate to provide this information as part of the IRP docket.

Dr. Haar
May 1, 2014
Page 2 of 2

Copies of this filing have been served on the Minnesota Department of Commerce, Division of Energy Resources, the Minnesota Office of Attorney General-Residential and Small Business Utilities Division, and the attached service list.

Respectfully submitted,

/s/ Paula N. Johnson
Paula N. Johnson
Senior Attorney – Regulatory

PNJ/rlw
Enclosures

cc: Service List

STATE OF MINNESOTA

BEFORE THE MINNESOTA PUBLIC UTILITIES COMMISSION

Beverly Jones Heydinger
David C. Boyd
Nancy Lange
Dan Lipschultz
Betsy Wergin

Chair
Commissioner
Commissioner
Commissioner
Commissioner

IN THE MATTER OF INTERSTATE
POWER AND LIGHT COMPANY'S 2014
INTEGRATED RESOURCE PLAN

DOCKET NO. E001/RP-14-77

AFFIDAVIT OF SERVICE

STATE OF IOWA)
) ss.
COUNTY OF LINN)

Tonya A. O'Rourke, being first duly sworn on oath, deposes and states:

That on the 1st day of May, 2014, copies of the foregoing Affidavit of Service, together with Interstate Power and Light Company's, Informational Filing, were served upon the parties on the attached service list, by e-filing, overnight delivery, electronic mail, and/or first-class mail, proper postage prepaid from Cedar Rapids, Iowa.

/s/ Tonya A. O'Rourke
Tonya A. O'Rourke

Subscribed and Sworn to Before Me
this 1st day of May, 2014.

/s/ Kathleen J. Faine
Kathleen J. Faine
Notary Public
My Commission Expired on February 20, 2015

First Name	Last Name	Email	Company Name	Address	Delivery Method	View Trade Secret	Service List Name
Bobby	Adam	bobby.adam@conagrafoods.com	ConAgra	Suite 5022 11 ConAgra Drive Omaha, NE 68102	Electronic Service	No	OFF_SL_14-77_RP-14-77
Christopher	Anderson	canderson@allete.com	Minnesota Power	30 W Superior St Duluth, MN 558022191	Electronic Service	No	OFF_SL_14-77_RP-14-77
Julia	Anderson	Julia.Anderson@ag.state.mn.us	Office of the Attorney General-DOC	1800 BRM Tower 445 Minnesota St St. Paul, MN 551012134	Electronic Service	Yes	OFF_SL_14-77_RP-14-77
William A.	Blazar	bblazar@mnchamber.com	Minnesota Chamber Of Commerce	Suite 1500 400 Robert Street North St. Paul, MN 55101	Electronic Service	No	OFF_SL_14-77_RP-14-77
Michael	Bradley	mike.bradley@lawmoss.com	Moss & Barnett	Suite 4800 90 S 7th St Minneapolis, MN 55402-4129	Electronic Service	No	OFF_SL_14-77_RP-14-77
City	Clerk	sschulte@ci.albertlea.org	City of Albert Lea	221 E Clark St Albert Lea, MN 56007	Electronic Service	No	OFF_SL_14-77_RP-14-77
Ian	Dobson	ian.dobson@ag.state.mn.us	Office of the Attorney General-RUD	Antitrust and Utilities Division 445 Minnesota Street, 1400 BRM Tower St. Paul, MN 55101	Electronic Service	No	OFF_SL_14-77_RP-14-77
Sharon	Ferguson	sharon.ferguson@state.mn.us	Department of Commerce	85 7th Place E Ste 500 Saint Paul, MN 551012198	Electronic Service	No	OFF_SL_14-77_RP-14-77
Elizabeth	Goodpaster	bgoodpaster@mncenter.org	MN Center for Environmental Advocacy	Suite 206 26 East Exchange Street St. Paul, MN 551011667	Electronic Service	Yes	OFF_SL_14-77_RP-14-77
David	Grover	dgrover@itctransco.com	ITC Midwest	901 Marquette Avenue Suite 1950 Minneapolis, MN 55402	Electronic Service	No	OFF_SL_14-77_RP-14-77

First Name	Last Name	Email	Company Name	Address	Delivery Method	View Trade Secret	Service List Name
Burl W.	Haar	burl.haar@state.mn.us	Public Utilities Commission	Suite 350 121 7th Place East St. Paul, MN 551012147	Electronic Service	Yes	OFF_SL_14-77_RP-14-77
Annete	Henkel	mui@mnuutilityinvestors.org	Minnesota Utility Investors	413 Wacouta Street #230 St. Paul, MN 55101	Electronic Service	No	OFF_SL_14-77_RP-14-77
Linda	Jensen	linda.s.jensen@ag.state.mn.us	Office of the Attorney General-DOC	1800 BRM Tower 445 Minnesota Street St. Paul, MN 551012134	Electronic Service	No	OFF_SL_14-77_RP-14-77
Paula	Johnson	paulajohnson@alliantenergy.com	Alliant Energy-Interstate Power and Light Company	P.O. Box 351 200 First Street, SE Cedar Rapids, IA 524060351	Electronic Service	No	OFF_SL_14-77_RP-14-77
Jim	Krueger	jkrueger@fmcs.coop	Freeborn-Mower Cooperative Services	Box 611 Albert Lea, MN 56007	Electronic Service	No	OFF_SL_14-77_RP-14-77
John	Lindell	agorud.ecf@ag.state.mn.us	Office of the Attorney General-RUD	1400 BRM Tower 445 Minnesota St St. Paul, MN 551012130	Electronic Service	Yes	OFF_SL_14-77_RP-14-77
Kavita	Maini	kmainsi@wi.rr.com	KM Energy Consulting LLC	961 N Lost Woods Rd Oconomowoc, WI 53066	Electronic Service	No	OFF_SL_14-77_RP-14-77
Pam	Marshall	pam@energycents.org	Energy CENTS Coalition	823 7th St E St. Paul, MN 55106	Electronic Service	No	OFF_SL_14-77_RP-14-77
David	Moeller	dmoeller@allete.com	Minnesota Power	30 W Superior St Duluth, MN 558022093	Electronic Service	No	OFF_SL_14-77_RP-14-77
Carl	Nelson	cnelson@mncee.org	Center for Energy and Environment	212 3rd Ave N Ste 560 Minneapolis, MN 55401	Electronic Service	No	OFF_SL_14-77_RP-14-77

First Name	Last Name	Email	Company Name	Address	Delivery Method	View Trade Secret	Service List Name
Steven	Nyhus	swnyhus@flaherty-hood.com	Flaherty & Hood PA	525 Park St Ste 470 Saint Paul, MN 55103	Electronic Service	No	OFF_SL_14-77_RP-14-77
Richard	Savelkoul	rsavelkoul@martinsquires.com	Martin & Squires, P.A.	332 Minnesota Street Ste W2750 St. Paul, MN 55101	Electronic Service	No	OFF_SL_14-77_RP-14-77
Larry L.	Schedin	Larry@LLSResources.com	LLS Resources, LLC	12 S 6th St Ste 1137 Minneapolis, MN 55402	Electronic Service	No	OFF_SL_14-77_RP-14-77
Matthew J.	Schuerger P.E.	mjsreg@earthlink.net	Energy Systems Consulting Services, LLC	PO Box 16129 St. Paul, MN 55116	Electronic Service	No	OFF_SL_14-77_RP-14-77
Ron	Spangler, Jr.	rlspangler@otpc.com	Otter Tail Power Company	215 So. Cascade St. PO Box 496 Fergus Falls, MN 565380496	Electronic Service	No	OFF_SL_14-77_RP-14-77
Marya	White	mwhite@misoenergy.org	MISO	1125 Energy Park Dr St. Paul, MN 55108	Electronic Service	No	OFF_SL_14-77_RP-14-77
Robyn	Woeste	robynwoeste@alliantenergy.com	Interstate Power and Light Company	200 First St SE Cedar Rapids, IA 52401	Electronic Service	No	OFF_SL_14-77_RP-14-77



Alliant Energy Corporate Services
Legal Department
608-458-3318 – Phone
608-458-4820 – Fax

Michael S. Greiveldinger
Senior Attorney

Interstate Power and Light Co.
An Alliant Energy Company

Alliant Tower
200 First Street SE
P.O. Box 351
Cedar Rapids, IA 52406-0351

Office: 1.800.822.4348
www.alliantenergy.com

March 3, 2014

Ms. Joan Conrad, Executive Secretary
Iowa Utilities Board
1375 East Court Avenue, Room 69
Des Moines, IA 50319-0069

**FILED WITH
Executive Secretary
March 03, 2014
IOWA UTILITIES BOARD**

RE: Interstate Power and Light Company
Docket Nos. RPU-2012-0003 and GCU-2012-0001
First Semi-Annual Status Report Marshalltown Generating Station

Dear Secretary Conrad:

Enclosed please find Interstate Power and Light Company's First Semi-Annual Status Report Marshalltown Generating Station, as filed today on EFS in the above-referenced dockets.

Very truly yours,

/s/ Michael S. Greiveldinger

Michael S. Greiveldinger
Senior Attorney

MSG/kjf
Enclosures

FILED WITH
Executive Secretary

March 03, 2014

STATE OF IOWA

BEFORE THE IOWA UTILITIES BOARD

IOWA UTILITIES BOARD

IN RE:	
INTERSTATE POWER AND LIGHT COMPANY	DOCKET NOS. GCU-2012-0001 RPU-2012-0003

**FIRST SEMI-ANNUAL STATUS REPORT
MARSHALLTOWN GENERATING STATION**

COMES NOW, Interstate Power and Light Company (IPL), and submits to the Iowa Utilities Board (Board) its First Semi-Annual Status Report regarding construction, transmission, permitting, and other activities related to the Marshalltown Generating Station (MGS). IPL also submits additional permits and approvals as provided for in Section 2 of IPL's Application for Generating Facility Siting Certificate (Siting Application) in Docket No. GCU-2012-0001.

MGS PROJECT STATUS

1. On November 8, 2013, the Board issued its Proposed Decision and Order (November 8th Order), of which Order Clause No. 5 requires IPL to, among other things:

...file a status report on MGS on or before March 3, 2014, and every six months thereafter, with the final report due three months after all aspects of the project subject to the overall cost cap are completed. At a minimum, the report shall provide updates on the information identified in the body of this order.

The Board also addressed this requirement at page 29 of its November 8th Order:

IPL will be required to file semi-annual reports with construction progress, both for MGS and any necessary transmission upgrades. The reports are to include detailed information regarding completed

transmission work, including interconnection details and Marshalltown area network modifications related to the project....

2. Attachment A to this pleading provides the requested information, and is hereby incorporated by reference.

NEW PERMITS OBTAINED

3. As a part of this First Semi-Annual Status Report, IPL provides to the Board its fourth supplement regarding certain permitting information. IPL submits the attached permit information as provided for in Section 2 of IPL's Application for Generating Facility Siting Certificate (Siting Application) in Docket No. GCU-2012-0001, described below.

In Section 2 of its November 14, 2012, Siting Application, IPL submitted information available at that time regarding its permitting processes and progress. In Section 2.3 of that Siting Application, IPL stated that it would provide to the Board, "[i]nformation included in permits and approvals ... as it becomes available." In compliance with that statement, IPL submits the attached documents to be appended to the Siting Application as Figure 2.3-8 and Figure 2.3-9.

4. In Section 2.1 of the Siting Application, IPL states that there is both a state and local Floodplain Development Permit that may be required for the MGS (Siting Application, at 2-2 & 2-5). IPL has been working with both the Iowa Department of Natural Resources (IDNR) and the City of Marshalltown to fully understand the floodplain permitting requirements associated with the MGS project. Based on IPL's commitment to construct and locate the MGS facility structures on natural ground at or above the established 500-year floodplain of

863.5 feet, no floodplain permitting is triggered. In addition, IPL will ensure that it meets the other obligatory construction related items noted in the IDNR and the City of Marshalltown Floodplain Permit Determination letters, attached as Figure 2.3-8 and 2.3-9.

5. IPL's intends Figure 2.3-8 and Figure 2.3-9 to supplement the Agency Application Information as noted in Section 2.3 of its Siting Application, with particular regard to the discussion of the IDNR and City of Marshalltown Floodplain Development Permits.

WHEREFORE, Interstate Power and Light Company respectfully requests that the Iowa Utilities Board accept this documentation as the First Semi-Annual Status Report.

Dated this 3rd day of March, 2014.

Respectfully Submitted,

Interstate Power and Light Company

By: /s/ Michael S. Greiveldinger
Michael S. Greiveldinger
Senior Attorney
Alliant Energy Corporate Services, Inc.
4902 N Biltmore Lane
Madison, WI 53718
(608) 458-3318
michaelgreiveldinger@alliantenergy.com

Paula N. Johnson
Senior Attorney
Alliant Energy Corporate Services, Inc.
200 First Street S.E.
Cedar Rapids, IA 52406-0351
(319) 786-4742
paulajohnson@alliantenergy.com

Attachment A

I. Regulatory Approval Status – Marshalltown Generating Station (MGS)

On November 8, 2013, the Iowa Utilities Board (Board) issued the Proposed Order for the construction of MGS (November 8th Order). The November 8th Order was accepted by IPL's Board of Directors on November 19, 2013.

On November 12, 2013, the Large Energy Group (LEG) filed a request for clarification of the record, regarding the November 8th Order. The two clarifications that LEG requested were 1) the Order should clarify that the cost cap should include reimbursements that IPL may be required to pay ITC Midwest, and that any tax gross-up should be included in the cost cap; 2) the order should clarify that if IPL is reimbursed for transmission upgrade project costs, that the cost cap should be reduced by said amount. On December 2, 2013, the Iowa Consumers Coalition (ICC) filed a letter supporting LEG's request.

On December 9, 2013 the Board issued the Order Clarification Decision, stating that the amount of the tax gross-up does not increase the cost cap, and that all transmission network upgrade costs count against the cost cap, and that the cost cap therefore would not be decreased. Since no party has sought either administrative or judicial review of the November 8th Order, the Order has been deemed final and un-appealable.

II. Permitting Status - MGS

As noted in the GCU Application Filing, IPL is committed to obtaining all necessary federal, state, and local permits and approvals for the MGS. Consistent with the Board's November 8th Order, IPL's near-term focus is to obtain all required pre-construction permits and approvals so that the Board may issue a final non-conditional GCU Order, as provided in Ordering Clause 1.

The following are the remaining pre-construction permits and approvals that need to be obtained prior to issuance of the non-conditional GCU Order:

1. Iowa Department of Natural Resources (IDNR) Stormwater Construction Permit (Siting Application, at 2-1).
2. IDNR New Source Review-Prevention of Significant Deterioration (PSD) Air Permits (Siting Application, at 2-1). The New Source Review-PSD Air Permits are considered the "critical path" pre-construction permits for MGS.
3. City of Marshalltown Variance Request (Siting Application, at 2-7).
4. City of Marshalltown Site Review Approval (Siting Application, at 2-5).
5. City of Marshalltown Stormwater Permit for Construction (Siting Application, at 2-7).

Regarding the critical path New Source Review-PSD Air Permits, IPL filed an Air Permit application for the MGS with the IDNR on October 1, 2013. The IDNR recently issued draft PSD Air Permits for public comment; the public comment period extends from February 10, 2014 until March 14, 2014. The IDNR will be

hosting a public hearing on draft PSD Air Permits on March 13, 2014, at the Marshalltown Public Library in Marshalltown, Iowa. IPL anticipates IDNR issuing the MGS New Source Review-PSD Air Permits in the early part of the second quarter of 2014.

Once the MGS New Source Review-PSD Air Permits are obtained, IPL will submit a request to the Board for issuance of a non-conditional certificate for the MGS. IPL anticipates submitting this request in the second quarter of 2014.

III. Permitting Status – MGS Gas Pipeline

On May 1, 2013, IPL submitted a Petition for Pipeline Permit to the Board, in Docket No. P-0888. On May 15, 2013 and June 26, 2013, Iowa Utilities Board Safety and Engineering staff informed IPL of deficiencies in the petition and requested additional information. IPL filed amendments to its petition and exhibits, and provided additional information on June 14, 2013, July 26, 2013, and October 17, 2013. A hearing was held on November 13, 2013 in Marshalltown, Iowa. On November 18, 2013 the Administrative Law Judge issued the Proposed Decision and Order Granting Permit. Since no notice of appeal of the Proposed Decision and Order Granting Permit was filed, the Proposed Decision and Order Granting Permit became a final decision of the Board on December 3, 2013.

IV. Transmission Status Update

A. Work Completed/Interconnection Details: IPL submitted a request to Midcontinent Independent System Operator, Inc. (MISO) on July 1, 2013 to include MGS in the August 2013 Definitive Planning Phase (DPP) study cycle. The DPP process includes a System Impact Study and a Facilities Study.

The DPP System Impact Study process identifies required system upgrades. IPL was an active participant throughout the DPP System Impact Study process, and worked with MISO and ITC Midwest (ITC-M) to review and validate study results. After several rounds of review, feedback, and edits by all study participants, MISO issued the final DPP System Impact Study in January, 2014 (MISO August 2013 West Area DPP Group Study, dated January 8, 2014), which IPL filed with the Board on February 25, 2014. The DPP System Impact Study included, among other information, a thermal overload screening, a stability analysis, and a deliverability study.

The DPP Facilities Study, which was initiated in February, 2014, will provide detailed cost estimates for interconnection and upgrades identified in the System Impact Study. IPL will continue to work with MISO and ITC-M throughout the Facilities Study process. IPL anticipates that the DPP Facility Study will be completed within the next several months. Upon completion, IPL will submit the DPP Facility Study to the Board consistent with Ordering Clause 5 of the November 8th Order.

Once the DPP Facilities Study has been finalized, a Generator Interconnection Agreement (GIA) between IPL, MISO, and ITC-M will be entered into for MGS. The GIA will set the schedule for the construction of the required ITC-M upgrades, and enable ITC-M to move forward with constructing those upgrades. IPL currently anticipates that the GIA will be executed in second quarter of 2014.

B. Marshalltown Electric Network Modifications: There are no updates regarding the Marshalltown electric network modifications at this time beyond the results of the DPP System Impact Study.

C. Transmission Costs: As discussed in the record, IPL filed a complaint with the Federal Energy Regulatory Commission (FERC) in September 2012, which sought a change to certain cost recovery provisions of Attachment FF of the MISO Tariff that applied to network upgrades within ITC-M's zone. FERC granted IPL's complaint in its July 18, 2013, Order in Docket No. EL12-104-000 (July 18th Order). IPL filed the FERC Order with the Board in its August 1, 2013 Additional Information filing, and noted that:

Assuming a new Schedule FF, revised pursuant to the FERC Order ... most of the transmission system upgrade costs related to MGS would become part of IPL's rate base and billed to customers as part of the revenue requirement established in periodic IPL rate cases in the retail jurisdictions it serves.

(Additional Information at 2.)

ITC-M filed a request for a rehearing and, in the alternative, a request for clarification on August 16, 2013, and IPL filed a request for clarification on August 19, 2013. On February 20, 2014 FERC issued an order denying ITC-M's

request for rehearing, granting in part and deny in part ITC-M and IPL's respective requests for clarification (February 20th Order). FERC's February 20th Order substantially affirms the July 18th Order. Given that there is not currently a GIA for MGS, the effect of FERC's February 20th Order on MGS is insignificant.

IPL has become aware that ITC-M has an option under the terms of the MISO Generator Interconnection Procedures that enables ITC-M to self-fund the network upgrades. IPL believes that, if ITC-M self-funds those additional network upgrades, then ITC-M will retain the assets on its books and levy a direct charge on IPL for the additional electric transmission service costs. IPL currently believes that ITC-M will pursue the self-fund option. Under such a scenario, IPL expects those ITC-M costs under the self-fund option to be included as part of IPL's Cost Cap calculation.

V. Construction Status Update – MGS

IPL is utilizing an Engineer-Procure-Construct (EPC) contracting methodology for the Project. IPL has selected Kellogg, Brown and Root, LLC (KBR) as its EPC contractor. IPL entered into a Limited Notice to Proceed (LNTP) with KBR on November 15, 2013. IPL anticipates executing the EPC contract in the second quarter 2014, providing KBR with a Full Notice to Proceed (FNTP).

A. Engineering: The LNTP allows the MGS project to move forward with the necessary preliminary engineering and design work required to maintain the overall project schedule.

B. Procurement: The LNTP provides KBR with authorization to sub-contract with its combustion turbine and steam turbine generator Original Equipment Manufacturer (OEM), and other miscellaneous procurement activities to meet the overall project schedule.

C. Construction: Contingent upon issuance of the non-conditional GCU certificate from the Board, IPL expects to mobilize and prepare to start construction, following IPL's issuance of the FNTP to KBR, in the second quarter of 2014.

Based upon information currently available to IPL, IPL continues to anticipate that MGS will be on-line in the second quarter of 2017.

VI. Construction Status Update – MGS Gas Pipeline

IPL has finalized the pipeline route, and has obtained 100% of the associated land easements. Pipeline engineering and design work is currently 98% complete. Additionally, the geotechnical borings have been completed. IPL anticipates site mobilization and start-up of construction to begin late third quarter or early fourth quarter, 2014. IPL currently anticipates the construction of the pipeline to be completed in the third quarter of 2015. As contained in Docket No. P-0888, IPL will submit weekly reports to the Board regarding construction of the pipeline, once construction commences.

VII. MGS Project Cost

The Cost Cap as identified in the Board Order is \$920M. From inception to date, IPL has spent approximately \$20.5M. Based upon the information currently available to IPL, IPL anticipates that the Project will be completed within the Cost Cap.

At this time, IPL is finalizing contracts, and has not entered into a Full Notice to Proceed (FNTP) with the selected Engineering Procurement and Construction (EPC) Contractor. Additionally, IPL has not received the detailed cost estimate for Transmission Upgrades.



STATE OF IOWA

TERRY E. BRANSTAD, GOVERNOR
KIM REYNOLDS, LT. GOVERNOR

DEPARTMENT OF NATURAL RESOURCES
CHUCK GIPP, DIRECTOR

December 2, 2013

IPL
c/o Justin Bailey
Burns & McDonnell Engineering Co., Inc.
9400 Ward Parkway
Kansas City, MO 64114

RE: Marshalltown Generating Station Project Work Item I: Proposed Construction of a New Natural Gas Combined Cycle Power Plant Facility (Iowa River) Section 31, T84N, R17W, Marshall County, within the incorporated limits of the City of Marshalltown, Iowa

Marshalltown Generating Station Project Work Item II: Proposed Installation of an Underground Natural Gas Pipeline (multiple watercourses) Commencing in Section 31, T84N, R17W, Marshall County, within the incorporated limits of the City of Marshalltown, Iowa and traversing to the NE¼ of Section 12, T85N, R17W, in an unincorporated area of Marshall County, Iowa

Dear Mr. Bailey:

This is in response to your Flood Plain Development Permit application received on August 27, 2013, and our telephone conversations on November 27, 2013, on behalf of IPL, concerning the above project work items. It is the Department's understanding that: 1) all of the Work Item I facility structures will be constructed/placed on natural ground situated above an elevation of 863.5 feet, NGVD 29; 2) the natural gas pipeline will be installed using both open-cut trenching and directional drilling techniques; 3) all ground surface contours along Work Item II will be restored to their pre-project elevations; and 4) no dam type structures will be constructed as part of the project.

Based on the information received, the Department has determined the following:

- Proposed Work Items I and II will not require a Flood Plain Development Permit from our office, as long as all excess spoil material will either be removed from the flood plain or spread thinly (less than 0.5 ft. thick) on the surrounding ground. In addition, spoil material should not be placed in an area that is, or could be, classified as a regulated wetland.

IPL
c/o Justin Bailey


Page 2 of 2
December 2, 2013

- Work Item I might require a local flood plain permit from the City of Marshalltown. If you have not yet done so, please contact the local Flood Plain Manager (Lynn Couch at 641-754-5734) regarding the local flood plain permit. The Flood Plain Manager should make a determination of whether construction of any portion of the facility requires flood plain permitting and, if so, provide assistance on applying for the local permit. We have reviewed the project and would not object if the City grants a flood plain permit for this work item, as long as you show that all facility structures will be constructed/placed on natural ground situated above an elevation of 863.5 feet, NGVD 29.
- It appears that Work Item II (e.g.; trenches, boreholes, and grading) in certain locations will require local flood plain permits from both Marshall County and the City of Marshalltown. If you have not yet done so, please contact the local Flood Plain Managers (John Kunc at 641-754-6370 for Marshall County and Lynn Couch at 641-754-5734 for the City of Marshalltown) for assistance on applying for the local flood plain permits. We have reviewed the project and would not object if the County and the City grant their respective permits for this work item, as long as you show that all excess spoil material will either be removed from the flood plain or spread thinly (less than 0.5 ft. thick) on the surrounding ground.

The applicant is responsible for complying with all other local, state and federal statutes, ordinances, rules and permit requirements applicable to the construction, operation and maintenance of the approved works. The project may require a Section 404 Permit from the U.S. Army Corps of Engineers. Please note that the project does not require a Sovereign Lands Construction Permit from the Department.

Thank you for your cooperation. If you have any questions, please call me at 515-281-8968.

Sincerely,




Jeff Simmons
Water Resources Section
Flood Plain Management Program

- Copies
- Ward Lenz; Rock Island District, U.S. Army Corps of Engineers; P.O. Box 2004; Rock Island, IL 61204-2004
 - IDNR FO #5
 - Lynn Couch, Public Works Director; City of Marshalltown; 24 North Center Street; Marshalltown, IA 50158-4911
 - John Kunc; Marshall County Planning & Zoning Administrator; 1 East Main Street; Marshalltown, IA 50158


IOWA DEPARTMENT OF NATURAL RESOURCES
WALLACE STATE OFFICE BUILDING
502 E 9TH STREET
DES MOINES, IOWA 50319-0034

15DEC1305M14503

PRESORTED
FIRST CLASS



02 1M \$ 00.38⁴
0008004134 DEC 04 2013
MAILED FROM ZIP CODE 50319



15DEC1305M14503





James L. Lowrance, Mayor
Randy Wetmore, Administrator
24 North Center Street
Marshalltown, IA 50158-4911
Tel - (641) 754-5734
Fax - (641) 754-5793

2/11/14

PUBLIC WORKS DEPARTMENT

Alan Arnold
PO Box 351
Cedar Rapids, IA 52406-0351

RE: Marshalltown Generating Station Project Work Items I and II

Dear Mr. Arnold,

Based on the information received by this office the proposed work items will not require a Flood Plain Development Permit from this office, as long as all spoil material will either be removed from the flood plain or spread thinly (less than 0.5 ft. thick) on the surrounding ground.

If you have any questions in regards to this matter please contact me.

Sincerely



Lynn E. Couch, P.E.
Marshalltown Flood
Plain Manager

City Council
Leon Lamer, Mike Gowdy, Joel Greer, Al Hoop
Bill Martin, Robert Schubert, Bethany Wirin





Alliant Energy Corporate Services
Legal Department
608-458-3318 – Phone
608-458-4820 – Fax

Michael S. Greiveldinger
Senior Attorney

Interstate Power and Light Co.
An Alliant Energy Company

Alliant Tower
200 First Street SE
P.O. Box 351
Cedar Rapids, IA 52406-0351

Office: 1.800.822.4348
www.alliantenergy.com

April 17, 2014

Ms. Joan Conrad, Executive Secretary
Iowa Utilities Board
1375 East Court Avenue, Room 69
Des Moines, IA 50319-0069

RE: Interstate Power and Light Company
Docket Nos. GCU-2012-0001 and RPU-2012-0003
Request for Issuance of a Generating Certificate

Dear Secretary Conrad:

Enclosed please find Interstate Power and Light Company's Request for Issuance of a Generating Certificate, as filed today on EFS in the above-referenced dockets.

Very truly yours,

/s/ Michael S. Greiveldinger
Michael S. Greiveldinger
Senior Attorney

MSG/kjf
Enclosures

STATE OF IOWA
BEFORE THE IOWA UTILITIES BOARD

IN RE: INTERSTATE POWER AND LIGHT COMPANY	DOCKET NOS. GCU-2012-0001 RPU-2012-0003
--	--

REQUEST FOR ISSUANCE OF A GENERATING CERTIFICATE

COMES NOW, Interstate Power and Light Company (IPL), and provides to the Iowa Utilities Board (Board) its fifth and final supplement regarding certain permitting information,¹ and requests issuance of an unconditional Generating Certificate pursuant to Ordering Clause 1 of the Board's November 8, 2013 Proposed Decision and Order ("Order").

INTRODUCTION

1. Ordering Clause 1 of the Board's November 8, 2013 Order provides:

Pursuant to Iowa Code chapter 476A (2013), Interstate Power and Light Company's application to construct and operate a generating facility is granted, subject to final pre-construction permits being issued. A certificate will be issued once IPL notifies the Board that final pre-construction permits have been issued.

As of the filing of IPL's First Semi-Annual Status Report on March 3, 2014, IPL needed to obtain the following five pre-construction permits and approvals prior to issuance of the unconditional Generating Certificate:

- Iowa Department of Natural Resources (IDNR) New Source Review-Prevention of Significant Deterioration (PSD) Air Permits;

¹ IPL's fourth supplement was filed as part of its first Semi-Annual Report on March 3, 2014.

- IDNR National Pollutant Discharge Elimination System (NPDES) Stormwater Construction Permit;
- City of Marshalltown Site Review;
- City of Marshalltown Stormwater Permit for Construction; and
- City of Marshalltown Variance.

(See, First Semi-Annual Status Report, App. A, § II.) As discussed below, IPL has now received those five permits and approvals or, in the case of the site review, has received recognition that the City of Marshalltown will provide the approval. Accordingly, IPL requests herein that the Board issue an unconditional Generating Certificate.

NEW PERMITS OBTAINED

2. As part of this Request for Issuance of a Generating Certificate, IPL provides to the Board its fifth and final supplement regarding certain permitting information. IPL submits the attached permits and approvals, which are described below, as provided for in Section 2 of IPL's Application for Generating Facility Siting Certificate (Siting Application) in Docket No. GCU-2012-0001.

3. In Section 2 of its November 14, 2012, Siting Application, IPL submitted information available at that time regarding its permitting processes and progress. In Section 2.3 of that Siting Application, IPL stated that it would provide to the Board, "[i]nformation included in permits and approvals ... as it becomes available." In compliance with that statement, IPL submits the attached documents to be appended to the Siting Application as Figures 2.3-10, 2.3-11, 2.3-12, 2.3-13, and 2.3-14.

4. In Section 2.1 of the Siting Application, IPL states that a necessary state permit for the construction of MGS is a New Source Review—Prevention of

Significant Deterioration (PSD) Air Permit from the Iowa Department of Natural Resources (IDNR). The PSD program applies to new facilities sited in attainment areas, such as Marshalltown, Iowa. The PSD Air Permits are required to construct a new stationary combustion source, such as the Marshalltown Generating Station (MGS), under federal PSD program and state air quality control programs. IDNR issued the air permit for MGS on April 14, 2014. Copies of the PSD Air Permits are attached as Figure 2.3-10.

5. In Section 2.1 of the Siting Application, IPL states that another state permit that may be necessary is a NPDES Stormwater Permit for Construction Activities and Stormwater Management Plan from the IDNR. A NPDES permit is required to control pollutants in stormwater runoff from construction site activities greater than one acre. The IDNR has issued to IPL a NPDES "Notice of General Permit Coverage under General Permit No. 2" pursuant to section 402 (b) of the Clean Water Act (33 U.S.C. 1342(b)), Iowa Code 455B.174, and Iowa Administrative Code sub-rule 567--64.4(2). A copy of the NPDES Stormwater Permit and General Permit No. 2 are attached as Figure 2.3-11.

6. In Section 2.1 of the Siting Application, IPL states that a local City of Marshalltown approval process that will be required is a Site Plan Review. An overall Site Plan Review effort is necessary before the City of Marshalltown will issue permits authorizing specific construction activities, such as building permits. Upon receipt and review of the overall MGS Site Plan, the City Planner for the City of Marshalltown issued a letter to IPL, dated March 6, 2014, which stated, in part:

As you are aware, the City of Marshalltown's site plan approval process takes place concurrently with the building permit process. As such, I am unable to issue any formal site plan approval permits for the MGS at this time but rather inform you that the plans, as presented, **will be approved** at the time IPL or its designated Contractor applies for the construction permits. With the exception of the public right-of-way on East Nevada Street, which will require a public sidewalk, the plans are acceptable to this office.

(Emphasis in original.) The letter also recognizes that no additional documents or permit applications in regards to MGS project site plan or site layout are required. The letter acknowledges Marshalltown's acceptance of the MGS site arrangement and the intent to approve IPL's specific site plans for the new MGS. Given that the City of Marshalltown's Site Plan Review process is done concurrently with the building permit process, and the building permit process will be completed following commencement of construction activities (i.e. after issuance of the Generating Certificate), IPL avers that the City's letter satisfies the intent and requirement of Ordering Clause 1 of the Boards November 8, 2013 Order. A copy of the City's letter is attached as Figure 2.3-12.

7. In Table 2.2-1 of the Siting Application, IPL recognized that a local permit that may be required is a Storm Water Permit for Construction Activities. IPL has received a Construction Site Erosion and Sediment Control Permit from the City of Marshalltown, Department of Public Works. The permit was issued pursuant to City of Marshalltown Municipal Code, Article VI Erosion and Sediment Control for Construction Sites. A copy of that permit is attached as Figure 2.3-13.

8. In Table 2.2-1 of the Siting Application, IPL recognized that another local permit that may be required is a Variance Permit. IPL has received a

Variance Permit from the City of Marshalltown, allowing for the MGS building structures to be up to and including 130 feet in height. The permit was issued to address Zoning Regulations in the City of Marshalltown, which typically limit buildings in the M2 Heavy Industry district to a height of up to 100 feet. A copy of the Variance Permit is attached as Figure 2.3-14.

9. IPL intends Figures 2.3-10, 2.3-11, 2.3-12, 2.3-13, and 2.3-14 to supplement the Agency Application Information as noted in Section 2.3 of its Siting Application, with particular regard to the discussion of the IDNR PSD Air Permits and NPDES General Permit No. 2, and the City of Marshalltown Site Plan Review, Storm Water Permit for Construction Activities, and Variance Permit.

REQUEST FOR ISSUANCE OF GENERATING CERTIFICATE

10. Pursuant to Ordering Clause 1 of the Board's November 8, 2013 Order, IPL hereby notifies the Board that it has received all necessary pre-construction permits and approvals (or, in the case of the City of Marshalltown's Site Review, has received recognition that approval will be provided) for MGS. Accordingly, IPL avers that the Board's issuance of an unconditional Generating Certificate for the Marshalltown Generating Station is appropriate.

WHEREFORE, Interstate Power and Light Company respectfully requests that the Iowa Utilities Board accept Figures 2.3-10, 2.3-11, 2.3-12, 2.3-13, and 2.3-14 as the fifth and final permitting Supplement to its Siting Application.

Interstate Power and Light Company further requests the Iowa Utilities Board issue an unconditional Generating Certificate in accordance with Iowa Code Chapter 476(A) and Ordering Clause 1 of the Board's November 8, 2013 Order.

Dated this 17th day of April, 2014.

Respectfully submitted,

INTERSTATE POWER AND LIGHT
COMPANY

By: /s/ Michael S. Greiveldinger
Michael S. Greiveldinger
Senior Attorney
Alliant Energy Corporate Services, Inc.
4902 N Biltmore Lane
Madison, WI 53718
(608) 458-3318
michaelgreiveldinger@alliantenergy.com

Paula N. Johnson
Senior Attorney
Alliant Energy Corporate Services, Inc.
200 First Street S.E.
Cedar Rapids, IA 52406-0351
(319) 786-4742
paulajohnson@alliantenergy.com



STATE OF IOWA

TERRY E. BRANSTAD, GOVERNOR
KIM REYNOLDS, L.T. GOVERNOR

DEPARTMENT OF NATURAL RESOURCES
CHUCK GIPP, DIRECTOR

April 14, 2014

CERTIFIED MAIL

Alan Arnold
Interstate Power and Light
200 First Street, SE
Cedar Rapids, IA 52401-1409

Re: DNR Project Number: 13-395
Plant Number: 64-01-012

Dear Mr. Arnold:

The department has completed a review of the air construction permit application submitted and a determination has been made that the following permit(s) shall be issued:

Source Description	Control	Testing	Permit #	Misc.
1. EP 401, Turbine #1, EU 401	CO catalyst, SCR, low-NOx burner	Yes	13-A-499-P	NSPS KKKK
2. EP 402, Turbine #2, EU 402	CO catalyst, SCR, low-NOx burner	Yes	13-A-500-P	NSPS KKKK
3. EP 403, Auxiliary Boiler, EU 403	CO catalyst	Yes	13-A-501-P	NSPS Dc
4. EP 404, MGS Dew Point Heater, EU 404	NA	Yes	13-A-502-P	NSPS Dc
5. EP 405, GD Dew Point Heater, EU 405	NA	Yes	13-A-503-P	
6. EP 406, Cooling Tower, EU 406	Mist Eliminator	No	13-A-504-P	
7. EP 407, Emergency Generator, EU 407	NA	No	13-A-505-P	NSPS IIII
8. EP 408, Fire Pump Engine, EU 408	NA	No	13-A-506-P	NSPS IIII
9. EP 409, Circuit Breakers, EU 409	NA	No	13-A-507-P	
10. EP 410, CT Dew Point Heater, EU 410	NA	Yes	13-A-508-P	
11. EP 411, Fuel Oil Tank, EU 411	NA	No	13-A-509-P	
12. EP 412, Fuel Oil Tank, EU 412	NA	No	13-A-510-P	
13.				

As a result of this project the following information has been determined:


1. This project allows the construction of new turbines and associated equipment at the existing facility in Marshalltown, Iowa.
2. This facility is considered a major source for Title V. This permit may require the modification of the

- existing Title V permit. Please contact Weston Li at (515) 725-9580 if you have any questions concerning Title V.
3. This facility is considered a major source for Prevention of Significant Deterioration (PSD). This project is subject to PSD.
 4. This project is subject to New Source Performance Standards (NSPS) subpart KKKK, for Stationary Combustion Turbines, 40 CFR 60.4300 and Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (IAC 23.1(2)“yyy”). The auxiliary boiler and dew point heater #1 are subject to NSPS subpart Dc, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units; 40 CFR §60.40c – 40 CFR §60.48c. This project is also subject to NSPS subpart A, General Requirements.
 5. This project is subject to National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE NESHAP) [40 CFR Part 63, Subpart ZZZZ]. The turbines are of the source type for NESHAP subpart YYYYY for Stationary Combustion Turbines but are not subject because it is not located at a major source of HAPs. **For information only:** Several units are of the source category affected by the following federal regulations: National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart JJJJJ]. The federal rule states that gas-fired boilers, as defined in 40 CFR 63.11237, are not subject to this subpart. See section 13 for details.
 6. Emission testing is required for several units. Continuous emissions monitoring for NOx and CO is required for the turbines. See section 12 for details. If you have any questions concerning stack testing please contact Dennis Thielen at (515) 725-9545.
 7. Prior to commencing any renovation or demolition project, the facility is required to inspect the area involved for asbestos containing materials. The facility must notify the Department in writing 10 working days before initiating most asbestos removal projects and all demolition projects per 40 CFR 61.145. For further information please contact Tom Wuehr, Asbestos Coordinator at (515) 725-9576.
 8. Updates to construction permitting projects are now available at the State Permitting and Air Reporting System (SPARS). The website is located at the following address:
<http://www.dnraq.state.ia.us/>.

Please review your construction permit(s) so that you understand what is required to remain in compliance. Of particular importance are the “Operating Limits” (Section 14) and the “Operating Condition Monitoring” (Section 15). Also, attached is a copy of the “Air Quality Equipment Notification Form” to assist you in the “Notification, Reporting and Recordkeeping” (Section 8).

If you have any questions regarding this project you may contact Gary Smith, Construction Permit Engineer. His telephone number is (515) 725-9563.

Sincerely,



Gary Smith
Senior Environmental Engineer
Air Construction Permitting
Air Quality Bureau

c: Field Office: 5 (w/ attachments)
enc. Permit 13-A-499-P, 13-A-500-P, 13-A-501-P, 13-A-502-P, 13-A-503-P, 13-A-504-P, 13-A-505-P, 13-A-506-P, 13-A-507-P, 13-A-508-P, 13-A-509-P, 13-A-510-P, response to comments

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Combustion Turbine #1, 2258 mmBtu/hr (based on HHV), EU 401

Control Equipment: CO catalyst, CE OXCAT1, SCR, CE SCR1;
Low-NOx burner, CE LNB1


Emission Point: EP 401

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-499-P	13-395	Original PSD Permit	04/14/2014	Yes


 Under the Direction of the Director of
 the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 2 of 12

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 3 of 12

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 4 of 12

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 5 of 12

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 6 of 12

10a. BACT Emission Limits

The following BACT emission limits apply to Combustion Turbine #1 (EU 401).

Pollutant	Ton/yr ^{3,5}	lb/MMBtu	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	114.5	NA	2 ppm ¹	BACT
PM/ PM ₁₀ / PM _{2.5}	77.1	0.01 ²	NA	BACT
Volatile Organic Compounds (VOC)	71.2	NA	1 ppm ²	BACT
Carbon Monoxide (CO)	552.4	NA	2 ppm ¹	BACT
Sulfuric Acid Mist	31.3	0.0032 ²	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Carbon Dioxide (CO ₂)	NA	NA	951 lb CO ₂ /MW-hr (gross) ^{4,5}	BACT
Greenhouse Gas (CO ₂ e)	1,318,647	NA	NA	BACT

¹ Standard is a 30-day rolling average not including startup, shutdown and malfunction. Corrected to 15% O₂.

² Standard is the average of three test runs not including startup, shutdown and malfunction. Corrected to 15% O₂.

³ Standard is a 12-month rolling total.

⁴ Standard is a 12-month rolling average.

⁵ Standard includes all emissions, including startup, shutdown and malfunction.

10b. NSPS Emission Limits

The following NSPS emission limits apply to Combustion Turbine #1 (EU 401).

Pollutant	lb/hr	tons/yr	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	NA	15 ppm ¹	NSPS KKKK

¹ Limit of 15 ppm corrected to 15% O₂. Limit is a 30-day rolling average.

10c. Other Emission Limits

Pollutant	lb/hr	tons/yr	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.1 gr/dscf	23.3(2)a(1)
PM ₁₀	17.6 ^{1,3}	NA	NA	NAAQS
PM _{2.5}	17.6 ^{1,3}	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	4.29 ¹	NA	NA	NAAQS
Nitrogen Oxides (NO _x)	19.1 ^{2,3} 174.3 ⁴	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	11.6 ^{2,3} 3126.1 ⁴	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is monitored by CEMs.

³ Limit used in NAAQS modeling for normal operation. NO_x is a one-hour standard, CO is a 30-day rolling average.

⁴ Limit used in NAAQS modeling for start-up and shutdown. NO_x is a one-hour standard, CO is a 30-day rolling average.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 7 of 12

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	199
Discharge Style	Vertical unobstructed
Stack Opening (inches)	282
Exhaust Temperature (°F)	210
Exhaust Flowrate (scfm)	1,041,173

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 8 of 12

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	Yes	Stack test	One time
PM ₁₀	Yes	Stack test	One time
PM _{2.5}	Yes	Stack test	One time
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	Yes	CEM	Continuous
VOC	Yes	Stack test	One time
CO	Yes	CEM	Continuous
Pb	No	NA	NA
CO ₂	Yes ¹	Stack test	One time
CH ₄	Yes ¹	Stack test	One time
N ₂ O	Yes ¹	Stack test	One time
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	Yes	Stack test	One time
HAP	No	NA	NA

¹ Stack test shall be used to determine unit specific emission factors for CO₂e. Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #1 (EP 401)
13-A-499-P

Page 9 of 12

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This unit is subject to NSPS subpart KKKK, New Source Performance Standards for Stationary Combustion Turbines, 40 CFR 60.4300. This unit is also subject to NSPS subpart A, General Requirements.

This unit is of the source type for NESHAP subpart YYYY for Stationary Combustion Turbines but is not subject because it is not located at a major source of HAPs.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This turbine shall be fired by natural gas only.
- B. The sulfur content of the natural gas used in this turbine shall not exceed 20 grains per 100 standard cubic feet.
- C. The SCR shall be operated at all times during steady state operation.
- D. All existing turbines and boilers at this facility (64-01-012) shall be fired by natural gas only by the start of commercial operation of this unit.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of the sulfur content of any fuel used in this turbine.
 - B. Submit reports as required by 40 CFR 60.4375.
 - C. Maintain a record of catalyst replacement.
 - D. Maintain a record of gross electricity generated, in MW-hr. Calculate the 12-month rolling CO₂/MW-hr gross ratio.
 - E. Calculate total CO₂e emissions on a 12-month rolling basis based on unit specific emission factors and fuel usage.
-

16. Continuous Emission Monitoring

The owner or operator shall demonstrate compliance with the nitrogen oxide emission limits (both NSPS and non-NSPS) through the use of a continuous emission monitoring system (CEMS). The owner or operator shall install, calibrate, maintain, and operate a CEMS for measuring nitrogen oxides emissions discharged from the emission point to the atmosphere. The CEM shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 2 (PS2). The specifications of 40 CFR 60, Appendix F (Quality Assurance/Quality Control) shall apply. Appendix F requirements shall be supplemented with a quarterly notice to the Department with the dates of the quarterly cylinder gas audits and annual relative accuracy test audit.

Each NO_x diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO_x diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

As specified in §60.13(e)(2), during each full unit operating hour, both the NO_x monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO_x emission rate for the hour.

Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.

Each watt meter, steam flow meter, and each pressure or temperature measurement device used to calculate emission rates shall be installed, calibrated, maintained, and operated according to the QA plan described below.

The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

The owner or operator shall demonstrate compliance with the carbon monoxide emission limits through the use of a continuous emission monitoring system (CEMS). The owner or operator shall install, calibrate, maintain, and operate a CEMS for measuring carbon monoxide emissions discharged from the emission point to the atmosphere. The CEM shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 4 (PS4). The specifications of 40 CFR 60, Appendix F (Quality Assurance/Quality Control) shall apply. Appendix F requirements shall be supplemented with a quarterly notice to the Department with the dates of the quarterly cylinder gas audits and annual relative accuracy test audit.

The owner or operator shall demonstrate compliance with the NO_x and CO pound per hour emission limits through the use of a continuous flow monitoring system (flowmeter). The owner or operator shall install, calibrate, maintain, and operate a flowmeter for calculating the lb/hr emission rates of NO_x and CO discharged from the emission point to the atmosphere. The flowmeter shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 6 (PS6). Alternatively, as stated above, each fuel flowmeter can be installed, calibrated, maintained and operated according to the requirements of appendix D to part 75.

If requested by the Department, the owner/operator shall coordinate the quarterly cylinder gas audits with the Department to afford the Department the opportunity to observe these audits. The relative accuracy test audits shall be coordinated with the Department.

The procedures under 40 CFR §60.13 shall be followed for installation, evaluation, and operation of the CEMS.

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
HHV	Higher Heating Value
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants

Interstate Power and Light
Marshalltown, Iowa
tons/yr
yr

Combustion Turbine #1 (EP 401)
13-A-499-P

Tons per year
Year

Page 12 of 12

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Combustion Turbine #2, 2258 mmBtu/hr (based on HHV), EU 402

Control Equipment: CO catalyst, CE OXCAT2, SCR, CE SCR2;
Low-NOx burner, CE LNB2


Emission Point: EP 402

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-500-P	13-395	Original PSD Permit	04/14/2014	Yes


Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 2 of 12

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 3 of 12

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 4 of 12

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 5 of 12

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
 Air Quality Bureau
 Iowa Department of Natural Resources
 7900 Hickman Road, Suite 1
 Windsor Heights, IA 50324
 Telephone: (515) 725-9549
 Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
 Air Quality Bureau
 Iowa Department of Natural Resources
 7900 Hickman Road, Suite 1
 Windsor Heights, IA 50324
 Telephone: (515) 725-9545
 Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 6 of 12

10a. BACT Emission Limits

The following BACT emission limits apply to Combustion Turbine #2 (EU 402).

Pollutant	Ton/yr ^{3,5}	lb/MMBtu	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	114.5	NA	2 ppm ¹	BACT
PM/ PM ₁₀ / PM _{2.5}	77.1	0.01 ²	NA	BACT
Volatile Organic Compounds (VOC)	71.2	NA	1 ppm ²	BACT
Carbon Monoxide (CO)	552.4	NA	2 ppm ¹	BACT
Sulfuric Acid Mist	31.3	0.0032 ²	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Carbon Dioxide (CO ₂)	NA	NA	951 lb CO ₂ /MW-hr (gross) ^{4,5}	BACT
Greenhouse Gas (CO ₂ e)	1,318,647	NA	NA	BACT

¹ Standard is a 30-day rolling average not including startup, shutdown and malfunction. Corrected to 15% O₂.

² Standard is the average of three test runs not including startup, shutdown and malfunction. Corrected to 15% O₂.

³ Standard is a 12-month rolling total.

⁴ Standard is a 12-month rolling average.

⁵ Standard includes all emissions, including startup, shutdown and malfunction.

10b. NSPS Emission Limits

The following NSPS emission limits apply to Combustion Turbine #2 (EU 402).

Pollutant	lb/hr	tons/yr	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	NA	15 ppm ¹	NSPS KKKK

¹ Limit of 15 ppm corrected to 15% O₂. Limit is a 30-day rolling average.

10c. Other Emission Limits

Pollutant	lb/hr	tons/yr	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.1 gr/dscf	23.3(2)a(1)
PM ₁₀	17.6 ^{1,3}	NA	NA	NAAQS
PM _{2.5}	17.6 ^{1,3}	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	4.29 ¹	NA	NA	NAAQS
Nitrogen Oxides (NO _x)	19.1 ^{2,3} 174.3 ⁴	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	11.6 ^{2,3} 3126.1 ⁴	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is monitored by CEMs.

³ Limit used in NAAQS modeling for normal operation. NO_x is a one-hour standard, CO is a 30-day rolling average.

⁴ Limit used in NAAQS modeling for start-up and shutdown. NO_x is a one-hour standard, CO is a 30-day rolling average.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 7 of 12

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	199
Discharge Style	Vertical unobstructed
Stack Opening (inches)	282
Exhaust Temperature (°F)	210
Exhaust Flowrate (scfm)	1,041,173

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 8 of 12

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	Yes	Stack test	One time
PM ₁₀	Yes	Stack test	One time
PM _{2.5}	Yes	Stack test	One time
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	Yes	CEM	Continuous
VOC	Yes	Stack test	One time
CO	Yes	CEM	Continuous
Pb	No	NA	NA
CO ₂	Yes ¹	Stack test	One time
CH ₄	Yes ¹	Stack test	One time
N ₂ O	Yes ¹	Stack test	One time
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	Yes	Stack test	One time
HAP	No	NA	NA

¹ Stack test shall be used to determine unit specific emission factors for CO₂e. Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Combustion Turbine #2 (EP 402)
13-A-500-P

Page 9 of 12

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This unit is subject to NSPS subpart KKKK, New Source Performance Standards for Stationary Combustion Turbines, 40 CFR 60.4300. This unit is also subject to NSPS subpart A, General Requirements.

This unit is of the source type for NESHAP subpart YYYY for Stationary Combustion Turbines but is not subject because it is not located at a major source of HAPs.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This turbine shall be fired by natural gas only.
- B. The sulfur content of the natural gas used in this turbine shall not exceed 20 grains per 100 standard cubic feet.
- C. The SCR shall be operated at all times during steady state operation.
- D. All existing turbines and boilers at this facility (64-01-012) shall be fired by natural gas only by the start of commercial operation of this unit.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of the sulfur content of any fuel used in this turbine.
 - B. Submit reports as required by 40 CFR 60.4375.
 - C. Maintain a record of catalyst replacement.
 - D. Maintain a record of gross electricity generated, in MW-hr. Calculate the 12-month rolling CO₂/MW-hr gross ratio.
 - E. Calculate total CO₂e emissions on a 12-month rolling basis based on unit specific emission factors and fuel usage.
-

16. Continuous Emission Monitoring

The owner or operator shall demonstrate compliance with the nitrogen oxide emission limits (both NSPS and non-NSPS) through the use of a continuous emission monitoring system (CEMS). The owner or operator shall install, calibrate, maintain, and operate a CEMS for measuring nitrogen oxides emissions discharged from the emission point to the atmosphere. The CEM shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 2 (PS2). The specifications of 40 CFR 60, Appendix F (Quality Assurance/Quality Control) shall apply. Appendix F requirements shall be supplemented with a quarterly notice to the Department with the dates of the quarterly cylinder gas audits and annual relative accuracy test audit.

Each NO_x diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO_x diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

As specified in §60.13(e)(2), during each full unit operating hour, both the NO_x monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO_x emission rate for the hour.

Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.

Each watt meter, steam flow meter, and each pressure or temperature measurement device used to calculate emission rates shall be installed, calibrated, maintained, and operated according to the QA plan described below.

The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

The owner or operator shall demonstrate compliance with the carbon monoxide emission limits through the use of a continuous emission monitoring system (CEMS). The owner or operator shall install, calibrate, maintain, and operate a CEMS for measuring carbon monoxide emissions discharged from the emission point to the atmosphere. The CEM shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 4 (PS4). The specifications of 40 CFR 60, Appendix F (Quality Assurance/Quality Control) shall apply. Appendix F requirements shall be supplemented with a quarterly notice to the Department with the dates of the quarterly cylinder gas audits and annual relative accuracy test audit.

The owner or operator shall demonstrate compliance with the NO_x and CO pound per hour emission limits through the use of a continuous flow monitoring system (flowmeter). The owner or operator shall install, calibrate, maintain, and operate a flowmeter for calculating the lb/hr emission rates of NO_x and CO discharged from the emission point to the atmosphere. The flowmeter shall be installed, evaluated, operated and data collected to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 6 (PS6). Alternatively, as stated above, each fuel flowmeter can be installed, calibrated, maintained and operated according to the requirements of appendix D to part 75.

If requested by the Department, the owner/operator shall coordinate the quarterly cylinder gas audits with the Department to afford the Department the opportunity to observe these audits. The relative accuracy test audits shall be coordinated with the Department.

The procedures under 40 CFR §60.13 shall be followed for installation, evaluation, and operation of the CEMS.

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
HHV	Higher Heating Value
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants

Interstate Power and Light
Marshalltown, Iowa
tons/yr
yr

Combustion Turbine #2 (EP 402)
13-A-500-P

Tons per year
Year

Page 12 of 12

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Auxiliary Boiler, 60.1 mmBtu/hr, EU 403

Control Equipment: CO oxidation catalyst, CE OXCAT3

Emission Point: EP 403

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-501-P	13-395	Original PSD Permit	04/14/2014	Yes

[Redacted Signature]

Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 2 of 10

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 3 of 10

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 4 of 10

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 5 of 10

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 6 of 10

10a. BACT Emission Limits

The following BACT emission limits apply to the Auxiliary Boiler (EU 403) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr ¹	lb/MMBtu ¹	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	0.013	NA	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	0.008	NA	BACT
Volatile Organic Compounds (VOC)	NA	0.005	NA	BACT
Carbon Monoxide (CO)	NA	0.0164	NA	BACT
Sulfuric Acid Mist	0.0055	NA	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	17,313 tpy ²	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	0.53 ⁴	NA	NA	NAAQS
PM _{2.5}	0.53 ⁴	NA	NA	NAAQS
Opacity	NA	NA	40% ³	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.04 ⁴	NA	500 ppm	23.3(3)e
Nitrogen Oxides (NO _x)	0.85 ⁴	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	2.7 ⁴	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ An exceedance of the indicator opacity of **no visible emissions** will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

⁴ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	140
Discharge Style	Vertical unobstructed
Stack Opening (inches)	37
Exhaust Temperature (°F)	305
Exhaust Flowrate (scfm)	12,700

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	Yes	Stack test	One time
PM ₁₀	Yes	Stack test	One time
PM _{2.5}	Yes	Stack test	One time
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	Yes	Stack test	One time
VOC	No	NA	NA
CO	Yes	Stack test	One time
Pb	No	NA	NA
CO ₂	Yes ¹	Stack test	One time
CH ₄	Yes ¹	Stack test	One time
N ₂ O	Yes ¹	Stack test	One time
CO _{2e}	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

¹ Stack test shall be used to determine unit specific emission factors for CO_{2e}. Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, IowaAuxiliary Boiler (EP 403)
13-A-501-P

Page 8 of 10

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

**13. New Source Performance Standards (NSPS) and
National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability**

This emission unit is subject to Subparts A (*General Provisions*; 40 CFR §60.1 – 40 CFR §60.19) and Dc (*Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units*; 40 CFR §60.40c – 40 CFR §60.48c) of the New Source Performance Standards (NSPS).

For information only: This boiler (EU-403) is of the source category affected by the following federal regulations: National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart JJJJJ]. The federal rule states that gas-fired boilers, as defined in 40 CFR 63.11237, are not subject to this subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This boiler shall be fired by natural gas only.
- B. The amount of fuel fired in this boiler shall not exceed 288.7 million cubic feet per 12-month rolling period.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Per 40 CFR §60.49c(d)(1), the owner or operator shall record and maintain records of the amount of each fuel combusted during each operating day.
- B. Record the amount of fuel fired in this boiler, in cubic feet. Calculate and record monthly and 12-month rolling totals.
- C. Maintain a record of catalyst replacement.
- D. Calculate total CO_{2e} emissions on a 12-month rolling basis based on unit specific emission factors and fuel usage.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

Interstate Power and Light
Marshalltown, Iowa

Auxiliary Boiler (EP 403)
13-A-501-P

Page 10 of 10

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): MGS Dew Point Heater #1, 13.32 mmBtu/hr; EU 404

Control Equipment: NA


Emission Point: EP 404

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-502-P	13-395	Original PSD Permit	04/14/2014	Yes


Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 2 of 9

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"P", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 3 of 9

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light MGS Dew Point Heater #1 (EP 404)
Marshalltown, Iowa 13-A-502-P

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the MGS Dew Point Heater #1 (EU 404) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr ¹	lb/MMBtu ¹	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	0.013	NA	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	0.008	NA	BACT
Volatile Organic Compounds (VOC)	NA	0.005	NA	BACT
Carbon Monoxide (CO)	NA	0.041	NA	BACT
Sulfuric Acid Mist	0.0007	NA	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	6860 tpy ^{2,3}	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

³ Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	0.12 ³	NA	NA	NAAQS
PM _{2.5}	0.12 ³	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.008 ³	NA	500 ppm	23.3(3)e
Nitrogen Oxides (NO _x)	0.19 ³	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	0.61 ³	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

⁴ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	15
Discharge Style	Vertical unobstructed
Stack Opening (inches)	12
Exhaust Temperature (°F)	919
Exhaust Flowrate (scfm)	1358

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	Na	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is subject to Subparts A (*General Provisions*; 40 CFR §60.1 – 40 CFR §60.19) and Dc (*Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units*; 40 CFR §60.40c – 40 CFR §60.48c) of the New Source Performance Standards (NSPS).

For information only: This unit (EU-404) is of the source category affected by the following federal regulations: National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart JJJJJ]. The federal rule states that gas-fired boilers, as defined in 40 CFR 63.11237, are not subject to this subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall be fired by natural gas only.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of the sulfur content of any fuel used in this unit.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

MGS Dew Point Heater #1 (EP 404)
13-A-502-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager


2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Gas Distribution Dew Point Heater #2, 4 mmBtu/hr, EU 405
Control Equipment: NA
Emission Point: EP 405
Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158
Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-503-P	13-395	Original PSD Permit	04/14/2014	Yes


Under the Direction of the Director of
the Department of Natural Resources

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 5 of 9

8. Notification, Reporting, and Recordkeeping (Continued)

(5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;

C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)

D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the Gas Distribution Dew Point Heater #2 (EU 405) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu ¹	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	0.013	NA	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	0.008	NA	BACT
Volatile Organic Compounds (VOC)	NA	0.005	NA	BACT
Carbon Monoxide (CO)	NA	0.041	NA	BACT
Sulfuric Acid Mist	0.0004	NA	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	2060 tpy ^{2,3}	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

³ Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	0.03 ³	NA	NA	NAAQS
PM _{2.5}	0.03 ³	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.0024 ³	NA	500 ppm	23.3(3)e
Nitrogen Oxides (NO _x)	0.06 ³	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	0.16 ³	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	15
Discharge Style	Vertical unobstructed
Stack Opening (inches)	14
Exhaust Temperature (°F)	325
Exhaust Flowrate (scfm)	1921

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO _{2e}	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is not subject to Subparts A (*General Provisions*; 40 CFR §60.1 – 40 CFR §60.19) and Dc (*Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units*; 40 CFR §60.40c – 40 CFR §60.48c) of the New Source Performance Standards (NSPS) because it is less than 10 mmBtu/hr heat input.

For information only: This unit (EU-405) is of the source category affected by the following federal regulations: National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart JJJJJ]. The federal rule states that gas-fired boilers, as defined in 40 CFR 63.11237, are not subject to this subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall be fired by natural gas only.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of the sulfur content of any fuel used in this unit.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light Gas Distribution Dew Point Heater #2 (EP 405)
Marshalltown, Iowa 13-A-503-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Cooling Tower (8 cells), 160,000 gallons per minute, EU 406

Control Equipment: Mist Eliminator, 0.0005%

Emission Point: EP 406

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-504-P	13-395	Original PSD Permit	04/14/2014	No

Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 2 of 9

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 3 of 9

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 5 of 9

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the Cooling Tower (EU 406) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Opacity	NA	NA	No visible emissions	BACT
PM/ PM ₁₀ / PM _{2.5}	1.2 ¹	NA	NA	BACT

¹ Standard is the average of three test runs. Limit is for all cooling tower cells combined.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.1 gr/dscf	23.3(2)a(1)
PM ₁₀	1.2 ³	NA	NA	NAAQS
PM _{2.5}	1.2 ³	NA	NA	NAAQS
Opacity	NA	NA	40% ³	23.3(2)"d"
Sulfur Dioxide (SO ₂)	NA	NA	NA	NA
Nitrogen Oxides (NO _x)	NA	NA	NA	NA
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	NA	NA	NA	NA
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit used in NAAQS modeling. Limit is for all cooling tower cells combined.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	46
Discharge Style	Vertical unobstructed
Stack Opening (inches)	396 (each cell)
Exhaust Temperature (°F)	105.5
Exhaust Flowrate (scfm)	11,158,400 (total)

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	Yes	TDS sampling	Once per quarter
PM _{2.5}	No	NA	NA
Opacity	No	NA	NA
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is not subject to New Source Performance Standards (NSPS) because there is no applicable subpart.

This emission unit is not subject to National Emission Standards for Hazardous Air Pollutants (NESHAP) because there is no applicable subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall not use chromium based water treatment chemicals.
- B. The total dissolved solids (TDS) content of the water in this cooling tower shall not exceed 3000 ppm.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of any water treatment chemicals used in this unit.
- B. Monitor the TDS content by sampling at least once per calendar quarter.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

Cooling Tower (EP 406)
13-A-504-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Emergency Generator, 2500kW, EU 407

Control Equipment: NA

Emission Point: EP 407

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-505-P	13-395	Original PSD Permit	04/14/2014	No

Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 2 of 10

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 4 of 10

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"F", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 5 of 10

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 6 of 10

10a. BACT Emission Limits

The following BACT emission limits apply to the Emergency Generator (EU 407) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	NA	6.4 grams/kW-hr ³	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	NA	0.20 grams/kW-hr ³	BACT
Volatile Organic Compounds (VOC)	NA	NA	0.32 g/hp-hr ¹	BACT
Carbon Monoxide (CO)	NA	NA	3.5 grams/kW-hr ³	BACT
Sulfuric Acid Mist	NA	NA	0.0003 tpy ²	BACT
Opacity	NA	NA	20/15/50% ³	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	145.3 tpy ^{2,4}	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

³ See section 13.

⁴ Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	1.2 ³	NA	NA	NAAQS
PM _{2.5}	1.2 ³	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.041 ³	NA	NA	NAAQS
Nitrogen Oxides (NO _x)	38.8 ³	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	21.2 ³	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	125
Discharge Style	Vertical unobstructed
Stack Opening (inches)	13
Exhaust Temperature (°F)	800
Exhaust Flowrate (scfm)	6705

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	Yes	Engine certification	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	Yes	Engine certification	NA
SO ₂	No	NA	NA
NO _x	Yes	Engine certification	NA
VOC	No	NA	NA
CO	Yes	Engine certification	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 8 of 10

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. NSPS and NESHAP Applicability

- A. This engine is subject to 40 CFR Part 60 NSPS Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (IAC 23.1(2)"yyy"). The engine is an emergency stationary internal combustion engine that is not a fire pump engine.
 - i. In accordance with §60.4211(c), the engine must be certified by its manufacturer to comply with the emissions standards from §60.4205 (b) and §60.4202 (a)(2). The emission standards that the engine must be certified by the manufacturer to meet are:

Pollutant	Emission Standard	Basis
Particulate Matter (PM)	0.20 grams/kW-hr	§ 89.112 Table 1
NMHC ¹ + NOx	6.4 grams/kW-hr	§ 89.112 Table 1
Carbon Monoxide (CO)	3.5 grams/kW-hr	§ 89.112 Table 1
Opacity – acceleration mode	20%	§ 89.113 (a)(1)
Opacity – lugging mode	15%	§ 89.113 (a)(2)
Opacity – peaks in acceleration or lugging modes	50%	§ 89.113 (a)(3)

¹ Non-methane hydrocarbon

- ii. In accordance with §60.4211(c), the owner or operator must comply with the required NSPS emissions standards by purchasing an engine certified by its manufacturer to meet the applicable emission standards for the same model year and engine power. The engine must be installed and configured to the manufacturer's specifications. Provided these requirements are satisfied, no further demonstration of compliance with the emission standards from §60.4205 (b) and §60.4202 (a)(2) is required.

This unit is subject to National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE NESHAP) [40 CFR Part 63, Subpart ZZZZ]. Complying with NSPS subpart IIII is considered compliance with NESHAP subpart ZZZZ.

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 9 of 10

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall be fired by diesel fuel only.
 - B. The number of hours this unit is operated for maintenance and testing shall not exceed 100 hours per 12-month rolling period.
 - C. The sulfur content of any fuel used in this unit shall not exceed 15 ppm.
 - D. The cetane index of any fuel used in this unit shall not be less than 40.
 - E. The aromatic content of any fuel used in this unit shall not exceed 35% by volume.
-

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Record the number of hours this unit is operated. Calculate and record monthly and 12-month rolling totals.
 - B. Maintain a record of the sulfur content of any fuel used in this unit.
 - C. Maintain a record of the cetane index and aromatic content of any fuel used in this unit.
-

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

Emergency Generator (EP 407)
13-A-505-P

Page 10 of 10

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Fire Pump Engine, 282 HP, EU 408

Control Equipment: NA

Emission Point: EP 408

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-506-P	13-395	Original PSD Permit	04/14/2014	No

Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 2 of 10

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "Maintenance and Repair".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 3 of 10

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 4 of 10

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

A. The owner or operator shall furnish the Department the following written notifications:

- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
- (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
- (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

B. The owner or operator shall furnish the Department with the following reports:

- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
- (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
- (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
- (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 5 of 10

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 6 of 10

10a. BACT Emission Limits

The following BACT emission limits apply to the Fire Pump Engine (EU 408) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	NA	4.0 grams/kW-hr	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	NA	0.20 grams/kW-hr	BACT
Volatile Organic Compounds (VOC)	NA	NA	1.14 g/hp-hr	BACT
Carbon Monoxide (CO)	NA	NA	3.5 grams/kW-hr	BACT
Sulfuric Acid Mist	NA	NA	0.001 tpy ²	BACT
Opacity	NA	NA	20/15/50% ³	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	18 tpy ^{2,4}	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

³ See section 13.

⁴ Global warming potential for N₂O shall be 298 and for CH₄ shall be 25.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	0.10 ³	NA	NA	NAAQS
PM _{2.5}	0.10 ³	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.17 ³	NA	NA	NAAQS
Nitrogen Oxides (NO _x)	2.10 ³	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	1.80 ³	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	12
Discharge Style	Vertical unobstructed
Stack Opening (inches)	6
Exhaust Temperature (°F)	961
Exhaust Flowrate (scfm)	615

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	Yes	Engine certification	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	Yes	Engine certification	NA
SO ₂	No	NA	NA
NO _x	Yes	Engine certification	NA
VOC	No	NA	NA
CO	Yes	Engine certification	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 8 of 10

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. NSPS and NESHAP Applicability

- A. This engine is subject to 40 CFR Part 60 NSPS Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (IAC 23.1(2)"yyy"). The engine is a stationary internal combustion engine that is a fire pump engine.
 - i. In accordance with §60.4211(c), the engine must be certified by its manufacturer to comply with the emissions standards from §60.4205 (b) and §60.4202 (a)(2). The emission standards that the engine must be certified by the manufacturer to meet are:

Pollutant	Emission Standard	Basis
Particulate Matter (PM)	0.20 grams/kW-hr	§ 89.112 Table 1
NMHC ¹ + NOx	4.0 grams/kW-hr	§ 89.112 Table 1
Carbon Monoxide (CO)	3.5 grams/kW-hr	§ 89.112 Table 1
Opacity – acceleration mode	20%	§ 89.113 (a)(1)
Opacity – lugging mode	15%	§ 89.113 (a)(2)
Opacity – peaks in acceleration or lugging modes	50%	§ 89.113 (a)(3)

¹ Non-methane hydrocarbon

- ii. In accordance with §60.4211(c), the owner or operator must comply with the required NSPS emissions standards by purchasing an engine certified by its manufacturer to meet the applicable emission standards for the same model year and engine power. The engine must be installed and configured to the manufacturer's specifications. Provided these requirements are satisfied, no further demonstration of compliance with the emission standards from §60.4205 (b) and §60.4202 (a)(2) is required.

This unit is subject to National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE NESHAP) [40 CFR Part 63, Subpart ZZZZ]. Complying with NSPS subpart IIII is considered compliance with NESHAP subpart ZZZZ.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 9 of 10

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall be fired by diesel fuel only.
 - B. The number of hours this unit is operated for maintenance and testing shall not exceed 100 hours per 12-month rolling period.
 - C. The sulfur content of any fuel used in this unit shall not exceed 15 ppm.
 - D. The cetane index of any fuel used in this unit shall not be less than 40.
 - E. The aromatic content of any fuel used in this unit shall not exceed 35% by volume.
-

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Record the number of hours this unit is operated. Calculate and record monthly and 12-month rolling totals.
 - B. Maintain a record of the sulfur content of any fuel used in this unit.
 - C. Maintain a record of the cetane index and aromatic content of any fuel used in this unit.
-

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Engine (EP 408)
13-A-506-P

Page 10 of 10

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Circuit Breakers, (12-345 kV, 2-18 kV), EU 409

Control Equipment: NA

Emission Point: EP 409

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-507-P	13-395	Original PSD Permit	04/14/2014	No

Under the Direction of the Director of
the Department of Natural Resources

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "Maintenance and Repair".

3. Transferability

As limited by 567 IAC 22.3(3)"f", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

A. The owner or operator shall furnish the Department the following written notifications:

- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
- (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
- (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

B. The owner or operator shall furnish the Department with the following reports:

- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
- (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
- (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
- (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 5 of 9

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9550
Fax: (515) 725-9502

Field Office 5
7900 Hickman Road, Suite 200
Windsor Heights, Iowa 50324
Phone: 515.725.0268
FAX: 515.725.0268

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director
Iowa Department of Natural Resources
502 East 9th Street
Des Moines, IA 50319

Bureau Chief
Legal Services Bureau
Iowa Department of Natural Resources
502 East 9th Street
Des Moines, IA 50319

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the Circuit Breakers (EU 409) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Sulfur Hexafluoride (SF ₆)	NA	NA	0.5% loss per year ¹	BACT

¹ Standard is based on a calendar year.

10b. Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	NA	NA
PM ₁₀	NA	NA	NA	NA
Opacity	NA	NA	NA	NA
Sulfur Dioxide (SO ₂)	NA	NA	NA	NA
Nitrogen Oxides (NO _x)	NA	NA	NA	NA
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	NA	NA	NA	NA
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	NA
Discharge Style	NA
Stack Opening (inches)	NA
Exhaust Temperature (°F)	NA
Exhaust Flowrate (scfm)	NA

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	No	NA	NA
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfur Hexafluoride (SF ₆)	Yes	Mass balance	Annual
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner's authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner's authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner's authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is not subject to New Source Performance Standards (NSPS) because there is no applicable subpart.

This emission unit is not subject to National Emission Standards for Hazardous Air Pollutants (NESHAP) because there is no applicable subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. Operate and maintain these units to minimize emissions of SF₆.
- B. Develop and implement a written leak detection and repair (LDAR) program for switches containing SF₆ that are owned by Interstate Power and Light and are part of this project.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of any SF₆ replenished in these units. Calculate and record the percentage of SF₆ replenished on an annual basis.
- B. Record the results of the LDAR program.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

Circuit Breakers (EP 409)
13-A-507-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Marshalltown CT Dew Point Heater #3, 5 mmBtu/hr, EU 410

Control Equipment: NA

Emission Point: EP 410

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-508-P	13-395	Original PSD Permit	04/14/2014	Yes

Under the Direction of the Director of
the Department of Natural Resources

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

Page 3 of 9

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

A. The owner or operator shall furnish the Department the following written notifications:

- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
- (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
- (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

B. The owner or operator shall furnish the Department with the following reports:

- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
- (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
- (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
- (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

Page 5 of 9

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the Dew Point Heater #3 (EU 410) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr ¹	lb/MMBtu ¹	Additional Limits	Reference (567 IAC)
Nitrogen Oxides (NO _x)	NA	0.013	NA	BACT
PM/ PM ₁₀ / PM _{2.5}	NA	0.008	NA	BACT
Volatile Organic Compounds (VOC)	NA	0.005	NA	BACT
Carbon Monoxide (CO)	NA	0.041	NA	BACT
Sulfuric Acid Mist	0.0005	NA	NA	BACT
Opacity	NA	NA	No visible emissions	BACT
Greenhouse Gas (CO ₂ e)	NA	NA	2574 tpy ²	BACT

¹ Standard is the average of three test runs.

² Standard is a 12-month rolling total.

10b. Other Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	0.6 lb/mmBtu	23.3(2)b(3)
PM ₁₀	0.04 ³	NA	NA	NAAQS
PM _{2.5}	0.04 ³	NA	NA	NAAQS
Opacity	NA	NA	40%	23.3(2)"d"
Sulfur Dioxide (SO ₂)	0.003 ³	NA	500 ppm	23.3(3)e
Nitrogen Oxides (NO _x)	0.07 ³	NA	NA	NAAQS
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	0.21 ³	NA	NA	NAAQS
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

³ Limit used in NAAQS modeling.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	15
Discharge Style	Vertical unobstructed
Stack Opening (inches)	14
Exhaust Temperature (°F)	325
Exhaust Flowrate (scfm)	1921

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	Yes	Observation	One time
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is not subject to Subparts A (*General Provisions*; 40 CFR §60.1 – 40 CFR §60.19) and Dc (*Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units*; 40 CFR §60.40c – 40 CFR §60.48c) of the New Source Performance Standards (NSPS) because it is less than 10 mmBtu/hr heat input.

For information only: This boiler (EU-403) is of the source category affected by the following federal regulations: National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial and Institutional Boilers and Process Heaters [40 CFR Part 63 Subpart JJJJJ]. The federal rule states that gas-fired boilers, as defined in 40 CFR 63.11237, are not subject to this subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This unit shall be fired by natural gas only.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

- A. Maintain a record of the sulfur content of any fuel used in this unit.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light Marshalltown CT Dew Point Heater #3 (EP 410)
Marshalltown, Iowa 13-A-508-P

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company – Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): Fire Pump Fuel Oil Tank #1, 300 gallons, EU 411

Control Equipment: NA

Emission Point: EP 411

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-509-P	13-395	Original PSD Permit	04/14/2014	No

Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 2 of 9

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "Maintenance and Repair".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 3 of 9

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

- A. The owner or operator shall furnish the Department the following written notifications:
- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
 - (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
 - (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

- B. The owner or operator shall furnish the Department with the following reports:
- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
 - (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
 - (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
 - (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 5 of 9

8. Notification, Reporting, and Recordkeeping (Continued)

(5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;

C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)

D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

10a. BACT Emission Limits

The following BACT emission limits apply to the Fire Pump Fuel Oil Tank #1(EU 411) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Volatile Organic Compounds (VOC)	NA	NA	4 x 10 ⁻⁵ ton/year ¹	BACT

¹ Standard is a 12-month rolling total.

10. Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	NA	NA
PM ₁₀	NA	NA	NA	NA
Opacity	NA	NA	NA	NA
Sulfur Dioxide (SO ₂)	NA	NA	NA	NA
Nitrogen Oxides (NO _x)	NA	NA	NA	NA
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	NA	NA	NA	NA
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	10
Discharge Style	NA
Stack Opening (inches)	NA
Exhaust Temperature (°F)	NA
Exhaust Flowrate (scfm)	Breathing losses

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	No	NA	NA
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light Fire Pump Fuel Oil Tank #1 (EP 411)
Marshalltown, Iowa 13-A-509-P

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

**13. New Source Performance Standards (NSPS) and
National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability**

This emission unit is not subject to New Source Performance Standards (NSPS) subpart Kb because the maximum true vapor pressure of the stored liquid is less than 3.5 kPa.

This emission unit is not subject to National Emission Standards for Hazardous Air Pollutants (NESHAP) because there is no applicable subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This tank shall be used to store fuel oil #1 or fuel oil #2 only.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

There are no monitoring requirements at this time.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

Fire Pump Fuel Oil Tank #1 (EP 411)
13-A-509-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT

Iowa Department of Natural Resources Air Quality PSD Construction Permit

Permit Holder

Firm: Interstate Power and Light Company -- Marshalltown Generating Station

Contact:

Alan Arnold

319-786-4476

200 First Street
Cedar Rapids, IA 52401-1409

Responsible Party:

Craig Crawford
Plant Manager

2115 East Nevada Street
Marshalltown, IA 50158

Permitted Equipment

Emission Unit(s): EDG Fuel Oil Tank #2, 3500 gallons, EU 412

Control Equipment: NA


Emission Point: EP 412

Equipment Location: 2115 East Nevada Street
Marshalltown, IA 50158

Plant Number: 64-01-012

Issuance of this permit shall not relieve the owner or operator of the responsibility to comply fully with applicable provisions of the State Implementation Plan (SIP), and any other requirements of local, state, and federal law.

Permit No.	Proj. No.	Description	Date	Stack Testing
13-A-510-P	13-395	Original PSD Permit	04/14/2014	No


Under the Direction of the Director of
the Department of Natural Resources

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 2 of 9

PERMIT CONDITIONS

1. Departmental Review

This permit is issued based on information submitted by the applicant. Any misinformation, false statements or misrepresentations by the applicant or by the applicant's representative(s) shall cause this permit to be void. In addition, the applicant may be subject to criminal penalties according to Iowa Code Section 455B.146A.

This permit is issued under the authority of 567 Iowa Administrative Code (IAC) 22.3. The proposed equipment has been evaluated for conformance with Iowa Code Chapter 455B; 567 IAC Chapters 20 – 35; and 40 Code of Federal Regulations (CFR) Parts 51, 52, 60, 61, and 63 and has the potential to comply.

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. The Department assumes no liability, directly or indirectly, for any loss due to damage to persons or property caused by, resulting from, or arising out of the design, installation, maintenance or operation of the proposed equipment.

2. Owner and Operator Responsibility

This permit is for the construction and operation of specific emission unit(s), control equipment, and emission point as described in this permit and in the application for this permit. The permit holder, owner, and operator of the facility shall assure that the installation of the equipment listed in this permit conforms to the design in the application (i.e. type, maximum rated capacity, etc.). No person shall construct, install, reconstruct or alter this emission unit(s), control equipment, or emission point without the required amended permit.

Any owner or operator of the specified emission unit(s), control equipment, or emission point, including any person who becomes an owner or operator subsequent to the date on which this permit is issued, is responsible for assuring that the installation, operation, and maintenance of the equipment listed in this permit is in compliance with the provisions of this permit and all other applicable requirements.

The owner or operator of any emission unit or control equipment shall maintain and operate the equipment and control equipment at all times in a manner consistent with good practice for minimizing emissions, as required by paragraph 567 IAC 24.2(1) "*Maintenance and Repair*".

3. Transferability

As limited by 567 IAC 22.3(3)"F", this permit is not transferable from one location to another or from one piece of equipment to another, unless the equipment is portable. When portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified in writing at least seven (7) days prior to transferring to the new location unless the equipment will be located in an area which is classified as nonattainment for the National Ambient Air Quality Standards (NAAQS) or is a maintenance area for the NAAQS in which case notification shall be given fourteen (14) days prior to the relocation of equipment¹ (See Permit Condition 8.A.2). The owner or operator will be notified at least ten (10) days prior to the scheduled relocation if the relocation will cause a violation of the (NAAQS). In such case, a supplemental permit shall be required prior to the initiation of construction of additional control equipment or modifications to equipment needed to meet the standards.

¹ A list of nonattainment areas and maintenance areas for the NAAQS can be obtained from the Department.

4. Construction

A. General Requirements

It is the owner's responsibility to ensure that construction conforms to the final plans and specifications as submitted, and that adequate operation and maintenance is provided to ensure that no condition of air pollution is created.

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 3 of 9

4. Construction (Continued)

In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. If a proposed project is not timely completed, the owner or operator shall seek a permit amendment in order to revert back to the most recent previous version of the permit. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

This permit or amendment shall become void if any one of the following conditions occurs:

- (1) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not initiated within eighteen (18) months after the permit issuance date; or
- (2) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within forty-eight (48) months after the permit issuance date; or
- (3) the construction or implementation of the proposed project, as it affects the emission point permitted herein, is not completed within a time period specified elsewhere in this permit.

B. Changes to Plans and Specifications

The owner or operator shall amend this permit or amendment prior to startup of the equipment if:

- (1) Any changes are made to the final plans and specifications submitted for the proposed project; or
- (2) This permit becomes void.

Changes to the final plans and specification shall include changes to plans and specifications for permitted equipment and control equipment and the specified operation thereof.

C. Amended Permits

The owner or operator may continue to act under the provisions of the previous permit for the affected emission unit(s) and emission point, together with any previous amendment to the permit, until one of the following conditions occurs:

- (1) The proposed project authorized by this amendment is completed as it affects the emission unit(s) and emission point permitted herein; or
- (2) This current amendment becomes void.

5. Credible Evidence

As stated in 567 IAC 21.5 and also in 40 CFR Part §60.11(g), where applicable, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions specified in this permit or any provisions of 567 IAC Chapters 20 through 35.

6. Excess Emissions

Per 567 IAC 24.1(1), excess emissions during a period of startup, shutdown, or cleaning of control equipment are not a violation of the emission standard if it is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions except when another regulation applicable to the unit or process provides otherwise. Cleaning of control equipment, which does not require the shutdown of process equipment, shall be limited to one (1) six-minute period per one (1) hour period.

An incident of excess emissions other than the above is a violation and may be subject to criminal penalties according to Iowa Code 455B.146A. If excess emissions are occurring, either the control equipment causing the excess shall be repaired in an expeditious manner, or the process generating the emissions shall be shutdown within a reasonable period of time, as specified in 567 IAC 24.1.

An incident of excess emissions shall be orally reported by telephone, electronic mail or in person to the appropriate field office within eight (8) hours of, or at the start of, the first working day following the onset of the incident (See Permit Condition 8.B.1). A written report of an incident of excess emissions shall be submitted as a follow-up to all required initial reports within seven (7) days of the onset of the upset condition (See Permit Condition 8.B.2).

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 4 of 9

7. Permit Violations

Knowingly committing a violation of this permit may carry a criminal penalty of up to \$10,000 per day fine and two (2) years in jail according to Iowa Code Section 455B.146A.

8. Notification, Reporting, and Recordkeeping

A. The owner or operator shall furnish the Department the following written notifications:

- (1) Per 567 IAC 22.3(3)"b":
 - (a) The date construction, installation, or alteration is initiated postmarked within thirty (30) days following initiation of construction, installation, or alteration;
 - (b) The actual date of startup, postmarked within fifteen (15) days following the start of operation;
- (2) Per 567 IAC 22.3(3)"f", when portable equipment for which a permit has been issued is to be transferred from one location to another, the Department shall be notified:
 - (a) at least fourteen (14) days before equipment relocation if the equipment will be located in a nonattainment area for the National Ambient Air Quality Standards (NAAQS) or a maintenance area for the NAAQS;
 - (b) at least seven (7) days before equipment relocation.
- (3) Per 567 IAC 22.3(8), a new owner shall notify the Department of the transfer of equipment ownership within thirty (30) days of the occurrence. The notification shall be mailed to:

Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324

and include the following information:

- The date of ownership change,
 - The name, address, and telephone number of the responsible official, the contact person, and the owner of the equipment both before and after the ownership change; and
 - The construction permit number(s) of the equipment changing ownership.
- (4) Unless specified per a federal regulation, notification of each compliance test required by Permit Condition 12 shall be done not less than thirty (30) days before the required test or performance evaluation of a continuous emission monitor [567 IAC 25.1(7)]. The notification shall include:
- the time,
 - the place,
 - the name of the person who will conduct the tests,
 - and other information as required by the Department;

If the owner or operator does not provide timely notice to the Department, the Department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with the applicable rules or permit conditions. Upon written request, the Department may allow a notification period of less than thirty (30) days.

B. The owner or operator shall furnish the Department with the following reports:

- (1) Per 567 IAC 24.1(2), an incident of excess emissions as defined in 567 IAC 20.2 shall be reported within eight (8) hours or at the start of the first working day following the onset of the incident. The report may be made by electronic mail, in person or by telephone.
- (2) Per 567 IAC 24.1(3), a written report of an incident of excess emissions as defined in 567 IAC 20.2 shall be submitted as a follow-up to all required initial reports to the Department within seven (7) days of the onset of the upset condition.
- (3) Operation of this emission unit(s) or control equipment outside of those operating parameters specified in Permit Condition 14 in accordance to the schedule set forth in 567 IAC 24.1.
- (4) Per 567 IAC 25.1(6), the owner or operator of any facility required to install a continuous monitoring system or systems shall provide quarterly reports to the Director, no later than thirty (30) calendar days following the end of the calendar quarter, on forms provided by the Director.

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

8. Notification, Reporting, and Recordkeeping (Continued)

- (5) Per 567 IAC 25.1(7), a written compliance demonstration report for each compliance testing event, whether successful or not, postmarked not later than six (6) weeks after the completion of the test period unless other regulations provide for other notification requirements. In that case, the more stringent reporting requirement shall be met;
- C. All data, records, reports, documentation, construction plans, and calculations required under this permit shall be available at the plant during normal business hours for inspection and copying by federal, state, or local air pollution regulatory agencies and their authorized representatives, for a minimum of two (2) years from the date of recording unless otherwise required by another applicable law (i.e. NSPS, NESHAP, etc.)
- D. The owner or operator shall send correspondence regarding this permit to the following address:

Construction Permit Supervisor
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9549
Fax: (515) 725-9501

- E. The owner or operator shall send correspondence concerning stack testing to:

Stack Testing Coordinator
Air Quality Bureau
Iowa Department of Natural Resources
7900 Hickman Road, Suite 1
Windsor Heights, IA 50324
Telephone: (515) 725-9545
Fax: (515) 725-9502

- F. The owner or operator shall send reports and notifications to:

Compliance Unit Supervisor Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite 1 Windsor Heights, IA 50324 Telephone: (515) 725-9550 Fax: (515) 725-9502	Field Office 5 7900 Hickman Road, Suite 200 Windsor Heights, Iowa 50324 Phone: 515.725.0268 FAX: 515.725.0268
---	---

9. Appeal Rights

All conditions within an original permit may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. Amended conditions within a permit amendment may be appealed, subject to the appeal rights set forth in 561 IAC Chapter 7. In permit amendments, all provisions of the original permit remain in full force and effect unless they are specifically changed by the permit amendment. The previous, unchanged permit provisions are included in the amendment for your convenience only and are unappealable.

Per 561 IAC 7.4(1), the owner or operator shall file any written notice of appeal within thirty (30) days of receipt of the issued permit. The written notice of appeal shall be filed with the Director of the Department with a copy to the Legal Services Bureau Chief at the following addresses:

Director Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319	Bureau Chief Legal Services Bureau Iowa Department of Natural Resources 502 East 9 th Street Des Moines, IA 50319
---	--

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 6 of 9

10a. BACT Emission Limits

The following BACT emission limits apply to the EDG Fuel Oil Tank #2 (EU 412) at all times including during periods of startup, shutdown and malfunction:

Pollutant	lb/hr	lb/MMBtu	Additional Limits	Reference (567 IAC)
Volatile Organic Compounds (VOC)	NA	NA	4.9×10^{-4} ton/year ¹	BACT

¹ Standard is a 12-month rolling total.

10. Emission Limits

Pollutant	lb/hr ¹	tons/yr ²	Additional Limits	Reference (567 IAC)
Particulate Matter (PM)	NA	NA	NA	NA
PM ₁₀	NA	NA	NA	NA
Opacity	NA	NA	NA	NA
Sulfur Dioxide (SO ₂)	NA	NA	NA	NA
Nitrogen Oxides (NO _x)	NA	NA	NA	NA
Volatile Organic Compounds	NA	NA	NA	NA
Carbon Monoxide (CO)	NA	NA	NA	NA
Lead (Pb)	NA	NA	NA	NA
(Single HAP)	NA	NA	NA	NA
(Total HAP)	NA	NA	NA	NA

¹ Standard is expressed as the average of three (3) runs.

² Standard is a 12-month rolling total.

11. Emission Point Characteristics

This emission point shall conform to the specifications listed below:

Parameter	Value
Stack Height, (ft, from the ground)	10
Discharge Style	NA
Stack Opening (inches)	NA
Exhaust Temperature (°F)	NA
Exhaust Flowrate (scfm)	Breathing losses

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 7 of 9

12. Compliance Demonstration(s)

Pollutant	Compliance Demonstration	Compliance Methodology	Frequency
PM – Federal	No	NA	NA
PM – State	No	NA	NA
PM ₁₀	No	NA	NA
PM _{2.5}	No	NA	NA
Opacity	No	NA	NA
SO ₂	No	NA	NA
NO _x	No	NA	NA
VOC	No	NA	NA
CO	No	NA	NA
Pb	No	NA	NA
CO ₂	No	NA	NA
CH ₄	No	NA	NA
N ₂ O	No	NA	NA
CO ₂ e	No	NA	NA
Sulfuric Acid Mist	No	NA	NA
HAP	No	NA	NA

If an initial compliance demonstration specified above is testing, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 within sixty (60) days after achieving maximum production rate and no later than one hundred eighty (180) days after the initial startup date of the proposed equipment.

If subsequent testing is specified above, the owner or the owner’s authorized agent shall verify compliance with the emission limitations contained in Permit Condition 10 according to the frequency and timeframe noted above.

If testing is required, the owner or the owner’s authorized agent shall use the test method and run time listed in the table below unless another testing methodology is approved by the Department prior to testing.

Pollutant	Test Run Time	Test Method
PM – Federal	1 hour	40 CFR 60, Appendix A, Method 5
PM – State	1 hour	40 CFR 60, Appendix A, Method 5 40 CFR 51 Appendix M Method 202
PM ₁₀	1 hour	40 CFR 51, Appendix M, 201A with 202
PM _{2.5}	1 hour	40 CFR 51, Appendix M, 201A with 202
Opacity	1 hour	40 CFR 60, Appendix A, Method 9
SO ₂	1 hour	40 CFR 60, Appendix A, Method 6C
NO _x	1 hour	40 CFR 60, Appendix A, Method 7E
VOC	1 hour	40 CFR 60, Appendix A, Method 25A
CO	1 hour	40 CFR 60, Appendix A, Method 10
Pb	1 hour	40 CFR 60, Appendix A, Method 12
CO ₂	1 hour	40 CFR 60, Appendix A, Method 3A
CH ₄	1 hour	40 CFR 60, Appendix A, Method 18
N ₂ O	1 hour	40 CFR 60, Appendix A, Method 320
Sulfuric Acid Mist	1 hour	40 CFR 60, Appendix A, Method 8
HAP	1 hour	40 CFR 60, Appendix A, Method 18

Each emissions compliance test must be approved by the Department. Unless otherwise specified by the Department, each test shall consist of three (3) separate runs. The arithmetic mean of three (3) acceptable test runs shall apply for compliance, unless otherwise indicated by the Department.

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 8 of 9

12. Compliance Demonstration(s) (Continued)

Per 567 IAC 25.1(7)"a", at the Department's request, a pretest meeting shall be held not later than fifteen (15) days before the owner or operator conducts the compliance demonstration. A testing protocol shall be submitted to the Department no later than fifteen (15) days before the owner or operator conducts the compliance demonstration. Representatives from the Department shall attend this meeting, along with the owner and the testing firm, if any. It shall be the responsibility of the owner to coordinate and schedule the pretest meeting. A representative of the Department shall be allowed to witness the test(s). The Department shall reserve the right to impose additional, different, or more detailed testing requirements.

The owner shall be responsible for the installation and maintenance of test ports. The unit(s) being sampled shall be operated in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which this unit(s) will be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the Department that this unit(s) has been physically altered so that capacity cannot be exceeded, or the Department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the Department to determine whether this unit(s) is in compliance.

13. New Source Performance Standards (NSPS) and National Emission Standards for Hazardous Air Pollutants (NESHAP) Applicability

This emission unit is not subject to New Source Performance Standards (NSPS) subpart Kb because the maximum true vapor pressure of the stored liquid is less than 3.5 kPa.

This emission unit is not subject to National Emission Standards for Hazardous Air Pollutants (NESHAP) because there is no applicable subpart.

14. Operating Limits

Operating limits for this emission unit shall be:

- A. This tank shall be used to store fuel oil #1 or fuel oil #2 only.

15. Operating Condition Monitoring and Recordkeeping

Unless specified by a federal regulation, all records as required by this permit shall be kept on-site for a minimum of two (2) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. These records shall show the following:

There are no monitoring requirements at this time.

16. Continuous Emission Monitoring

Continuous emission monitoring is not required by this permit at this time.

Interstate Power and Light
Marshalltown, Iowa

EDG Fuel Oil Tank #2 (EP 412)
13-A-510-P

Page 9 of 9

17. Permit History

Permit No.	Proj. No.	Description	Date	Stack Testing

18. Description of Terms and Acronyms

The descriptions below are meant only as a brief explanation of terms contained within the permit and may not be the exact definition of the term or acronym as contained within the regulations.

acfm	Actual cubic feet per minute
Applicant	The owner, company official or authorized agent
Btu	British thermal unit
°C	Degrees Celsius
Condensable PM	Material that condenses and/or reacts upon cooling and dilution in the ambient air to form particulate matter immediately after discharge from the stack
CO ₂ e	Carbon dioxide equivalent which is the aggregate emissions of greenhouse gas (GHG) emissions based on global warming potentials
Department	Iowa Department of Natural Resources
dia.	Diameter
°F	Degrees Fahrenheit
ft	Foot
GHG	Greenhouse Gas which is defined as being the group of carbon dioxide (CO ₂), methane (CH ₄), nitrous oxide (N ₂ O), hydrofluorocarbons (HFC), perfluorocarbons (PFC) and sulfur hexafluoride (SF ₆)
g	grams
g/dscm	Grams per dry standard cubic meter
gr	Grains
gr/dscf	Grains per dry standard cubic foot
gr/scf	Grains per standard cubic foot
HAP	Hazardous Air Pollutant(s)
hp	horsepower
hr	Hour
lb	Pound
lb/hr	Pounds per hour
m	Meter
mg	Milligram
MM	Million
MW	Megawatt
NA	Not Applicable
PM _{2.5}	Particulate Matter with an aerodynamic diameter equal to or less than 2.5 microns
PM ₁₀	Particulate Matter with an aerodynamic diameter equal to or less than 10 microns
PM – Federal	Particulate Matter that does not include the condensable PM
PM – State	Particulate Matter that includes condensable PM
ppm	parts per million
ppm _v	parts per million by volume
ppm _w	parts per million by weight
scfm	Standard cubic feet per minute
SHAP	Single hazardous air pollutant
THAP	Total hazardous air pollutants
tons/yr	Tons per year
yr	Year

END OF PERMIT



STATE OF IOWA

TERRY E. BRANSTAD, GOVERNOR
KIM REYNOLDS, LT. GOVERNOR

DEPARTMENT OF NATURAL RESOURCES
CHUCK GIPP, DIRECTOR

DEPARTMENT OF NATURAL RESOURCES
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
NOTICE OF GENERAL PERMIT COVERAGE UNDER
GENERAL PERMIT NO. 2

STORM WATER DISCHARGE ASSOCIATED WITH CONSTRUCTION ACTIVITY

This notice of general permit coverage for a storm water discharge associated with construction activity is issued pursuant to the authority of section 402 (b) of the Clean Water Act (U.S.C. 1342(b)), Iowa Code 455B.174, and subrule 567--64.4(2), Iowa Administrative Code. A Notice of Intent has been filed with the Iowa Department of Natural Resources that this storm water discharge complies with the terms and conditions of NPDES General Permit No. 2. Authorization is hereby issued to discharge storm water associated with industrial activity as defined in Part VIII of the Iowa Department of Natural Resources NPDES General Permit No. 2 in accordance with the terms and conditions set forth in the permit.

Owner: INTERSTATE POWER AND LIGHT COMPANY
200 FIRST STREET, SE
CEDAR RAPIDS IA 52401
(319)786-4476

Permit Coverage Issued To:

**INTERSTATE POWER AND LIGHT, MARSHALLTOWN GENERATING
STATION - CONSTRUCTION**
2115 EAST NEVADA ST.
in MARSHALLTOWN, MARSHALL COUNTY
located at

1/4 Section	Section	Township	Range
NW, NE, SW, SE-31, NW	32	84N	17W

Coverage Provided Through: 5/1/2018
NPDES Permit Discharge Authorization Number: 24847 - 24589
Discharge Authorization Date: 5/1/2014

**Project Description: CONSTRUCTION OF A NOMINAL 600 MW COMBINED CYCLE
NATURAL GAS FIRED POWER ELECTRIC GENERATION PLANT AND
ASSOCIATED LINEAR FACILITIES 115 ACRES**

IOWA DEPARTMENT OF NATURAL RESOURCES

**NATIONAL POLLUTANT DISCHARGE ELIMINATION
SYSTEM (NPDES)**

GENERAL PERMIT NO. 2

**EFFECTIVE DATES
OCTOBER 1, 2012 THROUGH OCTOBER 1, 2017**

FOR

**STORM WATER DISCHARGE ASSOCIATED WITH
CONSTRUCTION ACTIVITIES**

NPDES GENERAL PERMIT NO. 2
TABLE OF CONTENTS

PART I. COVERAGE UNDER THIS PERMIT..... 1

- A. PERMIT AREA..... 1**
- B. ELIGIBILITY..... 1**
- C. REQUIRING AN INDIVIDUAL PERMIT. 1**
- D. AUTHORIZATION..... 2**

PART II. NOTICE OF INTENT (NOD) REQUIREMENTS 2

- A. DEADLINES FOR FILING A NOTICE OF INTENT..... 2**
- B. FAILURE TO NOTIFY..... 2**
- C. CONTENTS OF THE NOTICE OF INTENT. 2**
- D. WHERE TO SUBMIT. 3**
- E. RENOIFICATION..... 3**
- F. TRANSFER OF COVERAGE UNDER THIS PERMIT. 3**
- G. NOTICE OF DISCONTINUATION. 4**

**PART III. SPECIAL CONDITIONS, MANAGEMENT PRACTICES, AND OTHER NON-
NUMERIC LIMITATIONS..... 4**

- A. PROHIBITION ON NON-STORM WATER DISCHARGES. 4**
- B. RELEASES IN EXCESS OF REPORTABLE QUANTITIES. 4**

PART IV. STORM WATER POLLUTION PREVENTION PLANS 5

- A. DEADLINES FOR POLLUTION PREVENTION PLAN PREPARATION AND COMPLIANCE..... 5**
- B. SIGNATURE AND PLAN REVIEW..... 5**
- C. KEEPING PLANS CURRENT. 5**
- D. CONTENTS OF THE POLLUTION PREVENTION PLAN..... 6**

PART V. RETENTION OF RECORDS..... 10

PART VI. STANDARD PERMIT CONDITIONS..... 11

- A. DUTY TO COMPLY..... 11**
- B. CONTINUATION OF THE EXPIRED GENERAL PERMIT..... 11**
- C. NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE..... 11**

D. DUTY TO MITIGATE 11

E. DUTY TO PROVIDE INFORMATION 11

F. OTHER INFORMATION..... 11

G. SIGNATORY REQUIREMENTS..... 11

H. CERTIFICATION..... 12

I. OIL AND HAZARDOUS SUBSTANCE LIABILITY..... 12

J. PROPERTY RIGHTS..... 12

K. SEVERABILITY..... 12

L. TRANSFERS 12

M. PROPER OPERATION AND MAINTENANCE..... 12

N. INSPECTION AND ENTRY 12

O. PERMIT ACTIONS 13

P. ENVIRONMENTAL LAWS 13

PART VII. REOPENER CLAUSE 13

PART VIII. DEFINITIONS..... 13

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

PART I. COVERAGE UNDER THIS PERMIT

A. **PERMIT AREA** This permit covers all areas of the State of Iowa.

B. **ELIGIBILITY**

1. A. Except for discharges identified under Parts I.B.2. and I.B.3., this permit may authorize the discharge of storm water associated with industrial activity from construction sites, (those sites or common plans of development or sale that will result in the disturbance of one or more acres total land area), (hereafter referred to as storm water discharge associated with industrial activity for construction activities) occurring after the effective date of this permit (including discharges occurring after the effective date of this permit where the construction activity was initiated before the effective date of this permit), including storm water discharge associated with industrial activity from areas that are dedicated to producing earthen materials, such as soils, sand and gravel, for use at a single construction site.

B. This permit may authorize storm water discharge from a construction site that is mixed with storm water discharge associated with industrial activity from sources other than construction activities provided that the storm water discharge from the industrial (non-construction) source is in compliance with the terms of a NPDES general permit, other than this general permit, or individual permit authorizing such discharge. In addition, the storm water other than from construction, shall be in compliance with Part IV.D.6. of this permit.

2. **LIMITATIONS ON COVERAGE** The following storm water discharges associated with industrial activity for construction activities are **not** authorized by this permit:

A. storm water discharges that are mixed with sources of non-storm water other than discharges identified in Part III.A.2. of this permit;

B. storm water discharges associated with industrial activity for construction activities which are covered by an existing individual NPDES permit or which are issued a permit in accordance with Part I.C. of this permit.

Storm water discharges authorized by an existing individual NPDES permit will be eligible to apply for coverage under this general permit as the existing individual permit expires; and

C. storm water discharges associated with industrial activity for construction activities that the Iowa Department of Natural Resources has determined to be or may reasonably be expected to be contributing to a violation of a water quality standard.

D. new or expanded “storm water discharge associated with industrial activity” that discharges to Outstanding Iowa Waters or to Outstanding National Resource Waters.

3. **EXCLUSIONS** The following “storm water discharges associated with industrial activity” from construction activities do not require a NPDES permit:

discharges from agricultural and silvicultural activities including storm water runoff from orchards, cultivated crops, pastures, range lands, and forest lands, but not discharges from concentrated animal feeding operations as defined in 40 CFR 122.23, concentrated aquatic production facilities as defined in 40 CFR 122.24, discharges to aquaculture projects as defined in 40 CFR 122.25, and discharges from silvicultural point sources as defined in 40 CFR 122.27.

C. **REQUIRING AN INDIVIDUAL PERMIT**

1. The Department may require any person authorized by this permit to apply for and obtain an individual NPDES permit. The Department may require any owner or operator authorized to discharge under this permit to apply for an individual NPDES permit only if the owner or operator has been notified in writing that a permit application is required. This notice shall include a brief

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

statement of the reasons for this decision, an application form, a statement setting a deadline for the owner or operator to file the application, and a statement that on the effective date of the individual NPDES permit, coverage under this general permit shall automatically terminate. If an owner or operator fails to submit an individual NPDES permit application required by the Department under this paragraph, coverage of this general permit automatically is terminated at the end of the day specified for submittal of the individual NPDES application.

2. Any person authorized to discharge under this permit may apply for an individual NPDES permit. In such cases, the discharger shall submit the following in accordance with the requirements of subrule (567)--64.3(4) in the Iowa Administrative Code:

- A. an individual application, using DNR Form 1 and EPA Form 2F, and,

- B. all applicable fees identified in rule (567)--64.16 in the Iowa Administrative Code.

3. When an individual NPDES permit is issued to a discharger covered under this general permit, the applicability of this general permit to the individual NPDES permittee is automatically terminated on the effective date of the individual NPDES permit.

When an individual NPDES permit is denied to a discharger otherwise subject to this permit, the applicability of this permit to the individual NPDES permittee is automatically terminated on the date of such denial, unless otherwise specified by the Department.

D. AUTHORIZATION

A discharger must submit a Notice of Intent (NOI) in accordance with the requirements of Part II of this permit in order for storm water discharge associated with industrial activity for construction activities pursuant to Part I.B. of this permit to be authorized to discharge under this general permit.

PART II. NOTICE OF INTENT (NOI) REQUIREMENTS

A. DEADLINES FOR FILING A NOTICE OF INTENT

For storm water discharge associated with industrial activity for construction activities where construction begins after October 1, 1992, construction activities shall not commence until an authorization has been issued for the project by the Department.

- B. FAILURE TO NOTIFY** Dischargers who fail to notify the Department of their intent to be covered, and discharge pollutants to water of the United States within Iowa, without an NPDES permit, are in violation of the Clean Water Act and the Code of Iowa.

- C. CONTENTS OF THE NOTICE OF INTENT** A complete Notice of Intent shall include the items described in Parts II.C.1., II.C.2., and II.C.3. of this permit.

1. A completed Notice of Intent (NOI) form, DNR Form 542-1415, signed in accordance with Part VI.G. of this permit. The information on the form shall include the following:

- A. Name, address, and location of the construction site for which this notification is submitted. The location should be provided as the 1/4 section, township, range, and the county in which the storm water discharge is located.

- B. The owner's name, address, telephone number, and status (federal, state, private, public or other entity).

- C. The name, address and telephone number of any operator (contractor) that has been identified as having a role in the storm water pollution prevention plan for the site required under Part IV.D.7. of this permit. Contractors (operators) identified after the submittal of the completed Notice of Intent shall be identified in the pollution prevention plan.

Figure 2.3-11
Page 8 of 21

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

D. The type of discharge (new or existing as related to October 1, 1992); whether or not the discharge is to a municipal separate storm sewer system; the date the discharge is to commence; the permit status of the discharge; and, the name of the receiving waters.

E. An indication if any existing quantitative data is available describing the concentration of pollutants in storm water discharges and a summary of available existing data. (Existing data should not be included as part of the NOI, it should retained as part of the Pollution Prevention Plan).

F. A brief description of the project; an estimated timetable for major activities; and, an estimate of the number of acres of the site on which soil will be disturbed.

G. A certification that compliance with G.(1). through G.(4). are met:

G.(1). the pollution prevention plan has been developed before this Notice of Intent is submitted to the Department;

G.(2). the pollution prevention plan will be implemented on October 1, 1992 for any existing storm water discharge associated with industrial activity for construction activities. For a storm water discharge associated with industrial activity for construction activities that commence after October 1, 1992, the pollution prevention plan shall be implemented with the start of construction activities;

G.(3). this Notice of Intent will be included and incorporated into the pollution prevention plan and will be updated as required; and,

G.(4). the storm water pollution prevention plan provides compliance with section 467A.64 of the Code of Iowa and local sediment and erosion plans and are consistent with the requirements of Part IV of this general permit.

2. APPLICABLE FEES The applicable fees specified in Iowa Administrative Code 567 -- 64.16(455B).

3. PUBLIC NOTIFICATION A demonstration that the public notice specified in Iowa Administrative Code 567--64.6(1)"c"(2) was published at least one day, in at least two newspapers with the largest circulation in the area in which the facility is located or the activity will occur.

D. WHERE TO SUBMIT Facilities which discharge storm water associated with industrial activity for construction activities must submit items described in Parts II.C.1., 2., and 3. of this permit to the Department at the following address:

Storm Water Coordinator
Iowa Department of Natural Resources
502 E. 9th St.
Des Moines, IA 50319-0034

E. RENOTIFICATION Prior to the expiration of an authorization issued under this general permit, the permittee is required to resubmit a Notice of Intent (no additional public notices are required) with the Department for coverage under the new general permit. If a new general permit has not been reissued prior to the expiration of the current permit, the provisions and coverage of the current permit are extended until replaced by the adoption of a new general permit.

F. TRANSFER OF COVERAGE UNDER THIS PERMIT For storm water discharge associated with industrial activity for construction activities where the ownership changes, the Department must be notified of the title transfer within 30 days. Both the previous owner(s) and the new owner(s) are responsible for notifying the Department of the transfer and the new owner's name and contact information. This requirement shall be satisfied upon the Department's receipt of the notification of this information by either the previous owner(s) or the new owner(s). If a storm water discharge associated with industrial activity for construction activities is covered by this general permit, the new

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

owner(s) shall be subject to all terms and conditions of this general permit. A copy of the notice of transfer that was sent to the Department shall be included in the pollution prevention plan. For construction activity which is part of a larger common plan of development such as a housing or commercial development project, if a permittee transfers ownership of all or any part of property subject to this permit, both the permittee and transferee shall be responsible for compliance with the provisions of this permit for that portion of the project which has been transferred including when the transferred property is less than one acre in area. If the new owner(s) agree in writing to be solely responsible for compliance with the provisions of this permit for the property which has been transferred, then the existing permittee(s) shall be relieved of responsibility for compliance with this permit for the transferred property, from and after the date the Department receives written notice of transfer of responsibility. A copy of the notice of transfer of responsibility shall be included in the pollution prevention plan.

G. NOTICE OF DISCONTINUATION

1. Within 30 days after final stabilization at a construction site (as defined in Part VIII of this permit), the operator or owner of the facility shall submit a Notice of Discontinuation to the Department.
2. The Notice of Discontinuation shall include the following information:
 - A. the name of the owner/operator to which the permit was issued;
 - B. the general permit number and permit authorization number;
 - C. the date the construction site reached final stabilization; and,
 - D. the following certification signed in accordance with Part VI.G. of this permit:

"I certify under penalty of law that disturbed soils at the identified facility have been finally stabilized and temporary erosion and sediment

control measures have been removed or will be removed at an appropriate time. I understand that by submitting this Notice of Discontinuation, that I am no longer authorized to discharge storm water associated with industrial activity for construction activities by Iowa Department of Natural Resources General NPDES Permit No. 2. and that discharging pollutants from storm water associated with industrial activity to waters of the United States is unlawful under the Clean Water Act where the discharge is not authorized by a NPDES permit."

PART III. SPECIAL CONDITIONS, MANAGEMENT PRACTICES, AND OTHER NON-NUMERIC LIMITATIONS

A. PROHIBITION ON NON-STORM WATER DISCHARGES

1. All discharges authorized by this permit shall be composed entirely of storm water except for non-storm discharges listed in Part III.A.2.
2. Discharges from fire fighting activities; fire hydrant flushings; waters used to wash vehicles in accordance with Part IV.D.2.c.(2); potable water sources including waterline flushings; irrigation drainage; routine external building washdown which does not use detergents; pavement washwaters where spills or leaks of toxic or hazardous materials have not occurred (unless all spilled material has been removed) and where detergents are not used; air conditioning condensate; springs; uncontaminated groundwater; and foundation or footing drains where flows are not contaminated with process materials such as solvents; may be authorized by this permit provided the non-storm water component of the discharge is in compliance with Part IV.D.5. of this permit.

B. RELEASES IN EXCESS OF REPORTABLE QUANTITIES Any owner or operator identified in the pollution prevention plan is subject to the spill notification requirements as specified in 455B.386 of the Iowa Code. Iowa law requires that as soon as possible but not more than six hours after the onset of

Figure 2.3-11
Page 10 of 21

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

a "hazardous condition" the Department and local sheriff's office or the office of the sheriff of the affected county be notified.

The storm water pollution prevention plan described in Part IV of this permit must be modified within 5 calendar days of knowledge of the release to provide a description of the release and the circumstances leading to the release and to identify and provide for the implementation of steps to prevent the reoccurrence of such releases and to respond to such releases.

PART IV. STORM WATER POLLUTION PREVENTION PLANS

A storm water pollution prevention plan shall be developed for each construction site covered by this permit. Storm water pollution prevention plans shall be prepared in accordance with good engineering practices. The plan shall identify potential sources of pollution which may reasonably be expected to affect the quality of the storm water discharge from the construction activities. In addition, the plan shall describe and ensure the implementation of practices which will be used to reduce the pollutants in storm water discharge associated with industrial activity for construction activities at the construction site and to assure compliance with the terms and conditions of this permit. Facilities must implement the provisions of the storm water pollution prevention plan required under this part as a condition of this permit.

A. DEADLINES FOR POLLUTION PREVENTION PLAN PREPARATION AND COMPLIANCE

1. POLLUTION PREVENTION PLAN PREPARATION DEADLINE

The pollution prevention plan shall be completed prior to the submittal of an NOI to the Department to be covered under this permit and shall be updated as appropriate.

2. POLLUTION PREVENTION PLAN COMPLIANCE DEADLINE

The pollution prevention plan shall provide for compliance with the terms and schedule of the plan prior to the initiation of construction activities.

B. SIGNATURE AND PLAN REVIEW

1. The plan shall be signed in accordance with Part VI.G., and be retained at the construction site from the date construction activities begin to the date of final stabilization.

2. The permittee shall make plans available to the Department upon request, or in the case of a storm water discharge associated with industrial activity for construction activities which discharge through a municipal separate storm sewer system with an NPDES permit, to the municipal operator of the system.

3. The Department may notify the permittee at any time that the plan does not meet one or more of the minimum requirements of this Part. After such notification from the Department, the permittee shall make changes to the plan and shall submit to the Department a written certification that the requested changes have been made. Unless otherwise provided by the Department, the permittee shall have 3 business days after such notification to make the necessary changes.

4. All storm water pollution prevention plans received by the Department from the permittee are considered reports that shall be available to the public under Section 308(b) of the CWA and Chapter 22 of the Code of Iowa. However, the permittee may claim any portion of a storm water pollution plan as confidential in accordance with Chapter 22 of the Code of Iowa and Iowa Administrative Code (561)--2.5.

C. KEEPING PLANS CURRENT The permittee shall amend the plan whenever there is a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to the waters of the United States and which has not been addressed in the plan or if the storm water pollution prevention plan proves to be ineffective in eliminating or significantly minimizing pollutants from sources identified in Part IV.D.2. of this permit, or in otherwise achieving the general objectives of controlling pollutants in storm water discharge associated

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

with industrial activity for construction activities. In addition, the pollution prevention plan shall be updated to: expeditiously change the site map to include changes at the site, include contractors identified after the submittal of the Notice of Intent as Co-permittees, described in Part IV.D.7. of this permit; identify any change in ownership or transference of the permit and permit responsibilities; or, if required, by the occurrence of a hazardous condition (as defined in Part VIII of this permit). Amendments to the plan may be reviewed by the Department of Natural Resources in the same manner as Part IV.B.2.

D. CONTENTS OF THE POLLUTION PREVENTION PLAN. The storm water pollution prevention plan shall include the following items:

1. SITE DESCRIPTION Each plan shall provide a description of the following:

A. a description of the nature of the construction activity;

B. estimates of the total area of the site and the area of the site that is expected to be disturbed by excavation, grading, or other activities;

C. an estimate of the runoff coefficient of the site after construction activities are completed and existing data describing the soil or the quality of any discharge from the site;

D. a site map indicating drainage patterns and approximate slopes anticipated after major grading activities, areas of soil disturbance, the location of structural and nonstructural controls identified in the plan, the location of areas where stabilization practices are expected to occur, surface waters (including wetlands), and locations where storm water is discharged to a surface water; and

E. the name of the receiving water(s) and the ultimate receiving water(s).

2. CONTROLS Each plan shall include a description of controls that will be implemented at the construction site. The plan will clearly describe the intended sequence of major activities and for each activity, the appropriate control measures and the timing during the construction process that the measures will be implemented. (For example, perimeter controls for one portion of the site will be installed after the clearing and grubbing necessary for installation of the measure, but before the clearing and grubbing for the remaining portions of the site. Perimeter controls will be actively maintained until final stabilization of those portions of the site upward of the perimeter control. Temporary perimeter controls will be removed after final stabilization). The description of controls shall address the following minimum components:

A. EROSION AND SEDIMENT CONTROLS

A.(1). STABILIZATION PRACTICES A description of temporary and permanent stabilization practices, including site-specific scheduling of the implementation of the practices. Site plans should ensure that existing vegetation is preserved where attainable and that disturbed areas are stabilized. Stabilization practices may include: temporary seeding, permanent seeding, mulching, geotextiles, sod stabilization, vegetative buffer strips, protection of trees, preservation of mature vegetation, and other appropriate measures. Except as precluded by snow cover, stabilization measures shall be initiated on all disturbed areas as soon as practical but in no case where construction activity will not occur for a period of 21 or more calendar days later than the 14th day after no construction activity has occurred on such area. Where the initiation of stabilization measures by the 14th day after no construction activity occurs is precluded by snow cover, then stabilization measures shall be initiated as soon as practicable thereafter.

A.(2). STRUCTURAL PRACTICES A description of structural practices to the degree attainable, to divert flows from

Figure 2.3-11
Page 12 of 21

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

exposed soils, store flows or otherwise limit runoff from exposed areas of the site. Such practices may include silt fences, earth dikes, brush barriers, drainage swales, sediment traps, check dams, subsurface drains, pipe slope drains, level spreaders, storm drain inlet protection, rock outlet protection, reinforced soil retaining systems, gabions, and temporary or permanent sediment basins. Structural practices should be placed on upland soils to the degree attainable. The installation of these devices may be subject to Section 404 of the CWA.

A.(2).(a). For common drainage locations that serve an area with more than 10 disturbed acres at one time, a temporary or permanent sediment basin providing 3,600 cubic feet of storage per acre drained shall be provided where attainable until final stabilization of the site has been achieved. The 3,600 cubic feet of storage area per acre drained does not apply to flows from offsite areas and flows from onsite areas that are either undisturbed or have undergone final stabilization where such flows are diverted around the sediment basin. For drainage locations which serve more than 10 disturbed acres at one time and where a temporary sediment basin providing 3,600 cubic feet of storage per acre drained is not attainable, sediment traps, silt fences, or equivalent sediment controls are required for all sideslope and downslope boundaries of the construction area.

A.(2).(b). For drainage locations serving 10 or fewer acres, sediment traps, silt fences or equivalent sediment controls are required for all sideslope and downslope boundaries of the construction area or a sediment basin providing for 3,600 cubic feet of storage per acre drained.

A.(2).(c). Unless infeasible, the following measures shall be implemented at all sites: utilize outlet structures that withdraw water from the surface when discharging from basins, provide and maintain natural buffers around surface waters, direct storm water to vegetated areas to increase sediment removal and maximize storm water infiltration and minimize soil compaction. Topsoil shall be

preserved at all construction sites unless land use precludes the practice. The requirement to preserve topsoil shall be met only when the depth of topsoil after soil disturbing activities have been completed and final stabilization achieved for the permitted activity is equal to, or greater than, 4.0 inches, including soil contained in sod, on all areas of the site where the surface of the ground disturbed for the permitted construction activities is exposed and not covered by concrete, asphalt, gravel or other such material and where 4.0 inches or more of topsoil existed prior to the commencement of soil disturbing activities that are permitted under the current permit authorization for the site. On areas where less than 4.0 inches of topsoil existed prior to the commencement of soil disturbing activities that are permitted under the current permit authorization for the site, the minimum depth of topsoil after soil disturbing activities have been completed and final stabilization achieved for the permitted activity shall be equal to, or greater than, the depth of topsoil that existed prior to the commencement of soil disturbing activities that are permitted under the current permit authorization for the site.

The final topsoil depth is to be measured after the soil has been compacted in a fashion generally considered adequate for an established lawn and so that the expected settling that will occur after measurement will be minimal and shall include the soil contained in any sod that has been placed on the site. The type of topsoil at the site after soil disturbing activities have been completed and final stabilization achieved for the permitted activity shall be similar to that which exists or existed in the general area of the site.

For construction activity which is part of a larger common plan of development, such as a housing or commercial development project, in which a new owner agrees in writing to be solely responsible for compliance with the provisions of this permit for the property which has been transferred or in which the new owner has obtained authorization under this permit for a lot or lots (as specified in subrule 567-64.6(6) of the Iowa Administrative Code), the topsoil preservation

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

requirements described above must be met no later than at the time the lot or lots have reached final stabilization as described in this permit.

For sites where less than 4.0 inches of topsoil is to be in place after soil disturbing activities have been completed and final stabilization achieved for the permitted activity, a soil survey conducted by properly qualified personnel who regularly conduct soil surveys as part of their normal job duties must be conducted prior to commencement of soil disturbing activities that are permitted under the current permit authorization for the site. The results of the soil survey shall become part of the Pollution Prevention Plan and shall indicate the depth of topsoil at a suitable number of points on the site commensurate with standard engineering practices established for the size of the site.

The topsoil preservation requirement described above shall be implemented for projects that have not received an authorization under this permit prior to October 1, 2012. The topsoil preservation requirements are not required to be implemented for projects that have been authorized prior to October 1, 2012. In residential and commercial developments, a plat is considered a project. For other large areas that have been authorized for multiple construction sites, including those to be started at a future date, such as those located at industrial facilities, military installations and universities, a new construction project not yet surveyed and platted out is considered a project. This stipulation is intended to be interpreted as requiring the topsoil preservation requirements on development plats and construction activities on other extended areas that may have several construction projects permitted under the same authorization to be implemented on those projects not yet surveyed and platted out prior to October 1, 2012 even if other plats and construction activities in the same development or other extended area were authorized prior to October 1, 2012.

B. STORM WATER MANAGEMENT A description of measures that will be installed during construction to control pollutants in

storm water discharges that will occur after construction operations have been completed. The installation of these devices may be subject to Section 404 of the CWA. This permit only addresses the installation of storm water management measures, and not the ultimate operation and maintenance of such structures after the construction activities have been completed and the site has undergone final stabilization. Permittees are only responsible for the installation and maintenance of storm water management measures prior to final stabilization of the site, and are not responsible for maintenance after storm water discharges associated with industrial activity have been eliminated from the site.

B.(1). Such practices may include: storm water detention structures (including wet ponds); storm water retention structures; flow attenuation by use of open vegetated swales and natural depressions; and infiltration of runoff onsite; and sequential systems (which combine several practices). A goal of 80 percent removal of total suspended solids from those flows which exceed predevelopment levels should be used in designing and installing storm water management controls (where practicable). Where this goal is not met, the permittee shall provide justification for rejecting each practice based on site conditions.

B.(2). Velocity dissipation devices shall be placed at discharge locations and along the length of any outfall channel as necessary to provide a non-erosive velocity flow from the structure to a water course so that the natural physical and biological characteristics and functions are maintained and protected (e.g. maintenance of hydrologic conditions present prior to the initiation of construction activities).

C. OTHER CONTROLS

C.(1). WASTE DISPOSAL All wastes composed of building materials must be removed from the site for disposal in permitted disposal facilities. No building material wastes or unused building materials

Figure 2.3-11
Page 14 of 21

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

shall be buried, dumped, or discharged at the site.

C.(2). Off-site vehicle tracking of sediments shall be minimized.

C.(3). The plan shall ensure and demonstrate compliance with applicable State or local waste disposal, sanitary sewer or septic system regulations.

D. APPROVED STATE OR LOCAL PLANS

Facilities which discharge storm water associated with industrial activity for construction activities must include in their storm water pollution prevention plan procedures and requirements specified in applicable sediment and erosion site plans or storm water management plans approved by State or local officials. Applicable requirements specified in sediment and erosion plans, site permits or storm water management plans approved by State or local officials that are applicable to protecting surface water resources are, upon submittal of an NOI to be authorized to discharge under this permit, incorporated by reference and are enforceable under this permit even if they are not specifically included in a storm water pollution prevention plan required under this permit.

Operators of facilities seeking alternative permit requirements shall submit an individual permit application in accordance with Part I.C.2. of this permit along with a description of why requirements in approved State or local plans should not be applicable as a condition of an NPDES permit.

3. **MAINTENANCE** A description of procedures to maintain in good and effective operating conditions vegetation, erosion and sediment control measures and other protective measures identified in the site plan.

4. **INSPECTIONS** Qualified personnel (provided by the discharger) shall inspect disturbed areas of the construction site that have not been stabilized with a perennial, vegetative cover of sufficient density to preclude erosion at least once every seven calendar days. Unless erosion is evident or other conditions

warrant them, regular inspections are not required on areas that have been stabilized with a perennial, vegetative cover of sufficient density to preclude erosion.

A. Disturbed areas and areas used for storage of materials that are exposed to precipitation shall be inspected for evidence of, or the potential for, pollutants entering the drainage system. Erosion and sediment control measures identified in the plan shall be observed to ensure that they are operating correctly. Where discharge locations or points are accessible, they shall be inspected to ascertain whether erosion control measures are effective in preventing significant impacts to receiving waters. Locations where vehicles enter or exit the site shall be inspected for evidence of offsite sediment tracking.

B. Based on the results of the inspection, the description of potential pollutant sources identified in the plan in accordance with paragraph IV.D.1. of this permit and pollution prevention measures identified in the plan in accordance with paragraph IV.D.2. of this permit shall be revised as appropriate as soon as practicable after such inspection. Such modifications shall provide for implementation of any changes to the plan within 7 calendar days following the inspection.

C. A report summarizing the scope of the inspection, name(s) and qualifications of personnel making the inspection, the date(s) of the inspection, major observations relating to the implementation of the storm water pollution prevention plan, and actions taken in accordance with paragraph IV.D.4.B. of the permit shall be made and retained as part of the storm water pollution prevention plan for at least three years after final stabilization has been achieved and a Notice of Discontinuation has been submitted to the Department. The report shall be signed in accordance with Part VI.G. of this permit.

5. **NON-STORM WATER DISCHARGES** Except for flows from fire fighting activities, sources of non-storm water listed in Part III.A.2. of this permit that are combined with storm

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

water discharges associated with industrial activity from construction activities must be identified in the plan. The plan shall identify and ensure the implementation of appropriate pollution prevention measures for the non-storm water component(s) of the discharge.

6. ADDITIONAL REQUIREMENTS FOR STORM WATER DISCHARGE FROM INDUSTRIAL ACTIVITIES OTHER THAN CONSTRUCTION, INCLUDING DEDICATED ASPHALT PLANTS, AND DEDICATED CEMENT PLANTS

This permit may only authorize a storm water discharge associated with industrial activity from a construction site that is mixed with a storm water discharge from an industrial source other than construction, where:

A. the industrial source other than construction is located on the same site as the construction activity;

B. storm water discharges associated with industrial activity from the areas of the site where construction activities are occurring are in compliance with the terms of this permit; and,

C. storm water discharges associated with industrial activity from the areas of the site where industrial activity other than construction are occurring (including storm water discharges from dedicated asphalt plants and dedicated cement plants) are in compliance with the terms and conditions, including applicable NOI or application requirements, of a different NPDES general permit or individual permit authorizing such discharges.

7. CONTRACTORS

A. The storm water pollution prevention plan must clearly identify for each measure in the plan, the contractor(s) and/or subcontractor(s) that will implement the measure. All contractors and subcontractors identified in the plan must sign a copy of the certification statement in Part IV.D.7.B. of this permit in accordance with Part VI.G. of this permit. Upon signing the certification, the contractor or sub-contractor is a co-permittee with the

owner and other co-permittee contractors. All certifications must be included in the storm water pollution prevention plan.

B. CERTIFICATION STATEMENT

All contractors and subcontractors identified in a storm water pollution prevention plan in accordance with Part IV.D.7.A. of this permit shall sign a copy of the following certification statement before conducting any professional service at the site identified in the storm water pollution prevention plan:

"I certify under penalty of law that I understand the terms and conditions of the general National Pollutant Discharge Elimination System (NPDES) permit that authorizes the storm water discharges associated with industrial activity from the construction site as part of this certification. Further, by my signature, I understand that I am becoming a co-permittee, along with the owner(s) and other contractors and subcontractors signing such certifications, to the Iowa Department of Natural Resources NPDES General Permit No. 2 for "Storm Water Discharge Associated with Industrial Activity for Construction Activities" at the identified site. As a co-permittee, I understand that I, and my company, are legally required under the Clean Water Act and the Code of Iowa, to ensure compliance with the terms and conditions of the storm water pollution prevention plan developed under this NPDES permit and the terms of this NPDES permit."

The certification must include the name and title of the person providing the signature; the name, address and telephone number of the contracting firm; the address (or other identifying description) of the site; and the date the certification is made.

PART V. RETENTION OF RECORDS

A. The permittee shall retain copies of storm water pollution prevention plans and all reports required by this permit, and records of all data used to complete the Notice of Intent to be covered by this permit, for a period of at

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

least three years from the date that the site is finally stabilized and a Notice of Discontinuation has been submitted to the Department.

- B. If there is a construction trailer, shed or other covered structure located on the property the permittee shall retain a copy of the storm water pollution prevention plan required by this permit at the construction site from the date of project initiation to the date of final stabilization. If there is no construction trailer, shed or other covered structure located on the property, the permittee shall retain a copy of the plan at a readily available alternative site approved by the Department and provide it for inspection upon request. If the plan is maintained at an off-site location such as a corporate office, it shall be provided for inspection no later than three hours after being requested.
- C. **ADDRESSES** All written correspondence to the Department should be sent to the following address:

Storm Water Coordinator
Iowa Department of Natural Resources
502 E. 9th St.
Des Moines, IA 50319-0034

PART VI. STANDARD PERMIT CONDITIONS

A. DUTY TO COMPLY

1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Code of Iowa and the Clean Water Act and is grounds for enforcement action; for termination of coverage under this general permit; or, for denial of a request for coverage under a reissued general permit.
2. **TOXIC POLLUTANTS** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act (CWA) for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even

if this permit has not yet been modified to incorporate the requirement.

- B. **CONTINUATION OF THE EXPIRED GENERAL PERMIT** This permit expires on October 1, 2017. An expired general permit continues in force until replaced by adoption of a new general permit.
- C. **NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- D. **DUTY TO MITIGATE** The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
- E. **DUTY TO PROVIDE INFORMATION** The permittee shall furnish to the Department, within three hours, any information which the Department may request to determine compliance with this permit. The permittee shall also furnish to the Department upon request copies of records required to be kept by this permit.
- F. **OTHER INFORMATION** When the permittee becomes aware that he or she failed to submit any relevant facts or submitted incorrect information in the Notice of Intent or in any other report to the Department, he or she shall promptly submit such facts or information.
- G. **SIGNATORY REQUIREMENTS** All Notices of Intent, storm water pollution prevention plans, reports, certifications or information either submitted to the Department or the operator of a municipal separate storm sewer system, or that this permit requires be maintained by the permittee, shall be signed in accordance with rule 567--64.3(8) of the Iowa Administrative Code as follows:

64.3(8) *Identity of signatories of operation permit applications.* The person who signs

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

the application for an operation permit shall be:

a. *Corporations.* In the case of corporations, a principal executive officer of at least the level of vice-president.

b. *Partnerships.* In the case off a partnership, a general partner.

c. *Sole proprietorships.* In the case of a sole proprietorship, the proprietor.

d. *Public facilities.* In the case of a municipal, state, or other public facility, by either the principal executive officer, or the ranking elected official.

e. *Storm water discharge associated with industrial activity from construction activity.* In the case of a storm water discharge associated with industrial activity from construction as identified in 40 CFR 122.26(b)(14)(x), either the owner of the site or the general contractor.

The person who signs NPDES reports shall be the same, except that in the case of a corporation or a public body, monitoring reports required under the terms of the permit may be submitted by the person who is responsible for the overall operation of the facility from which the discharge originated.

H. **CERTIFICATION** Any person signing documents under paragraph VI.G. shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are

significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

I. **OIL AND HAZARDOUS SUBSTANCE LIABILITY** Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under section 311 of the Clean Water Act.

J. **PROPERTY RIGHTS** The issuance of this permit does not convey any property rights of any sort, nor any exclusive privileges, nor does it authorize any injury to private property nor any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

K. **SEVERABILITY** The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit shall not be affected thereby.

L. **TRANSFERS** This permit is not transferable to any person except after notice to the Department. The Department may require the discharger to apply for and obtain an individual NPDES permit as stated in Part I.C.

M. **PROPER OPERATION AND MAINTENANCE** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit and with the requirements of storm water pollution prevention plans. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. Proper operation and maintenance requires the operation of backup or auxiliary facilities or similar systems, installed by a permittee only when necessary to achieve compliance with the conditions or this permit.

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

N. **INSPECTION AND ENTRY** The permittee shall allow the Department or an authorized representative of EPA, the State, or, in the case of a facility which discharges through a municipal separate storm sewer, an authorized representative of the municipal operator or the separate storm sewer receiving the discharge, upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted or where records must be kept under the conditions of this permit;

2. Have access to and copy at reasonable times, any records that must be kept under the conditions of this permit; and,

3. Inspect at reasonable times any facilities or equipment (including monitoring and control equipment).

O. **PERMIT ACTIONS** Coverage under this permit may be terminated for cause. The filing of a request by the permittee for a permit discontinuance, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

P. **ENVIRONMENTAL LAWS** No condition of this permit shall release the permittee from any responsibility or requirements under other environmental statutes or regulations.

PART VII. REOPENER CLAUSE

If there is evidence indicating potential or realized impacts or water quality due to any storm water discharge associated with industrial activity for construction activities covered by this permit, the owner or operator of such discharge may be required to obtain individual permit in accordance with Part I.C of this permit.

PART VIII. DEFINITIONS

"Best Management Practices" ("BMPs") means schedules of activities, prohibitions of

practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

"Construction site" means a site or common plan of development or sale on which construction activity, including clearing, grading and excavating, results in soil disturbance. A construction site is considered one site if all areas of the site are contiguous with one another and one entity owns all areas of the site.

"CWA" or "Clean Water Act" means the Federal Water Pollution Control Act.

"Dedicated portable asphalt plant" means a portable asphalt plant that is located on or contiguous to a construction site and that provides asphalt only to the construction site that the plant is located on or adjacent to.

"Dedicated portable concrete plant" means a portable concrete plant that is located on or contiguous to a construction site and that provides concrete only to the construction site that the plant is located on or adjacent to.

"Dedicated sand or gravel operation" means an operation that produces sand and/or gravel for a single construction project.

"Department" means the Iowa Department of Natural Resources.

"Final Stabilization" means that all soil disturbing activities at the site have been completed, and that a uniform perennial vegetative cover with a density of 70% for the area has been established or equivalent stabilization measures have been employed or which has been returned to agricultural production.

"Hazardous condition" means any situation involving the actual, imminent, or probable spillage, leakage, or release of a hazardous substance on to the land, into a water of the state, or into the atmosphere, which creates an immediate or potential danger to the

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

public health or safety or to the environment.
455B.381(2) 1991, Code of Iowa

"Hazardous substance" means any substance or mixture of substances that presents a danger to the public health or safety and includes, but is not limited to, a substance that is toxic, corrosive, or flammable, or that is an irritant or that, in confinement, generates pressure through decomposition, heat, or other means. The following are examples of substances which, in sufficient quantity may be hazardous: acids; alkalis; explosives; fertilizers; heavy metals such as chromium, arsenic, mercury, lead and cadmium; industrial chemicals; paint thinners; paints; pesticides; petroleum products; poisons, radioactive materials; sludges; and organic solvents. "Hazardous substances" may include any hazardous waste identified or listed by the administrator of the United State Environmental Protection Agency under the Solid Waste Disposal Act as amended by the Resource Conservation and Recovery Act of 1976, or any toxic pollutant listed under section 307 of the federal Water Pollution Control Act as amended to January 1, 1977, or any hazardous substance designated under section 311 of the federal Water Pollution Control Act as amended to January 1, 1977, or any hazardous material designated by the secretary of transportation under the Hazardous Materials Transportation Act (49 CFR 172.101). 455B.381(1), 1991 Code of Iowa

"Municipality" means a city, town, borough, county, parish, district, association, or other public body created by or under State law.

"NOI" means Notice of Intent to be covered by this permit (see Part II of this permit.)

"Outstanding Iowa Waters" means those waters which constitute an outstanding state resource such as waters of exceptional recreational or ecological significance. These waters are identified in Appendix B of the Iowa Antidegradation Implementation Procedure manual.

"Outstanding National Resource Waters" means those waters which constitute an outstanding national resource such as waters of national and state parks and wildlife refuges and also waters of exceptional recreational or ecological significance. These waters are identified in Appendix B of the

Iowa Antidegradation Implementation Procedure manual.

"Permittee" means the owner of the facility or site.

"Qualified personnel" means those individuals capable enough and knowledgeable enough to perform the required functions adequately well to ensure compliance with the relevant permit conditions and requirements of the Iowa Administrative Code.

"Runoff coefficient" means the fraction of total rainfall that will appear at the conveyance as runoff.

"Storm Water" means storm water runoff, snow melt runoff, and surface runoff and drainage.

"Storm water discharge associated with industrial activity" means the discharge from any conveyance which is used for collecting and conveying storm water and which is directly related to manufacturing, processing or raw materials storage areas at an industrial plant. The term does not include discharges from facilities or activities excluded from the NPDES program under 40 CFR part 122. For the categories of industries identified in paragraphs (i) through (x) of this definition, the term includes, but is not limited to, storm water discharges from industrial plant yards; immediate access roads and rail lines used or traveled by carriers of raw materials, manufactured products, waste material, or by-products used or created by the facility; material handling sites; refuse sites; sites used for the application or disposal of process waste waters (as defined at 40 CFR part 401); sites used for the storage and maintenance of material handling equipment; sites used for residual treatment, storage, or disposal; shipping and receiving areas; manufacturing buildings; storage areas (including tank farms) for raw materials, and intermediate and finished products; and areas where industrial activity has taken place in the past and significant materials remain and are exposed to storm water.

For the categories of industries identified in paragraph (xi) of this definition, the term includes only storm water discharges from all the areas (except access roads and rail lines) that are listed in the previous sentence where material handling

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

equipment or activities, raw materials, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water. For the purposes of this paragraph, material handling activities include the storage, loading and unloading, transportation, or conveyance of any raw material, intermediate product, finished product, by-product, or waste product. The term excludes areas located on plant lands separate from the plant's industrial activities, such as office buildings and accompanying parking lots as long as the drainage from the excluded areas is not mixed with storm water drained from the above described areas. Industrial facilities (including industrial facilities that are Federally, State, or municipally owned or operated that meet the description of the facilities listed in these paragraphs (i)-(xi) of the definition) include those facilities designated under 40 CFR 122.26(a)(1)(v). The following categories of facilities are considered to be engaging in "industrial activity" for purposes of this definition;

(i) Facilities subject to storm water effluent limitations guidelines, new source performance standards, or toxic pollutant effluent standards under 40 CFR Subchapter N (except facilities with toxic pollutant effluent standards which are exempted under category (xi) of this definition);

(ii) Facilities classified as Standard Industrial Classifications 24 (except 2434), 26 (except 265 and 267), 28 (except 283 and 285), 29, 311, 32 (except 323), 33, 3441, 373;

(iii). Facilities classified as Standard Industrial Classifications 10 through 14 (mineral industry) including active or inactive mining operations (except for areas of coal mining operations no longer meeting the definition of a reclamation area under 40 CFR 434.11(1) because the performance bond issued to the facility by the appropriate SMCRA authority has been released, or except for areas of non-coal mining operations which have been released from applicable State or Federal reclamation requirements after December 17, 1990) and oil and gas exploration, production, processing, or treatment operations, or transmission facilities that discharge storm water contaminated by contact with or that has come into contact with, any overburden, raw material, intermediate products, finished products, byproducts or waste products located on the site of such operations; (inactive mining

operations are mining sites that are not being actively mined, but which have an identifiable owner/operator; inactive mining sites do not include sites where mining claims are being maintained prior to disturbances associated with the extraction, beneficiation, or processing of mined materials, nor sites where minimal activities are undertaken for the sole purpose of maintaining a mining claim);

(iv) Hazardous waste treatment, storage, or disposal facilities, including those that are operating under interim status or a permit under Subtitle C of RCRA;

(v) Landfills, land application sites, and open dumps that receive or have received any industrial wastes (waste that is received from any of the facilities described under this subsection) including those that are subject to regulation under Subtitle D of RCRA;

(vi) facilities involved in the recycling of materials, including metal scrap yards, battery reclaimers, salvage yards, and automobile junkyards, including but limited to those classified as Standard Industrial Classification 5015 and 5093;

(vii) Steam electric power generating facilities, including coal handling sites;

(viii) Transportation facilities classified as Standard Industrial Classifications 40, 41, 42 (except 4221-4225), 43, 44, 45 and 5171 which have vehicle maintenance shops, equipment cleaning operations, or airport deicing operations. Only those portions of the facility that are either involved in vehicle maintenance (including vehicle rehabilitation, mechanical repairs, painting, fueling, and lubrication), equipment cleaning operations, airport deicing operations, or which are otherwise identified under paragraphs (i)-(vii) or (ix)-(xi) of this definition are associated with industrial activity;

(ix) Treatment works treating domestic sewage or any other sewage sludge or wastewater treatment device or system, used in the storage treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated to the disposal of sewage sludge that are located within the confines of the facility, with a design flow of 1.0 mgd or more, or required to have an approved pretreatment program under 40 CFR 403. Not

IOWA DEPARTMENT OF NATURAL RESOURCES NPDES GENERAL PERMIT NO. 2
STORM WATER DISCHARGE ASSOCIATED WITH INDUSTRIAL ACTIVITY FOR CONSTRUCTION ACTIVITIES
EFFECTIVE DATE - OCTOBER 1, 2012 TO OCTOBER 1, 2017

included are farm lands, domestic gardens or lands used for sludge management where sludge is beneficially reused and which are not physically located in the confines of the facility, or areas that are in compliance with 40 CFR 503;

(x) Construction activity including clearing, grading and excavation activities except: operations that result in the disturbance of less than one acre of total land area which are not part of a larger common plan of development or sale;

(xi) Facilities under Standard Industrial Classifications 20, 21, 22, 23, 2434, 25, 265, 267, 27, 283, 285, 30, 31 (except 311), 323, 34 (except 3441), 35, 36, 37 (except 373), 38, 39, 4221-4225, (and which are not otherwise included within categories (ii)-(x));

"Storm water discharge associated with industrial activity for construction activities" means activities that fall under subparagraph (x) in the definition of storm water discharge associated with industrial activity.

"Topsoil" means the fertile, uppermost part of the soil containing significant organic matter largely devoid of debris and rocks and often disturbed in cultivation.

"Uncontaminated groundwater" means water that is potable for humans, meets the narrative water quality standards in subrule 567-61.3(2) of the Iowa Administrative Code, contains no more than half the listed concentration of any pollutants in subrule 567-61.3(3) of the IAC, has a pH of 6.5-9.0 and is located in soil or rock strata.



James L. Lowrance, Mayor
Randy A. Wetmore, City Administrator
36 North Center Street
Marshalltown, IA. 50158-4911
Tel - (641) 752-3154
Fax - (641) 754-5742

March 6, 2014

Dear Mr. Arnold:

This letter is in response to the documents you sent to this office on behalf of Interstate Power and Light (IPL) dated March 3, 2014, regarding the Marshalltown Generating Station (MGS).


As you are aware, the City of Marshalltown's site plan approval process takes place concurrently with the building permit process. As such, I am unable to issue any formal site plan approval permits for the MGS at this time but rather inform you that the plans, as presented, **will be approved** at the time IPL or its designated Contractor applies for the construction permits. With the exception of the public right-of-way on East Nevada Street, which will require a public sidewalk, the plans are acceptable to this office.

The plans, as presented, meet zoning regulations in regards to building setbacks, height (a height variance for 130' buildings was approved February 18, 2014), and required parking.

This office will require no additional documents or permit applications in regards to the site plan or site layout of the MGS project.

If you have any questions about this zoning, please contact me at 641-752-3154 or stroskey@ci.marshalltown.ia.us.

Thank you,



Stephen Troskey
City Planner
City of Marshalltown, Iowa

CC: City of Marshalltown Engineering Office

CITY COUNCIL:
*Leon Lamer, Bob Schubert, Mike Gowdy,
Joel Greer, Al Hoop, Bethany Wirin, Bill Martin*



The City of Marshalltown, Iowa
James L. Lowrance, Mayor
Randy A. Wetmore, City Administrator
Lynn E. Couch, Public Works Director
24 N. Center Street
Marshalltown IA 50158-4911
Tel - (641) 754-5734
Fax - (641) 754-5717
EMail - lcouch@ci.marshalltown.ia.us

PUBLIC WORKS DEPARTMENT

DEPARTMENT OF PUBLIC WORKS
CONSTRUCTION SITE EROSION AND SEDIMENT CONTROL
PERMIT

STORM WATER DISCHARGE ASSOCIATED WITH CONSTRUCTION ACTIVITY

A permit is hereby granted to discharge storm water in compliance with City of Marshalltown Municipal Code, Article VI Erosion and Sediment Control for Construction Sites

Owner:
CITY OF MARSHALLTOWN
36 N. CENTER ST.
MARSHALLTOWN, IOWA 50158
641-754-5734

Permit Coverage Issued To:
MARSHALLTOWN – INTERSTATE POWER & LIGHT COMPANY
P.O. BOX 351
CEDAR RAPIDS, IOWA 52406
In: MARSHALLTOWN, MARSHALL COUNTY

Located at: 2115 E. NEVADA ST.

Coverage Provided Through: 5/1/2018

Marshalltown Permit Number: 2014-002

NPDES Permit Discharge Authorization Number: 24847 - 24589

Discharge Authorization Date 5/1/2014

**Project Description: CONSTRUCTION OF A NOMINAL 600 MW COMBINED CYCLE
NATURAL GAS FIRED POWER ELECTRIC GENERATION PLANT AND ASSOCIATED
LINEAR FACILITIES 115 ACRES**

Brad T. Bateman, Civil Engineer 



Housing & Community Development

James L. Lowrance, Mayor
Randy A. Wetmore, City Administrator
36 North Center Street
Marshalltown, IA 50158-4911
Tel - (641) 752-3454
Fax - (641) 754-5742

February 20, 2014

To whom it may concern:

This letter is to confirm Interstate Power and Light applied for, and was granted, a variance to the building height regulations in the City of Marshalltown.

Zoning Regulations in the City of Marshalltown allow for buildings in the M2 Heavy Industry district to have a height of up to 100 feet. On February 18, 2014, the Marshalltown Board of Adjustment voted 4-0 to allow construction of the Marshalltown Generating Station to be up to and including 130 feet in height.

There were no restrictions or conditions put upon this approval.

All smokestacks and similar structures are exempt from City of Marshalltown height regulations so long as they meet FAA regulations.

If you have any questions about this zoning, please contact me at 641-752-3154 or stroskey@ci.marshalltown.ia.us.

Thank you,



Stephen Troskey
City Planner
City of Marshalltown, Iowa

CITY COUNCIL:
*Leon Lamer, Bob Schubert, Marla Grabenbauer,
Joel Greer, Al Hoop, Bethany Wirin, Bill Martin*