

- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy

Information Request No. 6

Docket No.: E002/M-19-666

Response To: Fresh Energy

Requestor: Isabel Ricker

Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) page 100.

Request:

- A. Please provide all interim and/or final reports or presentations with findings from the CEE geo-targeting demand response pilot.
- B. The Company states that, at the time the pilot site was identified, the estimated capacity need was 1.5 MVA. Please provide an updated estimate of the capacity need in the pilot site.

Response:

- A. The geo-targeting pilot is managed by Center for Energy and Environment (CEE). The pilot itself is to review and determine whether a non-wires alternative focusing on energy efficiency and demand response could defer a distribution need. Another important insight into this is how long it would take to accomplish the necessary changes.

CEE has provided the Company with three exhibits showing progress to-date, which we provide as Attachments A, B, and C to this response, as follows:

- Attachment A – Exhibit 1: Stakeholder Presentation July 2019
- Attachment B – Exhibit 2: AESP Conference Presentation
- Attachment C – Exhibit 3: Pilot Dashboard January 2020

- B. When the pilot site was identified in 2018, the estimated capacity need was 1.5 MVA. The site was chosen due to the mix of customers available for CEE's pilot, the location and a capacity need that was identified for several years into the future. This timeframe provides more time for CEE to analyze and address the projected capacity need through non-traditional means. The most recent forecast

shows the capacity need no longer exist for this area; however, this could change. For purposes of the pilot, the results will still be compared to the original estimation of a 1.5 MVA need to assess whether or not that need could be addressed with the non-traditional actions.

CEE's Geo-Targeting pilot is still ongoing and is set to conclude in June of 2020. The pilot should indicate whether non-traditional resources could have been used to eliminate or delay a 1.5 MVA need in this area in a cost-effective manner.

Preparer: Jessica Peterson
Title: Sr. Regulatory Analyst
Department: Customer Solutions
Telephone: 612.330.6850
Date: January 23, 2020

Geo-targeted Distributed Clean Energy Initiative

Non Wires Alternative Stakeholder Meeting

July 10, 2019



• Advanced and Integrated Grid Projects

- Advancing load as a resource in a modernized and low carbon grid
- Strategic and beneficial electrification
- Load shifting for renewables integration
- Energy efficiency in distribution planning



Project Funding

- Three year grant from the Legislative Citizen's Commission on Minnesota Resources (LCCMR)
 - Environmental trust fund – supports a variety of natural resource conservation efforts
 - 17-member Board, appropriate ~\$50 million per year
- CEE and Xcel Energy collaborating using current programs
- Additional support from the McKnight Foundation

CEE Core Team: Planning



Jenny Edwards
Principal Investigator (Planning)



Josh Quinnell
Grid & DER Analysis



Rabi Vandergon
Project Manager &
Data/GIS Analysis



Lauren Sweeney
Customer &
DER Analysis

CEE Core Team: Implementation



Jenny Edwards
Principal Investigator (Planning)



Carl Nelson
Principal Investigator
(Implementation)



Rabi Vandergon
Project Manager



Jon Blaufuss
Business Strategies Lead



Ashley Robertson
Marketing Lead



Kristen Funk
Director of Commercial
Programs




Stacy Boots Camp
Residential Strategies Lead




Non Wires Alternatives Overview

Non-Wires Definition


- Geotargeting = Non-Wires Alternative = Non-Wires Solution
- Locally targeted distributed energy resources (DER) to avoid the need for capital investments in the traditional distribution or transmission system (“Wires”)



Electric Power System Overview



“Wires” Capacity upgrades




Non-Wires Principles

- The non-wires project should cost less than the present value of the avoided wires project
- Large projects can defer transmission lines or substations; smaller projects can address transformers or feeders
- Larger projects need more deferral, but will have higher budgets and larger footprints to work with.


Non-Wires Cost Wires Cost
\$ < \$

Typical mainline distribution feeder with three sections capable of system intact N-0 and first contingency N-1 operations




(Xcel Energy 2017)


Examples of Other NWA Projects



Geotargeting Projects by Stage



Projects vary in scale



Context in Minnesota

- No existing mandate or incentive framework to pursue non-wires projects
- Pilots have been considered or proposed in some cases
- Utilities that file Integrated Distribution Plans with the MN PUC report on the number of potential projects
- Non-Pipes alternatives are also something to consider




Summer Savings Pilot


CEE Pilot: Learning Objectives

- What types of distribution system needs offer the best opportunity for DER?
- **To what extent can location-specific targeting with additional customer incentives lead to increased DER?**
- What customer end-use characteristics make for the best opportunities? Can the DER screening process be automated?
- What is the statewide potential for non-wires solutions to defer distribution upgrades?
- What type of program and policy changes are needed to support non-wires solutions in Minnesota?

Overall Project Timeline




Steps to Delivering NWA Resource





System Overview

Initial Site Evaluation



Developing Deferral Criteria


DISTRIBUTION NEEDS

- Project Timeframe
- Driving Need for Upgrade:
 - Load Growth / Capacity
 - Age of infrastructure
 - Reliability
 - New Development
- Project Cost
- Others

DER POTENTIAL

- Building and load type
- Customer type
- Customer propensity for action
- Land use
- Procurement “Scopability”
- Others

Non-wires solution deferral concept



Project Cost for Traditional Solution

- \$3.3 M total cost estimate in 2022 or later
- 1-year project deferral requires 0.5 MVA of savings
- Amounts to a value of \$152,050

BUDGET (TOTAL \$)	
	Year 1 Δ NPV
Proposed → 1-YEAR DEFERRAL (0.5 MVA)	(\$152,050)
Achievable → 2-YEAR DEFERRAL (1.0 MVA)	(\$295,361)
3-YEAR DEFERRAL (1.5 MVA)	(\$430,520)




System Analysis Overview

Screening Distribution Projects

- System/Project Needs:
 - Upgrade need is based on capacity
 - Capacity need is 3 - 5 years out
 - Project need is at the feeder level (versus substation)
 - Estimated project cost is > \$400,000
 - No community solar plans
 - Historical system data available
- Customer Types:
 - Representative balance of residential and business customers
 - Not dominated by a single large customer (> 20% of the load)
 - Over 1,000 customers

Initial Site Evaluation



Selection Criteria


Key Criteria

- Load at risk (MVA)
- Project Cost (\$)
- Customer Count (#)


Other Criteria

- Residential and Commercial Monthly Peak Factor
- Community Solar Garden Potential
- Loads by Customer Segment
- DR Penetration
- Location: Metro / non-Metro
- Distribution location: Substation / Feeder
- Project type
- Annual Energy (kWh)
- Monthly Peak (kWh)


Project Cost per Load at Risk



Load at Risk per Customer




Project Cost per Customer







Project Details

- Between 1.6 – 2.5 MVA load at risk in 3-5 years
- Project is “N-1” risk, meaning if there is an outage, not all of the predicted load can be transferred.
- Traditional wires is new 35 kV transformer and feeder and existing reconfigure feeders




Understanding System Needs

- Analyze 3 – 5 years of system data at the substation, transformer, and feeder levels
- Identify when and why do peak events occur
- Consider variations peak events across the system




• Peak Load versus Peak Characteristics

- Peak load for capacity planning
- Peak characteristics for how EE / DR will influence peaks




• Feeder Contribution to Peak Load

- Each feeder has its own characteristics



Final Estimate of N-1 Load at Risk



Project Cost for Traditional Solution


- \$3.3 M total cost estimate in 2022 or later
- 1-year project deferral requires 0.5 MVA of savings
- Amounts to a value of \$152,050

BUDGET (TOTAL \$)		
		Year 1 Δ NPV
Proposed →	1-YEAR DEFERRAL (0.5 MVA)	(\$152,050)
Achievable →	2-YEAR DEFERRAL (1.0 MVA)	(\$295,361)
	3-YEAR DEFERRAL (1.5 MVA)	(\$430,520)




Site Characteristics & Strategy

Sartell and Sauk Rapids, MN



Pilot Area Customer Base



Two-Pronged Strategy


1. Energy Efficiency and New Demand Response

- Use enhanced incentives and targeted marketing of existing programs to achieve higher goals in a shorter timeframe
- Goal of 500 kW locally coincident demand reduction

2. Existing Demand Response

- Activate existing DR in targeted location
- Examine customer response, potential attrition, etc.
- Goal of verifying 500 kW demand reduction

Strategy 1: EE and New DR



EE and New DR Impact

	Average Annual Participants (2015- 2017)	Geotargeting Incremental Participants	Total 2019 Participants	Geotargeting Demand Reduction (kW)
Home Energy Squad (Lighting Reduction)	20	130	150	51 kW
Home Lighting (Bulb Giveaways)	--	1,200	1,200	21 kW
Residential Demand Response (AC Rewards)	18	80	98	70 kW
Residential Smart Thermostat (Direct Install)	--	80	80	0 kW
Commercial Refrigeration (Including Custom)	--	7	7	83 kW
Commercial Lighting Efficiency	28	24	52	223 kW
One Stop Efficiency Shop (Small Business Lighting)	18	16	34	69 kW
Commercial Cooling Efficiency	11	7	18	14 kW
Total Demand Reduction				546 kW

Strategy 2: Existing Demand Response


- Activate existing customer resource in this targeted location
- Current Subscriber Count:

	Customer Count	Total Subscribed (kW)
Residential Saver's Switch	4,451	3,286
Saver's Switch for Business	518	698




Targeting Customers


Targeting residential premises (with fake data)



Targeting residential premises (with fake data)



Results from cleaned residential utility data




Targeting businesses

- High summer kW
- Business type (e.g. grocery store vs. school)
- Past demand side management (energy efficiency or demand response) program participation
- Aerial imagery analysis for cooling opportunities



Business blitz

- Door to door in focused areas
- Ranked by summer kW
- Warm leads (prior DSM)





Pilot Progress & Early Lessons

Marketing to customers

- Direct mail and email to customers
- City website content
- Social media
- City meetings (Chamber of Commerce, etc.)
- Business blitz

JUMP INTO SUMMER SAVINGS

Xcel Energy is teaming up with the cities of Sartell and Sauk Rapids to offer residents the chance to save money on utility bills with the City Summer Savings Program.

Schedule a visit
Residents can schedule a home energy visit for FREE. Call 651-328-6226 to schedule your visit today. *Visits are for one-on-one home visits; your visit is completed by August 31.

Complete your visit
Two energy experts from an Xcel Energy qualified service provider will come to your home and install energy saving materials on the spot for free. *Options may include: LED light bulbs, high-efficiency thermostats and smart meters, door weather stripping, seal strips.

Sign up for AC Rewards
If compatible with your home's cooling and related communication systems, you can have an outdoor smart thermostat installed free when you enroll in Xcel Energy's AC Rewards program.

Don't delay, schedule your visit today! Call 651-328-6226
Xcel Energy must be your electric service provider.

Xcel Energy® Sartell Sauk Rapids

ENERGY SAVINGS OPPORTUNITIES FOR BUSINESSES

Xcel Energy is teaming up with the cities of Sartell and Sauk Rapids to offer the City Summer Savings Program. Business owners will have the chance to save money on their utility bills by upgrading inefficient equipment and taking advantage of available rebates.

Bonus rebates from Xcel Energy are available for businesses that complete recommended upgrades — for a limited time only.

Xcel Energy® Sartell Sauk Rapids

JUMP INTO SUMMER SAVINGS

Illustration of a utility worker in a yellow shirt and blue cap holding a clipboard, interacting with a woman in a red jacket who is pointing at a smart thermostat displaying '75'.

Xcel Energy® Sartell Sauk Rapids

Initial Lessons

- Billing data vs. usage data
- Context of NWA within CIP
- Targeted marketing vs. enhanced incentives
- Political boundaries (cities) vs. feeder boundaries
- Using existing assets (e.g. DR) versus acquiring new

Pilot lessons to come

- Outreach channel success
 - Residential
 - Business
- Comparison of participation vs. baseline
- Verification of load reduction
 - Potential DR (figuring out operational details, TBD)
 - Deemed efficiency
 - Next summer – dependent upon hot days

High Level Takeaways

- Peak needs (and therefore non-wires solutions) can be highly variable at the feeder level
- There are untapped opportunities for customer segmentation to focus on peak reduction opportunities – but also paralysis by analysis.
- The “runway” for acquiring targeted non-wires alternatives is a key variable but this can be shortened with program design
- Working with the communities has been critical for success to date

Findings From Other Project Examples


- Predicted load growth does not always materialize
- Large and diverse customer subset is beneficial
- Implementers often leverage existing programs versus create new
- Efficiency/ DR remain lowest cost options, battery highest, though higher value in firm resources for grid operators



Next Steps

- Goal to finalize pilot signups by August 2019, with projects completed at the end of this year
- We will be evaluating statewide potential for these types of projects
- Report out will include:
 - Achieved participation and savings
 - Pilot costs
 - Program design opportunities to integrate non-wires alternatives

Questions?




WHEN SUMMER SERVES A HOTDISH OF PEAK LOAD, DERS TAKE ACTION

A summary of
Minnesota's
first non-wires
alternative pilot


KEY CONCEPTS: NON-WIRES ALTERNATIVES

- NWA projects use geographically-targeted distributed energy resources to avoid the need for capital investments in transmission or distribution systems
- The non-wires project provides value by deferring or reducing (but not necessarily totally avoiding) the need for infrastructure investment

(for our project: deferral value = net present value of interest & other capital costs avoided, for the number of years the investment is deferred)




MINNESOTA UTILITY SALES



Source: EIA. 2018. [Annual Electric Power Industry Report, Form EIA-861 detailed data files.](#)

EEVOLUTION


ENERGY EFFICIENCY LEADERSHIP



Source: ACEEE. 2018. [The State Energy Efficiency Scorecard](#)


EEVOLUTION

TOP 10 US STATES FOR DEMAND SAVINGS (MW)




Source: EIA. 2018. [Annual Electric Power Industry Report, Form EIA-861 detailed data files.](#)


OVERALL RESEARCH QUESTION: CAN WE EXPAND THE USE OF NON-WIRES ALTERNATIVES IN MN?



OVERALL PROJECT TIMELINE




SITE SELECTION




EEVOLUTION

SITE CHARACTERISTICS



ESTIMATE OF LOAD AT RISK




EEVOLUTION

DER PROGRAM GOALS

	2019 Participant Goal	% Increase from Average	Total Budget Increase	Demand Reduction (kW)
Residential Lighting – Direct Install	150	650%	\$10,500	51
Residential Bulb Giveaway (New)	1,200	N/A	\$1,332	21
Residential Smart Thermostats	80	340%	\$13,200	70
Commercial Refrigeration (New)	7	N/A	\$24,900	83
Commercial Lighting – Large Business	52	86%	\$66,924	223
Commercial Lighting – Small Business	34	89%	\$20,706	69
Commercial Cooling	18	64%	\$4,200	14
Total			\$141,762	531

EEVOLUTION

DER LOAD SHAPES



EXISTING DEMAND RESPONSE

- High penetration of existing demand response enrollment on target feeders
- Current subscriber count:

	Customer Count	Total Subscribed (kW)
Residential Saver's Switch	4,451	3,286
Saver's Switch for Business	518	698

RESIDENTIAL ANALYSIS



BUSINESS ANALYSIS

- High summer kW
- Business type
- Past program participation
- Aerial imagery analysis for cooling opportunities



EEVOLUTION

COMMUNITY BASED MARKETING



JUMP INTO SUMMER SAVINGS

Xcel Energy is teaming up with the cities of Sartell and Sauk Rapids to offer the City Summer Savings Program. Business owners will have the chance to save money on their utility bills by upgrading inefficient equipment and taking advantage of available rebates.

Two energy experts from our service provider will come to your business to assess your energy saving materials. Options may include high-efficiency windows, doors, weatherstripping, and more.

ENERGY SAVINGS OPPORTUNITIES FOR BUSINESSES

Xcel Energy is teaming up with the cities of Sartell and Sauk Rapids to offer the City Summer Savings Program. Business owners will have the chance to save money on their utility bills by upgrading inefficient equipment and taking advantage of available rebates.

Bonus rebates from Xcel Energy are available for businesses that complete recommended upgrades — for a limited time only.


Xcel Energy

EEVOLUTION


BUSINESS AUDITS



RESULTS TO DATE: RESIDENTIAL REFERRAL SOURCES




RESULTS TO DATE: RESIDENTIAL VISITS AND THERMOSTAT INSTALLATIONS



EVOLUTION

RESULTS TO DATE: BUSINESS AUDITS AND COMPLETED PROJECTS



EARLY TAKEAWAYS

- Existing demand response resources can be deployed at a distribution level



Presenter's Direct Load
Control Switch on AC Unit

EARLY TAKEAWAYS

- Existing demand response resources can be deployed at a distribution level
- **Non wires alternative pilots can be useful to break down internal silos**



Source: [Good Free Photos.](#)

EEVOLUTION

EARLY TAKEAWAYS

- Existing demand response resources can be deployed at a distribution level
- Non wires alternative pilots can be useful to break down internal silos
- **Higher and faster penetration of existing programs is achievable**

JUMP INTO SUMMER SAVINGS

Xcel Energy is teaming up with the cities of Sartell and Sauk Rapids to offer residents the chance to save money on utility bills with the City Summer Savings Program.



Schedule a visit

Residents can schedule a home energy visit for FREE. Call 651-328-6226 to schedule your visit today. Visits are limited—you must have your visit completed by August 31.



Complete your visit

Two energy experts from an Xcel Energy-qualified service provider will come to your home and install energy saving materials on the spot for free. Options may include: LED light bulbs, high-efficiency showerheads and faucet aerators, door weather stripping, and more.



Sign up for AC Rewards

If compatible with your home's cooling and internet communication systems, you can have an ecobee smart thermostat installed free when you enroll in Xcel Energy's AC Rewards program.

Don't delay, schedule your visit today! Call 651-328-6226
Xcel Energy must be your electric service provider.



EEVOLUTION

EARLY TAKEAWAYS

- Existing demand response resources can be deployed at a distribution level
- Non wires alternative pilots can be useful to break down internal silos
- Higher and faster penetration of existing programs is achievable
- **Tight budget – heavy lift**



EEVOLUTION

EARLY TAKEAWAYS

- Existing demand response resources can be deployed at a distribution level
- Non wires alternative pilots can be useful to break down internal silos
- Higher and faster penetration of existing programs is achievable
- Tight budget – heavy lift
- **Partnering with local communities can pay off, even with boundary challenges**



EEVOLUTION



Thank you for attending our Summer Conference!

**Register for AESP's Certificate of Excellence DSM
Program Management Cohort in Toronto**



October 7-10, 2019

A.E.S.P.
ASSOCIATION OF ENERGY
SERVICES PROFESSIONALS
EEVOLUTION


GEOTARGETING

RESIDENTIAL


Residential Visit and Thermostat Goals & Status



Residential Visits - Referral Source



kW Goal Status by Item




GEOTARGETING

COMMERCIAL


Business Blitz Results

	Date ^	Businesses visited	Audit sign ups
1.	Jul 11, 2019	82	8
2.	Jul 16, 2019	64	11
3.	Jul 24, 2019	127	7
4.	Jul 29, 2019	128	9
1 - 4 / 4 < >			


Commercial Audit Sign Ups



Commercial Completed Jobs Goals & Status



kW Goal Status by Sector



- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy

Information Request No. 7

Docket No.: E002/M-19-666

Response To: Fresh Energy

Requestor: Isabel Ricker

Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) page 107.

Request:

Please provide all data, analysis, studies, reports, or spreadsheets with all formulas and links intact supporting the Company's claim of the "need to improve reliability on those elements of the system that are the closest to our customers as well as provide the infrastructure to support increased DER integration."

Response:

Northern States Power Company objects to this Request as overly broad and unduly burdensome. Subject to the foregoing objection, we respond as follows:

The programs we propose as part of our ISI initiative may support both reliability and improving the distribution system's readiness to support increased Distributed Energy Resources (DER) integration. We do not, however, maintain spreadsheets or workpapers specific to each of these objectives. That said, please see our response to Fresh Energy Information Request No. 2 for discussion regarding reliability. In this response, we discuss ISI in relation to increased DER integration.

Design standards for our NSP system have evolved since significant portions of the system were originally designed and installed. Over time, our typical specifications for transformer and wire size have increased, and our current NSP design standards provide both increased capacity and better impedance attributes over what may have been historically installed. Replacing older equipment with equipment that satisfies our current design standards is one way we can support higher adoption levels of DER and electric vehicles (EV).

A tangible example contemplated by ISI is the replacement of 25kVA transformers, which was a common design standard for a shared secondary service to neighboring residential customers, with 50kVA transformers, which is our current design standard. Such upgrades to transformers and related secondary replacements increase the capacity of the system, which increases the level of DER or EV that can be accommodated without voltage and/or thermal impacts.

We also note that Xcel Energy is a participant in Electric Power Research Institute's (EPRI) DER integration research and working group, and there has been much discussion around how pockets of distributed solar resources connected in localized areas can contribute to high voltage situations. Programs we propose as part of our ISI initiative would address this through targeted equipment upgrades, such as the transformer example noted above and as further discussed in our response to FE-11.

Finally, please also see our response to FE-9 for discussion regarding preliminary efforts we have underway to gain insights into the design of our residential secondary service in relation to EV charging. We also outline the work we are currently doing with NREL to model and analyze the impacts of higher penetrations levels of EVs on our Minnesota distribution system.

Preparer:	Betsy Coppock	<i>As to Objection Only:</i> Matt Harris
Title:	Principal Engineer	Principal Attorney
Department:	Electric System Performance	General Counsel
Telephone:	303.571.3537	612-330-7641
Date:	January 30, 2020	

- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy

Information Request No. 9

Docket No.: E002/M-19-666

Response To: Fresh Energy

Requestor: Isabel Ricker

Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) page 110.

Request:

Please provide all data, analysis, studies, reports, or spreadsheets with all formulas and links intact supporting the Company's claim that its system is in need of investment to "prepare ... for electric vehicle penetration in advance of rapid and widespread customer adoption."

Response:

Northern States Power Company objects to this Request as overly broad and unduly burdensome. Subject to the foregoing objection, we respond as follows:

Our work on preparing our distribution system for electric vehicle (EV) adoption to date has involved high-level or preliminary analysis pertaining to the clustering of EV charging (level 2) on a residential secondary service. We are conducting this work to develop a framework that would help to identify areas for further analysis and research, as well as to identify potential pathways for cost-effectively increasing EV hosting on secondary services, while limiting customer impacts that can result in outages, such as those we discuss below.

The kinds of impacts we are beginning to examine in relation to residential EV charging include: feeder and secondary service voltage and thermal management, and other operational considerations including power quality and switching limitations. One of our objectives is to gain insights into the effects of EV charging on secondary service designs to ensure our current and legacy residential secondary service designs are capable of meeting the loading (thermal), voltage and power quality performance limits in a variety of scenarios of EV growth.


Preliminary findings from our work identified potential system elements, primarily older and smaller conductor and transformers that may require upgrading to accommodate clustered EV loads. The upgrades that may be necessary appear to be largely due to low voltage concerns but also overloads in some cases.

This residential customer-level focus is appropriate because we expect that 80 percent to 85 percent of light weight vehicle charging will be done at home, with some shift to workplace and other commercial charging as such infrastructure becomes available. We also expect that battery electric vehicles (BEV), which are best supported at the residential level by Level 2 (240 V) charging equipment, will predominate the EV market. Level 2 chargers comprise a range of higher capacity options (generally from 5-10 kW, but potentially as high as 19 kW) which place a greater demand on the distribution system than that of Level 1 (120 V) chargers. Today, the residential system has many small 25kV and 37.5kV transformers along with smaller wires. Many of these transformers and wires have been in place for decades and have gradually supported increases in load as customers adopt new technology. Electric vehicle charging load has the potential to be too large of a step increase on the current infrastructure, such that it may have difficulty adequately supporting the new level of load in some locations.

In addition, we expect that electric vehicles will cluster in certain neighborhoods, but the impacts of such clustering have not been well studied. Today, industry EV studies largely focus on the higher level aggregate impacts, such as generation adequacy or impacts to system load growth. Where studies do address distribution impacts, EV clustering is not significantly addressed, and there is little to no consideration of neighborhoods built to legacy design practices. We look forward to additional industry analysis in this area to complement the work that we are doing directly. In the future, we intend to leverage advanced metering infrastructure (AMI) data to help examine EV impacts. For example, we could utilize data analytics to identify issues with transformer overloading or low voltage.

The figure below illustrates the large impact EV charging could play on a neighborhood secondary system compared to historical loads.


Figure [FE-9] 1: Illustration – EV Impact in Relation to Historical Residential Loads



Source: San Diego Gas & Electric

As peak demands increase at the neighborhood level, with larger capacity chargers and EV clustering, voltage drops on the secondary and service conductor will increase with the potential for greater service voltage issues. Low voltage at the meter will likely be the first indicator that the secondary system is inadequate, but outages due to overloaded transformers will also likely occur. The figure below illustrates how quickly the addition of just one EV charger can overload a 25kVA transformer.

Figure [FE-9] 2: Illustration – EV Charger Impact on 25kVA Transformer



Risks posed by the legacy overhead (OH) distribution installations may be mitigated by performing proactive circuit loading analysis to identify locations where infill of

high capacity EV charging has the highest probability of causing overloading and voltage quality issues.


Attachment A to this response is a map showing distribution backyard transformer capacity per customer, illustrating the potential impacts to the residential distribution infrastructure as EV penetration increases. Our analysis is ongoing.

Finally, we note that we are currently working with NREL to model and analyze the impacts of higher penetrations levels of EVs on our Minnesota distribution system. This project is part of a widespread DOE research effort in this area.¹ The project will be modeling 15 feeders on the distribution system with varying adoption levels of EVs on each feeder. The NREL model will compare distribution impacts for both unmanaged and managed charging scenarios. The research project is underway, and we expect results to be available likely later in 2020.

Preparer:	Betsy Coppock	<i>As to Objection Only:</i> Matt Harris
Title:	Principal Engineer	Principal Attorney
Department:	Electric Distribution Engineering	General Counsel
Telephone:	303.571.3535	612-330-7641
Date:	January 30, 2020	

¹ See DOE Announces \$80 Million invested in Advanced Vehicle Technologies Research, <https://www.energy.gov/articles/departments-energy-announces-80-million-investment-advanced-vehicletechnologies-research>

Minnesota KVA Capacity Per Customer



- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy

Information Request No. 11

Docket No.: E002/M-19-666

Response To: Fresh Energy

Requestor: Isabel Ricker

Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) pages 111-113.

Request:

Please provide all data, analysis, studies, reports, or spreadsheets with all formulas and links intact supporting the need to:

- A. Underground 20 miles of overhead tap system in 2021 and 30 miles in 2022.
- B. Reinforce the equipment on up to 900 poles in 2021 and 2022.
- C. Replace the transformer and the associated secondary wire at up to 150 locations in 2021 and 2022.
- D. Address up to 200 different high customer count taps in both 2021 and 2022.

Response:

Northern States Power Company objects to this Request as overly broad and unduly burdensome. Subject to the foregoing objection, we respond as follows:

As we discussed in our response(s) to Fresh Energy IR No(s). 2, 8 and 10, we do not yet have specific plans related to these particular investments. Rather, the ISI represents planned capital investment in the out-years of our 5-year budget cycle that is composed of programs intended to address system interruptions and the customer experience, and improve our system resiliency through a multi-pronged approach. As also discussed in other responses, the specific quantities of system components associated with our ISI plans and discussed in the 2019 IDP for individual ISI programs are estimates and are still being evaluated.

That said, after identifying the categories of investments and underlying programs planned for ISI, as laid out in Attachment A to Fresh Energy IR No. 8, we developed the estimated quantities by first considering high-level dollar estimates associated with each work type, as well as finding a blend of work that would not exhaust engineering, design, construction or material resources in any given time period or area. We believe

this approach strikes an appropriate balance of capital investment across all categories and programs we identified while continuing to maintain our strategic objective to keep customer bills low. While we do not have any final reports or analyses at this time, we discuss several of the referenced ISI program components below, as well as our current thoughts on various opportunities to make our system more resilient to the operational, physical, and electrical stresses it experiences every day – and at the same time, improve service to the customers served from those components of our system. Finally, we note that we intend to deploy ISI programs in a way that allows us to learn and adjust based on our findings throughout the project lifecycle.

ISI Program Insights

Underground 20 miles of overhead tap system in 2021 and 30 miles in 2022. As noted in the IDP, and to provide perspective for this program, we have over 13,000 miles of overhead tap lines. That means the 50 miles of proposed undergrounding represents 0.4 percent of our overhead tap system. This program proposes to underground approximately 50 miles of high impact tap lines that will provide valuable experience and information to guide future work. At the same time, it will yield substantial service performance improvement for customers connected to those lines.

Reinforce the equipment on up to 900 poles in 2021 and 2022. As noted in the IDP, our current pole inspection program flags approximately 2,500 potentially degraded components each year. This ISI program would incrementally increase our focus on improving the resilience of these important system components, which will translate to improved service to customers from less frequent and/or shorter outages.

Replace the transformer and the associated secondary wire at up to 150 locations in 2021 and 2022. This ISI program would take a modest initial step to upgrade aged service transformers and secondary wire on a sample of locations at greatest risk of overload/voltage issues from present and future demands, including growing DER/EV adoption by customers.

Address up to 200 different high customer count taps in both 2021 and 2022. As noted in the IDP, high customer count taps have a large contribution to tap-level SAIDI. This program takes a step toward addressing performance on taps with the highest improvement opportunities. Through this program, we expect to reduce the number of tap outages with high customer counts. We discuss this further on pages 113-114 of the IDP.

Potential System Hardening Opportunities

The Xcel Energy electric distribution system serves customers with an average electric service availability of 99.96 percent (including times of stormy weather). Although the company provides a very high level of service availability, the average customer is still

without electric power 145 minutes per year. Some of the customers experiencing outage events can see total interruption durations many times this level, and, at the same time, customers have an increasing expectation of uninterrupted electric service.

The number and impact of electric system outages increases with greater physical stresses on the system. The design and health of electric distribution assets affects their ability to provide uninterrupted supply of electric power to customers during routine operation and under conditions that place additional operational physical and electrical stresses on the electric distribution system. (e.g. vegetation/trees, wind, ice, electric loading)

Electric distribution outages can be reduced through actions taken to harden distribution assets to stresses they may be subjected to. To harden the distribution system means to increase its resilience (survivability) to stresses that could cause power interruptions and that could damage system components and reduce outage duration if an event were to occur. We discuss below, the implications of these stresses in terms of service disparities among customers and also the system constraints to meet changing customer service demands – both of which will also help to sustain the health and performance of a system, portions of which have been in service for many decades.

Service disparities. Overhead (OH) electric distribution assets have the highest risk for outages stemming from environmental stressors. For example, NSPM All Day System Average Interruption Duration Index (SAIDI) per circuit mile for underground (UG) Tap is approximately 17 percent of OH Tap, and UG Mainline is only about 21 percent of OH Mainline. This illustrates a performance disparity for service to OH customers that focused hardening efforts can improve.

Distribution Constraints. A change with the potential for significant impacts to the distribution system that is beginning to take place is increasing adoption of electric vehicles and the associated demands of home charging. As discussed in our response to Fresh Energy Information Request No. 9, infill of residential electric vehicle load will stretch and in many cases exceed the capability of older distribution secondary lines with small size conductor and small size transformers, causing capacity and voltage constraints. Connection of distributed energy resources (DER) will also have similar impacts. These upgrades will address aging infrastructure while also meeting changing electric distribution service demands, including those stemming from EVs and DER.

Line improvement options include rebuilding OH lines or replacing OH lines with UG lines. At the time of rebuild, we will complete a review of the capacity needs and

consider incorporating capacity upgrades, which may involve incremental cost but provide a better long-term solution.

For example, rebuilding an OH line to increase capacity will upgrade it to current design standards – improving its asset health and service reliability performance while also increasing capacity and power quality performance– however, the many stresses that impact OH systems will remain a threat. Alternatively, converting that same line to UG, we can increase the line capacity and power quality performance – at the same time incrementally improving its resilience beyond an overhead rebuild by eliminating the additional stressors associated with OH lines. Generally, UG construction is more expensive than OH construction, but those increased costs can be offset by the benefits from the increased resilience and customer experience.

Converting lines from OH to UG provides many benefits in terms of improved reliability, avoided costs associated with outage response and maintenance – and qualitative benefits, including public safety and improved aesthetics. Challenges associated with undergrounding previously overhead lines include: (1) obtaining UG construction easements, (2) fewer but generally longer fault repair times (durations can however, be mitigated with looped construction), and (3) deciding which portions are to be undergrounded and which will remain overhead. Cost implications include: (1) higher incremental construction costs compared to OH rebuild and repair of faulted equipment, and (2) lower costs associated with vegetation management and pole inspection, to name a few.

Some of the considerations relevant to determining where we may get the greatest benefit from converting OH to UG rather than rebuilding the OH lines vary by distribution level. At all levels, relevant considerations include:

- The disparity between OH and UG performance
- The customer impact/benefit per avoided interruption event
- Costs and other implications associated with the conversion

Additional considerations specific to each distribution level include the following:

- *Feeder-Level.* The prevalence of remote sensors and controls, such as from Fault Location Isolation and Service Restoration (FLISR), which has the potential to reduce the incremental benefits associated with UG conversion by on average, about 45 percent.
- *Primary-Level.* Significant portions of the aged OH Primary system have degraded components and smaller copper conductor.
- *Secondary-Level.* In addition to changes to Service and Service Entrance

facilities estimated to average several thousand dollars per home, there are potential challenges and costs for customers if it impacts their service panel or other customer-owned equipment. Significant portions of the aged OH secondary system have degraded components and smaller copper conductor.

We note that combined, investments in Secondary, Transformer and Services have about 1/10th the reliability impact of investments in Tap Primary – however, they contribute about 43 percent of outage events during major event days (storms), which is a heavy demand on resources during escalated operations. That said, at this time, we believe investing at the OH Primary level provides the greatest opportunity for hardening to improve system performance – particularly where existing OH is inadequate to serve changing capacity demands, and asset health has deteriorated to the point that the OH assets would require a substantial rebuild to serve the changing load.

We provide Attachment A, which is an example of work we have underway that will assist in identifying areas of opportunity for overhead tap programs. It is a map of our Minnesota service area color-coded based on volume of customer minutes out (CMO) for the 2014-2018 time period, and the location of smaller conductor that may not adequately support changing customer service demands, including those stemming from EVs and DER.


Preparer:	Betsy Coppock	<i>As to Objection Only:</i> Matt Harris
Title:	Principal Engineer	Principal Attorney
Department:	Electric Distribution Engineering	General Counsel
Telephone:	303.571.3535	612-330-7641
Date:	January 30, 2020	

Minnesota CMO 2014 - 2018 All Days

Docket No. E002/M-19-666

FE IR No. 11

Attachment A - Page 1 of 1



- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy

Information Request No. 14

Docket No.: E002/M-19-666

Response To: Fresh Energy

Requestor: Isabel Ricker

Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) pages 116-124.

Request:

Please provide all data, analysis, studies, reports, or spreadsheets with all formulas and links intact supporting the need to:

- A. Replace up to four additional miles of mainline cable in 2021, up to nine additional miles of mainline cable in 2022, 10 additional miles of URD cable in 2021, and up to 12 additional miles of URD cable in 2022.
- B. Perform up to 60 miles of cable assessment and rehabilitation in 2021 and 2022.
- C. In-service up to eight feeder exits in 2021 and 2022.
- D. Replace up to four additional substation transformers in 2021 and approximately 10 additional substation transformers in 2022.
- E. Replace up to 32 breakers, 42 relays, and 5 RTU/LCUs at multiple substation locations across Minnesota during 2022.
- F. Address up to 500 poles with the pole fire mitigation program in 2021 and 2022.
- G. Replace up to 1,000 lighting arrestors in 2021 and 2022.

Response:

Northern States Power Company objects to this Request as overly broad and unduly burdensome. Subject to the foregoing objection, we respond as follows:

With respect to Parts A-E, please see our response to FE-11 for general information about our approach and how we identified ISI program component estimates. We discuss several of the referenced ISI program components below and, as with all ISI programs, note that we intend to deploy ISI programs in a way that we can learn and adjust based on our findings throughout the project lifecycle.

Replace up to four additional miles of mainline cable in 2021, up to 9 in 2022; Additional 10 miles of URD in 2021 and 12 miles in 2022. As noted in the IDP, we have approximately 250 miles of mainline and 2,700 miles of underground tap cables of a legacy design and manufacture that we have learned over time are prone to a significantly shorter useful life than the underground cables we currently install. Failures of underground cables can result in extended repair times. We have ongoing cable replacement programs that have resulted in improvements to underground system reliability performance. This program provides would enhance those existing programs and work to more quickly replace the poorest performing legacy cable on our system.

Perform up to 60 miles of cable assessment and rehabilitation in 2021 and 2022. The degradation of the legacy underground cable population does not occur uniformly. Portions of this cable population may continue to provide good service life if we identify and address weak spots. Modern cable condition assessment technology has the promise of locating weak spots and facilitating informed repair/replace decisions. This program would fund a trial of this underground cable management approach to see if it provides a reliable lower-cost approach to assessing and improving the quality of our electric service to customers.

Address up to 500 poles with pole fire mitigation program in 2021 and 2022. As noted in the IDP we currently have 2,600 mainline poles deemed to be at high risk for pole fire initiation. Pole fires can have a large impact on reliability due to an extended customer interruption time while repairs are completed. The scope of this program would support work to address approximately 20 percent of high risk poles.

Pole fires are initiated by high voltage tracking (conductive path over insulating material) and enhanced by contamination of airborne chemicals. A typical example of this in Minnesota is the chemicals applied for roadway de-icing during the winter. Airborne chemicals settle on the pole and can create a semi-conductive surface when damp, such as from drizzle or light rain.

Poles located along busy roads often support higher capacity electric distribution lines providing electric service to a great number of customers and also see a higher concentration of de-icing chemicals. A greater quantity of electrical equipment attached to the pole increases the opportunity for pole fire initiation. The degree of complexity of equipment attached to the pole also increases the time it takes to restore electric service when there is a problem. The weathered surface of older poles is more conducive to pole fire initiation. Therefore, poles located on high speed busy roads, are older and weathered, and that have a large quantity of electrical equipment attached are considered high risk for a pole fire and lengthy repair times leading us to focus our ISI efforts on these poles.

Mitigation activities to reduce the likelihood of pole fire occurrence include actions taken to interrupt the path of tracking current. This includes enhanced insulating components supporting the high voltage conductors. Examples of enhanced insulation components includes selective use of fog bowl insulators, fiberglass cross-arms and use of conductor support insulators of a higher voltage class than would normally be selected based on the operating voltage of the line. Other mitigations include replacement of degraded components including poles and supporting structures mounted on the poles.

Replace up to 1,000 lightning arrestors in 2021 and 2022. As noted in the IDP, about 90 percent of the SAIDI impact from lightning arrestors is attributable to a few vintage models that make up fewer than 30 percent of the arrestors.

Porcelain arresters are the oldest arresters on our Minnesota system. The mechanism that causes the majority of failures in porcelain arresters is the rubber gaskets at the bottom and/or top of the arrester. If the gasket begins to leak, changing air pressure can draw moisture into the arrester. Then, by either internal faulting or in conjunction with the next arrester operation, water turns to steam and ruptures the porcelain body or expels the sealing end caps. There is no test equipment or visual inspection that can be done to determine if the rubber seal has been compromised. We have not purchased any porcelain arresters since the early-1980s, so all our porcelain arresters on our system are well beyond their 30 year projected operational life. As a result, we believe all of these arrestors will need to be replaced over time, and this proposal is to do so in a systematic way that we believe will be most cost-efficient and will reduce the number of customer outages.

The other type of arrestor that this program would address is polymer-based, but we are able to take a more narrow and targeted approach to addressing. The oldest polymer arrestors on our Minnesota system are also beyond their 30 year projected life, but most brands show no signs of overheating and have not shown problematic failure patterns – with one exception. One manufacturer purchased in the mid-1980s has had a high failure rate. These arresters are easily identifiable and would be replaced.

Preparer:	Betsy Coppock	<i>As to Objection Only:</i> Matt Harris
Title:	Principal Engineer	Principal Attorney
Department:	Electric Distribution Engineering	General Counsel
Telephone:	303.571.3535	612-330-7641
Date:	January 30, 2020	

- ☐ Not Public Document – Not For Public Disclosure
☐ Public Document – Not Public Data Has Been Excised
☒ Public Document

Xcel Energy Information Request No. 24
Docket No.: E002/M-19-666
Response To: Fresh Energy
Requestor: Isabel Ricker
Date Received: January 13, 2020

Question:

Reference:

Xcel's November 1, 2019 Integrated Distribution Plan (IDP) Attachment G2.

Request:

Please provide a spreadsheet containing the data used by the Company to create Figure 1.

Response:

Attachment G2 is the Company's Distribution O&M Profile Trend (2014-2024) for NSPM – Total Company Electric.

As we compiled the data for purposes of this response, we found that the information for historic years 2014 and 2015 provided in our IDP filing was not accurate. As such, in addition to providing the underlying summaries and supporting data as Attachments B – K, we also provide an updated O&M profile chart as Attachment A displaying the corrected amounts. We note that we will also provide the updated 2014-2015 O&M information in our Reply Comments.

Preparer:	Joe Mansur	Nick Paidosh
Title:	Director	Principal Rate Analyst
Department:	Distribution Planning & Performance	Regulatory Affairs
Telephone:	651-229-2286	612-709-4203
Date:	January 23, 2020	