215 South Cascade Street PO Box 496 Fergus Falls, Minnesota 56538-0496 218 739-8200 www.otpco.com (web site)



August 26, 2020

Will Seuffert
Executive Secretary
Minnesota Public Utilities Commission
121 7<sup>th</sup> Place East, Suite 350
St. Paul, MN 55101-2147

RE: In the Matter of Otter Tail Power Company 2019 Annual Safety, Reliability and Service Quality Report and Proposed SAIFI, SAIDI and CAIDI Reliability Standards for 2020 - Docket No. E017/M-20-401 Reply Comments

Dear Mr. Seuffert:

Otter Tail Power Company (Otter Tail and Company) respectfully submits to the Minnesota Public Utilities Commission (Commission) these Reply Comments in response to the Comments received from the Department of Commerce, Division of Energy Resources (Department) dated August 12, 2020 in the above referenced docket.

We appreciate the comments from the Department. Specifically, we provide the additional information requested and responses to matters raised by the Department.

## **Reply to Department's Comments**

1. The Department recommends that Otter Tail keep the Company's reliability standards for 2020 frozen at the level of 2013 goals until Otter Tail demonstrates further improvement in meeting performance goals.

Otter Tail's new Interruption Monitoring System (IMS) utilizes AMI meters in a "bellwether" configuration, i.e. one single phase meter per phase per feeder -or- one three phase meter per feeder. Our old IMS (implemented in 2003) monitored one phase per feeder.

In theory and realized by our reliability results since the installation of our new IMS, we are now capturing more customer minutes and customer interruptions with the addition of monitoring all phases. For this reason, Otter Tail believes our current reliability standards, frozen since 2013, are statistically irrelevant and that a new set of standards should be deployed to accurately monitor future performance trends. As time progresses, our historic baseline of data will more accurately measure trends and reflect overall performance trends. Also, a move towards IEEE benchmarking (proposed), makes this a good time for a reset to our standards.



2. The Department requested that Otter Tail provide in Reply Comments further discussion on whether our new IMS will allow for performance by customer class information to be gathered as discussed in a previous annual report or to explain why this is not possible.

As described previously, Otter Tail's new Interruption Monitoring System utilizes AMI meters in a "bellwether" configuration. Feeders can have a combination of residential, commercial, and industrial; customers, thus, we do not have the capability to distinguish customer class.

Otter Tail will not have the ability to compare performance of **all three classes** until we complete a deployment of an Outage Manage System (OMS) or Advanced Meter Infrastructure (AMI) system. In combination with our new IMS, these systems will provide more granular reporting capabilities.

3. The Department supports establishing a systemwide reliability goal based on IEEE Reliability Working Group 2<sup>nd</sup> quartile results, and to continue to establish work-center-specific goals for Otter Tail.

Otter Tail realizes the benefits of keeping standards consistent between utilities and agrees to utilize a 5-year average of IEEE 2nd quartile threshold (Median) SAIDI, SAIFI, and CAIDI values for "Medium" sized respondents.

As described in our filing, Otter Tail utilizes collaborative efforts to restore service to our customers across our vast rural regions. This is core to our Vision and Mission assertions. We continue to believe that a transition towards a single Minnesota "work area," for reliability performance tracking, would more accurately reflect our restoration efforts.

Reliability indices, in our rural sparsely populated service centers, can be greatly impacted by non-normalized major storm events that hit regionally. Expanding to a Minnesota Customer region would provide for less variability in the indices and provide a better picture of our overall system performance and service to our customers.

Also, IEEE benchmark survey data, that is proposed to establish system reliability standards, utilizes survey data from approximately 90 different utilities, providing reliability results for their entire service territory so reporting for all our Minnesota service territory would provide more comparable results.

4. Should the Commission approve the use of IEEE benchmarking data to establish systemwide reliability goals, the Department supports requiring Otter Tail to make a supplemental filing within 20 days of receiving the benchmarking data from IEEE, proving a comparison of the IEEE 2<sup>nd</sup> quartile benchmarks with the Company's reliability performance.

Otter Tail realizes the benefits of keeping standards consistent between utilities and agrees to utilize a 5 year average of IEEE 2nd quartile threshold (Median) SAIDI, SAIFI, and CAIDI values for "Medium" sized respondents. Otter Tail agrees to a supplemental filing within 20 days of receiving the benchmarking data from IEEE. As an alternative, the filing date of the docket could also be adjusted to align with IEEE data release dates.

5. The Department noted that Otter Tail did not indicate a preference to use the calendar year's numbers or a 5-year average of the IEE benchmarking data.

Otter Tail realizes the benefits of keeping standards consistent between utilities and agrees to utilize a 5 year average of IEEE 2nd quartile threshold (Median) SAIDI, SAIFI, and CAIDI values for "Medium" sized respondents.

6. As it relates to the Department not being able to locate data as indicated on page 34 of Otter Tail's Annual Report.

Otter Tail apologizes for this information not being clearer in the Report. The reference is part of 2. b. (SAIDI, SAIFI, and CAIDI, MAIFI, CEMI, and CELI normalized values calculated using the IEEE 1366 standard) on page 34, not 2. c. (MAIFI – normalized and non-normalized). Also, it was identified during our review of this reference that it is incomplete. Section 2. b. on page 34 should read as follows with changes shown in redline.

b. Attachment B paragraph 2: SAIDI, SAIFI, and CAIDI, MAIFI, CEMI, and CELI normalized values calculated using the IEEE 1366 Standard.

These SAIDI, SAIFI, and CAIDI are previously shown in section IV Reliability Reporting Requirements 7826.0500, Table 4. MAIFI, CEMI, and CELI normalized values follow in Tables 9, 10 and 11.

## Conclusion

Otter Tail Power Company is committed to provide reliable, economical, and environmentally responsible service to our customers. We strive to utilize our existing reliability monitoring tools and assets to proactively provide information indicating where maintenance or upgrades are needed in our system.

We are available to provide any additional information or respond to any questions you may have. Feel free to contact me at (218) 739-8565 or mriewer@otpco.com.

Sincerely,

/s/ MICHAEL RIEWER
Michael Riewer
Manager System Infrastructure/Reliability

cjh
Enclosures
By electronic filing
c: Service List

## **CERTIFICATE OF SERVICE**

RE: In the Matter of Otter Tail Power Company 2019 Annual Safety, Reliability and Service Quality Report and Proposed SAIFI, SAIDI and CAIDI Reliability Standards for 2020

Docket No. E017/M-20-401

I, Carly Haiby, hereby certify that I have this day served a copy of the following, or a summary thereof, on Will Seuffert and Sharon Ferguson by e-filing, and to all other persons on the attached service list by electronic service or by First Class Mail.

Otter Tail Power Company Reply Comments

Dated this 26th day of August, 2020

/s/ CARLY HAIBY

Carly Haiby, Regulatory Filing Coordinator Otter Tail Power Company 215 South Cascade Street Fergus Falls MN 56537 (218) 739-8472

First Name	Last Name	Email	Company Name	Address	Delivery Method	View Trade Secret	Service List Name
Christopher	Anderson	canderson@allete.com	Minnesota Power	30 W Superior St  Duluth,  MN  558022191	Electronic Service	No	OFF_SL_20-401_20-401
Ray	Choquette	rchoquette@agp.com	Ag Processing Inc.	12700 West Dodge Road PO Box 2047 Omaha, NE 68103-2047	Electronic Service	No	OFF_SL_20-401_20-401
Generic Notice	Commerce Attorneys	commerce.attorneys@ag.st ate.mn.us	Office of the Attorney General-DOC	445 Minnesota Street Suite 1400 St. Paul, MN 55101	Electronic Service	Yes	OFF_SL_20-401_20-401
James C.	Erickson	jericksonkbc@gmail.com	Kelly Bay Consulting	17 Quechee St Superior, WI 54880-4421	Electronic Service	No	OFF_SL_20-401_20-401
Sharon	Ferguson	sharon.ferguson@state.mn .us	Department of Commerce	85 7th Place E Ste 280 Saint Paul, MN 551012198	Electronic Service	No	OFF_SL_20-401_20-401
Shane	Henriksen	shane.henriksen@enbridge .com	Enbridge Energy Company, Inc.	1409 Hammond Ave FL 2 Superior, WI 54880	Electronic Service	No	OFF_SL_20-401_20-401
Douglas	Larson	dlarson@dakotaelectric.co m	Dakota Electric Association	4300 220th St W Farmington, MN 55024	Electronic Service	No	OFF_SL_20-401_20-401
James D.	Larson	james.larson@avantenergy .com	Avant Energy Services	220 S 6th St Ste 1300  Minneapolis, MN 55402	Electronic Service	No	OFF_SL_20-401_20-401
Kavita	Maini	kmaini@wi.rr.com	KM Energy Consulting, LLC	961 N Lost Woods Rd Oconomowoc, WI 53066	Electronic Service	No	OFF_SL_20-401_20-401
Andrew	Moratzka	andrew.moratzka@stoel.co m	Stoel Rives LLP	33 South Sixth St Ste 4200  Minneapolis, MN 55402	Electronic Service	No	OFF_SL_20-401_20-401

First Name	Last Name	Email	Company Name	Address	Delivery Method	View Trade Secret	Service List Name
Wendi	Olson	wolson@otpco.com	Otter Tail Power Company	215 South Cascade Fergus Falls, MN 56537	Electronic Service	No	OFF_SL_20-401_20-401
Generic Notice	Residential Utilities Division	residential.utilities@ag.stat e.mn.us	Office of the Attorney General-RUD	1400 BRM Tower 445 Minnesota St St. Paul, MN 551012131	Electronic Service	Yes	OFF_SL_20-401_20-401
Larry L.	Schedin	Larry@LLSResources.com	LLS Resources, LLC	332 Minnesota St, Ste W1390 St. Paul, MN 55101	Electronic Service	No	OFF_SL_20-401_20-401
Will	Seuffert	Will.Seuffert@state.mn.us	Public Utilities Commission	121 7th PI E Ste 350  Saint Paul,  MN  55101	Electronic Service	Yes	OFF_SL_20-401_20-401
Cary	Stephenson	cStephenson@otpco.com	Otter Tail Power Company	215 South Cascade Street  Fergus Falls,  MN  56537	Electronic Service	No	OFF_SL_20-401_20-401
Stuart	Tommerdahl	stommerdahl@otpco.com	Otter Tail Power Company	215 S Cascade St PO Box 496 Fergus Falls, MN 56537	Electronic Service	No	OFF_SL_20-401_20-401
Nikhil	Vijaykar	NVijaykar@elpc.org	Enviornental Law & Policy Center	N/A	Electronic Service	No	OFF_SL_20-401_20-401