

Installing:
531 fdr 2021
250 fdr 2021

RGV-256 Intellerupters installed in 2012

Year	Storm Included			Storm Excluded		
	SAIFI	SAIFI	MAIFI	SAIFI	SAIFI	MAIFI
Before Install 5 Year Ave(2007-2011)	143.72	0.6	3.2	24.23	0.32	1.8
2020	160.33	2.73	1.98	160.33	2.73	1.98

RGV-252 Intellerupters installed in 2011

Year	Storm Included				Storm Excluded			
	SAIFI	SAIFI	MAIFI	CAIDI	SAIFI	SAIFI	MAIFI	CAIDI
Before Install 5 Year Ave(2006-2010)	195.37	1.47	7.8	132.90	55.32	0.66	7.4	83.82
2020	29.15	0.49	6.77	59.49	14.08	0.17	6.03	82.82

SLA-203 Intellerupters installed in 2015

Year	Storm Included				Storm Excluded			
	SAIFI	SAIFI	MAIFI	CAIDI	SAIFI	SAIFI	MAIFI	CAIDI
Before Install 5 Year Ave(2010-2014)	0	0	0	#DIV/0!	0	0	0	#DIV/0!
2020	0	0	1	#DIV/0!	0	0	0	#DIV/0!

SLA-208 Intellerupters installed in 2015

Year	Storm Included				Storm Excluded			
	SAIFI	SAIFI	MAIFI	CAIDI	SAIFI	SAIFI	MAIFI	CAIDI
Before Install 5 Year Ave(2010-2014)	0	0	0.2	#DIV/0!	0	0	0.2	#DIV/0!
2020	0.06	0	1	#DIV/0!	0.06	0	1	#DIV/0!

**0 customer feeder was in abnormal config during 1 outage

COL-240 Tripsavers installed in 2018

Year	Storm Included				Storm Excluded			
	SAIFI	SAIFI	MAIFI	CAIDI	SAIFI	SAIFI	MAIFI	CAIDI
Before Install 5 Year Ave(2012-2017 no 2016)	116.82	1.22	1.78	95.75	106.35	1.16	1.58	91.68
2020	101.81	1.18	0	86.28	90.35	1.14	0	79.25

FBG-269 Tripsavers installed in 2016

Year	Storm Included				Storm Excluded			
	SAIFI	SAIFI	MAIFI	CAIDI	SAIFI	SAIFI	MAIFI	CAIDI
Before Install 5 Year Ave(2011-2015)	246.57	1.35	0.2	182.64	242.59	1.35	0.2	179.70
2020	62.99	0.45	2	139.98	62.99	0.45	2	139.98